

DEQ/DWR
FACT SHEET FOR NPDES PERMIT DEVELOPMENT
NPDES PERMIT NC0003433

Facility Information					
Applicant/Facility Name:	Duke Energy Progress LLC– Cape Fear Steam Electric Plant (decommissioned)				
Applicant Address:	500 CP&L Road, Moncure, NC 27599				
Facility Address:	500 CP&L Road, Moncure, NC 27599				
Permitted Flow:	Outfall 007 – 0.73 MGD Daily Maximum Outfall 008 – 0.72 MGD Daily Maximum Outfall 009 – 0.005 MGD Daily Maximum				
Type of Waste:	100% Industrial (Ash basin clean up, remediation)				
Facility/Permit Status:	Class I/Renewal and Major Modification SIC 4911				
County:	Chatham				
Miscellaneous					
Receiving Stream			Index	7Q10s (cfs)	QA (cfs)
Outfall 007 – Unnamed tributary to Cape Fear River			18-(1)	0	0
Outfalls 008 – Cape Fear River			18-(1)	65	3,170
Outfall 009 – Cape Fear River			18-(1)	65	3,170
Outfall 008A – Cape Fear River					
Outfalls 001 & 005– Internal Outfalls					
Stream Classification:	WS-IV	Regional Office:	Raleigh		
303(d) Listed?:	No	USGS Topo Quad:	E22SE Moncure, NC		
HUC No.:	03030002	Permit Writer:	Bing Bai		
Subbasin:	03-06-07	Date:	August 22, 2018		
Cape Fear River Stream Statistics – 2016					
Drainage (mi ²):	-				
Summer – 7Q10 (cfs):	65 ¹				
Winter – 7Q10 (cfs):	89 ¹				
30Q2 (cfs):	150 ¹				
QA (cfs):	3,170 ¹				

1. Based on USGS recommendation and data

Current Status

Duke Energy's ceased operation of its combined 400 megawatts, coal-fire and combustion turbine, Cape Fear Steam Electric Plant in 2011. The plant was dismantled and no longer withdraws water from the Cape Fear River nor discharges wastewater as defined for an active operation of a steam electric generation facility. Historically, there were five ash basins, some of which contain a visible water level. As part of the current active NPDES issued in 2011, storm water was separated and is covered under its own permit.

In July 2014 Duke Energy submitted a modification application to amend permit conditions to address operation changes and update identified seeps. Duke Energy requested in February 2016 the current modification application under review be accepted as the required permit renewal application. As part of the required data to develop the permit, Duke provided documents and data associated with identified seeps, ash basin bulk water decanting/dewatering analyses, and landfill leachate analyses. Additional groundwater monitoring well analyses were obtained from the

Division's ground water unit. Based on the application amendments and data submitted through August 2016, and applicable Division guidance for this type facility, the initial draft permit was issued October 5, 2016 with a public hearing held November 28, 2016. The hearing officer extended the deadline for receiving public comments to December 5, 2016. The hearing officer's final report was delayed pending resolution of compliance boundary issues and changes in seep permitting requirements, and was issued March 2018.

The following recommendations from the hearing officer report will be implemented in this draft:

- 1) There will be only a single treatment system for decanting, dewatering, and groundwater remediation with a rated capacity of 0.72 MGD.
- 2) All required sampling types will be grab.
- 3) There will be no monitoring requirements for iron or magnesium.
- 4) Will revise the instream monitoring special condition to allow sampling to be done by the Middle Cape Fear Basin Association provided it is conducted at the locations specified in this permit.
- 5) Will apply USGS based flow information for this segment of the Cape Fear River to establish 7Q10, 30Q2, and QA based IWC values for Outfall 008.
- 6) Will re-evaluate limit requirements as determined by an RPA applying the new implemented IWC values for Outfall 008.
- 7) Will decrease Chronic Toxicity monitoring frequency when decanting to quarterly.
- 8) Revised flow measurement type to include pump logs when applicable but must use other methods defined in permit when discharge occurs and no pump are running.

The facility began a Division approved ash basin decanting as discussed and defined in the Division's December 2015 and July 2016 letters. Discharge of treated decanting wastewater was allowed through existing Outfalls 001, 005, and 007 with weekly monitoring for arsenic, selenium, mercury, chromium, lead, cadmium, copper zinc, and total dissolved solids. The decanting-based discharge cannot contravene NC Water Quality Standards (WQS) or EPA criteria.

Based on additional changes the Division determined a second draft for public comment was necessary. These changes include using USGS combined upstream flow criteria for this segment of the Cape Fear River to define instream waste concentration, adding a new outfall for proposed beneficiation facility miscellaneous wastewater discharge, removing landfill leachate wastewater criteria from outfall wastewater characterization as no landfill was to be built, limiting treated ash basin wastewater discharge to decanting only for Outfall 007, adding a ground water boundary compliance map, and implementing permit conditions for the Division updated seep strategy. The following is a summary of the final revisions from the active permit reflected in this second draft, the majority of which were originally proposed in the first draft;

- Activation of the former 1963/1970 ash basin stormwater Outfall 008 as an NPDES outfall for discharging treated ash basins decanting/dewatering/groundwater remediation wastewater from a treatment facility with a stated maximum design capacity of 0.72 MGD to the Cape Fear River.
- Approval to discharge treated ash basin's decanting wastewater from a treatment facility with a stated maximum design capacity of 0.72 MGD, defined engineering seeps, and the episodic emergency discharge from internal Outfalls 001 and 005, to the existing facility's effluent channel Outfall 007.

- Approval to discharge 0.005 MGD of beneficiation miscellaneous wastewater from a new Outfall 009 to the Cape Fear River.
- Approval to relocate Outfall 005 to a different location on the effluent channel.
- Provisions to allow for the discharge of treated decanting wastewater to Outfall 008.
- Provisions to allow for the discharge of treated dewatering wastewater to Outfall 008.
- Provisions to allow for the discharge of combined treated dewatering and treated groundwater remediation wastewater to Outfall 008.
- Provisions to allow for the discharge of treated groundwater remediation wastewater to Outfall 008, once all dewatering activity is completed.
- Provisions for repurposing existing Internal Outfalls 001 and 005 as emergency only overflow discharges for 1985 (East) and 1978 (West) Ash Basins decanting wastewater to the existing facility's effluent channel Outfall 007.
- Provisions for a new emergency only overflow Outfall 008A for 1963/1970 Ash Basin for discharging decanting wastewater to the Cape Fear River.
- Determination of constructed seep (French Drain) status, location, and entry point into effluent channel.
- Removal of all permit conditions associated with the operation of an Electric Generation Steam Plant that are no longer applicable.

The modified facility will have permitted discharges to two stream locations and an unnamed tributary to the Cape Fear River and directly to the Cape Fear River. All streams are classified as WS-IV and are not listed as impaired on the 2014 303(d) impairment list. Based on review of USGS 2016 recommendation, Outfall 007 receiving stream, the unnamed tributary to the Cape Fear River, has a 7Q10 summer flow considered to be "zero". USGS recommended using 65 cfs flow to approximate the 7Q10 summer and 95 cfs flow to approximate the 7Q10 winter for this portion of the Cape Fear River that are the receiving stream for Outfalls 008 and 009. Additional stream data was used from other nearby NPDES facilities and USGS gauge stations to determine 30Q2 and QA flows for this segment of the Cape Fear River. This facility is subject to NC Senate Bill 729 (Coal Ash Management Act).

Outfall Description for Proposed Permit

Internal Outfall 001 – 1978 (West) Ash Basin

This existing outfall will be re-designated as requested by the Permittee as an emergency overflow discharge only. This will be limited to discharging excess 1978 ash basin decanting wastewater above the available treatment plant capacity during an eminent threat of 1978 (West) Ash Basin overflow to the facility's effluent channel. The channel discharges through Outfall 007.

Internal Outfall 005 – 1985 (East) Ash Basin

This existing outfall will be relocated and re-designated as requested by the Permittee as an emergency overflow discharge only. This will be limited to discharging excess 1985 ash basin decanting wastewater above the available treatment plant capacity during an eminent threat of 1985 (East) Ash Basin overflow to the facility's effluent channel. The channel will continue to discharge through Outfall 007.

Outfall 007 - Combined Wastewater

This existing outfall will be re-designated as a comingled wastewater discharge as requested by the Permittee consisting of treated decanting wastewater from the 0.72 MGD capacity treatment

facility, area storm water, approved constructed seep, and episodic emergency discharge from Internal Outfalls 001 and 005. Outfall 007 discharges is to an unnamed tributary to the Cape Fear River. Treatment system will be added, if necessary, to assure state Water Quality Standards are not contravened in the receiving stream.

Outfall 008 - Combined Wastewater

This outfall was a previous retired 1963/1970 Ash Basin storm water outfall and as requested by the Permittee will be re-activated as a NPDES discharge. It will be designated for comingled wastewater discharge consisting of treated wastewater from the 0.72 MGD capacity treatment facility for either decanting/dewatering/groundwater remediation. Outfall 008 discharges to the Cape Fear River. Treatment system will be added, if necessary, to assure state Water Quality Standards are not contravened in the receiving stream.

Outfall 008A - 1963/1970 Ash Basin

This will be a new outfall requested by the Permittee and will be designated as an emergency discharge only. This will be limited to discharging excess 1963/1970 ash basin decanting wastewater above the available treatment plant capacity during an eminent threat of 1963/1970 Ash Basin overflow to the Cape Fear River.

Outfall 009 – Beneficiation Area Miscellaneous Wastewater

This will be a new outfall requested by the Permittee to address 0.005 MGD of potential miscellaneous wastewater that may occur in the Beneficiation process consisting of ash pile runoff, dust, and spills. Outfall 009 will discharge to the Cape Fear River.

Internal Outfall S-05 – Constructed Seep (French Drain)

This internal outfall is for discharge of combined French Drain to effluent channel of Outfall 007.

Compliance Review

During this permit cycle while operating as a steam electric generating facility up to shutting down in May 2014, the facility had two TSS limit violations on Internal Outfall 005 and some monitoring frequency violations. No fines were assessed.

A total of 11 chronic toxicity tests at 90% effluent concentration using *Ceriodaphnia dubia* were performed and passed.

During this permit cycle samples were taken from 13 monitoring wells for 22 parameters 3/ Year. Groundwater violations were noted for Total Manganese, Total Iron, Total Boron, Total Vanadium, TSS, Total Cobalt, Sulfates, Total Selenium, Total Cadmium, Total Chromium, and Total Thallium. As required the Permittee is preparing an Action Plan to address groundwater remediation and a compliance boundary map that will be submitted to the Groundwater Protection Branch for final approval. The map will be attached to the final NPDES permit.

Instream Monitoring

As part of the required site seep investigation and reporting, instream samples were taken in July 2014 in the Haw River at the mouth of Shaddox Creek, upstream in Shaddox Creek, in the Cape Fear River just upstream of the mouth of the unnamed tributary that receives flow from Outfall 007, and in the Cape Fear River approximately 1.9 miles downstream from the mouth of the unnamed tributary. There was a notable reduction in impact to the concentration of the measured

constituents that entered Haw River from Shaddox Creek most likely from dilution. The Cape Fear River samples did not show any significant differences. There were no reported values that violated NC water quality standards or EPA criteria.

Fish Tissue Study Near Ash Basins

As required a fish tissue study was conducted in the Cape Fear River in May 2014 to evaluate the uptake of arsenic, mercury, and selenium by fish near the ash basin discharge. There were four fish tissue samples out of the thirty-six sample taken, three upstream and one downstream, that were \geq the Mercury 2006 NC Health Directors Action Advisory Level of 0.4 $\mu\text{g/g}$ fresh weight. The fish tissue samples Mercury levels ranged from < 0.04 to 0.68 $\mu\text{g/g}$ fresh weight. There was no exceedance of the arsenic or the selenium fish tissue fresh weight criteria for any fish tissue sampled.

Proposed Permitting Action

In accordance with the 2014 Coal Ash Management Act and additional Division approval, the facility began decanting of the ash basins using a 0.72 MGD capacity treatment system. To comply with the remainder of the act, ash basin dewatering and final disposal of the ash must be completed. As part of this renewal and modified permit, requirement will be developed for treated decanting wastewater, treated dewatering wastewater, and in this case a proposed ash disposal Beneficiation process 0.005 MGD waste sources. In addition, the Permittee has requested as part of the permit modification to include groundwater remediation as part of the dewatering activities to be continued once dewatering activities are completed. Under current Division seep strategy only the constructed seep, S-05, that discharges to the effluent channel will be covered under this permit.

Outfall 007

This outfall discharges at the end of the effluent channel and to an unnamed tributary with a “zero” 7Q10 summer flow, thus, has an IWC=100%. Based on evaluation of all the contributing wastewater characteristics associated with this outfall, the ash basin decanting waste water source was the most dominant. A reasonable potential analysis was conducted using 0.73 MGD as the estimated flow and using the ash basin bulk water concentration data collected in October 2014. Based on this analysis, the following permitting actions are proposed for this permit:

- Effluent Limit with Monitoring. The following parameters will receive a water quality-based effluent limit (WQBEL) since they demonstrated a reasonable potential to exceed applicable water quality standards/criteria: Arsenic, Antimony, Molybdenum, Nickel, Selenium, Zinc
- Monitoring Only. The following parameters will receive a monitor-only requirement since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria, but the maximum predicted concentration was >50% of the allowable concentration: Cadmium, Copper, Fluoride, Sulfates, TDS, Thallium, Lead
- No Limit or Monitoring: The following parameters will not receive a limit or monitoring, since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria and the maximum predicted concentration was <50% of the allowable concentration: Chlorides, Aluminum, Chromium III, Chromium VI, Total Chromium, Barium

To comply with mercury TMDL requirements and minimum ash basin decanting monitoring requirements, monthly monitoring using test method 1631E will be required, with an annual average limit of 12 ng/L.

NPDES PERMIT FACT SHEET

Page 6

Duke Energy Progress LLC- Cape Fear Facility

NPDES No. NC0003433

Additional decanting monitoring parameters and conditions and other general permit requirements are summarized in Table 1: Outfall 007 – Ash Basin Decanting.

Table 1: Outfall 007 - Ash Basin Decanting

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.73 MGD DM	Daily	Decanting strategy, 15A NCAC 2B .0505
pH	6.0 ≤ pH ≤ 9.0 S.U. Continuous monitoring/auto shutoff	Monthly	Decanting strategy, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100 mg/L DM Continuous monitoring/auto shutoff	Monthly	Decanting strategy, EPA requirement, 40 CFR 423
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Monthly	Decanting strategy, 40 CFR 423
Total Antimony	5.6 µg/L MA 5.6 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Arsenic	10.0 µg/L MA 340.0 µg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Molybdenum	160 µg/L MA 160 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Lead	Monitor & Report, µg/L	Monthly	Pollutant of concern
Total Nickel	25.0 µg/L MA 335.2 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Selenium	5.0 µg/L MA 56.0 µg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Zinc	125.7 µg/L MA 125.7 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Mercury	12 ng/L, annual average	Weekly	Mercury TMDL
Total Cadmium	Monitor & Report, µg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Total Copper	Monitor & Report, µg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Fluoride	Monitor & Report, mg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Sulfates	Monitor & Report, mg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Total Dissolved Solids	Monitor & Report, mg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Total Thallium	Monitor & Report, µg/L	Monthly	No RP, predicted value ≥ 50% of the Allowable Cw
Turbidity	Net Turbidity ≤ 50 NTU	Monthly	Decanting strategy, EPA requirement
Effluent Hardness	Monitor & Report, mg/L	Quarterly	Required to assess dissolved metal limitations
Chronic Toxicity	90% concentration, P/F	Quarterly	Decanting strategy, DEQ Toxicity Policy
Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN

Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500

MDG – Million gallons per day, MA – Monthly Average, DM – Daily Max

Outfall 008 - Decanting

As requested by the Permittee this new outfall will discharge to a segment of the Cape Fear River and based on stream flow data has a 7Q10 summer-based IWC = 1.7%. A reasonable potential analysis was conducted using the 0.72 MGD capacity of the treatment as the estimated flow and using the highest bulk water concentration data collected in October 2014. Based on this analysis, the following permitting actions are proposed for this permit:

- Effluent Limit with Monitoring. The following parameters will receive a water quality-based effluent limit (WQBEL) since they demonstrated a reasonable potential to exceed applicable water quality standards/criteria: NA
- Monitoring Only. The following parameters will receive a monitor-only requirement since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria, but the maximum predicted concentration was >50% of the allowable concentration: Arsenic, Selenium, Lead, Nickel
NOTE: Arsenic and Selenium are major decanting pollutants of concern, weekly monitoring is required. Lead and Nickel are pollutants of concern, monthly monitoring is required.
- No Limit or Monitoring: The following parameters will not receive a limit or monitoring, since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria and the maximum predicted concentration was <50% of the allowable concentration: TDS, Cadmium, Chlorides, Aluminum, Chromium III, Chromium VI, Total Chromium, Copper, Fluoride, Molybdenum, Zinc, Antimony, Barium, Sulfates, Thallium.

To comply with mercury TMDL requirements and minimum ash basin decanting monitoring requirements, monthly monitoring using test method 1631E, or equivalent, will be required, with an annual average limit of 47 ng/L.

Additional decanting monitoring parameters and conditions and other general permit requirements are summarized in Table 2: Outfall 008 – Ash Basin Decanting.

Table 2: Outfall 008 -Ash Basin Decanting

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.72 MGD DM	Daily	Decanting strategy, 15A NCAC 2B .0505
pH	6.0 ≤ pH ≤ 9.0 S.U. Continuous monitoring/auto shutoff	Monthly	Decanting strategy, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100 mg/L DM Continuous monitoring/auto shutoff	Monthly	Decanting strategy, EPA requirement, 40 CFR 423
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Monthly	Decanting strategy, 40 CFR 423
Total Mercury	47 ng/L, annual average	Weekly	Mercury TMDL

Total Arsenic	Monitor & Report, µg/L	Weekly	Decanting strategy, EPA requirement
Total Selenium	Monitor & Report, µg/L	Weekly	Decanting strategy, EPA requirement
Total Lead	Monitor & Report, µg/L	Monthly	Pollutant of concern
Total Nickel	Monitor & Report, µg/L	Monthly	Pollutant of concern
Turbidity	Net Turbidity ≤ 50 NTU	Monthly	Decanting strategy, EPA requirement
Effluent Hardness	Monitor & Report, mg/L	Quarterly	Required to assess dissolved metal limitations
Chronic Toxicity	1.7% concentration, P/F	Quarterly	Decanting strategy, DEQ Toxicity Policy
Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500

MGD – Million gallons per day, MA – Monthly Average, DM – Daily Max

Outfall 008 - Dewatering

As requested by the Permittee this new outfall will discharge to a segment of the Cape Fear River and based on stream flow data has a 7Q10 summer-based IWC = 1.7%. A reasonable potential analysis was conducted using the 0.72 MGD capacity of the treatment system as the estimated flow and using the highest 1985 (East) and 1978 (West) Ash Basins interstitial water concentration data collected in January 2015. Based on this analysis, the following permitting actions are proposed for this permit:

- Effluent Limit with Monitoring. The following parameters will receive a water quality-based effluent limit (WQBEL) since they demonstrated a reasonable potential to exceed applicable water quality standards/criteria: Selenium
NOTE: Arsenic is a major dewatering pollutant of concern, weekly monitoring is required.
- Monitoring Only. The following parameters will receive a monitor-only requirement since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria, but the maximum predicted concentration was >50% of the allowable concentration: Aluminum, Arsenic, Cadmium, Copper, Lead, Nickel
- No Limit or Monitoring: The following parameters will not receive a limit or monitoring, since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria and the maximum predicted concentration was <50% of the allowable concentration: TDS, Chlorides, Chromium III, Chromium VI, Total Chromium, Fluoride, Molybdenum, Barium, Sulfates, Antimony, Zinc, Thallium

To comply with mercury TMDL requirements and minimum ash basin dewatering monitoring requirements, weekly monitoring using test method 1631E, or equivalent, will be required, with an annual average limit of 47 ng/L.

The Permittee shall notify the Raleigh Regional Office and the Division seven (7) calendar days prior to commencing ash basin dewatering operation.

Additional dewatering monitoring parameters and conditions and other general permit requirements are summarized in Table 3: Outfall 008 – Ash Basin Dewatering.

Table 3: Outfall 008 -Ash Basin Dewatering

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.72 MGD DM	Daily	Dewatering strategy, 15A NCAC 2B .0505
pH	6.0 \leq pH \leq 9.0 S.U. Continuous monitoring/auto shutoff	Weekly	Dewatering strategy, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100 mg/L DM Continuous monitoring/auto shutoff	Weekly	Dewatering strategy, EPA requirement, 40 CFR 423
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Weekly	Dewatering strategy, 40 CFR 423
Total Aluminum	Monitor & Report, mg/L	Weekly	No RP, predicted Cw \geq 50% of Allowable Cw
Total Arsenic	Monitor & Report, $\mu\text{g}/\text{L}$	Weekly	Dewatering strategy, EPA requirement
Total Cadmium	Monitor & Report, $\mu\text{g}/\text{L}$	Weekly	No RP, predicted Cw \geq 50% of Allowable Cw
Total Copper	466.9 $\mu\text{g}/\text{L}$ MA 509.9 $\mu\text{g}/\text{L}$ DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Lead	0.17 mg/L MA 3.68 mg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Mercury	47 ng/L, annual average	Weekly	Mercury TMDL
Total Nickel	Monitor & Report, $\mu\text{g}/\text{L}$	Weekly	Pollutant of concern
Total Selenium	0.30 mg/L MA 2.73 mg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Turbidity	Net Turbidity \leq 50 NTU	Weekly	Decanting strategy, EPA requirement
Effluent Hardness	Monitor & Report, mg/L	Quarterly	Required to assess dissolved metal limitations
Chronic Toxicity	1.7% concentration, P/F	Monthly	Dewatering strategy, DEQ Toxicity Policy
Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500

MGD – Million gallons per day, MA – Monthly Average, DM – Daily Max

Outfall 008 – Dewatering/Ground Water Remediation

As requested by the Permittee this new outfall will discharge to a segment of the Cape Fear River, and based on stream flow data and a maximum 0.72 MGD treatment system capacity has a 7Q10 summer-based IWC = 1.7%. A reasonable potential analysis was conducted using the 1.7% and using two source data points if available, one data point from the highest 1985 (East) and 1978 (West) Ash Basins interstitial water concentration data collected in January 2015 and a second data point from the highest ground water monitoring wells data collected in 2015 and 2016. Based on this analysis, the following permitting actions are proposed for this permit:

- Effluent Limit with Monitoring. The following parameters will receive a water quality-based effluent limit (WQBEL) since they demonstrated a reasonable potential to exceed applicable

water quality standards/criteria: TDS, Aluminum, Copper, Lead, Nickel, Selenium, Silver, Sulfates, Zinc

NOTE: Arsenic is a major dewatering pollutant of concern, weekly monitoring is required.

- Monitoring Only. The following parameters will receive a monitor-only requirement since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria, but the maximum predicted concentration was >50% of the allowable concentration: Beryllium, Copper, Cadmium, NOTE: Molybdenum is a major pollutant of interest, will be monitored weekly.
- No Limit or Monitoring: The following parameters will not receive a limit or monitoring, since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria and the maximum predicted concentration was <50% of the allowable concentration: Antimony, Chlorides, Chromium III, Chromium VI, Total Chromium, Fluoride, Barium, Thallium

To comply with mercury TMDL requirements and minimum ash basin dewatering monitoring requirements, weekly monitoring using test method 1631E, or equivalent, will be required, with an annual average limit of 47 ng/L.

The Permittee shall notify the Raleigh Regional Office and the Division seven (7) calendar days prior to the introduction of remediation ground water with the dewatering wastewater.

Additional dewatering monitoring parameters and ground water remediation monitoring parameters and other general permit requirements are summarized in Table 4: Outfall 008 – Ash Basin Dewatering/Ground Water Remediation.

Table 4: Outfall 008 - Ash Basin Dewatering/Ground Water Remediation

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.72 MGD DM	Daily	Dewatering strategy, 15A NCAC 2B .0505
Temperature, °C	Monitor & Report	Weekly	Ground Water Remediation NCG510000
pH	6.0 ≤ pH ≤ 9.0 S.U. Continuous monitoring/auto shutoff	Weekly	Dewatering strategy, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100 mg/L DM Continuous monitoring/auto shutoff	Weekly	Dewatering strategy, EPA requirement, 40 CFR 423
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Weekly	Dewatering strategy, 40 CFR 423
Total Aluminum	385.1 mg/L MA 385.1 mg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Arsenic	Monitor & Report, µg/L	Weekly	Dewatering strategy, EPA requirement
Total Beryllium	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw

NPDES PERMIT FACT SHEET

Page 11

Duke Energy Progress LLC- Cape Fear Facility

NPDES No. NC0003433

Total Cadmium	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Copper	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Lead	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Mercury	47 ng/L, annual average	Weekly	Mercury TMDL
Total Nickel	1.48 mg/L MA 16.3 mg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Selenium	0.30 mg/L MA 2.73 mg/L DM	Weekly	RP to exceed NC WQS and EPA criteria
Total Silver	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Zinc	Monitor & Report, µg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
TDS	Monitor & Report, mg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Sulfates	Monitor & Report, mg/L	Weekly	No RP, predicted Cw ≥ 50% of Allowable Cw
Turbidity	Net Turbidity ≤ 50 NTU	Weekly	Dewatering strategy, EPA requirement
Effluent Hardness	Monitor & Report, mg/L	Quarterly	Required to assess dissolved metal limitations
Chronic Toxicity	1.7% concentration, P/F	Monthly	Dewatering strategy, DEQ Toxicity Policy
Conductivity, µmhos/cm	Monitor and Report	Quarterly	Ground Water Remediation, NCG510000
Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500

MGD – Million gallons per day, MA – Monthly Average, DM – Daily Max

In addition, a special condition will be added to require the Permittee to submit EPA Form 2C to update the ground water remediation characterization 180 days after its initial introduction to the treatment system. The Division may reopen the permit to assign additional limits or conditions.

Outfall 008 – Ground Water Remediation

As requested by the Permittee this new outfall will discharge to a segment of the Cape Fear River, and based on stream flow data and a maximum 0.72 MGD treatment system capacity has a 7Q10 summer-based IWC = 1.7%. The reasonable potential analysis was conducted using only the highest ground water monitoring wells data toxicant concentration collected in 2015 and 2016 yielded the same results as the reasonable potential analysis conducted for comingled dewatering and groundwater remediation waste sources. Therefore, the only changes will be the removal of conditions related to dewatering activity, and a reduction in various parameters monitoring frequency and TSS limits to comply with Division ground water remediation permitting strategy.

NPDES PERMIT FACT SHEET

Page 12

Duke Energy Progress LLC- Cape Fear Facility

NPDES No. NC0003433

To comply with mercury TMDL requirements, quarterly monitoring using test method 1631E, or equivalent, will be required, with an annual average limit of 47 ng/L.

The Permittee shall notify the Raleigh Regional Office and the Division seven (7) calendar days prior to the completion of dewatering activities and the continuation of remediation ground water treatment.

Ground Water Remediation requirements and conditions are summarized in Table 5: Outfall 008 – Ground Water Remediation.

Table 5: Outfall 008 - Ground Water Remediation

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.72 MGD DM	Weekly	15A NCAC 2B .0400 et seq., 02B .0500 et seq.
Temperature, °C	Monitor & Report	Weekly	Ground Water Remediation, NCG510000
pH	6.0 ≤ pH ≤ 9.0 S.U.	Weekly	15A NCAC 2B .0200
TSS	30.0 mg/L MA 45.0 mg/L DM	Weekly	Ground Water Remediation, NCG510000
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Weekly	40 CFR 423
Total Aluminum	385.1 mg/L MA 385.1 mg/L DM	2/Month	RP to exceed NC WQS and EPA criteria
Total Arsenic	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Beryllium	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Lead	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Nickel	1.48 mg/L MA 16.3 mg/L DM	2/Month	RP to exceed NC WQS and EPA criteria
Total Selenium	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Silver	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Total Zinc	Monitor & Report, µg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
TDS	Monitor & Report, mg/L	2/Month	No RP, predicted Cw ≥ 50% of Allowable Cw
Sulfates	14,811 mg/L MA 14,811mg/L DM	2/Month	RP to exceed NC WQS and EPA criteria
Turbidity	Net Turbidity ≤ 50 NTU	2/Month	15 NCAC 2B .0500
Effluent Hardness	Monitor & Report, mg/L	Quarterly	Required to assess dissolved metal limitations
Chronic Toxicity	1.7% concentration, P/F	Quarterly	Dewatering strategy, DEQ Toxicity Policy
Conductivity, µmhos/cm	Monitor and Report	Quarterly	Ground Water Remediation, NCG510000

Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500

MGD – Million gallons per day, MA – Monthly Average, DM – Daily Max

Outfall 008A – 1963/1970 Ash Basins Emergency Outfall

This new outfall is designated as an emergency discharge only and will consist of ash basin decanting wastewater. This is limited to discharging excess wastewater above the available treatment plant capacity during an eminent treat of 1963/1970 Ash Basin overflow.

Outfall 008A requirements and conditions are summarized in Table 6: Outfall 008A – 1963/1970 Ash Basins Emergency.

Table 6: Outfall 008A - 1963/1970 Ash Basins Emergency

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	Monitor and report	Daily during Episodic Event	15A NCAC 2B .0400 et seq., 02B .0500 et seq.
pH	6.0 ≤ pH ≤ 9.0 S.U.	Daily during Episodic Event	15A NCAC 2B .0200
TSS	30.0 mg/L MA 100.0 mg/L DM	Daily during Episodic Event	Ground Water Remediation, NCG510000
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Daily during Episodic Event	40 CFR 423

Outfall 009 – Beneficiation Miscellaneous Wastewater

As requested by the Permittee this new outfall will discharge to a segment of the Cape Fear River, and based on stream flow data and a maximum 0.005 MGD discharge has a 7Q10 summer-based IWC = 0.012%. The expected sources of wastewater from the Beneficiation process area are ash pile run off, truck washing and ash dust spills. Data from an existing similar operation which included 21 toxicants was provided to characterize the proposed Beneficiation waste stream, and used to conducted a reasonable potential analysis.

No Limit or Monitoring: The following parameters will not receive a limit or monitoring, since they did not demonstrate reasonable potential to exceed applicable water quality standards/criteria and the maximum predicted concentration was <50% of the allowable concentration: Aluminum, Antimony, Cadmium, Chlorides, Barium, Beryllium, Total Chromium, Copper, Fluoride, Lead, Molybdenum, Nickel, Silver, Thallium, Zinc, Sulfates, TDS

NOTE: Monthly monitoring for Arsenic and Selenium will be required as they are toxicants of concern.

Beneficiation Miscellaneous requirements and conditions are summarized in Table 7: Outfall 009 – Ground Water Remediation.

Table 7: Outfall 009 – Beneficiation Miscellaneous Wastewater

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	0.005 MGD DM	Weekly	15A NCAC 2B .0400 et seq., 02B .0500 et seq.
Temperature, °C	Monitor & Report	Monthly	BPJ (untreated waste stream)
pH	6.0 ≤ pH ≤ 9.0 S.U.	Monthly	15A NCAC 2B .0200
TSS	30.0 mg/L MA 30.0 mg/L DM	Monthly	BPJ (untreated waste stream)
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Monthly	40 CFR 423
Total Mercury	47 ng/L, annual average	Monthly	Mercury TMDL
Total Arsenic	Monitor & Report	Monthly	Toxicant of concern, BPJ (coal ash source)
Total Selenium	Monitor & Report	Monthly	Toxicant of concern, BPJ (coal ash source)
Turbidity	Net Turbidity ≤ 50 NTU	Monthly	15 NCAC 2B .0500

MGD – Million gallons per day, MA – Monthly Average, DM – Daily Max

Internal Outfalls 001 and 005- Ash Basins Emergency Overflow Discharge

As requested by the Permittee internal outfalls will be permitted for the three ash basins to address potential emergency overflow only events. Outfall 005, an existing 1985 (East) Ash Basin internal outfall, will be relocate to a different section of the effluent channel and be repurposed as an episodic emergency overflow. Outfall 001, an existing 1968 (West) Ash Basin internal outfall, will be repurposed as an episodic emergency overflow and continue to discharge to the effluent channel.

An emergency discharge is defined as the ash basin decanting wastewater that is in excess of the facility 0.72 MGD treatment capacity that will overflow. Table 8 lists the notification ¹ and monitoring requirement in the event of ash basin emergency overflow from internal outfalls:

Table 8: Ash Basin Emergency Overflow Outfalls 001 and 005

Parameter	Monitoring Requirements ²	Sample Type
Flow	Monitor & Report, MGD	Estimate
Outfall 001(Internal)	Monitor & Report Outfall 007 per A. (3.) ³	
Outfall 005 (Internal)	Monitor & Report Outfall 007 per A. (3.) ³	

Notes

1. The Permittee shall notify the Raleigh Regional Office (919) 791 – 4200 no later than the end of the next business day of the occurrence of an emergency discharge event including time of occurrence, duration, and cause.
2. During the duration of a discharge event, the flow shall be reported daily.
3. Effluent monitoring shall commence immediately at the impacted external outfall (Outfalls 007 or 008) for the limited parameters except for Mercury and Chronic Toxicity. Monitoring parameters and continue weekly during the emergency discharge event. Any external outfall's monitoring requirements in effect prior to an emergency discharge shall remain in effect.

Instream Monitoring

The facility shall conduct representative monthly in-stream monitoring for total arsenic, total selenium, total mercury, total chromium, dissolved lead, dissolved cadmium, dissolved copper, dissolved zinc, total bromide, total hardness (as CaCO₃), turbidity, and total dissolved solids (TDS) at locations listed in Table 9. For the purpose of this requirement, “semi-annual” means that samples are collected twice per year with at least 120 calendar days between sampling events. The monitoring results shall be reported on the facility’s Discharge Monitoring Reports and included with the NPDES permit renewal application.

Instream monitoring is provisionally waived considering the permittee’s participation in the Middle Cape Fear River Basin Association provided the Association agrees to sample for all the parameters listed in this condition and at the specified locations. Instream monitoring shall be conducted as stated in this permit should the permittee end its participation in the Association.

Table 9: Instream Monitoring Locations

Instream Sample Description	Location
Upstream Outfall 008	0.9 miles upstream from Outfall 008 in Cape Fear River
Downstream Outfall 008	Approximately 250 meters downstream from Outfall 008 in Cape Fear River

Fish Tissue Monitoring

The current permit’s Fish Tissue Monitoring Near Ash Pond Discharge special condition will be modified to show the submittal of the proposed plan for approval by the Division shall be no later than 180 days after the effective date of this permit, and to provide the addresses for submittal of the proposed plan and the subsequent required report. Once the plan is approved it will become an enforceable part of the permit.

Removal of Special Conditions No Longer Valid

As a result of the decommissioning and removing of the steam and turbine components, removing of the domestic WWTP, and eliminating of other related on-site sources, the following current permit Special Conditions are no longer applicable and will be removed from this permit renewal:

- A. (2.) Internal Outfall 003
- A. (6) Intake Screen Backwashing
- A. (7.) Biocide Condition
- A. (8.) Domestic Wastewater Treatment Plant
- A. (10.) Section 316 (b) of CWA

Constructed Seep (French Drain)

As part of the required effluent channel evaluation completed by the Division on September 2, 2016 and subsequent updates to confirm status of constructed seep, Outfall S-05 is the recognized combined flow of the two French Drain sources that collect in the effluent channel. Table 10 lists the details related to S-05. The effluent channel flows go to Outfall 007, which discharges to an unnamed tributary to the Cape Fear River.

Table 10: Coordinates and Assigned Outfall

Discharge ID	Latitude	Longitude
S-05	35° 35' 25.62" N	79° 2' 46.96" W

Summary of Proposed Changes

1. Eliminated the current permit Internal Outfall 003 and its limitation page A. (2.); Special Conditions A. (6.) Intake Screen Backwash, A. (7.) Biocide Condition, A. (8.) Domestic Wastewater Treatment Plant, A. (10.) Section 316(b) of CWA; as they are no longer applicable.
2. Modified Supplement to Permit Cover Sheet to show the new outfalls' configuration.
3. Modified Internal Outfalls 001 and 005 limitation pages [new permit A. (1.) and A. (2.)] to repurpose their monitoring, narrative, and limit requirements for episodic emergency overflow of decanting wastewater from the West and East Ash Basins. Outfall 005 was relocated to different segment of the effluent channel.
4. Modified Outfall 007 limitation page [new permit A. (3.)], discharge to unnamed tributary to the Cape Fear River, to repurpose its monitoring, narrative, and limit requirements for comingled ash basin treated decanting wastewater and any other collected wastewater in the effluent channel approved by the Division.
5. Added new Outfall 008 limitation pages [new permit A. (4.), A. (5.), A. (6.), A. (7.)], discharge to the Cape Fear River, for monitoring and limit requirements, and applicable narrative conditions, for combination of treated wastewater sources starting with ash basin decanting, followed by ash basin dewatering, followed by the introduction of groundwater remediation in combination with ash basin dewatering, and ending with groundwater remediation only.
6. Added new Outfall 008A limitation page [new permit A. (8.)] for monitoring, narrative, and limit requirements for the episodic emergency overflow of decanting wastewater from the 1963/1970 Ash Basin.
7. Added new Outfall 009 limitation page [new permit A. (9.)], discharge to the Cape Fear River, for monitoring, narrative, and limit requirements for miscellaneous Beneficiation area wastewater.
8. Modified Special Condition A. (10.) Chronic Toxicity Limit (Quarterly) for Outfalls 007 and 008.
9. Added Special Condition A. (11.) Chronic Toxicity Limit (Monthly) for Outfall 008.
10. Added Special Condition A. (12.) Additional Conditions and Definitions for other applicable conditions associated with this permit.
11. Added Special Condition A. (13.) Instream Monitoring to implement monthly instream monitoring for Arsenic, Bromide, Cadmium, Chromium, Copper, Hardness, Lead, Mercury, Selenium, Zinc, TDS, Temperature and Turbidity at instream locations on the Cape Fear River.
12. Revised Special Condition A. (14.) Structural Integrity Inspections of Ash Basin Dam.
13. Modified Special Condition A. (15.) Fish Tissue Monitoring Near Ash Basin Discharge to redefine submittal and approval requirements for the required fish tissue monitoring plan, and to define the approved monitoring plan enforceable.
14. Added Special Condition A. (16.) Compliance Boundary. Boundary map will be attached to permit.
15. Added Special Condition A. (17.) Applicable State Law narrative to meet requirements of Senate Bill 729 (Coal Ash Management Act).
16. Added Special Condition A. (18.) Addition of Other Wastewater to Ash Basin Treatment System to require the submittal of EPA Form 2C upon addition of groundwater remediation wastewater to treatment system.
17. Added Special Condition A. (19.) Electronic Reporting of Discharge Monitoring Reports for electronic reporting of DMRs. Federal regulations require electronic submittal of all discharge monitoring reports (DMRs) and specify that, if a state does not establish a system

to receive such submittals, then permittees must submit DMRs electronically to the Environmental Protection Agency (EPA).

Proposed Schedule

Draft Permit to Public Notice: June 27, 2018
Permit Scheduled to Issue: August 30, 2018

Fact Sheet Addendum (if applicable):

*Were there any changes made since the Draft Permit was public noticed (Yes/No): Yes
If Yes, list changes and their basis below:*

- Facility class was corrected to Grade I Physical Chemical WPCS in the cover letter;
- Flow limit for Outfall 008 (groundwater remediation) has been changed from a Monthly Average to a Daily Maximum limitation in Section A. (7.) as requested by Permittee;
- Limits and monitoring for pH, TSS and Oil & Grease have been added to Outfall 008A in Section A. (8.) as requested by SELC. Additionally, paragraph (b) has been removed from the permit since Outfall 008A is no longer an internal outfall;
- Division has revised the wording in the requirement for Duck Energy to discontinue discharge of wastewater and report to the Regional Office if one of the pollutants reaches 85% of the allowable level during decanting and dewatering [See Section A. (3.) Paragraph c and Section A. (6.) Paragraph d];
- Paragraph c has been added to Section A. (9.) for Outfall 009 to require Permittee to submit completed EPA Form 2C for the addition of beneficiation wastewtaers no later than 180 days after the introduction of the beneficiation wastewters to the treatment system.
- Special Condition A. (11.) Chronic Toxicity Limit (Monthly) has been revised to exclude Outfall 007 since the monthly chronic toxicity limit is not applicable for Outfall 007. Quarterly chronic toxicity test remains for Outfall 007 [See Special Condition A. (10.) Chronic Toxicity Limit (Quarterly)].

Fact Sheet Attachments

RPA Spreadsheet Summary for Outfalls 007, 008 and 009

DWR Public Water Supply Memo

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58


 REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	007 base + decanting
Flow, Qw (MGD)	0.730
Receiving Stream	UT to Cape Faer River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	0.00
7Q10w (cfs)	0.00
30Q2 (cfs)	0.00
QA (cfs)	0.00
1Q10s (cfs)	0.00
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Applying highest decanting value, default hardness values, based on Raleigh Regional Office AOW evaluation, BPJ flow (500 gpm treated + base flow)
<input type="checkbox"/> CHECK TO APPLY MODEL	

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/l
Par07	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		µg/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		ug/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			ug/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L



Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Qw (MGD) = **0.7300**1Q10S (cfs) = **0.00**7Q10S (cfs) = **0.00**7Q10W (cfs) = **0.00**30Q2 (cfs) = **0.00**Avg. Stream Flow, QA (cfs) = **0.00**Receiving Stream: **UT to Cape Fear River HUC 03030002**WWTP/WTP Class: **Class II**IWC% @ 1Q10S = **100**IWC% @ 7Q10S = **100**IWC% @ 7Q10W = **100**IWC% @ 30Q2 = **100**IW%C @ QA = **100**Stream Class: **WS-IV****COMBINED HARDNESS (mg/L)**

Acute = 25 mg/L

Chronic = 25 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard: 0 value > 100 mg/L

Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW	340		ug/L	7	7	79.0	Acute (FW): 340.0 Chronic (FW): 150.0 No value > Allowable Cw	
Arsenic	C	10	HH/WS			ug/L	Note: n ≤ 9 Limited data set		C.V. (default)	Chronic (HH): 10.0 4 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Cadmium	NC	0.5899	FW	3.2396		ug/L	7	0	1.005	Acute: 3.240 Chronic: 0.590	Permittee shall sample to POL at 0.5 ug/L
Chlorides	NC	250	WS			mg/L	7	7	64.3	Acute: NO WQS Chronic: 250.0 No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Monthly Monitoring
Aluminum	NC	6.5	WS			mg/l	7	7	0.4	Acute: NO WQS Chronic: 6.50000 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Total Dissolved Solids	NC	500	WS			mg/L	7	7	482.4	Acute: NO WQS Chronic: 500.00000 No value > Allowable Cw	No RP , Predicted Max ≥ 50% of Allowable Cw - apply Monthly Monitoring
Chromium III	NC	117.7325	FW	905.0818		μg/L	0	0	N/A	Acute: 905.1 Chronic: 117.7	
Chromium VI	NC	11	FW	16		μg/L	0	0	N/A	Acute: 16.0 Chronic: 11.0	
Chromium, Total	NC					μg/L	7	0	1.0	Max reported value = 0.5 C.V. (default) NO DETECTS Max MDL = 1	a: No monitoring required if all Total Chromium samples are < 5 μg/L or Pred. max for Total Cr is < allowable Cw for Cr VI.
Copper	NC	7.8806	FW	10.4720		ug/L	7	3	7.01	Acute: 10.47 Chronic: 7.88 No value > Allowable Cw	No RP , Predicted Max ≥ 50% of Allowable Cw - apply Monthly Monitoring

Cape Fear Steam Electric Plant

NC0003433

Outfall 007 base + decanting

Qw = 0.73 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Fluoride	NC	1800	FW		ug/L	7 7 Note: n ≤ 9 Limited data set	1,547.7 C.V. (default)	Acute: NO WQS Chronic: 1,800.0 No value > Allowable Cw	No RP , Predicted Max ≥ 50% of Allowable Cw - apply Monthly Monitoring
Lead	NC	2.9416	FW	75.4871	ug/L	7 0 Note: n ≤ 9 Limited data set	1.005 C.V. (default) NO DETECTS	Acute: 75.487 Chronic: 2.942 Max MDL = 1	Pollutant of concern, apply monthly monitoring
Mercury	NC	12	FW	0.5	ng/L	7 4 Note: n ≤ 9 Limited data set	2,070,300.0 C.V. (default)	Acute: NO WQS Chronic: 12.0 7 value(s) > Allowable Cw	Mercury TMDL applied, 12 ng/L Limit as annual average with weekly monitoring
Molybdenum	NC	160	WS		ug/L	7 7 Note: n ≤ 9 Limited data set	357.8 C.V. (default)	Acute: NO WQS Chronic: 160.0 4 value(s) > Allowable Cw	RP shown - apply Monthly Monitoring with Limit
Nickel	NC	37.2313	FW	335.2087	µg/L	7 4 Note: n ≤ 9 Limited data set	87.4 C.V. (default)	Acute (FW): 335.2 Chronic (FW): 37.2 3 value(s) > Allowable Cw	
Nickel	NC	25.0000	WS		µg/L	7 4 Note: n ≤ 9 Limited data set	87.4 C.V. (default)	Chronic (WS): 25.0 3 value(s) > Allowable Cw	RP shown - apply Monthly Monitoring with Limit
Selenium	NC	5	FW	56	ug/L	7 7 Note: n ≤ 9 Limited data set	97.7 C.V. (default)	Acute: 56.0 Chronic: 5.0 4 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Zinc	NC	126.7335	FW	125.7052	ug/L	7 4 Note: n ≤ 9 Limited data set	552.8 C.V. (default)	Acute: 125.7 Chronic: 126.7 3 value(s) > Allowable Cw	RP shown - apply Monthly Monitoring with Limit
Antimony	NC	5.6	WS		µg/L	7 4 Note: n ≤ 9 Limited data set	21.90900 C.V. (default)	Acute: NO WQS Chronic: 5.60000 4 value(s) > Allowable Cw	RP shown - apply Monthly Monitoring with Limit
Barium	NC	1	WS		mg/L	7 7 Note: n ≤ 9 Limited data set	0.32361 C.V. (default)	Acute: NO WQS Chronic: 1.00000 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Sulfates	NC	250	WS		mg/L	7 7 Note: n ≤ 9 Limited data set	221.10000 C.V. (default)	Acute: NO WQS Chronic: 250.00000 No value > Allowable Cw	No RP , Predicted Max ≥ 50% of Allowable Cw - apply Monthly Monitoring
Thallium	NC	2	WS		µg/L	7 7 Note: n ≤ 9 Limited data set	2.65320 C.V. (default)	Acute: NO WQS Chronic: 2.00000 No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Monthly Monitoring

REASONABLE POTENTIAL ANALYSIS

H1				H2				Par01 & Par02				Par04				Par05			
Effluent Hardness				Upstream Hardness				Arsenic				Cadmium				Chlorides			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	default	25	25	1	default	25	25	1	10/10/2014	39.3	39.3	1	10/10/2014	<	1	1	0.5	Std Dev.	0.0000
2			N/A	2			Mean	2	10/10/2014	3.32	3.32	2	10/10/2014	<	1	0.5	Mean	0.5000	
3			C.V.	3			0.0000	3		3.05	3.05	3	10/10/2014	<	1	0.5	C.V. (default)	0.6000	
4			n	4			1	4		3.28	3.28	4	10/10/2014	<	1	0.5	n	7	
5			10th Per value	5			25.00 mg/L	5		38	38	5	10/10/2014	<	1	0.5	Mult Factor =	2.01	
6			Average Value	6			25.00 mg/L	6		38.5	38.5	6	10/10/2014	<	1	0.5	Mult Factor =	2.01	
7			Max. Value	7			25.00 mg/L	7		39	39	7	10/10/2014	<	1	0.5	Max. Value	0.500 ug/L	
8				8				8				8				Max. Pred Cw	79.0 ug/L		
9				9				9				9					1.005 ug/L		
Par06				Par07				Par10				Par10				Par06			
Chlorides				Aluminum				Total Dissolved Solids				Chromium, Total				Chlorides			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	10/10/2014	32	32	1	10/10/2014	0.222	0.222	1	10/10/2014	240	240	1	10/10/2014	<	1	0.5	Std Dev.	0.0000	
2	10/10/2014	16	Mean	2	10/10/2014	0.101	0.101	2	10/10/2014	230	230	2	10/10/2014	<	1	0.5	Mean	0.5000	
3	32	32	C.V. (default)	3	0.213	0.213	3	230	230	3	10/10/2014	<	1	0.5	C.V. (default)	0.6000			
4	32	32	n	4	0.218	0.218	4	240	240	4	10/10/2014	<	1	0.5	n	7			
5	16	16		5	0.217	0.217	5	220	220	5	10/10/2014	<	1	0.5	Mult Factor =	2.01			
6	16	16	Mult Factor =	6	0.1	0.1	6	230	230	6	10/10/2014	<	1	0.5	Mult Factor =	2.01			
7	16	16	Max. Value	7	0.101	0.101	7	230	230	7	10/10/2014	<	1	0.5	Max. Value	0.5 ug/L			
8			Max. Pred Cw	8			8			8			8		Max. Pred Cw	482.4 mg/L			
9				9			9			9			9				1.0 ug/L		
Pa11				Par13				Par14				Par16				Par17 & Par18			
Copper				Fluoride				Lead				Molybdenum				Copper			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	10/10/2014	3.49	3.49	1	10/10/2014	770	770	1	10/10/2014	<	1	1	0.5	Std Dev.	0.0000	1	10/10/2014	3.49	3.49
2	10/10/2014	<	1	2	10/10/2014	290	290	2	10/10/2014	Mean	564.2857	2	10/10/2014	<	1	0.5	Mean	0.5000	
3			0.5	3	10/10/2014	290	290	3	10/10/2014	C.V. (default)	0.6000	3	10/10/2014	<	1	0.5	C.V. (default)	0.6000	
4			0.6000	4	10/10/2014	290	290	4	10/10/2014	n	7	4	10/10/2014	<	1	0.5	n	7	
5			7	5	10/10/2014	770	770	5	10/10/2014	Mult Factor =	2.01	5	10/10/2014	<	1	0.5	Mult Factor =	2.01	
6			2.01	6	10/10/2014	770	770	6	10/10/2014	Max. Value	770.0 ug/L	6	10/10/2014	<	1	0.5	Max. Value	178.0 ug/L	
7			3.49 ug/L	7	10/10/2014	770	770	7	10/10/2014	Max. Pred Cw	1547.7 ug/L	7	10/10/2014	<	1	0.5	Max. Pred Cw	357.8 ug/L	
8				8				8				8							
9				9				9				9							
Par19				Par21				Par22				Par23				Par19			
Nickel				Selenium				Zinc				Antimony				Barium			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	10/10/2014	43.5	43.5	1	10/10/2014	48.6	48.6	1	10/10/2014	275	275	1	10/10/2014	<	1	0.5	Std Dev.	93.6258	
2	10/10/2014	1.14	Mean	2	10/10/2014	2.07	2.07	2	10/10/2014	20	20	2	10/10/2014	<	1	0.5	Mean	101.1871	
3	42.4	42.4	C.V. (default)	3	1.96	1.96	C.V. (default)	3	267	267	3	10/10/2014	<	1	0.5	C.V. (default)	0.6000		
4	42	42	n	4	1.81	1.81	n	4	263	263	4	10/10/2014	<	1	0.5	n	7		
5	<	1	0.5	5	46.9	46.9		5	<	5	5	10/10/2014	<	1	0.5	Mult Factor =	2.01		
6	<	1	0.5	6	47.6	47.6	Mult Factor =	6	<	5	2.5	6	10/10/2014	<	1	0.5	Mult Factor =	2.01	
7	<	1	0.5	7	48.5	48.5	Max. Value	7	<	5	2.5	7	10/10/2014	<	1	0.5	Max. Value	10.900000 ug/L	
8			Max. Pred Cw	8			Max. Pred Cw	8			Max. Pred Cw	8				Max. Pred Cw	21.909000 ug/L		
9				9				9				9							
Par24				Par25				Par26				Par23				Par24			
Sulfates				Thallium				Mercury				Par23				Sulfates			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1	10/10/2014	110	110	1	10/10/2014	1.32	1.32	1	10/10/2014	Std Dev.	0.1718	1	10/10/2014	1E+06	1030000	Std Dev.	#####	#####	#####
2	10/10/2014	91	91	2	10/10/2014	0.978	0.978	2	10/10/2014	Mean	1.1011	2	10/10/2014	9E+05	941000	Mean	#####	#####	#####
3	0.103	0.103	C.V. (default)	3	110	110	C.V. (default)	3	1.25	1.25	3	10/10/2014	1E+06	987000	C.V. (default)	0.6000	#####	#####	#####
4	0.102	0.102	n	4	110	110	n	4	1.28	1.28	4	10/10/2014	8E+05	761000	n	7	#####	#####	#####
5	0.159	0.159		5	90	90		5	0.967	0.967	5	10/10/2014	<	5	250000	Mult Factor =	2.01	#####	#####
6	0.16	0.16	Mult Factor =	6	90	90	Mult Factor =	6	0.962	0.962	6	10/10/2014	<	5	250000	Max. Value	1030000.0 ng/L	#####	#####
7	0.157	0.157	Max. Value	7	89	89	Max. Value	7	0.951	0.951	7	10/10/2014	<	5	250000	Max. Pred Cw	2070300.0 ng/L	#####	#####
8			Max. Pred Cw	8			Max. Pred Cw	8			Max. Pred Cw	8			9				
9				9				9				9							

FACILITY: Cape Fear Steam Electric Plant Outfall 007 base + c
 NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
0.0000	0.0000	0.0000	0.7300	10	25.000	25.000	100.0000	100.0000	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals Criteria after applying hardness equation		US EPA Translators- using Default Partition Coefficients (streams)	Total Metal Criteria		Total Metal = Dissolved Metal + Translator	COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):
	Chronic	Acute		Chronic	Acute		
	[ug/l]	[ug/l]		[ug/l]	[ug/l]		
Cadmium (d)	0.15	0.82	0.252	0.59	3.24		
Cd -Trout streams	0.15	0.51	0.252	0.59	2.01		
Chromium III (d)(h)	24	183	0.202	117.73	905.08		
Chromium VI (d)	11	16	1.000	11.00	16.00		
Chromium, Total (t)				N/A	N/A		
Copper (d)(h)	2.7	3.6	0.348	7.88	10.47		
Lead (d)(h)	0.54	14	0.184	2.94	75.49		
Nickel (d)(h)	16	145	0.432	37.23	335.21		
Ni - WS streams (t)				25	N/A		
Silver (d)(h,acute)	0.06	0.30	1.000	0.06	0.30		
Zinc (d)(h)	36	36	0.288	126.73	125.71		
Beryllium	6.5	65	1.000	6.5	65		
Arsenic (d)	150	340	1.000	150	340		

(d) = dissolved metal standard. See 15A NCAC 02B.0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B.0211 for more information.

(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B.0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

001
1675

Table 1
Cape Fear Plant Ash Basin Water Characterization Water Samples Collected October 10, 2014 (Page 1 of 2)

Parameter	Units	Sample Description			
		Bulk Water 1978-1'	Bulk Water 1978-4'	Bulk Water 1978-8'	Bulk Water 1985-1'
NO2 + NO3	mg/l	<0.01	0.028	0.018	<0.01
Total Kjeldahl Nitrogen	mg/l	0.28	0.28	0.19	0.22
Bromide	mg/l	1.2	1.5	1.4	0.47
Chloride	mg/l	32	32.	32	16
Fluoride	mg/l	0.29	0.29	0.29	0.77
Sulfate	mg/l	110	110	110	91
Aluminum (Al)	mg/l	0.101	0.101	0.098	0.217
Barium (Ba)	mg/l	0.104	0.103	0.102	0.161
Boron (B)	mg/l	0.221	0.222	0.215	1.27
Calcium (Ca)	mg/l	19.8	20	19.5	37
Iron (Fe)	mg/l	0.016	0.014	0.013	<0.01
Magnesium (Mg)	mg/l	7	7.06	6.95	5.14
Manganese (Mn)	mg/l	0.648	0.649	0.641	0.007
Phosphorus (P)	mg/l	<0.02	<0.02	<0.02	<0.02
Zinc (Zn)	mg/l	0.267	0.275	0.263	<0.005
Antimony (Sb)	µg/l	<1	<1	<1	0.02
Arsenic (As)	µg/l	3.05	3.28	3.32	38
Cadmium (Cd)	µg/l	<1	<1	<1	<1
Chromium (Cr)	µg/l	<1	<1	<1	<1
Copper (Cu)	µg/l	3.49	3.46	3.24	<1
Lead (Pb)	µg/l	<1	<1	<1	<1
Molybdenum (Mo)	µg/l	1.18	1.08	1.05	175
Nickel (Ni)	µg/l	42.4	43.5	42	<1
Selenium (Se)	µg/l	1.96	2.07	1.81	46.9
Thallium (Tl)	µg/l	<0.500	<0.500	<0.500	0.941
Mercury (CVAFS)	mg/l	230	240	240	220
TDS	mg/l	<5	<5	<5	<5
TSS	mg/l	<5	<5	<5	<5

Outfall 007 Decanting

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

(●) REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	008 Ash Basin Decanting
Flow, Qw (MGD)	0.720
Receiving Stream	Cape Fear River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	65.00
7Q10w (cfs)	89.00
30Q2 (cfs)	150.00
QA (cfs)	3170.00
1Q10s (cfs)	53.22
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Ash Basins 2014 - highest bulk water pollutant concentrations from basins; 500 GPM treatment flow; USGS suggested flows and data, default hardness
	Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Par07	→ Total Phenolic Compounds	Aquatic Life	NC	300	A			ug/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		μg/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		μg/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		μg/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		μg/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			μg/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L
Par25	Thallium	Water Supply	NC	2	WS			μg/L

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.72

1Q10S (cfs) = 53.22

7Q10S (cfs) = 65.00

7Q10W (cfs) = 89.00

30Q2 (cfs) = 150.00

Avg. Stream Flow, QA (cfs) = 3170.00

Receiving Stream: Cape Fear River HUC 03030002

WWTP/WTP Class: Class II

IWC% @ 1Q10S = 2.053886926

IWC% @ 7Q10S = 1.687942404

IWC% @ 7Q10W = 1.238403835

IWC% @ 30Q2 = 0.738505519

IW%C @ QA = 0.035192658

Stream Class: WS-IV

COMBINED HARDNESS (mg/L)

Acute = 25 mg/L

Chronic = 25 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard: 0 value > 100 mg/L

Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW(7Q10s)	340		ug/L	7	7	79.0	Acute (FW): 16,554.0 Chronic (FW): 8,886.6 No value > Allowable Cw	Major pollutant of concern apply weekly monitoring
Arsenic	C	10	HH/WS(Qavg)			ug/L	Note: n ≤ 9 Limited data set		Default C.V.	Chronic (HH): 28,415.0 No value > Allowable Cw	Major pollutant of concern apply weekly monitoring
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	7	7	482.40	Acute: NO WQS Chronic: 29,621.86 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Cadmium	NC	0.5899	FW(7Q10s)	3.2396		ug/L	7	0	1.005	Acute: 157.731 Chronic: 34.947 NO DETECTS	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chlorides	NC	250	WS(7Q10s)			mg/L	7	7	64.3	Acute: NO WQS Chronic: 14,810.9 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Aluminum	NC	6.5	WS(7Q10s)			mg/L	7	7	0.4	Acute: NO WQS Chronic: 385.1 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chromium III	NC	117.7325	FW(7Q10s)	905.0818		μg/L	0	0	N/A	Acute: 44,066.8 Chronic: 6,974.9	
Chromium VI	NC	11	FW(7Q10s)	16		μg/L	0	0	N/A	Acute: 779.0 Chronic: 651.7	
Chromium, Total	NC					μg/L	7	0	1.0	Max reported value = 0.5 NO DETECTS	No detects, MDL< Allowable Cw for Chromium III & VI - No Monitoring required
Copper	NC	7.8806	FW(7Q10s)	10.4720		ug/L	7	3	7.01	Acute: 509.86 Chronic: 466.88 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required

Cape Fear Steam Electric Plant

NC0003433

Outfall 008 Ash Basin Decanting

Qw = 0.72 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Fluoride	NC	1800	FW(7Q10s)		ug/L	7 7 Note: n ≤ 9 Limited data set	1,547.7 Default C.V.	Acute: NO WQS Chronic: 106,638.7 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Lead	NC	2.9416	FW(7Q10s)	75.4871	ug/L	7 0 Note: n ≤ 9 Limited data set	1.005 Default C.V. NO DETECTS	Acute: 3,675.329 Chronic: 174.273 Max MDL = 1	Pollutant of concern, apply monthly monitoring
Mercury	NC	12	FW(7Q10s)	0.5	ng/L	7 4 Note: n ≤ 9 Limited data set	2,070,300.0 Default C.V.	Acute: NO WQS Chronic: 710.9 7 value(s) > Allowable Cw	Value > stringent TBEL - apply limit of 47 ng/L annual average with weekly monitoring
Molybdenum	NC	160	WS(7Q10s)		ug/L	7 7 Note: n ≤ 9 Limited data set	357.8 Default C.V.	Acute: NO WQS Chronic: 9,479.0 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Nickel	NC	37.2313	FW(7Q10s)	335.2087	µg/L	7 4 Note: n ≤ 9 Limited data set	87.4 Default C.V.	Acute (FW): 16,320.7 Chronic (FW): 2,205.7 No value > Allowable Cw	Pollutant of concern, apply monthly monitoring
Nickel	NC	25.0000	WS(7Q10s)		µg/L	7 4 Note: n ≤ 9 Limited data set		Chronic (WS): 1,481.1 No value > Allowable Cw	Pollutant of concern, apply monthly monitoring
Selenium	NC	5	FW(7Q10s)	56	ug/L	7 7 Note: n ≤ 9 Limited data set	97.7 Default C.V.	Acute: 2,726.5 Chronic: 296.2 No value > Allowable Cw	Major pollutant of concern apply weekly monitoring
Zinc	NC	126.7335	FW(7Q10s)	125.7052	ug/L	7 4 Note: n ≤ 9 Limited data set	552.8 Default C.V.	Acute: 6,120.4 Chronic: 7,508.2 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Antimony	NC	5.6	WS(7Q10s)		µg/L	7 4 Note: n ≤ 9 Limited data set	21.90900 Default C.V.	Acute: NO WQS Chronic: 331.76487 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Barium	NC	1	WS(7Q10s)		mg/L	7 7 Note: n ≤ 9 Limited data set	0.32361 Default C.V.	Acute: NO WQS Chronic: 59.24373 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Sulfates	NC	250	WS(7Q10s)		mg/L	7 7 Note: n ≤ 9 Limited data set	221.10000 Default C.V.	Acute: NO WQS Chronic: 14810.93190 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Thallium	NC	2	WS(7Q10s)		µg/L	7 7 Note: n ≤ 9 Limited data set	2.65320 Default C.V.	Acute: NO WQS Chronic: 118.48746 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required

REASONABLE POTENTIAL ANALYSIS

H1				H2				Par01 & Par02				Par03				Par04											
Effluent Hardness				Upstream Hardness				Arsenic				Total Dissolved Solids				Cadmium											
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results								
1	default	25	25	1	default	25	25	1	10/10/2014	39.3	39.3	1	10/10/2014	240	240	1	10/10/2014	240	6.9007								
2			N/A	2				2	10/10/2014	3.32	3.32	2	10/10/2014	230	230	2	10/10/2014	230	231.4286								
3				3				3		3.05	3.05	3		230	230	3		230	C.V. (default)								
4				4				4		3.28	3.28	4		240	240	4		240	n								
5				5				5		38	38	5		220	220	5		220	7								
6				6				6		38.5	38.5	6		230	230	6		230	Mult Factor =								
7				7				7		39	39	7		230	230	7		230	2.01								
8				8				8		Max. Value	39.3 ug/L	8		Max. Value	240.00 mg/L	8		Max. Value	240.00 mg/L								
9				9				9		Max. Pred Cw	79.0 ug/L	9		Max. Pred Cw	482.40 mg/L												
Par05				Par06				Par10				Par16				Par04											
Cadmium				Chlorides				Aluminum				Chromium, Total				Cadmium											
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results								
1	10/10/2014	<	1	1	0.5	Std Dev.	0.0000	1	10/10/2014	0.222	0.222	1	10/10/2014	1	0.5	Std Dev.	0.0000	1	10/10/2014	<	1						
2	10/10/2014	<	1	2	0.5	Mean	0.5000	2	10/10/2014	0.101	0.101	2	10/10/2014	<	1	0.5	Mean	0.5000	2	10/10/2014	<	1					
3	10/10/2014	<	1	3	0.5	C.V. (default)	0.6000	3	10/10/2014	0.213	0.213	3	10/10/2014	<	1	0.5	C.V. (default)	0.6000	3	10/10/2014	<	1					
4	10/10/2014	<	1	4	0.5	n	7	4	10/10/2014	0.218	0.218	4	10/10/2014	<	1	0.5	n	7	10/10/2014	<	1						
5	10/10/2014	<	1	5	16	16	16	5	10/10/2014	0.217	0.217	5	10/10/2014	<	1	0.5	n	7	10/10/2014	<	1						
6	10/10/2014	<	1	6	16	16	16	6	10/10/2014	0.1	0.1	6	10/10/2014	<	1	0.5	Mult Factor =	2.01	6	10/10/2014	<	1					
7	10/10/2014	<	1	7	16	16	16	7	10/10/2014	0.101	0.101	7	10/10/2014	<	1	0.5	Max. Value	0.2 mg/L	7	10/10/2014	<	1					
8				8				8		Max. Pred Cw	64.3 mg/L	8		Max. Pred Cw	0.4 mg/L	8		Max. Pred Cw	1.0 µg/L	9							
Pa11				Pa13				Par14				Par16				Par17 & Par18											
Copper				Fluoride				Lead				Molybdenum				Nickel											
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results								
1	10/10/2014	3.49	3.49	1	10/10/2014	770	770	1	10/10/2014	<	1	1	10/10/2014	178	178	1	10/10/2014	178	93.6258								
2	10/10/2014	<	1	2	0.5	Mean	1.7457	2	10/10/2014	<	1	2	10/10/2014	1.18	1.18	2	10/10/2014	1.18	101.1871	3	10/10/2014	<	1				
3				3	3.49	3.49	C.V. (default)	0.6000	3	10/10/2014	<	1	3	10/10/2014	1.08	1.08	3	10/10/2014	1.08	0.6000	4	10/10/2014	<	1			
4				4	3.24	3.24	n	7	4	10/10/2014	<	1	4	10/10/2014	1.05	1.05	4	10/10/2014	1.05	n	5	10/10/2014	<	1			
5				5	<	1	0.5		5	10/10/2014	<	1	5	10/10/2014	1.05	1.05	5	10/10/2014	1.05	1.05	6	10/10/2014	<	1			
6				6	<	1	0.5	Mult Factor =	2.01	6	10/10/2014	<	1	6	10/10/2014	10.5	10.5	6	10/10/2014	10.5	2.01	7	10/10/2014	<	1		
7				7	<	1	0.5	Max. Value	3.49 ug/L	7	10/10/2014	<	1	7	10/10/2014	10.8	10.8	7	10/10/2014	10.8	10.900000 ug/L	8	10/10/2014	<	1		
8				8				8		Max. Pred Cw	70.1 ug/L	8		Max. Pred Cw	1.05 ug/L	8		Max. Pred Cw	357.8 ug/L	9							
Par19				Par21				Par22				Par26				Par23											
Selenium				Zinc				Antimony				Mercury				Barium											
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results								
1	10/10/2014	43.5	43.5	1	10/10/2014	48.6	48.6	1	10/10/2014	275	275	1	10/10/2014	10.9	10.9	1	10/10/2014	10.9	5.4668	2	10/10/2014	<	1				
2	10/10/2014	1.14	1.14	2	1.14	Mean	18.6466	2	10/10/2014	2.07	2.07	2	10/10/2014	<	1	2	10/10/2014	<	6.3429	3	10/10/2014	<	1				
3				3	42.4	42.4	C.V. (default)	0.6000	3	1.96	1.96	3	1.96	C.V. (default)	0.6000	3	10/10/2014	<	1	3	10/10/2014	<	0.6000	4	10/10/2014	<	1
4				4	42	42	n	7	4	1.81	1.81	4	1.81	n	7	4	263	263	0.6000	5	10/10/2014	<	1				
5				5	46.9	46.9			5	46.9	46.9	5	46.9	2.5	2.5	5	2.5	2.5	0.6000	6	10/10/2014	<	1				
6				6	47.6	47.6	Mult Factor =	2.01	6	47.6	47.6	6	47.6	Mult Factor =	2.01	6	10.8	10.8	0.6000	7	10/10/2014	<	1				
7				7	48.5	48.5	Max. Value	43.5 ug/L	7	48.5	48.5	7	48.5	Max. Value	48.6 ug/L	7	275.0 ug/L	275.0 ug/L	0.6000	8	10/10/2014	<	1				
8				8	87.4	87.4	Max. Pred Cw	87.4 ug/L	8	97.7	97.7	8	97.7	Max. Pred Cw	97.7 ug/L	8	552.8 ug/L	552.8 ug/L	0.6000	9							
Par24				Par25				Par26				Par23				Par19											
Sulfates				Thallium				Antimony				Mercury				Barium											
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results								
1	10/10/2014	0.161	0.161	1	10/10/2014	110	110	1	10/10/2014	1.32	1.32	1	10/10/2014	1.32	1.32	1	10/10/2014	1.32	0.1718	2	10/10/2014	<	1				
2	10/10/2014	0.104	0.104	2	10/10/2014	91	91	2	10/10/2014	0.978	0.978	2	10/10/2014	0.978	0.978	2	10/10/2014	0.978	1.1011	3	10/10/2014	<	1				
3				3	0.103	0.103	C.V. (default)	0.6000	3	110	110	3	110	C.V. (default)	0.6000	3	1.25	1.25	0.6000	4	10/10/2014	<	1				
4				4	0.102	0.102	n	7	4	110	110	4	110	n	7	4	1.28	1.28	n	5	10/10/2014	<	1				
5				5	90	90			5	90	90	5	90	0.967	0.967	5	0.967	0.967	0.6000	6	10/10/2014	<	1				
6				6	90	90	Mult Factor =	2.01	6	90	90	6	90	Mult Factor =	2.01	6	0.962	0.962	0.6000	7	10/10/2014	<	1				
7				7	89	89	Max. Value	0.161000 mg/L	7	89	89	7	89	Max. Value	110.000 mg/L	7	1.320000 µg/L	1.320000 µg/L	0.6000	8	10/10/2014	<	1				
8				8	0.323610	0.323610	Max. Pred Cw	0.323610 mg/L	8	221.100	221.100	8	221.100	Max. Pred Cw	2.653200 µg/L	8	2.653200 µg/L	2.653200 µg/L	0.6000	9							

FACILITY: Cape Fear Steam Electric Plant
NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
65.000	41.9355	34.3355	0.7200	10	25.000	25.000	1.6879	2.0539	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals		US EPA Translators- using Default Partition Coefficients (streams)	Maximum Allowable Effluent Concentration (MAEC) as a Total Metal		COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):				
	Dissolved Metal	Translator		Chronic	Acute					
	[ug/l]	[ug/l]		[ug/l]	[ug/l]					
Cadmium (d)	0.15	0.82		0.252	0.59	3.24				
Cd -Trout streams	0.15	0.51		0.252	0.59	2.01				
Chromium III (d)(h)	24	183		0.202	117.73	905.08				
Chromium VI (d)	11	16		1.000	11.00	16.00				
Chromium, Total (t)					N/A	N/A				
Copper (d)(h)	2.7	3.6		0.348	7.88	10.47				
Lead (d)(h)	0.54	14		0.184	2.94	75.49				
Nickel (d)(h)	16	145		0.432	37.23	335.21				
Ni - WS streams (t)					25	N/A				
Silver (d)(h,acute)	0.06	0.30		1.000	0.06	0.30				
Zinc (d)(h)	36	36		0.288	126.73	125.71				
Beryllium	6.5	65		1.000	6.5	65				
Arsenic (d)	150	340		1.000	150	340				

(d) = dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B .0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

Cape Fear Plant Ash Basin Water Characterization Water Samples Collected October 10, 2014 (Page 1 of 2)

Parameter	Units	Sample Description			
		Bulk Water 1978-1'	Bulk Water 1978-4'	Bulk Water 1978-8'	Bulk Water 1985-1'
NO2 + NO3	mg/l	<0.01	0.028	0.018	<0.01
Total Kjeldahl Nitrogen	mg/l	0.28	0.28	0.19	0.22
Bromide	mg/l	1.2	1.5	1.4	0.47
Chloride	mg/l	32	32.	32	16
Fluoride	mg/l	0.29	0.29	0.29	0.77
Sulfate	mg/l	110	110	110	91
Aluminum (Al)	mg/l	0.101	0.101	0.098	0.217
Barium (Ba)	mg/l	0.104	0.103	0.102	0.161
Boron (B)	mg/l	0.221	0.222	0.215	1.27
Calcium (Ca)	mg/l	19.8	20	19.5	37
Iron (Fe)	mg/l	0.016	0.014	0.013	<0.01
Magnesium (Mg)	mg/l	7	7.06	6.95	5.14
Manganese (Mn)	mg/l	0.648	0.649	0.641	0.007
Phosphorus (P)	mg/l	<0.02	<0.02	<0.02	<0.02
Zinc (Zn)	mg/l	0.267	0.275	0.263	<0.005
Antimony (Sb)	µg/l	<1	<1	<1	0.02
Arsenic (As)	µg/l	3.05	3.28	3.32	38
Cadmium (Cd)	µg/l	<1	<1	<1	<1
Chromium (Cr)	µg/l	<1	<1	<1	<1
Copper (Cu)	µg/l	3.49	3.46	3.24	<1
Lead (Pb)	µg/l	<1	<1	<1	<1
Molybdenum (Mo)	µg/l	1.18	1.08	1.05	175
Nickel (Ni)	µg/l	42.4	43.5	42	<1
Selenium (Se)	µg/l	1.96	2.07	1.81	46.9
Thallium (Tl)	µg/l	<0.500	<0.500	<0.500	0.941
Mercury (CVAFS)	mg/l	230	240	240	220
TDS	mg/l	<5	<5	<5	<5
TSS	mg/l				<5

Outfall 008 Decanting

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

(●) REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	008 - Ash Basin Dewatering
Flow, Qw (MGD)	0.720
Receiving Stream	Cape Fear River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	65.00
7Q10w (cfs)	89.00
30Q2 (cfs)	150.00
QA (cfs)	3170.00
1Q10s (cfs)	53.22
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Ash Basins Interstitial Water Data 2014 - highest pollutant concentration, 500 GPM treatment flow; USGS suggested flow data, default hardness
	<input type="checkbox"/> CHECK TO APPLY MODEL
	Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Par07	→ Total Phenolic Compounds	Aquatic Life	NC	300	A			ug/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		μg/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		μg/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		μg/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		μg/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			μg/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L
Par25	Thallium	Water Supply	NC	2	WS			μg/L

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.72

1Q10S (cfs) = 53.22

7Q10S (cfs) = 65.00

7Q10W (cfs) = 89.00

30Q2 (cfs) = 150.00

Avg. Stream Flow, QA (cfs) = 3170.00

Receiving Stream: Cape Fear River HUC 03030002

WWTP/WTP Class: Class II

IWC% @ 1Q10S = 2.053886926

IWC% @ 7Q10S = 1.687942404

IWC% @ 7Q10W = 1.238403835

IWC% @ 30Q2 = 0.738505519

IW%C @ QA = 0.035192658

Stream Class: WS-IV

COMBINED HARDNESS (mg/L)

Acute = 25 mg/L

Chronic = 25 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard: 0 value > 100 mg/L

Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW(7Q10s)	340		ug/L	2	2	2,486.2	Acute (FW): 16,554.0	
Arsenic	C	10	HH/WS(Qavg)			ug/L	Note: n ≤ 9 Limited data set		Default C.V.	Chronic (FW): 8,886.6	Major pollutant of concern apply weekly monitoring
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	2	2	2,008.70	Acute: NO WQS	
Cadmium	NC	0.5899	FW(7Q10s)	3.2396		ug/L	2	0	18.950	Chronic: 29,621.86	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chlorides	NC	250	WS(7Q10s)			mg/L	2	2	113.6	Chronic: 14,810.9	
Aluminum	NC	6.5	WS(7Q10s)			mg/L	2	2	362.7	Acute: NO WQS	
Chromium III	NC	117.7325	FW(7Q10s)	905.0818		μg/L	0	0	N/A	Chronic: 6,974.9	
Chromium VI	NC	11	FW(7Q10s)	16		μg/L	0	0	N/A	Acute: 779.0	
Chromium, Total	NC					μg/L	Tot Cr value(s) > 50 but < Cr VI Allowable Cw Note: n ≤ 9 Limited data set		587.5	Max reported value = 155	a. No Monitoring required if all Total Chromium samples are < the Chromium VI Allowable Cw
Copper	NC	7.8806	FW(7Q10s)	10.4720		ug/L	2	2	1,546.32	Acute: 509.86	
							Note: n ≤ 9 Limited data set		Default C.V.	Chronic: 466.88	RP for Limited Dataset (n<8 samples) - apply weekly Monitoring
										No value > Allowable Cw	

Cape Fear Steam Electric Plant

Outfall 008 - Ash Basin Dewatering

NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Qw = 0.72 MGD

Fluoride	NC	1800	FW(7Q10s)		ug/L	2 1 Note: n ≤ 9 Limited data set	8,368.3 Default C.V.	Acute: NO WQS Chronic: 106,638.7 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Lead	NC	2.9416	FW(7Q10s)	75.4871	ug/L	2 2 Note: n ≤ 9 Limited data set	424.480 Default C.V.	Acute: 3,675.329 Chronic: 174,273 No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply weekly Monitoring
Mercury	NC	12	FW(7Q10s)	0.5	ng/L	2 2 Note: n ≤ 9 Limited data set	290,314,000.0 Default C.V.	Acute: NO WQS Chronic: 710.9 2 value(s) > Allowable Cw	Value > stringent TBEL - apply limit of 47 ng/L annual average with weekly monitoring
Molybdenum	NC	160	WS(7Q10s)		ug/L	2 2 Note: n ≤ 9 Limited data set	1,197.6 Default C.V.	Acute: NO WQS Chronic: 9,479.0 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Nickel	NC	37.2313	FW(7Q10s)	335.2087	μg/L	2 2 Note: n ≤ 9 Limited data set	462.4 Default C.V.	Acute (FW): 16,320.7 Chronic (FW): 2,205.7 No value > Allowable Cw	
Nickel	NC	25.0000	WS(7Q10s)		μg/L	2 2 Note: n ≤ 9 Limited data set		Chronic (WS): 1,481.1 No value > Allowable Cw	Pollutant of concern, apply weekly monitoring
Selenium	NC	5	FW(7Q10s)	56	ug/L	2 2 Note: n ≤ 9 Limited data set	1,614.5 Default C.V.	Acute: 2,726.5 Chronic: 296.2 1 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Zinc	NC	126.7335	FW(7Q10s)	125.7052	ug/L	2 2 Note: n ≤ 9 Limited data set	2,039.0 Default C.V.	Acute: 6,120.4 Chronic: 7,508.2 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Antimony	NC	5.6	WS(7Q10s)		μg/L	2 0 Note: n ≤ 9 Limited data set	18.95000 Default C.V. NO DETECTS	Acute: NO WQS Chronic: 331.76487 Max MDL = 10	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Barium	NC	1	WS(7Q10s)		mg/L	2 2 Note: n ≤ 9 Limited data set	5.60920 Default C.V.	Acute: NO WQS Chronic: 59.24373 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Sulfates	NC	250	WS(7Q10s)		mg/L	2 2 Note: n ≤ 9 Limited data set	1,671.39000 Default C.V.	Acute: NO WQS Chronic: 14810.93190 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Thallium	NC	2	WS(7Q10s)		μg/L	2 2 Note: n ≤ 9 Limited data set	18.79840 Default C.V.	Acute: NO WQS Chronic: 118.48746 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required

REASONABLE POTENTIAL ANALYSIS

H1				H2				Par01 & Par02				Par03				Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
Effluent Hardness				Upstream Hardness				Arsenic				Total Dissolved Solids										
1 Date default 1/15/2015	2 Data 25 < 10	3 BDL=1/2DL 5 Std Dev. 0.0000	4 Results 58	1 Date default 1/15/2015	2 Data 25 < 10	3 BDL=1/2DL 5 Std Dev. 0.0000	4 Results 58	1 Date 1/15/2015	2 Data 656 71	3 BDL=1/2DL 656 Std Dev. 413.6575	4 Results 58	1 Date 1/15/2015	2 Data 530 480	3 BDL=1/2DL 530 Std Dev. 35.3553	4 Results 58	Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
2 Mean 25.0000	3 C.V. (default) 0.6000	4 n 1	5 10th Per value 25.00 mg/L	6 Average Value 25.00 mg/L	7 Max. Value 25.00 mg/L	8	3 Mean 25.0000	4 C.V. (default) 0.6000	5 n 1	6 Mult Factor = 3.79	7 Max. Value 656.0 ug/L	8 Max. Pred Cw 2486.2 ug/L	9	3 Mean 363.5000	4 C.V. (default) 0.6000	5 n 2	6 Mult Factor = 3.79	7 Max. Value 530.00 mg/L	8 Max. Pred Cw 2088.70 mg/L			
3	4	5	6	7	8	9	4	5	6	7	8	9	5	6	7	8	9	5	6	7	8	9
Par04				Cadmium				Par05				Par06				Par10						
1 Date 1/15/2015	2 Data < 10	3 BDL=1/2DL 5 Std Dev. 0.0000	4 Results 58	1 Date 1/15/2015	2 Data 29.97 < 10	3 BDL=1/2DL 29.97 Std Dev. 2.3759	4 Results 58	1 Date 1/15/2015	2 Data 95.7 72	3 BDL=1/2DL 95.7 Std Dev. 16.7584	4 Results 58	1 Date 1/15/2015	2 Data 155 44.6	3 BDL=1/2DL 155 Std Dev. 78.0646	4 Results 58	Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
2 Mean 5.0000	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 5.000 ug/L	7 Max. Pred Cw 18.950 ug/L	8	2 Mean 28.3	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.8	6 Max. Value 30.0 mg/L	7 Max. Pred Cw 113.6 mg/L	9	2 Mean 83.8500	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 155.0 ug/L	7 Max. Pred Cw 587.5 ug/L			
3	4	5	6	7	8	9	4	5	6	7	8	9	4	5	6	7	8	5	6	7	8	9
Pa11				Copper				Par13				Par14				Par16						
1 Date 1/15/2015	2 Data 408 179	3 BDL=1/2DL 408 Std Dev. 161.9275	4 Results 58	1 Date 1/15/2015	2 Data 2208 < 1	3 BDL=1/2DL 2208 Std Dev. 1560.9382	4 Results 58	1 Date 1/15/2015	2 Data 112 91.9	3 BDL=1/2DL 112 Std Dev. 14.2128	4 Results 58	1 Date 1/15/2015	2 Data 316 22.6	3 BDL=1/2DL 316 Std Dev. 207.4651	4 Results 58	Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
2 Mean 293.5000	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 408.00 ug/L	7 Max. Pred Cw 1546.32 ug/L	8	2 Mean 1104.2500	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 2208.0 ug/L	7 Max. Pred Cw 8368.3 ug/L	9	2 Mean 101.9500	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 316.0 ug/L	7 Max. Pred Cw 1197.6 ug/L			
3	4	5	6	7	8	9	4	5	6	7	8	9	4	5	6	7	8	5	6	7	8	9
Par17 & Par18				Nickel				Par19				Par21				Par16						
1 Date 1/15/2015	2 Data 122 94.1	3 BDL=1/2DL 122 Std Dev. 19.7283	4 Results 58	1 Date 1/15/2015	2 Data 426 55.7	3 BDL=1/2DL 426 Std Dev. 261.8416	4 Results 58	1 Date 1/15/2015	2 Data 538 200	3 BDL=1/2DL 538 Std Dev. 239.0021	4 Results 58	1 Date 1/15/2015	2 Data 316 22.6	3 BDL=1/2DL 316 Std Dev. 207.4651	4 Results 58	Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
2 Mean 108.0500	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 122.0 ug/L	7 Max. Pred Cw 462.4 ug/L	8	3 Mean 240.8500	4 C.V. (default) 0.6000	5 n 2	6 Mult Factor = 3.79	7 Max. Value 426.0 ug/L	8 Max. Pred Cw 1614.5 ug/L	9	3 Mean 369.0000	4 C.V. (default) 0.6000	5 n 2	6 Mult Factor = 3.79	7 Max. Value 538.0 ug/L	8 Max. Pred Cw 2039.0 ug/L			
3	4	5	6	7	8	9	4	5	6	7	8	9	4	5	6	7	8	5	6	7	8	9
Par23				Barium				Par24				Par25				Par26						
1 Date 1/15/2015	2 Data 1.48 1.36	3 BDL=1/2DL 1.48 Std Dev. 0.0849	4 Results 58	1 Date 1/15/2015	2 Data 441 169.7	3 BDL=1/2DL 441 Std Dev. 191.8381	4 Results 58	1 Date 1/15/2015	2 Data 4.96 3.45	3 BDL=1/2DL 4.96 Std Dev. 1.0677	4 Results 58	1 Date 1/15/2015	2 Data 4E+07 8E+07	3 BDL=1/2DL 40600000 Std Dev. 25455844	4 Results 58	Use "PASTE SPECIAL-Values" then "COPY". Maximum data points = 58						
2 Mean 1.4200	3 C.V. (default) 0.6000	4 n 2	5 Mult Factor = 3.79	6 Max. Value 1.480000 mg/L	7 Max. Pred Cw 5.609200 mg/L	8	3 Mean 305.3500	4 C.V. (default) 0.6000	5 n 2	6 Mult Factor = 3.79	7 Max. Value 441.000 mg/L	8 Max. Pred Cw 1671.390 mg/L	9	3 Mean 4.2050	4 C.V. (default) 0.6000	5 n 2	6 Mult Factor = 4	7 Max. Value 4.960000 ug/L	8 Max. Pred Cw 18.798400 ug/L			
3	4	5	6	7	8	9	4	5	6	7	8	9	4	5	6	7	8	5	6	7	8	9

FACILITY: Cape Fear Steam Electric Plant
NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
65.000	41.9355	34.3355	0.7200	10	25.000	25.000	1.6879	2.0539	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals		US EPA Translators- using Default Partition Coefficients (streams)	Maximum Allowable Effluent Concentration (MAEC) as a Total Metal		COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):				
	Dissolved Metal	Translator		Chronic	Acute					
	[ug/l]	[ug/l]		[ug/l]	[ug/l]					
Cadmium (d)	0.15	0.82		0.252	0.59	3.24				
Cd -Trout streams	0.15	0.51		0.252	0.59	2.01				
Chromium III (d)(h)	24	183		0.202	117.73	905.08				
Chromium VI (d)	11	16		1.000	11.00	16.00				
Chromium, Total (t)					N/A	N/A				
Copper (d)(h)	2.7	3.6		0.348	7.88	10.47				
Lead (d)(h)	0.54	14		0.184	2.94	75.49				
Nickel (d)(h)	16	145		0.432	37.23	335.21				
Ni - WS streams (t)					25	N/A				
Silver (d)(h,acute)	0.06	0.30		1.000	0.06	0.30				
Zinc (d)(h)	36	36		0.288	126.73	125.71				
Beryllium	6.5	65		1.000	6.5	65				
Arsenic (d)	150	340		1.000	150	340				

(d) = dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B .0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

EAST**Cape Fear Plant Ash Basin Water Characterization Water Samples Collected January 15, 2015 (Page 2 of 2)**

Parameter	Units	Sample Description			
		PZ-6 0.45 filter	PZ-6 10u filter	PZ-6 20u filter	PZ-9 10u filter
NO2 +NO3	mg/l	<0.01	0.016	0.023	<0.01
Total Kjeldahl Nitrogen	mg/l	2.3	0.92	1	1.1
Bromide	mg/l	2.313	1.847	2.026	2.168
Chloride	mg/l	26.61	22.83	23.03	24.9
Fluoride	mg/l	2.208	1.952	1.965	2.118
Sulfate	mg/l	169.7	159.2	157.7	157.3
Aluminum (Al)	mg/l	72	0.034	0.323	2.86
Barium (Ba)	mg/l	1.48	0.215	0.215	0.261
Boron (B)	mg/l	3.91	3.9	3.81	3.84
Calcium (Ca)	mg/l	123	118	116	117
Iron (Fe)	mg/l	27	0.036	0.156	1.09
Magnesium (Mg)	mg/l	20.7	15.2	15	15.2
Manganese (Mn)	mg/l	0.746	0.558	0.548	0.559
Phosphorus (P)	mg/l	1.08	0.091	0.108	0.165
Vanadium (V)	mg/l	0.334	0.022	0.023	0.035
Zinc (Zn)	mg/l	0.2	<0.005	<0.005	0.013
Antimony (Sb)	µg/l	<10	3.56	3.64	4.06
Arsenic (As)	µg/l	656	378	375	386
Cadmium (Cd)	µg/l	<10	<1	<1	<10
Chromium (Cr)	µg/l	44.6	<1	<1	2.33
Copper (Cu)	µg/l	179	4.63	5.78	14.6
Lead (Pb)	µg/l	91.9	<1	<1	5.69
Molybdenum (Mo)	µg/l	316	339	337	335
Nickel (Ni)	µg/l	94.1	7.93	8.33	13.6
Selenium (Se)	µg/l	55.7	1.53	1.36	2.47
Thallium (Tl)	µg/l	3.45	0.603	0.576	0.717
Vanadium (V)	µg/l	232	21.5	23	31.6
Mercury (CVAFS)	mg/l	40.6	0.92	3.02	16.5
pH	SI Units	7.93	8.18	8.06	8.04
TDS	mg/l	530	540	530	480
TSS	mg/l	2000	<10	96	5700

Outfall 008 Dewatering

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

(●) REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	008 - Ash Basin Dewatering/GWR
Flow, Qw (MGD)	0.720
Receiving Stream	Cape Fear River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	65.00
7Q10w (cfs)	89.00
30Q2 (cfs)	150.00
QA (cfs)	3170.00
1Q10s (cfs)	53.22
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Ash Basins Interstitial Water Data 2014 AND Highest GWR - highest pollutant concentration, 500 GPM treatment flow; USGS suggested flow and data NOTE: develop separate limitation page for GWR only with reduced frequency but same limits
	Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Par07	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		μg/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		ug/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			ug/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L
Par25	Thallium	Water Supply	NC	2	WS			ug/L

Cape Fear Steam Electric Plant
NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Outfall 008 - Ash Basin Dewatering/GWR
Qw = 0.72 MGD

Qw (MGD) = **0.72**
1Q10S (cfs) = **53.22**
7Q10S (cfs) = **65.00**
7Q10W (cfs) = **89.00**
30Q2 (cfs) = **150.00**
Avg. Stream Flow, QA (cfs) = **3170.00**
Receiving Stream: Cape Fear River HUC 03030002

WWTP/WTP Class: **Class II**
IWC% @ 1Q10S = **2.053886926**
IWC% @ 7Q10S = **1.687942404**
IWC% @ 7Q10W = **1.238403835**
IWC% @ 30Q2 = **0.738505519**
IW%C @ QA = **0.035192658**
Stream Class: **WS-IV**

COMBINED HARDNESS (mg/L)
Acute = 25 mg/L
Chronic = 25 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW(7Q10s)	340		ug/L	3	3	3,030.0	Acute (FW): 16,554.0 Chronic (FW): 8,886.6 Default C.V. No value > Allowable Cw	
Arsenic	C	10	HH/WS(Qavg)			ug/L	Note: n ≤ 9 Limited data set		Chronic (HH): 28,415.0 No value > Allowable Cw		Major pollutant of concern apply weekly monitoring Major pollutant of concern apply weekly monitoring
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	3	3	36,000.00	Acute: NO WQS Chronic: 29,621.86 Default C.V. No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring
Cadmium	NC	0.5899	FW(7Q10s)	3.2396		ug/L	3	1	15.000	Acute: 157.731 Chronic: 34.947 Default C.V. No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chlorides	NC	250	WS(7Q10s)			mg/L	3	3	2,490.0	Acute: NO WQS Chronic: 14,810.9 Default C.V. No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Aluminum	NC	6.5	WS(7Q10s)			mg/L	6	6	1,836.1	Acute: NO WQS Chronic: 385.1 Default C.V. 4 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Beryllium	NC	6.5	FW(7Q10s)	65.0000		ug/L	4	4	865.1	Acute: 3,164.7 Chronic: 880.2 Default C.V. No value > Allowable Cw	No RP, Predicted Max ≥ 50% of Allowable Cw - apply Weekly Monitoring
Chromium III	NC	117.7325	FW(7Q10s)	905.0818		μg/L	0	0	N/A	Acute: 44,066.8 Chronic: 6,974.9	
Chromium VI	NC	11	FW(7Q10s)	16		μg/L	1	1	91.8	Acute: 779.0 Chronic: 651.7 Default C.V. No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chromium, Total	NC					μg/L	Tot Cr value(s) > 50 but < Cr VI Allowable Cw Note: n ≤ 9 Limited data set		552.0	Max reported value = 184 Default C.V.	a. No Monitoring required if all Total Chromium samples are < the Chromium VI Allowable Cw
Copper	NC	7.8806	FW(7Q10s)	10.4720		ug/L	3	3	1,224.00	Acute: 509.86 Chronic: 466.88 Default C.V. No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring

Cape Fear Steam Electric Plant

NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Outfall 008 - Ash Basin Dewatering/GWR

Qw = 0.72 MGD

≥									
		Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators							
		Outfall 008 - Ash Basin Dewatering/GWR							
Fluoride	NC	1800	FW(7Q10s)		ug/L	2 1	8,368.3 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 106,638.7 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Lead	NC	2.9416	FW(7Q10s)	75.4871	ug/L	3 3	336.000 Default C.V.	Acute: 3,675.329	
						Note: n ≤ 9 Limited data set		Chronic: 174.273 No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring
Mercury	NC	12	FW(7Q10s)	0.5	ng/L	8 2	145,540,000.0 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 710.9 2 value(s) > Allowable Cw	Value > stringent TBEL - apply limit of 47 ng/L annual average with weekly monitoring
Molybdenum	NC	160	WS(7Q10s)		ug/L	3 3	3,720.0 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 9,479.0 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Nickel	NC	37.2313	FW(7Q10s)	335.2087	μg/L	6 6	5,585.4 Default C.V.	Acute (FW): 16,320.7	
						Note: n ≤ 9 Limited data set		Chronic (FW): 2,205.7 3 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Nickel	NC	25.0000	WS(7Q10s)		μg/L	6 6	5,585.4 Default C.V.	Chronic (WS): 1,481.1 4 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Selenium	NC	5	FW(7Q10s)	56	ug/L	3 3	1,278.0 Default C.V.	Acute: 2,726.5	
						Note: n ≤ 9 Limited data set		Chronic: 296.2 1 value(s) > Allowable Cw	RP shown - apply Weekly Monitoring with Limit
Silver	NC	0.06	FW(7Q10s)	0.29639789	ug/L	1 1	39.7 Default C.V.	Acute: 14.431	
						Note: n ≤ 9 Limited data set		Chronic: 3.555 1 value(s) > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring
Zinc	NC	126.7335	FW(7Q10s)	125.7052	ug/L	6 6	9,779.8 Default C.V.	Acute: 6,120.4	
						Note: n ≤ 9 Limited data set		Chronic: 7,508.2 No value > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring
Antimony	NC	5.6	WS(7Q10s)		μg/L	3 1	21.00000 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 331.76487 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Barium	NC	1	WS(7Q10s)		mg/L	3 3	4,44000 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 59.24373 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Sulfates	NC	250	WS(7Q10s)		mg/L	3 3	69,000.00000 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 14810.93190 1 value(s) > Allowable Cw	RP for Limited Dataset (n<8 samples) - apply Weekly Monitoring
Thallium	NC	2	WS(7Q10s)		μg/L	3 3	39.30000 Default C.V.	Acute: NO WQS	
						Note: n ≤ 9 Limited data set		Chronic: 118.48746 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required

REASONABLE POTENTIAL ANALYSIS

Effluent Hardness				Upstream Hardness				Arsenic				Total Dissolved Solids				
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
				Std Dev.								Std Dev.				
1	default	25	25	0.0000					1	1/15/2015	656	656	474.2120			
2				Mean	25.0000				2		71	71	579.0000			
3				C.V. (default)	0.6000				3	gwr	1010	1010	0.6000			
4				n	1				4				3			
5				10th Per value	25.00 mg/L				5							
6				Average Value	25.00 mg/L				6				Mult Factor =			
7				Max. Value	25.00 mg/L				7				3.00			
8									8				Max. Value	1010.0 ug/L		
9									9				Max. Pred Cw	3030.0 ug/L		
Par04	Cadmium				Chlorides				Aluminum				Beryllium			
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
1	1/15/2015	< 10	5	Std Dev.	1.2471				1	1/15/2015	95.7	95.7	314.09			
2		< 10	5	Mean	4.2800				2		72	72	450.28			
3	gwr	2.84	2.84	C.V. (default)	0.6000				3	gwr	858	858	0.6000			
4				n	3				4				6			
5									5							
6				Mult Factor =	3.00				6				Mult Factor =			
7				Max. Value	5.000 ug/L				7				2.14			
8				Max. Pred Cw	15.000 ug/L				8				Max. Value	830.0 mg/L		
9									9				Max. Pred Cw	2,490.0 mg/L		
Par09	Chromium VI				Par10 Chromium, Total				Pa11 Copper				Par13 Fluoride			
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
1	gwr	14.8	14.8	Std Dev.	0.0000				1	1/15/2015	155	155	174.2479			
2				Mean	14.8000				2		179	179	217.6667			
3				C.V. (default)	0.6000				3	gwr	66	66	0.6000			
4				n	1				4				3			
5									5							
6				Mult Factor =	6.20				6				Mult Factor =			
7				Max. Value	14.8 ug/L				7				3.00			
8				Max. Pred Cw	91.8 ug/L				8				Max. Value	408.0 ug/L		
9									9				Max. Pred Cw	1224.0 ug/L		
Par14	Lead				Par16 Molybdenum				Par17 & Par18 Nickel				Par19 Selenium			
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
1	1/15/2015	112	112	Std Dev.	29.9951				1	1/15/2015	122	122	1200.0533			
2		91.9	91.9	Mean	85.6333				2		94.1	94.1	1634.3500			
3	gwr	53	53	C.V. (default)	0.8000				3	gwr	2610	2610	0.6000			
4				n	3				4				6			
5									5							
6				Mult Factor =	3.00				6				Mult Factor =			
7				Max. Value	112.000 ug/L				7				2.14			
8				Max. Pred Cw	336.000 ug/L				8				Max. Value	2610.0 ug/L		
9									9				Max. Pred Cw	5585.4 ug/L		
Par20	Silver				Par21 Zinc				Par22 Antimony				Par23 Barium			
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
1	gwr	6.4	6.4	Std Dev.	0.0000				1	1/15/2015	< 10	5	1.15			
2				Mean	6.4000				2		< 10	5	5.67			
3				C.V. (default)	0.6000				3	gwr	7	7	0.6000			
4				n	1				4				3			
5									5							
6				Mult Factor =	6.20				6				Mult Factor =			
7				Max. Value	6.400 ug/L				7				3.00			
8				Max. Pred Cw	39.680 ug/L				8				Max. Value	7.00 ug/L		
9									9				Max. Pred Cw	21.00 ug/L		
Par24	Sulfates				Par25 Thallium				Par26 Mercury				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results				
1	1/15/2015	441	441	Std Dev.	12677.43				1	1/15/2015	4.96	4.96	4060000			
2		1697	1697	Mean	8379.33				2		3.45	3.45	7660000			
3	gwr	23000	23000	C.V. (default)	0.6000				3	gwr	13.1	13.1	14650019			
4				n	3				4							
5									5							
6				Mult Factor =	3.00				6				Mult Factor =			
7				Max. Value	23000.00 mg/L				7				2			
8				Max. Pred Cw	69000.00 mg/L				8				Max. Value	7660000 ug/L		
9									9				Max. Pred Cw	145540000 ug/L		

FACILITY: Cape Fear Steam Electric Plant
NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
65.000	41.9355	34.3355	0.7200	10	25.000	25.000	1.6879	2.0539	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals		US EPA Translators- using Default Partition Coefficients (streams)	Maximum Allowable Effluent Concentration (MAEC) as a Total Metal		COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):				
	Dissolved Metal	Translator		Chronic	Acute					
	[ug/l]	[ug/l]		[ug/l]	[ug/l]					
Cadmium (d)	0.15	0.82		0.252	0.59	3.24				
Cd -Trout streams	0.15	0.51		0.252	0.59	2.01				
Chromium III (d)(h)	24	183		0.202	117.73	905.08				
Chromium VI (d)	11	16		1.000	11.00	16.00				
Chromium, Total (t)					N/A	N/A				
Copper (d)(h)	2.7	3.6		0.348	7.88	10.47				
Lead (d)(h)	0.54	14		0.184	2.94	75.49				
Nickel (d)(h)	16	145		0.432	37.23	335.21				
Ni - WS streams (t)					25	N/A				
Silver (d)(h,acute)	0.06	0.30		1.000	0.06	0.30				
Zinc (d)(h)	36	36		0.288	126.73	125.71				
Beryllium	6.5	65		1.000	6.5	65				
Arsenic (d)	150	340		1.000	150	340				

(d) = dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B .0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

EAST
Cape Fear Plant Ash Basin Water Characterization Water Samples Collected January 15, 2015 (Page 2 of 2)

Parameter	Units	Sample Description			
		PZ-6 0.45 filter	PZ-6 10u filter	PZ-6 20u filter	PZ-9 10u filter
NO2 +NO3	mg/l	<0.01	0.016	0.023	<0.01
Total Kjeldahl Nitrogen	mg/l	2.3	0.92	1	1.1
Bromide	mg/l	2.313	1.847	2.026	2.168
Chloride	mg/l	26.61	22.83	23.03	24.9
Fluoride	mg/l	2.208	1.952	1.965	2.118
Sulfate	mg/l	169.7	159.2	157.7	157.3
Aluminum (Al)	mg/l	72	0.034	0.323	2.86
Barium (Ba)	mg/l	1.48	0.215	0.215	0.261
Boron (B)	mg/l	3.91	3.9	3.81	3.84
Calcium (Ca)	mg/l	123	118	116	117
Iron (Fe)	mg/l	27	0.036	0.156	1.09
Magnesium (Mg)	mg/l	20.7	15.2	15	15.2
Manganese (Mn)	mg/l	0.746	0.558	0.548	0.559
Phosphorus (P)	mg/l	1.08	0.091	0.108	0.165
Vanadium (V)	mg/l	0.334	0.022	0.023	0.035
Zinc (Zn)	mg/l	0.2	<0.005	<0.005	0.013
Antimony (Sb)	µg/l	<10	3.56	3.64	4.06
Arsenic (As)	µg/l	656	378	375	386
Cadmium (Cd)	µg/l	<10	<1	<1	<10
Chromium (Cr)	µg/l	44.6	<1	<1	2.33
Copper (Cu)	µg/l	179	4.63	5.78	14.6
Lead (Pb)	µg/l	91.9	<1	<1	5.69
Molybdenum (Mo)	µg/l	316	339	337	335
Nickel (Ni)	µg/l	94.1	7.93	8.33	13.6
Selenium (Se)	µg/l	55.7	1.53	1.36	2.47
Thallium (Tl)	µg/l	3.45	0.603	0.576	0.717
Vanadium (V)	µg/l	232	21.5	23	31.6
Mercury (CVAFS)	mg/l	40.6	0.92	3.02	16.5
pH	SI Units	7.93	8.18	8.06	8.04
TDS	mg/l	530	530	540	480
TSS	mg/l	2000	<10	96	5700

Outfall 008 Dewatering

Sample ID	Associated Basin	Latitude	Longitude	Sample Collection Date	INORGANIC PARAMETERS (TOTAL CONCENTRATION)																				
					Chloride	Sulfate	Total Dissolved Solids	Aluminum	Antimony	Arsenic	Barium	Beryllium	Cadmium	Chromium	Chromium (VI)	Copper	Lead	Mercury	Molybdenum	Nickel	Selenium	Silver	Thallium	Zinc	
					mg/L	mg/L	mg/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
ABMW-1S	1985 Basin	35.59027	-79.040531	05/08/2015	20	130	360	720	1.85	27.7	94	<1	<1	<1	NA	<1	<1	<0.05	1240	4.5	3.4	NA	<0.2	<5	
ABMW-4	1963 Basin	35.58791	-79.049524		37	120	500	30	<1	1010	258	<1	<1	<1	NA	<1	<1	<0.05	35.3	3.07	<1	NA	<0.2	<5	
CHATH-79-P100	1985 Basin	35.58902	-79.041608	01/07/2016	830	370	2500	137	<1	7.18	183	<1	<1	<1	0.063	<1	<1	<0.05	2.25	5.94	1.05	NA	<0.2	<5	
CMW-6	1985 Basin	35.58576	-79.037311	10/11/2011	31	14.9	396	<100	<0.5	<5	14.4	NA	<0.08	<5	NA	66	<5	<0.2	NA	<5	<10	NA	<0.1	40.2	
MW-6BR	1985 Basin	35.58574	-79.037465	06/30/2015	250	42	770	10	<1	<1	842	<1	<1	<1	NA	<1	<1	<0.05	3.17	<1	<1	NA	<0.2	<5	
MW-23S	1985 Basin	35.59023	-79.03708	07/12/2016	23	210	87	42	<1	<1	56	<1	<1	19.5	14.8	<1	<1	<0.05	15.5	2.8	1.27	NA	<0.2	<5	
PZ-1	1985 Basin	35.59301	-79.045201	04/22/2010	21	350	360	NA	<10	<10	42	<4	<2	<5	NA	<5	14	<0.1	NA	<40	<10	6.4	<50	<20	
PZ-5	1985 Basin	35.58885	-79.041899	03/07/2007	24	280	570	NA	<0.58	<2	777	0.9	<0.5	101	NA	48.9	53	0.3	NA	84.8	<2	<2	0.478	360	
PZ-7	1970 Basin	35.58638	-79.048355	08/06/2015	13	18000	12000	466000	<10	193	<500	318	<10	138	NA	<10	10	<0.05	<10	2050	16.4	NA	12.6	3450	
				09/02/2015	22	23000	12000	534000	<10	195	<250	334	<10	161	NA	<10	11	<0.05	<10	2330	<10	NA	13.1	3850	
				12/03/2015	31	12000	15000 N1	676000	<10	128	<50	309	<10	184	<0.03	<10	13	<0.05	<10	2600	<10	NA	11.6	3920	
				01/06/2016	42	12000	12000	858000	<1	166	<500	274	2.84	177	<0.06	7.99	12	<0.05	1.03	2610	<1	NA	12.6	4570	
PZ-8	1963 Basin	35.58939	-79.049605	09/05/2013	32.8	192	529	6290	7	61.7	370	NA	0.49 j	7.1 j	NA	16.3	5.9	<0.06	NA	8.6 j	26.1	NA	1.2	11.3 j	
PZ-9	1978 Basin	35.58789	-79.047978	08/06/2015	29	110	240	1110	<1	<1	44	<1	<1	1.91	NA	6.94	<1	<0.05	<1	41.9	96.1	NA	0.574	99	

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

(●) REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	008 - GWR only
Flow, Qw (MGD)	0.720
Receiving Stream	Cape Fear River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	65.00
7Q10w (cfs)	89.00
30Q2 (cfs)	150.00
QA (cfs)	3170.00
1Q10s (cfs)	53.22
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	GWR - highest pollutant concentration, 500 GPM treatment flow; USGS suggested flow and data
<input type="checkbox"/> CHECK TO APPLY MODEL	
	<i>Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.</i>

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Par07	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		μg/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		ug/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			ug/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L
Par25	Thallium	Water Supply	NC	2	WS			ug/L

Cape Fear Steam Electric Plant

NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Outfall 008 - GWR only

Qw = 0.72 MGD

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.72

1Q10S (cfs) = 53.22

7Q10S (cfs) = 65.00

7Q10W (cfs) = 89.00

30Q2 (cfs) = 150.00

Avg. Stream Flow, QA (cfs) = 3170.00

Receiving Stream: Cape Fear River HUC 03030002

WWTP/WTP Class: Class II

IWC% @ 1Q10S = 2.053886926

IWC% @ 7Q10S = 1.687942404

IWC% @ 7Q10W = 1.238403835

IWC% @ 30Q2 = 0.738505519

IWC% @ QA = 0.035192658

Stream Class: WS-IV

COMBINED HARDNESS (mg/L)

Acute = 25 mg/L

Chronic = 25 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard: 0 value > 100 mg/L

Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW(7Q10s)	340		ug/L	1	1	6,262.0 Default C.V.	Acute (FW): 16,554.0 Chronic (FW): 8,886.6 No value > Allowable Cw	
Arsenic	C	10	HH/WS(Qavg)			ug/L	Note: n ≤ 9 Limited data set			Chronic (HH): 28,415.0 No value > Allowable Cw	Major pollutant of concern apply 2/month monitoring Major pollutant of concern apply 2/month monitoring
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	3	3	36,000.00 Default C.V.	Acute: NO WQS Chronic: 29,621.86 No value > Allowable Cw	
Cadmium	NC	0.5899	FW(7Q10s)	3.2396		ug/L	4	1	12,950 Default C.V.	Acute: 157.731 Chronic: 34.947 No value > Allowable Cw	
Chlorides	NC	250	WS(7Q10s)			mg/L	2	2	3,145.7 Default C.V.	Acute: NO WQS Chronic: 14,810.9 No value > Allowable Cw	
Aluminum	NC	6.5	WS(7Q10s)			mg/L	7	7	1,724.6 Default C.V.	Acute: NO WQS Chronic: 385.1 4 value(s) > Allowable Cw	RP shown - apply 2/Month Monitoring with Limit
Beryllium	NC	6.5	FW(7Q10s)	65.0000		ug/L	4	4	865.1 Default C.V.	Acute: 3,164.7 Chronic: 880.2 No value > Allowable Cw	
Chromium III	NC	117.7325	FW(7Q10s)	905.0818		ug/L	0	0	N/A	Acute: 44,066.8 Chronic: 6,974.9	
Chromium VI	NC	11	FW(7Q10s)	16		ug/L	1	1	91.8 Default C.V.	Acute: 779.0 Chronic: 651.7 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chromium, Total	NC					ug/L	Tot Cr value(s) > 50 but < Cr VI Allowable Cw Note: n ≤ 9 Limited data set		369.8 Default C.V.	Max reported value = 184	a. No Monitoring required if all Total Chromium samples are < the Chromium VI Allowable Cw

Cape Fear Steam Electric Plant

NC0003433

Outfall 008 - GWR only

Qw = 0.72 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Copper	NC	7.8806	FW(7Q10s)	10.4720		ug/L	5	5	153.12 Default C.V.	Acute:	509.86	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	466.88	
Lead	NC	2.9416	FW(7Q10s)	75.4871		ug/L	6	6	113.420 Default C.V.	Acute:	3,675.329	No RP , Predicted Max ≥ 50% of Allowable Cw - apply 2/Monthly Monitoring
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	174.273	
Mercury	NC	12	FW(7Q10s)	0.5		ng/L	6	0	NO DETECTS	Acute:	NO WQS	Major pollutant of concern apply 2/month monitoring
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	710.9	
Molybdenum	NC	160	WS(7Q10s)			ug/L	6	6	2,653.6 Default C.V.	Acute:	NO WQS	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	9,479.0	
Nickel	NC	37.2313	FW(7Q10s)	335.2087		ug/L	6	6	5,585.4 Default C.V.	Acute (FW):	16,320.7	RP shown - apply 2/Month Monitoring with Limit
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic (FW):	2,205.7	
Nickel	NC	25.0000	WS(7Q10s)			ug/L	6	6	5,585.4 Default C.V.	Chronic (WS):	1,481.1	RP shown - apply 2/Month Monitoring with Limit
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		4 value(s) > Allowable Cw		
Selenium	NC	5	FW(7Q10s)	56		ug/L	6	6	205.7 Default C.V.	Acute:	2,726.5	No RP , Predicted Max ≥ 50% of Allowable Cw - apply 2/Month Monitoring
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	296.2	
Silver	NC	0.06	FW(7Q10s)	0.29639789		ug/L	2	2	24.3 Default C.V.	Acute:	14.431	RP for Limited Dataset (n<8 samples) - apply 2/Month Monitoring
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	3.555	
Zinc	NC	126.7335	FW(7Q10s)	125.7052		ug/L	6	6	9,779.8 Default C.V.	Acute:	6,120.4	RP for Limited Dataset (n<8 samples) - apply 2/Month Monitoring
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	7,508.2	
Antimony	NC	5.6	WS(7Q10s)			ug/L	1	1	43.40000 Default C.V.	Acute:	NO WQS	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	331.76487	
Barium	NC	1	WS(7Q10s)			mg/L	1	1	5.22040 Default C.V.	Acute:	NO WQS	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	59.24373	
Sulfates	NC	250	WS(7Q10s)			mg/L	7	7	46,230.00000 Default C.V.	Acute:	NO WQS	RP for Limited Dataset (n<8) but 2 values > Allowable Cw - apply 2/Month Monitoring with Limit
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	14810.93190	
Thallium	NC	2	WS(7Q10s)			ug/L	7	7	26.33100 Default C.V.	Acute:	NO WQS	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
							Note: n ≤ 9 Limited data set	Note: n ≤ 9 Limited data set		Chronic:	118.48746	

REASONABLE POTENTIAL ANALYSIS

Effluent Hardness				Upstream Hardness				Arsenic				Total Dissolved Solids				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results	Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 default	25	25	Std Dev. 0.0000	1 default	25	25	Std Dev. 0.0000	1 gwr	1010	1010	Std Dev. 0.0000	1 gwr	12000	12000	Std Dev. 0.0000	1 gwr	12000	12000	Std Dev. 0.0000
2			Mean 25.0000	2			Mean 25.0000	2			Mean 1010.0000	2			Mean 12000.0000	2			C.V. (default) 0.6000
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000	3			C.V. (default) 0.6000	3			C.V. (default) 0.6000	3			n 3
4			n 1	4			n 1	4			n 1	4			n 1	4			10th Per value 25.00 mg/L
5			10th Per value 25.00 mg/L	5			10th Per value 25.00 mg/L	5			10th Per value 25.00 mg/L	5			10th Per value 25.00 mg/L	5			Average Value 25.00 mg/L
6			Average Value 25.00 mg/L	6			Average Value 25.00 mg/L	6			Average Value 25.00 mg/L	6			Average Value 25.00 mg/L	6			Max. Value 25.00 mg/L
7			Max. Value 25.00 mg/L	7			Max. Value 25.00 mg/L	7			Max. Value 25.00 mg/L	7			Max. Value 25.00 mg/L	7			Max. Pred Cw 6262.00 ug/L
8			Max. Pred Cw 6262.00 ug/L	8			Max. Pred Cw 6262.00 ug/L	8			Max. Pred Cw 6262.00 ug/L	8			Max. Pred Cw 6262.00 ug/L	8			Max. Pred Cw 3600.00 mg/L
9			Max. Pred Cw 3600.00 mg/L	9			Max. Pred Cw 3600.00 mg/L	9			Max. Pred Cw 3600.00 mg/L	9			Max. Pred Cw 3600.00 mg/L	9			
Par04				Cadmium				Par05				Par06				Par07			
Chromium VI				Chlorides				Aluminum				Beryllium				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 gwr	2.84	2.84	Std Dev. 1.0800	1 gwr	830	830	Std Dev. 410.1219	1 gwr	858	858	Std Dev. 358.7720	1 gwr	334	334	Std Dev. 25.3689	1 gwr	334	334	Std Dev. 25.3689
2 < 10	< 10	5	Mean 4.4600	2 250	250	250	Mean 540.0	2 466	466	466	Mean 363.1586	2 318	318	Mean 308.7500	2 318	318	Mean 308.7500	C.V. (default) 0.6000	
3 < 10	< 10	5	C.V. (default) 0.6000	3			C.V. (default) 0.6000	3 534	534	534	C.V. (default) 0.6000	3 309	309	C.V. (default) 0.6000	3 309	309	C.V. (default) 0.6000		
4 < 10	< 10	5	n 4	4			n 2	4 676	676	676	n 7	4 274	274	n 4	4 274	274	n 4	Mult Factor = 2.59	
5				5				5 6.29	6.29	6.29		5			5				Max. Value 5.000 ug/L
6				6				6 1.1	1.1	1.1	Mult Factor = 2.01	6			6				Max. Pred Cw 12.950 ug/L
7				7				7 0.72	0.72	0.72	Max. Value 830.0 mg/L	7			7				Max. Pred Cw 3,145.7 mg/L
8				8				8 Max. Pred Cw	3,145.7	3,145.7	Max. Pred Cw 1724.6 mg/L	8			8				Max. Pred Cw 865.1 ug/L
9				9				9				9			9				
Par09				Par10				Pa11				Par14				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
Chromium VI				Chromium, Total				Pa11				Par14				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 gwr	14.8	14.8	Std Dev. 0.0000	1 gwr	184	184	Std Dev. 74.4790	1 gwr	66	66	Std Dev. 26.7119	1 gwr	53	53	Std Dev. 16.7978	1 gwr	53	53	Std Dev. 16.7978
2			Mean 14.8000	2 177	177	177	Mean 111.7729	2 48.9	48.9	48.9	Mean 29.2260	2 14	14	Mean 18.8333	2 14	14	Mean 18.8333	C.V. (default) 0.6000	
3			C.V. (default) 0.6000	3 161	161	161	C.V. (default) 0.6000	3 16.3	16.3	16.3	C.V. (default) 0.6000	3 10	10	C.V. (default) 0.6000	3 10	10	C.V. (default) 0.6000		
4			n 1	4 138	138	138	n 7	4 7.99	7.99	7.99	n 5	4 11	11	n 6	4 11	11	n 6	Mult Factor = 6.20	
5				5 101	101	101		5 6.94	6.94	6.94		5 13	13		5 13	13			
6				6 19.5	19.5	19.5	Mult Factor = 2.01	6 1.27	1.27	1.27	Mult Factor = 2.32	6 6	6	Mult Factor = 2.14	6 6	6	Mult Factor = 2.14	Max. Value 14.8 ug/L	
7				7 1.91	1.91	1.91	Max. Value 184.0 ug/L	7 2.14	2.14	2.14	Max. Value 96.1 ug/L	7 7	7	Max. Value 66.00 ug/L	7 7	7	Max. Value 66.00 ug/L	Max. Pred Cw 91.8 ug/L	
8				8 2653.6	2653.6	2653.6	Max. Pred Cw 2610.0 ug/L	8 1.05	1.05	1.05	Max. Pred Cw 205.7 ug/L	8 8	8	Max. Pred Cw 205.7 ug/L	8 8	8	Max. Pred Cw 24.26 ug/L	Max. Pred Cw 9779.8 ug/L	
9				9				9				9			9				
Par16				Par17 & Par18				Par19				Par20				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
Molybdenum				Nickel				Par19				Par20				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 gwr	1240	1240	Std Dev. 501.4245	1 gwr	2610	2610	Std Dev. 1222.8440	1 gwr	96.1	96.1	Std Dev. 36.6832	1 gwr	6.4	6.4	Std Dev. 3.8184	1 gwr	6.4	6.4	Std Dev. 3.8184
2	35.3	35.3	Mean 216.7867	2 2600	2600	2600	Mean 1619.4500	2 26.1	26.1	26.1	Mean 24.0533	2 1	1	Mean 3.7000	2 1	1	Mean 3.7000	C.V. (default) 0.6000	
3	15	15	C.V. (default) 0.6000	3 2330	2330	2330	C.V. (default) 0.6000	3 16.4	16.4	16.4	C.V. (default) 0.6000	3 6	6	C.V. (default) 0.6000	3 6	6	C.V. (default) 0.6000		
4	5	5	n 6	4 2050	2050	2050	n 6	4 3.4	3.4	3.4	n 6	4 12000	12000	n 7	4 12000	12000	n 7	Mult Factor = 2.25	
5	2.25	2.25		5 84.8	84.8	84.8		5 1.05	1.05	1.05		5 370	370		5 370	370			
6	3.17	3.17	Mult Factor = 2.14	6 41.9	41.9	41.9	Mult Factor = 2.14	6 1.27	1.27	1.27	Mult Factor = 2.14	6 350	350	Mult Factor = 3.79	6 350	350	Mult Factor = 3.79	Max. Value 1240.0 ug/L	
7			Max. Value 4570.0 ug/L	7 2610.0	2610.0	2610.0	Max. Value 7.000000 ug/L	7 0.842000	0.842000	0.842000	Max. Value 0.842000 mg/L	7 280	280	Max. Value ###### mg/L	7 280	280	Max. Value ###### mg/L	Max. Pred Cw 5.220400 mg/L	
8			Max. Pred Cw 9779.8 ug/L	8 43.400000	43.400000	43.400000	Max. Pred Cw O DETECTS ug/L	8 9				8 9			8 9				Max. Pred Cw ###### mg/L
9				9				9				9			9				
Par21				Zinc				Par22				Par23				Par24			
Thallium				Antimony				Barium				Sulfates				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 gwr	4570	4570	Std Dev. 1955.0295	1 gwr	7	7	Std Dev. 0.0000	1 gwr	0.842	0.842	Std Dev. 0.0000	1 gwr	23000	23000	Std Dev. 9301.0043	1 gwr	23000	23000	Std Dev. 9301.0043
2	3920	3920	Mean 2708.1667	2 < 50	< 50	25	Mean 7.0000	2 0.8420	0.8420	0.8420	Mean 9428.5714	2 18000	18000	Mean 9428.5714	2 18000	18000	Mean 9428.5714	C.V. (default) 0.6000	
3	3850	3850	C.V. (default) 0.6000	3 < 50	< 50	25	C.V. (default) 1	3 0.8420	0.8420	0.8420	C.V. (default) 0.6000	3 12000	12000	C.V. (default) 0.6000	3 12000	12000	C.V. (default) 0.6000		
4	3450	3450	n 6	4 < 50	< 50	25	n 6	4 0.8420	0.8420	0.8420	n 1	4 12000	12000	n 7	4 12000	12000	n 7	Mult Factor = 1.2	
5	360	360		5 < 50	< 50	25		5 0.8420	0.8420	0.8420		5 370	370		5 370	370			
6	99	99	Mult Factor = 2.14	6 < 50	< 50	25	Mult Factor = 2.14	6 0.8420	0.8420	0.8420	Mult Factor = 2.14	6 350	350	Mult Factor = 2.01	6 350	350	Mult Factor = 2.01	Max. Value 4570.0 ug/L	
7			Max. Value 4570.0 ug/L	7 < 50	< 50	25	Max. Value 25 ug/L	7 0.8420	0.8420	0.8420	Max. Value 0.842000 mg/L	7 280	280	Max. Value ###### mg/L	7 280	280	Max. Value ###### mg/L	Max. Pred Cw 26.331000 ug/L	
8			Max. Pred Cw 9779.8 ug/L	8 < 50	< 50	25	Max. Pred Cw O DETECTS ug/L	8 0.8420	0.8420	0.8420	Max. Pred Cw 0.842000 mg/L	8 9			8 9				Max. Pred Cw ###### mg/L
9				9				9				9			9				
Par25				Thallium				Par26				Mercury				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58			
1 gwr	13.1	13.1	Std Dev. 6.2868	1 gwr	< 50	25	Std Dev. 7.4503	1 gwr	< 50	25	Std Dev. 0.0000	1 gwr	1010	1010	Std Dev. 1010.0000	1 gwr	1010	1010	Std Dev. 1010.0000
2	12.6	12.6	Mean 11.6	2 < 50	< 50	25	C.V. (default) 0.6000	2 0.8420	0.8420	0.8420	Mean 1010.0000	2 1010	1010	Mean 1010.0000	2 1010	1010	Mean 1010.0000	C.V. (default) 0.6000	
3	11.6	11.6	C.V. (default) 0.6000	3 < 50	< 50	25	n 7	3 0.8420	0.8420	0.8420	C.V. (default) 0.6000	3 1010	1010	C.V. (default) 0.6000	3 1010	1010	C.V. (default) 0.6000		
4	12.6	12.6	n 7	4 < 50	< 50	25	n 6	4 0.8420	0.8420	0.8420	n 1	4 1010	1010	n 7	4 1010	1010	n 7	Mult Factor = 1.2	

FACILITY: Cape Fear Steam Electric Plant
NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
65.000	41.9355	34.3355	0.7200	10	25.000	25.000	1.6879	2.0539	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals		US EPA Translators- using Default Partition Coefficients (streams)	Maximum Allowable Effluent Concentration (MAEC) as a Total Metal		COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):				
	Dissolved Metal	Translator		Chronic	Acute					
	[ug/l]	[ug/l]		[ug/l]	[ug/l]					
Cadmium (d)	0.15	0.82		0.252	0.59	3.24				
Cd -Trout streams	0.15	0.51		0.252	0.59	2.01				
Chromium III (d)(h)	24	183		0.202	117.73	905.08				
Chromium VI (d)	11	16		1.000	11.00	16.00				
Chromium, Total (t)					N/A	N/A				
Copper (d)(h)	2.7	3.6		0.348	7.88	10.47				
Lead (d)(h)	0.54	14		0.184	2.94	75.49				
Nickel (d)(h)	16	145		0.432	37.23	335.21				
Ni - WS streams (t)					25	N/A				
Silver (d)(h,acute)	0.06	0.30		1.000	0.06	0.30				
Zinc (d)(h)	36	36		0.288	126.73	125.71				
Beryllium	6.5	65		1.000	6.5	65				
Arsenic (d)	150	340		1.000	150	340				

(d) = dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B .0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

			INORGANIC PARAMETERS (TOTAL CONCENTRATION)																		
Longitude	Sample Collection Date	Chloride	Sulfate	Total Dissolved Solids	Aluminum	Antimony	Arsenic	Barium	Beryllium	Cadmium	Chromium	Chromium (VI)	Copper	Lead	Mercury	Molybdenum	Nickel	Selenium	Silver	Thallium	Zinc
		mg/L	mg/L	mg/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
-79.040531	05/08/2015	20	130	360	720	1.85	27.7	94	<1	<1	<1	NA	<1	<1	<0.05	1240	4.5	3.4	NA	<0.2	<5
		mg/L	mg/L	mg/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L	ug/L
-79.049524	05/14/2015	37	120	500	30	<1	1010	258	<1	<1	<1	NA	<1	<1	<0.05	35.3	3.07	<1	NA	<0.2	<5
-79.041608	01/07/2016	830	370	2500	137	<1	7.18	183	<1	<1	<1	0.063	<1	<1	<0.05	2.25	5.94	1.05	NA	<0.2	<5
-79.037311	10/11/2011	31	14.9	396	<100	<0.5	<5	14.4	NA	<0.08	<5	NA	66	<5	<0.2	NA	<5	<10	NA	<0.1	40.2
-79.037465	06/30/2015	250	42	770	10	<1	<1	842	<1	<1	<1	NA	<1	<1	<0.05	3.17	<1	<1	NA	<0.2	<5
-79.03708	07/12/2016	23	210	87	42	<1	<1	56	<1	<1	19.5	14.8	<1	<1	<0.05	15.5	2.8	1.27	NA	<0.2	<5
-79.045201	04/22/2010	21	350	360	NA	<10	<10	42	<4	<2	<5	NA	<5	14	<0.1	NA	<40	<10	6.4	<50	<20
-79.041899	03/07/2007	24	280	570	NA	<0.58	<2	777	0.9	<0.5	101	NA	48.9	53	0.3	NA	84.8	<2	<2	0.478	360
-79.048355	08/06/2015	13	18000	12000	466000	<10	193	<500	318	<10	138	NA	<10	10	<0.05	<10	2050	16.4	NA	12.6	3450
	09/02/2015	22	23000	12000	534000	<10	195	<250	334	<10	161	NA	<10	11	<0.05	<10	2330	<10	NA	13.1	3850
	12/03/2015	31	12000	15000 N1	676000	<10	128	<50	309	<10	184	<0.03	<10	13	<0.05	<10	2600	<10	NA	11.6	3920
	01/06/2016	42	12000	12000	858000	<1	166	<500	274	2.84	177	<0.06	7.99	12	<0.05	1.03	2610	<1	NA	12.6	4570
-79.049605	09/05/2013	32.8	192	529	6290	7	61.7	370	NA	0.49 j	7.1 j	NA	16.3	5.9	<0.06	NA	8.6 j	26.1	NA	1.2	11.3 j
-79.047978	08/06/2015	29	110	240	1110	<1	<1	44	<1	<1	1.91	NA	6.94	<1	<0.05	<1	41.9	96.1	NA	0.574	99

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

 REQUIRED DATA ENTRY

Table 1. Project Information

	<input type="checkbox"/> CHECK IF HQW OR ORW WQS
Facility Name	Cape Fear Steam Electric Plant
WWTP/WTP Class	Class II
NPDES Permit	NC0003433
Outfall	New 009 - beneficiation
Flow, Qw (MGD)	0.005
Receiving Stream	Cape Fear River
HUC Number	03030002
Stream Class	WS-IV
<input checked="" type="checkbox"/> Apply WS Hardness WQC	
7Q10s (cfs)	65.00
7Q10w (cfs)	89.00
30Q2 (cfs)	150.00
QA (cfs)	3170.00
1Q10s (cfs)	53.22
Effluent Hardness	25 mg/L (Avg)
Upstream Hardness	25 mg/L (Avg)
Combined Hardness Chronic	25 mg/L
Combined Hardness Acute	25 mg/L
Data Source(s)	Duke beneficiation data, BPJ, flow (5,000 GPD), USGS stream flow data, default hardness
<input type="checkbox"/> CHECK TO APPLY MODEL	

Table 2. Parameters of Concern

	Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01	Arsenic	Aquatic Life	C	150	FW	340		ug/L
Par02	Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Par03	Total Dissolved Solids	Water Supply	NC	500	WS			mg/L
Par04	Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Par05	Chlorides	Water Supply	NC	250	WS			mg/L
Par06	Aluminum	Water Supply	NC	6.5	WS			mg/L
Par07	Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Par08	Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Par09	Chromium VI	Aquatic Life	NC	11	FW	16		ug/L
Par10	Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Par11	Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Par12	Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Par13	Fluoride	Aquatic Life	NC	1,800	FW			ug/L
Par14	Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Par15	Mercury	Aquatic Life	NC	12	FW		0.5	ng/L
Par16	Molybdenum	Water Supply	NC	160	WS			ug/L
Par17	Nickel	Aquatic Life	NC	37.2313	FW	335.2087		ug/L
Par18	Nickel	Water Supply	NC	25.0000	WS	N/A		ug/L
Par19	Selenium	Aquatic Life	NC	5	FW	56		ug/L
Par20	Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Par21	Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Par22	Antimony	Water Supply	NC	5.6	WS			ug/L
Par23	Barium	Water Supply	NC	1	WS			mg/L
Par24	Sulfates	Water Supply	NC	250	WS			mg/L

Cape Fear Steam Electric Plant
NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Qw (MGD) = **0.01**
1Q10S (cfs) = **53.22**
7Q10S (cfs) = **65.00**
7Q10W (cfs) = **89.00**
30Q2 (cfs) = **150.00**
Avg. Stream Flow, QA (cfs) = **3170.00**
Receiving Stream: Cape Fear River HUC 03030002

WWTP/WTP Class: **Class II**
IWC% @ 1Q10S = **0.014560074**
IWC% @ 7Q10S = **0.011921655**
IWC% @ 7Q10W = **0.008707107**
IWC% @ 30Q2 = **0.0051664**
IW%C @ QA = **0.000244479**
Stream Class: **WS-IV**

Outfall New 009 - beneficiation
Qw = **0.005 MGD**

COMBINED HARDNESS (mg/L)

Acute = 25 mg/L
Chronic = 25 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			PQL	UNITS	REASONABLE POTENTIAL RESULTS				RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			n	# Det.	Max Pred Cw	Allowable Cw	
Arsenic	C	150	FW(7Q10s)	340		ug/L	1	1	496.0	Acute (FW): 2,335,152.9 Chronic (FW): 1,258,214.5 No value > Allowable Cw	
Arsenic	C	10	HH/WS(Qavg)			ug/L	Note: n ≤ 9 Limited data set		Default C.V.	Chronic (HH): 4,090,332.6 No value > Allowable Cw	Major pollutant of concern apply monthly monitoring
Total Dissolved Solids	NC	500	WS(7Q10s)			mg/L	1	1	13,640.00	Acute: NO WQS Chronic: 4,194,048.39 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Cadmium	NC	0.5899	FW(7Q10s)	3.2396		ug/L	1	1	5.580	Acute: 22,249.967 Chronic: 4,947.963 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chlorides	NC	250	WS(7Q10s)			mg/L	1	1	2,046.0	Acute: NO WQS Chronic: 2,097,024.2 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Aluminum	NC	6.5	WS(7Q10s)			mg/L	1	1	19.8	Acute: NO WQS Chronic: 54,522.6 No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Beryllium	NC	6.5	FW(7Q10s)	65.0000		ug/L	1	0	15.5	Acute: 446,426.3 Chronic: 125,813.0 NO DETECTS Max MDL = 5	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required
Chromium III	NC	117.7325	FW(7Q10s)	905.0818		μg/L	0	0	N/A	Acute: 6,216,189.3 Chronic: 987,552.0	
Chromium VI	NC	11	FW(7Q10s)	16		μg/L	0	0	N/A	Acute: 109,889.5 Chronic: 92,269.1	
Chromium, Total	NC					μg/L	Tot Cr value(s) < 50 and < Cr VI Allowable Cw Note: n ≤ 9 Limited data set		39.7 Default C.V.	Max reported value = 6.4	a. No Monitoring required if all Total Chromium samples are < the Chromium VI Allowable Cw
Copper	NC	7.8806	FW(7Q10s)	10.4720		ug/L	1	0	31.00 Default C.V. NO DETECTS	Acute: 71,922.67 Chronic: 66,103.56 Max MDL = 10	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required

Cape Fear Steam Electric Plant

NC0003433

Outfall New 009 - beneficiation

Qw = 0.005 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

≥									
Metal	State	Value	Unit	n	C.V.	Default C.V.	Acute:	NO WQS	Notes
							Chronic:	No RP, Predicted Max < 50% of Allowable Cw - No Monitoring required	
Fluoride	NC	1800	FW(7Q10s)		ug/L	2 1	8,368.3	Default C.V.	Chronic: 15,098,574.2 No value > Allowable Cw
Lead	NC	2.9416	FW(7Q10s) 75.4871		ug/L	1 1	29,760	Default C.V.	Acute: 518,452.736 Chronic: 24,674.627 No value > Allowable Cw
Mercury	NC	12	FW(7Q10s)	0.5	ng/L	1 1	291.4	Default C.V.	Acute: NO WQS Chronic: MAX 47 No value > Allowable Cw
Molybdenum	NC	160	WS(7Q10s)		ug/L	2 2	1,197.6	Default C.V.	Acute: NO WQS Chronic: 1,342,095.5 No value > Allowable Cw
Nickel	NC	37.2313	FW(7Q10s) 335.2087		µg/L	1 1	74.4	Default C.V.	Acute (FW): 2,302,245.8 Chronic (FW): 312,300.1 No value > Allowable Cw
Nickel	NC	25.0000	WS(7Q10s)		µg/L	1 1	74.4	Default C.V.	Chronic (WS): 209,702.4 No value > Allowable Cw
Selenium	NC	5	FW(7Q10s) 56		ug/L	1 1	1,550.0	Default C.V.	Acute: 384,613.4 Chronic: 41,940.5 No value > Allowable Cw
Silver	NC	0.06	FW(7Q10s) 0.29639789		ug/L	1 1	31.0	Default C.V.	Acute: 2,035.689 Chronic: 503.286 No value > Allowable Cw
Zinc	NC	126.7335	FW(7Q10s) 125.7052		ug/L	1 1	223.2	Default C.V.	Acute: 863,355.6 Chronic: 1,063,052.7 No value > Allowable Cw
Antimony	NC	5.6	WS(7Q10s)		µg/L	1 1	48.98000	Default C.V.	Acute: NO WQS Chronic: 46973.34194 No value > Allowable Cw
Barium	NC	1	WS(7Q10s)		mg/L	1 1	1.05400	Default C.V.	Acute: NO WQS Chronic: 8388.09677 No value > Allowable Cw
Sulfates	NC	250	WS(7Q10s)		mg/L	2 2	1,671.39000	Default C.V.	Acute: NO WQS Chronic: 2097024.19 No value > Allowable Cw
Thallium	NC	2	WS(7Q10s)		µg/L	1 0	155.00000	Default C.V.	Acute: NO WQS Chronic: 16776.19355 Max MDL = 50

REASONABLE POTENTIAL ANALYSIS

Effluent Hardness				Upstream Hardness				Arsenic				Total Dissolved Solids								
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results								
				Maximum data points = 58									Maximum data points = 58							
1	default	25	25	Std Dev. 0.0000	1	default	25	25	Std Dev. 0.0000	1	ben data	80	80	Std Dev. 0.0000	1	ben data	2200	2200	Results Std Dev. 0.0000	
2				Mean 25.0000	2				Mean 25.0000	2				Mean 80.0000	2			Mean 2200.0000		
3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 1	4				n 1	4				n 1	4			n 1		
5				10th Per value 25.00 mg/L	5				10th Per value 25.00 mg/L	5				Mult Factor = 6.20	6			Mult Factor = 6.20		
6				Average Value 25.00 mg/L	6				Average Value 25.00 mg/L	6				Max. Value 80.00 ug/L	7			Max. Value 2200.00 mg/L		
7				Max. Value 25.00 mg/L	7				Max. Value 25.00 mg/L	7				Max. Pred Cw 496.00 ug/L	8			Max. Pred Cw 1364.00 mg/L		
8					8					9						9				
9																				
Par04				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58				Par05				Par06				Par07				
				Cadmium				Chlorides				Aluminum				Beryllium				
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results
				Maximum data points = 58													Maximum data points = 58			
1	ben data	0.9	0.9	Std Dev. 0.0000	1	ben data	330	330	Std Dev. 0.0000	1	ben data	3.2	3.2	Std Dev. 0.00	1	ben data	< 5	2.5	Results Std Dev. 0.0000	
2				Mean 0.9000	2				Mean 330.0	2				Mean 3.20	2			Mean 2.5000		
3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 1	4				n 1	4				n 1	4			n 1		
5					5					5						5				
6				Mult Factor = 6.20	6				Mult Factor = 6.2	6				Mult Factor = 6.20	6			Mult Factor = 6.20		
7				Max. Value 0.900 ug/L	7				Max. Value 330.0 mg/L	7				Max. Value 3.2 mg/L	7			Max. Value 2.5 ug/L		
8				Max. Pred Cw 5.580 ug/L	8				Max. Pred Cw 2,046.0 mg/L	8				Max. Pred Cw 19.8 mg/L	8			Max. Pred Cw 15.5 ug/L		
9					9					9						9				
Par10				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58				Pa11				Par13				Par14				
				Chromium, Total				Copper				Fluoride				Lead				
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results
				Maximum data points = 58													Maximum data points = 58			
1	ben data	6.4	6.4	Std Dev. 0.0000	1	ben data	< 10	5	Std Dev. 0.0000	1	dewatering	2208	2208	Std Dev. 1560.9382	1	ben data	4.8	4.8	Results Std Dev. 0.0000	
2				Mean 6.4000	2				Mean 5.0000	2				Mean 1104.2500	2			Mean 4.8000		
3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 1	4				n 1	4				n 1	4			n 1		
5					5					5						5				
6				Mult Factor = 6.20	6				Mult Factor = 6.20	6				Mult Factor = 3.79	6			Mult Factor = 6.20		
7				Max. Value 6.4 ug/L	7				Max. Value 5.00 ug/L	7				Max. Value 2208.0 ug/L	7			Max. Value 4.800 ug/L		
8				Max. Pred Cw 39.7 ug/L	8				Max. Pred Cw 31.00 ug/L	8				Max. Pred Cw 8368.3 ug/L	8			Max. Pred Cw 29.760 ug/L		
9					9					9						9				
Par16				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58				Par17 & Par18				Par19				Par20				
				Molybdenum				Nickel				Selenium				Silver				
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results
				Maximum data points = 58													Maximum data points = 58			
1	dewatering	316	316	Std Dev. 207.4651	1	ben data	12	12	Std Dev. 0.0000	1	ben data	250	250	Std Dev. 0.0000	1	ben data	< 10	5	Results Std Dev. 0.0000	
2	dewatering	22.6	22.6	Mean 169.3000	2				Mean 12.0000	2				Mean 250.0000	2			Mean 5.0000		
3				C.V. (default) 0.8000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 2	4				n 1	4				n 1	4			n 1		
5					5					5						5				
6				Mult Factor = 3.79	6				Mult Factor = 6.20	6				Mult Factor = 6.20	6			Mult Factor = 6.20		
7				Max. Value 316.0 ug/L	7				Max. Value 12.0 ug/L	7				Max. Value 250.0 ug/L	7			Max. Value 5.000 ug/L		
8				Max. Pred Cw 1197.6 ug/L	8				Max. Pred Cw 74.4 ug/L	8				Max. Pred Cw 1550.0 ug/L	8			Max. Pred Cw 31.00 ug/L		
9					9					9						9				
Par21				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58				Zinc				Par22				Par23				
				Antimony				Barium				Sulfates				Par24				
	Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results					Date	Data	BDL=1/2DL	Results
				Maximum data points = 58													Maximum data points = 58			
1	ben data	36	36	Std Dev. 0.0000	1	ben data	7.9	7.9	Std Dev. 0.00	1	ben data	0.17	0.17	Std Dev. 0.00	1	dewatering	441	441	Results Std Dev. 191.84	
2				Mean 36.0000	2				Mean 7.90	2				Mean 0.17	2			Mean 305.35		
3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 1	4				n 1	4				n 1	4			n 2		
5					5					5						5				
6				Mult Factor = 6.20	6				Mult Factor = 6.20	6				Mult Factor = 6.20	6			Mult Factor = 3.79		
7				Max. Value 36.0 ug/L	7				Max. Value 7.90 ug/L	7				Max. Value 0.17 mg/L	7			Max. Value 441.00 mg/L		
8				Max. Pred Cw 223.2 ug/L	8				Max. Pred Cw 48.98 ug/L	8				Max. Pred Cw 1.05 mg/L	8			Max. Pred Cw 1671.39 mg/L		
9					9					9						9				
Par25				Thallium				Mercury				Par26				Par27				
				Use "PASTE SPECIAL Values" then "COPY". Maximum data points = 58																
	Date	Data	BDL=1/2DL	Results													Maximum data points = 58			
				Maximum data points = 58																
1	ben data	< 50	25	Std Dev. 0.00	1	ben data	47	47	Std Dev. 0.00	1	ben data	47	47	Std Dev. 0.00	1	dewatering	169.7	169.7	Results Std Dev. 305.35	
2				Mean 25.00	2				Mean 47.00	2				Mean 0.6000	2			Mean 0.6000		
3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3				C.V. (default) 0.6000	3			C.V. (default) 0.6000		
4				n 1	4				n 1	4				n 1	4			n 2		
5					5					5						5				
6				Mult Factor = 6.20	6				Mult Factor = 6.20	6				Mult Factor = 6.20	6			Mult Factor = 3.79		
7				Max. Value 25.00 ug/L	7				Max. Value 47.00 ug/L	7				Max. Value 0.17 mg/L	7			Max. Value 441.00 mg/L		
8				Max. Pred Cw 155.00 ug/L	8				Max. Pred Cw 291.40 ug/L	8				Max. Pred Cw 1.05 mg/L	8			Max. Pred Cw 1671.39 mg/L		
9					9					9						9				

FACILITY: Cape Fear Steam Electric Plant
NPDES PERMIT: NC0003433

Dissolved to Total Metal Calculator

In accordance with Federal Regulations, permit limitations must be written as Total Metals per 40 CFR 122.45(c)

Receiving Stream summer 7Q10 (CFS)	Receiving Stream summer 7Q10 (MGD)	Rec. Stream 1Q10 [MGD]	NPDES Flow Limit [MGD]	Total Suspended Solids -Fixed Value- (mg/L)	Combined Hardness chronic (mg/L)	Combined Hardness Acute (mg/L)	Instream Wastewater Concentration (Chronic)	Instream Wastewater Concentration (Acute)	Upstream Hardness Average (mg/L)	Effluent Hardness Average (mg/L)
65.000	41.9355	34.3355	0.0050	10	25.000	25.000	0.0119	0.0146	25	25
Upstream Hard Avg (mg/L) = 25										
EFF Hard Avg (mg/L) = 25										

PARAMETER	Dissolved Metals		US EPA Translators- using Default Partition Coefficients (streams)	Maximum Allowable Effluent Concentration (MAEC) as a Total Metal		COMMENTS (identify parameters to PERCS Branch to maintain in facility's LTMP/STMP):				
				Dissolved Metal	Translator					
	Chronic [ug/l]	Acute [ug/l]		Chronic [ug/l]	Acute [ug/l]					
Cadmium (d)	0.15	0.82		0.252	0.59	3.24				
Cd -Trout streams	0.15	0.51		0.252	0.59	2.01				
Chromium III (d)(h)	24	183		0.202	117.73	905.08				
Chromium VI (d)	11	16		1.000	11.00	16.00				
Chromium, Total (t)					N/A	N/A				
Copper (d)(h)	2.7	3.6		0.348	7.88	10.47				
Lead (d)(h)	0.54	14		0.184	2.94	75.49				
Nickel (d)(h)	16	145		0.432	37.23	335.21				
Ni - WS streams (t)					25	N/A				
Silver (d)(h,acute)	0.06	0.30		1.000	0.06	0.30				
Zinc (d)(h)	36	36		0.288	126.73	125.71				
Beryllium	6.5	65		1.000	6.5	65				
Arsenic (d)	150	340		1.000	150	340				

(d) = dissolved metal standard. See 15A NCAC 02B .0211 for more information.

(h) = hardness-dependent dissolved metal standard. See 15A NCAC 02B .0211 for more information.


(t) = based upon measurement of total recoverable metal. See 15A NCAC 02B .0211 for more information.

The Human Health standard for Nickel in Water Supply Streams is 25 mg/L which is Total Recoverable metal standard.

The Human Health standard for Arsenic is 10 µg/L which is Total Recoverable metal standard.

Table 3. – Untreated Wash Water Data from another site

Parameter	CAS Number	Analytical Method	Result	PQL	MDL	Units
Alkalinity		SM 2320B-20	59	10	2	mg/L
Chloride		300	330	10	2	mg/L
COD		SM 5220D-20	23	10	2	mg/L
pH		9040C	7.16		8	mg/L
Specific Conductance		SM 2510B-20	2610	10	0.717	umhos/cm
TDS		SM 2540C-20	2200	10	3.4	mg/L
TS		SM 2540B-20	2400	10	2.2	mg/L
TSS		SM 2540D-20	40	2	0.5	mg/L
Aluminum	7429-90-5	6010D	3.2	0.4	0.1	mg/L
Antimony	7440-36-0	6010D	0.0079	0.02	0.007	mg/L
Arsenic	7440-38-2	6010D	0.08	0.015	0.0025	mg/L
Barium	7440-39-3	6010D	0.17	0.025	0.0031	mg/L
Beryllium	7440-41-7	6010D	ND	0.005	0.0006	mg/L
Cadmium	7440-43-9	6010D	0.0009	0.005	0.0006	mg/L
Calcium	7440-70-2	6010D	440	5	0.63	mg/L
Chromium	7440-47-3	6010D	0.0064	0.01	0.0013	mg/L
Cobalt	7440-48-4	6010D	0.0035	0.025	0.0031	mg/L
Copper	7440-50-8	6010D	ND	0.01	0.002	mg/L
Iron	7439-89-6	6010D	1.5	0.1	0.04	mg/L
Lead	7439-92-1	6010D	0.0048	0.01	0.0047	mg/L
Magnesium	7439-95-4	6010D	60	5	0.63	mg/L
Manganese	7439-96-5	6010D	0.047	0.015	0.0019	mg/L
Mercury	7439-97-6	7470A	0.000047	0.0001	0.000028	mg/L
Nickel	7440-02-0	6010D	0.012	0.04	0.005	mg/L
Potassium	7440-09-7	6010D	17	5	0.63	mg/L
Selenium	7782-49-2	6010D	0.25	0.02	0.0085	mg/L
Silver	7440-22-4	6010D	ND	0.01	0.0021	mg/L
Sodium	7440-23-5	6010D	120	5	0.63	mg/L
Thallium	7440-28-0	6010D	ND	0.05	0.0063	mg/L
Vanadium	7440-62-2	6010D	0.056	0.05	0.0063	mg/L
Zinc	7440-66-6	6010D	0.036	0.02	0.0025	mg/L



ROY COOPER
Governor
MICHAEL S. REGAN
Secretary
LINDA CULPEPPER
Interim Director

July 27, 2018

MEMORANDUM

To: Allen Hardy
NC DEQ / DWR / PWS Regional Engineer
Raleigh Regional Office

From: Bing Bai
919-807-6389
NPDES Unit

Subject: Review of Draft NPDES Permit NC0003433
Duke Energy Cape Fear Steam Plant
Chatham County

Please indicate below your agency's position or viewpoint on the draft permit and return this form by **July 27, 2017**. If you have any questions on the draft permit, please feel free to contact me at the telephone number shown above.

RESPONSE: (Check one)

Concur with the issuance of this permit provided the facility is operated and maintained properly, the stated effluent limits are met prior to discharge, and the discharge does not contravene the designated water quality standards.



Concurs with issuance of the above permit, provided the following conditions are met:



Opposes the issuance of the above permit, based on reasons stated below, or attached:

Signed

W. Allen Hardy

Date:

6/28/18

 Nothing Compares™

State of North Carolina | Environmental Quality

1611 Mail Service Center | Raleigh, North Carolina 27699-1611

919-707-9000