NORTH CAROLINA DIVISION OF AIR QUALITY Application Review							Region: Raleigh Regional Office County: Johnston NC Facility ID: 5100226 Inspector's Name: N/A		
Issue Date:							Date of Last Inspection: N/A Compliance Code: N/A		
Facility Data							Permit Applicability (this application only)		
 Applicant (Facility's Name): Duke Energy Progress, LLC – Novo Nordisk Facility Address: Duke Energy Progress, LLC – Novo Nordisk 638 GLP One Way Clayton, NC 27527 SIC: 4911/Electric Services NAICS: 221112/Electric power generation, fossil fuels 						SIP: 02D .0516, 02D .0521, 02D .0524, 02D .1111 NSPS: Subpart IIII NESHAP: Subpart ZZZZ PSD: N/A PSD Avoidance: N/A NC Toxics: N/A 112(r):N/A Other: N/A			
Fee Classif	ication: Before	fore: Permit/Re : N/A After: T		nding After: 7	Γitle V	Annl	ication Data		
Contact DataFacility ContactAuthorized ContJonathan GardnerJim FisherProject Manager IIDir. of Energy Sv(910) 305-5857Operations4650 Simms Creek Road(919) 616-3121Raleigh, NC 276164650 Simms CreeRaleigh, NC 27616Raleigh, NC 2761		Svcs. 1 Sreek Road 7616	Technical Contact Jerray Battle Environmental Specialist II (919) 247-5295 411 Fayetteville Street Raleigh, NC 27601		Application Number: 5100226.24A Date Received: 11/27/2024 Application Type: Greenfield Facility Application Schedule: State Existing Permit Data Existing Permit Number: N/A Existing Permit Issue Date: N/A Existing Permit Expiration Date: N/A				
		n TONS/YEAR		~~~					
CY	SO2	NOX	VOC	СО	PM10]	Fotal HAP	Largest HAP	
Greenfield	Greenfield facility, no previous inventory data								
Review Engineer: Lissabeth GardnerReview Engineer's Signature:Date:					Comments Issue 10859 Permit Issue Permit Exp	/R00 e Date:		5:	

1. Purpose of Application

Duke Energy One's Energy Services is a branch of Duke Energy Progress, LLC (Duke Energy). Duke Energy is currently operating seventeen (17) emergency backup generators for a large pharmaceutical customer in Clayton, NC. It currently does not have an air permit in accordance with 15A NCAC 02Q .0102. Duke Energy intends to install an additional thirteen (13) diesel fired emergency generators in 2025.

Pursuant to 15A NCAC 2Q .0501(b)(2) and 02Q .0504, Duke Energy has requested to obtain a construction and operation permit in accordance with 02Q .0300, before it is required to obtain a Title V permit. Therefore, the submitted application will be processed under the 02Q .0300 program at this time. Pursuant to 02Q .0504(c), the facility will be required to submit another application per Title V procedures (02Q .0500) after obtaining an initial permit within 12 months of commencement of operations.

The name of the proposed facility is Duke Energy Progress, LLC - Novo Nordisk

2. Facility Description

Duke Energy currently operates seventeen (17) emergency backup generators for a large pharmaceutical customer in Clayton, NC (Johnston County). The current generators are located at 3612 Powhatan Rd. (IFP) and 3611 Powhatan Rd. (API). The applicant determined that these emission sources should be permitted under Duke Energy and not Novo Nordisk as they are under ownership of Duke Energy and will be operated and maintained by Duke Energy. These generators' actual emissions are less than 100 tons per calendar year for any regulated pollutant, 10 tons per calendar year of any hazardous air pollutant, and 25 tons per calendar year of any combination of hazardous air pollutants. Therefore, these generators fall under exemption 15A NCAC 02Q .0903.

The purpose of this air permit application is to request authorization to install an additional 13 emergency generators to properly support backup generation needs for the expanding large pharmaceutical company. With the addition of these 13 generators the facility-wide potential-to emit (PTE) for NOx exceeds 100 tons per year (tpy).

The proposed facility's PTE for the pollutant NOx exceeds the major source threshold under the Clean Air Act (CAA)'s Title V operating program. The name of the proposed facility is Duke Energy Progress, LLC – Novo Nordisk

Duke Energy Progress, LLC – Novo Nordisk is considered a minor source for Prevention of Significant Deterioration (PSD) purposes because the potential to emit (PTE) for each regulated NSR pollutant is less than 250 tpy. The facility will be classified as minor for Hazardous Air Pollutants (HAPs) because potential emissions are below the major source thresholds of 10 tpy of any single HAP and 25 tpy of all HAPs combined.

Date	Event				
November 27, 2024	Application 5100226.24A received in the Raleigh Central Office				
December 4, 2024 Application 5100226.24A assigned to Lissabeth Gardner					
December 11, 2024	Lissabeth Gardner requested additional information from Duke Energy pertaining to missing information on Form B				
December 18, 2024	Lissabeth Gardner requested Duke Energy submit a Zoning Consistency Determination Form with proof of delivery consistent with 15A NCAC 02Q .0507(d) (1) for the application to be deemed complete.				
January 22, 2025	Lissabeth Gardner received verification from Alicia Thomas at the Town of Clayton via email and voicemail that the Zoning Consistency Determination Letter Request was received by the Town of Clayton.				

3. Application Chronology

Date	Event
January 29, 2025	Erin Wallace of Duke Energy informed Lissabeth Gardner that Duke Energy would be conducting the air dispersion modeling for the pollutants exceeding the emission rates in 15A NCAC 02Q .0711 as per 15A NCAC 02Q .07004(C).
February 24, 2025	Lissabeth Gardner received the air dispersion modeling for the Duke Energy site from Jerray Battle of Duke Energy.
March 26, 2025	Nancy Jones from the DAQ reviewed and approved the air dispersion modeling for the Duke Energy site.
March 26, 2025	Erin Wallace sent the Zoning Consistency Determination Form (properly filled out and signed) to Lissabeth Gardner via email.
April 30, 2025	Draft of permit and technical Review sent to supervisor, received comments back and updated accordingly
May 27, 2025	Lissabeth Gardner notified of a name change to the facility on XX via email from Jerray Battle. She requested an AA3 form be filled out and sent to the DAQ.
June 9, 2025	Received hard copy of the AA3 form and the Zoning Consistency Determination Form
June 10, 2025	Revised draft sent to DAQ RRO staff, DAQ SSCB staff, and Duke Energy staff. Erin Wallace requested two weeks to review the permit. Lissabeth Gardner agreed.
June 27, 2025	Duke Energy staff responded with comments to the draft inquiring if reporting requirements were necessary as emergency engines under NSPS IIII and MACT ZZZZ do not have reporting requirements.
July 1, 2025	Jerray Battle dropped off AA3 form requesting a name change for the facility from Duke Energy Premier Power- Novo Nordisk FFEx to Duke Energy Progress, LLC- Novo Nordisk
July 8, 2025	Lissabeth Gardner sent responses to comments and made minor changes to reporting requirements for
July 10, 2025	Jerray Battle responded that Duke Energy had no further comments
	The Public Notice and EPA Review periods began.

4. Compliance Status

The proposed facility has not yet been constructed. It is expected to start construction and operation for the emissions sources included in the application after obtaining an air permit. Therefore, no compliance status is available or can be determined.

5. Proposed Facility

17 diesel-fired emergency generators are currently installed between sites at 3612 Powhatan Road Clayton, NC(IFP) and 3611 Powhatan Road Clayton, NC (API). An additional 13 diesel-fired emergency generators will be installed in year 2025 at site 3612 Powhatan Road Clayton, NC to supply emergency power during power outages for Novo Nordisk. Upon permitting the site address will be 638 GLP One Way, Clayton NC.

All permitted engines will fire ultra-low sulfur diesel fuel. Potential emissions are based on 500 hours¹ of operation per year per engine. Duke Energy has classified this activity, with respect to the Standard Industrial Classification System, under the Code 4911, "Electric Services" and for the North American Industry Classification System (NAICS), under the Code 221112 "Fossil Fuel Electric Power Generation".

E' C ID	Table 5.1	Cartal Daria ID	Centul Della
Emission Source ID	Emission Source Description	Control Device ID	Control Device
		No.	Description
ES-1 through ES-7	Seven No.2 fuel oil-fired emergency	N/A	N/A
NSPS IIII	generator engines (917 horsepower		
MACT ZZZZ	engine output, each)		27/4
ES-8 through ES-11	Four No.2 fuel oil-fired emergency	N/A	N/A
NSPS-IIII	generator engines (917 horsepower		
MACT ZZZZ	engine output, each)		
ES-12	No.2 fuel oil-fired emergency generator	N/A	N/A
MACT ZZZZ	engine (2,172 horsepower engine		
	output)		
ES-13	No.2 fuel oil-fired emergency generator	N/A	N/A
MACT ZZZZ	engine (2,172 horsepower engine		
	output)		
ES-14	No. 2 fuel oil-fired emergency generator	N/A	N/A
MACT ZZZZ	engine (2,520 horsepower engine		
	output)		
ES-15	No. 2 fuel oil-fired emergency generator	N/A	N/A
MACT ZZZZ	engine (2,520 horsepower engine		
	output)		
ES-16	No.2 fuel oil-fired emergency generator	N/A	N/A
NSPS-IIII	engine (2,584 horsepower engine		
MACT ZZZZ	output)		
ES-17	No.2 fuel oil-fired emergency generator	N/A	N/A
MACT ZZZZ	engine (2,520 horsepower engine		
	output)		
ES-18 through ES-26	Nine No.2 fuel oil-fired emergency	N/A	N/A
NSPS-IIII	generator engines (3,399 horsepower		
MACT ZZZZ	engine output, each)		

Table 5.1

¹ 500 hours of operation per year was suggested by EPA in a memo titled *Calculating Potential to Emit (PTE) for Emergency Generators*

Emission Source ID	Emission Source Description	Control Device ID	Control Device
No.		No.	Description
ES-27 through ES-30	Four No.2 fuel oil-fired emergency	N/A	N/A
NSPS-IIII	generator engines (4,079 horsepower		
MACT ZZZZ	engine output, each)		

6. **Emission Estimates**

Table 6.0-1 provides the potential emissions estimates for the proposed facility based on a maximum of 500 hours per year for emergency engines. Appendices show the PTE calculated by Duke Energy and the DAQ respectively. The slight deviations in values are due to different emission factors being used.

The PTE was calculated for all emission sources (ES-1 through ES-30) excluding ES-12-15, and ES-17 using the Tier 2 emission standards for NSPS Subpart IIII subject engines. Potential emissions for the remaining emission sources were calculated using AP-42 emission standards for emergency engines as those sources were not subject to NSPS IIII. The fuel used in the emergency generators will be Ultra Low Sulfur Diesel fuel with a sulfur content of 0.0015% (as is required pursuant to NSPS IIII and MACT ZZZZ). SO₂ emissions were calculated using this sulfur content assumption. VOC emissions were calculated using AP-42 Section 3.4 emissions factors for Large Stationary Diesel Engines. The VOC used 91% of the TOC emission factor to calculate VOC. The remaining 9% of TOC is methane by weight. Methane is not a volatile organic compound.

Table 6.0-1							
Criteria Air Pollutants and HAPs	PTE in TPY (tpy)	Emission Factor (lb/hp-hr)					
PM	6.71	3.29E-04*/7.00E-04**					
PM ₁₀	6.71	3.29E-04*/7.00E-04**					
PM _{2.5}	6.71	3.29E-04*/7.00E-04**					
NO _x ,	219	1.05E-02*/2.4E-02**					
СО	98.4	5.75E-03*/5.50E-03					
SO _x	0.21	1.21E-05					
VOC	11.05	6.42E-04					
Total HAP	0.22	1.23E-05					
Largest HAP (benzene)	0.10	5.43E-06					

т. н. с. о. 1

*Value from NSPS IIII, 40 CFR Part 1039 Table 2 for subject engines

**Value from AP-42 Vol 1, 3.4-1, GASEOUS EMISSION FACTORS FOR LARGE STATIONARY DIESSEL AND ALL STATIONARY DUAL-FUEL ENGINES

Table 6.0-2 provides the potential emission estimates for TAPs and their associated rates per 15A NCAC 02Q .0711(a). The emergency generators have obstructed emission release points, so the applicable emission rates are shown in 15A NCAC 02Q .0711 (a). Duke Energy exceeds toxic air pollutant emission rates for Arsenic (ASC-Other), Benzene (71-43-2), Beryllium metal (unreacted) (7440-41-7), Cadmium metal (elemental unreacted) (7440-43-9), soluble chromate compounds, as chromium (VI) equivalent, Formaldehyde (50-00-0), and Mercury Vapor (7439-97-6).

1 able 0.0-2							
Regulated Toxic Air Pollutants	Unit	Emergency Generator ES-1 through ES-30 Total Emissions	Limits per 15A NCAC 02Q .0711(a)				
Acetaldehyde	lb/hr	0.013	6.8 lb/hr				
Acrolein	lb/hr	0.004	0.02 lb/hr				
Arsenic	lb/yr	1.0	0.053 lb/yr				
Benzene	lb/yr	196.6	8.1 lb/yr				
Benzo(a)pyrene	lb/yr	0.070	2.2 lb/yr				
Beryllium metal	lb/yr	0.76	0.28 lb/yr				
Cadmium metal	lb/yr	0.76	0.37 lb/yr				
(elemental unreacted)							
Chromic acid (VI)	lb/day	0.040	0.013 lb/day				
(soluble chromic							
compounds)							
Formaldehyde	lb/hr	0.040	0.04 lb/hr				
Manganese unlisted	lb/day	0.070	0.63 lb/day				
compounds							
Mercury Vapor	lb/day	0.040	0.013 lb/day				
Nickel Metal	lb/day	0.040	0.13 lb/day				
Toluene	lb/hr						
	lb/day	0.14 lb/hr 3.42 lb/day	14.4lb/hr 98lb/day				
Xylene	lb/hr						
	lb/day	0.098 lb/hr 2.35 lb/day	16.4 lb/hr 57 lb/day				

Table 6.0-2

7. Regulatory Review

Duke Energy is subject to the following regulatory requirements and requirements in the General Conditions:

 15A NCAC 02D .0516: Sulfur Dioxide Emissions from Combustion Sources

 15A NCAC 02D 0.0521: Control of Visible Emissions

 15A NCAC 02D .0524: New Source Performance Standards (Subpart IIII)

 15A NCAC 02D .1111: Maximum Achievable Control Technology

Consistent with current DAQ permitting policy, all subsequent calculations for the potential emissions of emergency generators assume 500 hours per year operation at maximum capacity.

7.1 15A NCAC 02D .0516: SULFUR DIOXIDE EMISSIONS FROM COMBUSTION SOURCES

Applicability: This rule applies to combustion sources that do not meet the standards from Rules .0524, .0527, .1110, .1111, .1205, .1206, .1210, or .1211. Sulfur dioxide formed by the combustion of sulfur in fuels, wastes, ores, and other substances shall be included when determining compliance with this standard.

The emergency generators are combustion sources and are therefore subject to this rule.

Emission Limit: Emission of sulfur dioxide from any source of combustion that is discharged from any vent, stack, or chimney shall not exceed 2.3 pounds of sulfur dioxide per million Btu heat input.

Monitoring/Recordkeeping/Reporting: Pursuant to NSPS IIII (see discussion below) these engines will only fire ultra-low sulfur fuel oil which has a sulfur content of 0.0015% by weight. A sample calculation is shown below.

Sulfur dioxide emissions for No. 2 fuel oil combustion are calculated using the equation AP-42 emission factor which is (1.01*weight percent sulfur) lb/MMBtu (ref. AP-42 Table 3.4-1).

Emissions rates from this fuel:

$$1.01 * 0.0015 = 0.0015 \frac{lb}{mmBtu}$$

0.0015 pounds per million Btu of heat input is orders of magnitude less than the emission limit of 2.3 pounds of sulfur dioxide per million Btu. Given the large margin of compliance and consistent with current DAQ permitting policy, no monitoring/recordkeeping/reporting is necessary for emergency engines firing ultra-low sulfur diesel fuel.

Compliance: Compliance with this rule is expected.

7.2 15A NCAC 02D .0521: CONTROL OF VISIBLE EMISSIONS

Background: This rule is to prevent and control emissions generated from both fuel burning operations and industrial processes where an emission can occur with the exclusion of startups, shutdowns, and malfunctions approved according to procedures in 15A NCAC 02D .0535. It encompasses equipment manufactured after July 1, 1971. A source subject to an emission standard for visible emissions in Rules 02D .0506, .0508, .0524, .1110, .1111, .1206, or .1210 of 15A NCAC shall meet the standard in that rule instead of the standard contained in 02D .0521.

Applicability: These generators have a manufactured dates after 1971, so they are subject to the 20% limit. This rule applies to each emission source at the facility as all the generators burn fuel.

Emission Limits: The visible emissions shall not exceed 20 percent for any six-minute period However, one exceedance may occur per hour and four exceedances may occur per 24-hour period. The emissions shall never exceed 87-percent opacity.

Monitoring/Recordkeeping/Reporting: Properly maintained diesel engines generally have minimal visible emissions and comply with 15A NCAC 02D .0521. Consistent with current DAQ permitting policy, no monitoring/recordkeeping/reporting is required for visible emissions from these emission sources.

Compliance: Compliance with this rule is expected. Compliance will be verified during inspections.

7.3 15A NCAC 2D .0524: NEW SOURCE PERFORMANCE STANDARDS (NSPS IIII)

Applicability: On July 11, 2006, EPA promulgated NSPS "Standards of Performance for Stationary Compression Ignition Internal Combustion Engines" in 40 CFR 60 Subpart IIII. As per 40 CFR §60.4200(a)(2), owners and operators of stationary compression ignition internal combustion engines (CI ICE that commence construction after July 1, 2005, where the stationary CI ICE manufactured after April 1, 2006), are subject to NSPS Subpart IIII requirements.

With the exception of **ID** Nos. **ES-12 through ES-15 and ES-17**, all of the CI ICE considered in this application commenced construction after July 11, 2005, and the engines were manufactured after April 1, 2006. See Appendices. Thus 25 of the 30 proposed diesel-fired emergency generators (**ID** Nos. **ES-1 through ES-30** excluding **ID** Nos. **ES-12 through ES-15 and ES-17**) are subject to 15A NCAC 02D .0524 and 40 CFR Subpart IIII.

Emission Limits: In accordance with 40 CFR 60.4205(b), owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new non-road CI engines in §60.4202 for 2007 model year and later emergency stationary CI ICE.

In accordance with 40 CFR 60.4202(a)(2) and 40 CFR 60.4204(b), the owner/operator must comply with the emission standards listed in 40 CFR Part 1039 Table 2 for new non-road CI engines for 2006 model year and their respective engine horsepower. According to §60.4202, the Permittee must meet the smoke standards specified in 40 CFR 1039.105. However, the engines are assumed to not be "constant speed" engines, and as such, they are exempt from the smoke standard compliance requirements (§60.4202, 40 CFR §1039.105).

Fuel Requirements: In accordance with 40 CFR 60.4207(b), the facility will be limited to using diesel fuel with a sulfur content of less than 15 ppm. Furthermore, in accordance with 40 CFR 80.510(b) and (c), the diesel fuel must meet one of the following standards: (1) minimum cetane index of 40 and (2) maximum aromatic content of 35 volume percent.

Monitoring/Operation & Maintenance: As per 40 CFR 60.4209(a), the emergency engines must be equipped with a non-resettable hour meter prior to startup of the engine.

In accordance with 40 CFR 60.4209(b), if the emergency engines are equipped with diesel particulate filters to comply with the above emissions standards, the Permittee shall install a backpressure monitor on each diesel particulate filter that notifies the Permittee when the high backpressure limit of the engine is approached.

In accordance with 40 CFR 60.4206 and 60.4211(a), the Permittee shall operate and maintain each stationary CI ICE that achieves the emission standards in 40 CFR 60.4205 over the entire life of the engine according to the manufacturer's emission-related written instructions or procedures developed by the Permittee that are approved by the engine manufacturer. The Permittee may only change engine settings that are permitted by the manufacturer.

In accordance with 40 CFR 60.4211(c), the Permittee is required to purchase engines which are certified to the emission standards listed in Table 1 of 40 CFR 1039.

In accordance with 40 CFR 60.4211(f), the Permittee will be allowed to operate the emergency engines for the purposes of maintenance checks and readiness testing for no more than 100 hours per year. Any operation of the emergency engines other than for emergency operation, maintenance, and readiness testing will be prohibited. If an engine is not operated according to the requirements of 40 CFR 60.4211 paragraphs (f)(1) through (3), the engine will not be considered an emergency engine under this Subpart and shall meet all requirements for non-emergency engines.

Recordkeeping Requirements: In accordance with 40 CFR 60.4214(b), if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the Permittee shall keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The Permittee shall record the time and operation of the engine and the reason the engine was in operation during that time.

In accordance with 40 CFR 60.4214(c), if the stationary CI internal combustion engine is equipped with a diesel particulate filter, the Permittee shall keep records of any corrective action taken after the backpressure monitor has notified the Permittee that the high backpressure limit of the engine is approached.

Reporting: In accordance with 40 CFR 60.4214(d), if the Permittee owns or operates an emergency stationary CI ICE with a maximum engine power more than 100 HP that operates for the purpose specified in 40 CFR 60.4211(f)(3)(i), he/she must submit an annual report according to the requirements in paragraphs (d)(1) through (3) of 40 CFR 60.4214.

In accordance with 40 CFR 60.4214(e), owners or operators of stationary CI ICE equipped with AECDs pursuant to the requirements of 40 CFR 1039.665 must report the use of AECDs as required by 40 CFR 1039.665(e).

The facility has indicated that the engines are EPA certified, and the documents shall be available for viewing during the initial compliance inspection. The facility indicated in the application that it will only purchase ultra-low sulfur fuel to be used in the emergency engines.

Testing: The displacement of these emergency compression ignition internal combustion engines is less than 30 liters per cylinder for the model year 2007 and later, and the Permittee will use a certified engine to meet the emission standards in §60.4205(b), no performance testing is required.

Notification, Reports and Records for Owners and Operators: As per §60.4214(b), no initial notification is required for an emergency stationary internal combustion engine. However, the Permittee must keep records of all hours the engine is operated in emergency and non-emergency use (maintenance and readiness checks). If the engine is equipped with a diesel particulate filter, the owner or operator must keep records of any corrective action taken after the backpressure monitor has notified the owner or operator that the high backpressure limit of the engine is approached.

Compliance: Compliance with this rule is expected. Compliance will be verified during inspections.

7.4-15A NCAC 2D .1111: MAXIMUM ACHIEVABLE CONTROL TECHNOLOGY

Applicability: All diesel-fired emergency generators (**ID Nos. ES-1 through ES-30**) are subject to 15A NCAC 2D .1111, Maximum Achievable Control Technology and 40 CFR 63, Subpart ZZZZ: National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

Existing Engines

Pursuant to 40 CFR 63.6590(a)(1)(iii) and (iv):

- (iii) For stationary RICE located at an area source of HAP emissions, a stationary RICE is existing if you commenced construction or reconstruction of the stationary RICE before June 12, 2006.
- (iv) A change in ownership of an existing stationary RICE does not make that stationary RICE a new or reconstructed stationary RICE.

Thus, the engines (ID Nos. ES-12 through ES-15 and ES-17) are considered existing affected sources with respect to the rule.

As existing affected sources at an area source of HAP emissions, the Permittee shall comply with the rule as follows:

- Use ultra-low sulfur diesel fuel (15 ppm) that has a minimum cetane index of 40 or maximum aromatic content of 35 volume percent.
- Keep records of the hours of operation and the reason for the engine being operated onsite.
- Emergency use engines are limited to a maximum operation of 100 hours per year for the purpose of maintenance checks and readiness testing.
- Operate all engines according to manufacturer's recommendations (a facility may change only those settings approved by the manufacturer).
- Install a non-resettable hour meter.
- If the unit is equipped with a diesel particulate filter, keep records of any corrective action taken after the backpressure monitor has notified that the high backpressure limit of the engine is approached. Maintain all maintenance records.
- Perform the following maintenance
 - Except during periods of startup of the engine, the Permittee shall:
 - i. change oil and filter every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first;
 - ii. inspect air cleaner every 1,000 hours of operation or within 1 year + 30 days of the previous change, whichever comes first; and
 - iii. inspect all hoses and belts every 500 hours of operation or within 1 year + 30 days of the previous change, whichever comes first, and replace as necessary

Monitoring/Recordkeeping/Reporting: The Permittee shall be required to meet the applicable monitoring, recordkeeping, and reporting requirements of MACT ZZZZ as summarized above and specified in the permit.

Compliance: Compliance will be determined during inspections and semi-annual reporting.

New Engines

Pursuant to 40 CFR 63.6590(a)(2)(iii):

(iii) A stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary RICE on or after June 12, 2006.

Thus, all the remaining engines (ID Nos. ES-1 through ES-30, excluding ID Nos. ES-12 through ES-15 and ES-17) are considered new affected sources with respect to the rule.

According to 40 CFR §63.6590(c)(1) these new stationary RICE located at an area source shall meet the requirements of 40 CFR 63 Subpart ZZZZ by complying with requirements under 40 CFR Part 60 Subpart IIII for compression ignition engines.

Monitoring/Recordkeeping/Reporting: The Permittee shall be required to meet the monitoring, recordkeeping, and reporting for NSPS IIII to comply with the requirements of MACT ZZZZ.

Compliance: Compliance will be determined during inspections and semi-annual reporting.

8. NSPS, NESHAPS/MACT, PSD, 112(R), CAM

8.1 NSPS: 40 CFR 60 Subpart IIII: New Source Performance Standard

Applicability: New Source Performance Standards (NSPS), 40 CFR 60, Subpart IIII, Standards of Performance for stationary Compression Ignition Internal Combustion Engines, is applicable to all diesel-fired emergency generators excluding (ID Nos. **ES-12 through ES-15 and ES-17**). See discussion in Section 7 above

8.2 MACT: 40 CFR 63 Subpart GACT ZZZZ NESHAP/MACT

Applicability: This facility is an area source for HAPs emissions. See discussion in Section 7 above with respect to the applicable MACT/GACT regulations.

8.3 PSD

The Federal rules for PSD are implemented into North Carolina's SIP under 15A NCAC 02D .0530. In general, a facility is a major stationary source for PSD if the facility has actual or potential emissions of a pollutant greater than the threshold listed in 40 CFR 51.166(b)(1). For facilities that fall under the specific categories listed in 40 CFR 51.166(b)(1)(i)(a), the threshold is 100 tpy. The activities at the Duke Energy site are not classified as one of the listed categories; therefore, the threshold is 250 tpy (see 40 CFR 51.166(b)(1)(i)(a)).

Duke Energy has potential emissions of each regulated NSR pollutant less than 250 tpy. As such, Duke Energy is considered a minor source with respect to PSD.

Johnston County is in attainment for all regulated NSR pollutants.

Johnston County has triggered the PSD minor source baseline dates for PM_{10} and SO_2 . The proposed project is assumed to result in an increase of:

1.53 lb/hr of PM₁₀

$0.050 \ lb/hr \ of \ SO_2$

These increases are based on the assumptions that all proposed engines operate at maximum capacity and fire No 2. fuel oil with a maximum sulfur content of 15 ppm at a maximum of 500 hours per year. The SO₂ and PM₁₀ hourly emission rates for the 1-hour NAAQS limit (above) were calculated differently than the emission estimates in Section 6. To calculate these increases, the emission estimates from section 6 in tpy are divided by (2000 lb / 8,760 hours). The equation below shows a sample of the calculation used in determining compliance with the 1-hour NAAQS limit.

Annual PM₁₀ emissions(tpy) x (2,000 lb/ton) / 8760 hours = Average 1-hour PM₁₀ emission rate (lb/hr)

8.4 112(r)

This rule requires facilities that store materials above the threshold quantities in 40 CFR 68.130 above their respective thresholds to prepare and submit a risk management plan (RMP).

On Form A3 of the application the facility states that it is not subject to Section 112(r) of the Clean Air Act requirements because it does not store any of the regulated substances in quantities above the 112(r) thresholds.

8.5 CAM

Applicability: This application is processed pursuant to 15A NCAC 02Q .0300 "Construction and Operation Permits" and not under 02Q .0500 "Title V Procedures". Compliance assurance monitoring (CAM) requirement under 40 CFR 64, as implemented through 02D .0614, is strictly a Title V requirement. When DAQ processes the facility's initial Title V application, such applicability analysis will be conducted. Therefore, CAM analysis need not be performed at this time.

9. Facility Wide Air Toxics Air Toxics Evaluation

State enforceable only

15A NCAC 02Q .0700: TOXIC AIR POLLUTANT PROCEDURES 15A NCAC 02D .1100: CONTROL OF TOXIC AIR POLLUTANTS

Per 15A NCAC 02Q .0704(a) and (c), the owner or operator of a new facility shall submit a permit application to comply with 15A NCAC 02D .1100 if emissions of any toxic air pollutant, excluding sources exempt from evaluation pursuant to 02Q .0702, exceed the levels set forth in 02Q .0711. In addition, the state agency shall evaluate the impacts of the air toxic emissions sources, specifically meeting the exemption set forth in 02Q .0702(a)(27), pursuant to NCGS 143-215.107(a)(5)b. Duke Energy did not initially submit an explanation of exceedances of toxic air pollutants pursuant to 15A NCAC 02Q .1100. The emergency generators have obstructed emission release points, so the applicable emission rates are shown in 15A NCAC 02Q .0711 (a). Duke Energy exceeds toxic air pollutant emission rates for Arsenic (ASC-Other), Benzene (71-43-2), Beryllium metal (unreacted) (7440-41-7), Cadmium metal (elemental unreacted) (7440-43-9), soluble chromate compounds, as chromium (VI) equivalent, Formaldehyde (50-00-0), and Mercury Vapor (7439-97-6).

With this new facility construction, there are increases in emissions of certain toxics air pollutants, causing exceedance of toxic air pollutant emission rates (TPERs) in 02Q .0711(a). Thus, per 02Q .0704, toxic air pollutant (TAP) compliance demonstration is required for this new facility to ensure that the emissions of TAPs will not cause the exceedance of the applicable acceptable ambient level (AAL) listed in 15A NCAC 02D .1104 beyond the property line. It needs to be emphasized that although the air emissions sources, subject to Part 63 standards (thirty emergency generators) are exempt from air toxics permitting pursuant to 02Q .0702(a)(27)(B), the Permittee has included the emissions of all exempt sources for compliance purposes.

Table 6.0-2 above shows that the emissions higher than the emissions rates set forth in 15A NCAC 02Q .0711 are Arsenic, Benzene, Beryllium metal, cadmium metal, soluble chromate compounds, as chromium (VI) equivalent, formaldehyde, and mercury vapor across both the DAQ calculated emission rate and the Duke Energy calculated

emission rates. This facility is exempt from NC air toxics per 15A NCAC 02Q .0702(a)(27). However, 15A NCAC 02Q .0704(c) states that for new facilities that meet exemptions for toxic air pollutants set forth in 15A NCAC 02Q .0702(a)(27) shall be reviewed by the Division pursuant to G.S. 143-215.107(a)(5)b. G.S. 143-215.107(a)(5)b states that the Department shall review the application to determine if the emission of toxic air pollutants from the source or facility present an unacceptable risk to human health. Duke Energy has elected to do the air dispersion modeling for this facility.

Duke Energy elected to complete the air dispersion modeling to ensure no unacceptable health risk. Table 9-1 shows the model inputs. Table 9-2 shows the maximum impacts for Duke Energy.

Source ID	Easting (X)	Northing (Y)	Base Elevation	Stack Height	Temp.	Exit Velocity	Stack Diameter
	(m)	(m)	(m)	(ft)	(°F)	(fps)	(ft)
ES_1	735519	3944240	87	14	842	171	0.67
ES_2	735521	3944239	87	14	842	171	0.67
ES_3	735523	3944238	87	14	842	171	0.67
ES_4	735525	3944238	87	14	842	171	0.67
ES_5	735523	3944251	87	14	842	171	0.67
ES_6	735525	3944250	87	14	842	171	0.67
ES_7	735527	3944249	87	14	842	171	0.67
ES_8	734455	3944817	89	13	842	171	0.67
ES_9	734457	3944816	89	13	842	171	0.67
ES_10	734458	3944815	89	13	842	171	0.67
ES_11	734460	3944814	89	13	842	171	0.67
ES_12	734479	3944817	88	14	806	141	1.33
ES_13	734482	3944821	87	14	806	141	1.33
ES_14	734519	3944816	87	14	955	180	1.33
ES_15	734521	3944820	86	14	798	165	1.33
ES_16	734297	3944698	87	14	849	64	1.33
ES_17	734589	3944975	90	14	955	180	1.33
ES_18P12	735533	3943947	88	16	915	150	1.67
ES_19P11	735535	3943942	88	16	915	150	1.67
ES_20P8	735543	3943924	87	16	915	150	1.67
ES_21P2	735570	3943930	87	16	915	150	1.67
ES_22P3	735572	3943926	87	16	915	150	1.67
ES_23B4	735590	3943950	88	16	915	150	1.67
ES_24B3	735592	3943947	88	16	915	150	1.67
 ES_25B2	735598	3943931	87	16	915	150	1.67
 ES_26B1	735600	3943927	87	16	915	150	1.67
ES_27P10	735541	3943929	88	19	902	174	1.67
 ES_28P7	735551	3943908	87	19	902	174	1.67
 ES_29P6	735553	3943903	87	19	902	174	1.67
ES 30P1	735564	3943946	88	19	902	174	1.67

 Table 9-1 Model Inputs for Duke Energy Progress, LLC – Novo Nordisk

Source ID	Arsenic	Benzene	Beryllium	Cadmium	Chromium	Formald.	Mercury
	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)	(lb/hr)
ES_1	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_2	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_3	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_4	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_5	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_6	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_7	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_8	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_9	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_10	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_11	1.47E-06	2.84E-04	1.10E-06	1.10E-06	1.93E-05	5.06E-04	1.93E-05
ES_12	3.46E-06	6.72E-04	2.60E-06	2.60E-06	4.55E-05	1.20E-03	4.55E-05
ES_13	3.47E-06	6.73E-04	2.60E-06	2.60E-06	4.56E-05	1.20E-03	4.56E-05
ES_14	4.03E-06	7.81E-04	3.02E-06	3.02E-06	5.29E-05	1.39E-03	5.29E-05
ES_15	3.99E-06	7.75E-04	3.00E-06	3.00E-06	5.25E-05	1.38E-03	5.25E-05
ES_16	4.13E-06	8.01E-04	3.10E-06	3.10E-06	5.43E-05	1.43E-03	5.43E-05
ES_17	4.03E-06	7.81E-04	3.02E-06	3.02E-06	5.29E-05	1.39E-03	5.29E-05
ES_18P12	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_19P11	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_20P8	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_21P2	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_22P3	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_23B4	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_24B3	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_25B2	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_26B1	5.43E-06	1.05E-03	4.07E-06	4.07E-06	7.14E-05	1.88E-03	7.14E-05
ES_27P10	6.52E-06	1.26E-03	4.89E-06	4.89E-06	8.57E-05	2.25E-03	8.57E-05
ES_28P7	6.52E-06	1.26E-03	4.89E-06	4.89E-06	8.57E-05	2.25E-03	8.57E-05
ES_29P6	6.52E-06	1.26E-03	4.89E-06	4.89E-06	8.57E-05	2.25E-03	8.57E-05
ES_30P1	6.52E-06	1.26E-03	4.89E-06	4.89E-06	8.57E-05	2.25E-03	8.57E-05

Table 9-2 Maximum Ambient Impacts for Duke Energy Progress, LLC – Novo Nordisk

Pollutant	Averaging Period	Max. Conc. (μg/m ³)	AAL (µg/m ³)	% of AAL
Arsenic	Annual	3.92E-5	2.1E-3	2
Benzene	Annual	7.61E-3	1.2E-1	6
Beryllium	Annual	3.01E-5	4.1E-3	1
Cadmium	Annual	2.94E-5	5.5E-3	1
Chromium	24-hr	4.78E-3	6.2E-1	1
Formaldehyde	1-hr	1.02E-1	1.5E+2	<1
Mercury	24-hr	4.78E-3	4.78E-3	1

The emissions factors and methodology used to estimate emissions have been verified for the various pollutants by the North Carolina Department of Air Quality and were found to be satisfactory. Emissions factors are discussed in

Section 6 above. The first toxic dispersion modeling analysis was submitted on February 24, 2025, for the pollutants arsenic, benzene, beryllium metal (unreacted), cadmium metal (elemental unreacted), soluble chromate compounds, as chromium (VI) equivalent, formaldehyde, and mercury vapor. The toxics dispersion modeling analysis was reviewed and approved by the Air Quality Analysis Branch (AQAB) on March 26, 2025.

Given that the modeling analysis assumed each engine operating at its maximum design capacity for 500 hours per year and the predicted impacts are well below each TAPs AAL, the DAQ has found that the emissions from the exempt sources will not present an unacceptable risk to human health. Consistent with 15A NCAC 02Q .0702(a)(27)(B), the DAQ will not include in the air permit the approved air toxics emissions rates for the toxics-exempt emergency engines.

10. Other Considerations

Professional Engineer (PE) Seal Requirement

15A NCAC 02Q .0112 APPLICATIONS REQUIRING PROFESSIONAL ENGINEER SEAL

Pursuant to 15A NCAC 02Q .0112 "Application requiring a Professional Engineering Seal," specifically 02Q .0112(a), a professional engineer's seal (PE Seal) is required to seal technical portions of air permit applications for new sources and modifications of existing sources as defined in 15A NCAC 02Q .0103 that involve:

- (1) design;
- (2) determination of applicability and appropriateness; or
- (3) determination and interpretation of performance of air pollution capture and control systems.

This application does not involve the three criteria above with respect to air pollution capture and control systems. Hence no PE Seal is required.

Zoning Requirement

15A NCAC 02Q .0305(a)(1)(B) and .0304(b)(1)

The new greenfield facility requires a local zoning consistency determination. A zoning consistency determination request was emailed to the Town of Clayton and signed by Conrad Olmedo on March 26, 2025. The form indicated that a "Site plan still required for final Town approval for complete development". No further actions are required by the DAQ.

Fee

A Title V Greenfield fee of \$12,074 was required for this application and was received by the DAQ on November 27, 2024.

Number of Copies

The appropriate number of application copies were received by the DAQ.

11. Public Participation

This application is being processed at the Permittee's request pursuant to the "two step" significant modification procedures at 15A NCAC 02Q .0501(b)(2) and 02Q .0504. This application, "step one", is being processed pursuant to 15A NCAC 02Q .0504(a), under the "state only" permitting rules at 15A NCAC 02Q .0300. As such, no public notice or EPA review procedures pursuant to 02Q .0500 apply at this time.

However, this application has met the criteria for enhanced public outreach under the DEQ's Public Participation Plan (PPP) (See the following link: Environmental Justice | NC DEQ). Pursuant to 15A NCAC 02Q .0306(a)(1) "Permits Requiring Public Participation," the Director shall provide public notice for comments with an opportunity for the public to request a public hearing on draft permits for any source that may be designated by the Director based on public interest relevant to air quality.

The draft permit will be subject to a 30 day public comment period. A summary of the comments received and DAQ's responses will be included in the final version of this review document.

12. Recommendations

The Greenfield permit application for Duke Energy Progress, LLC – Novo Nordisk has been reviewed by DAQ to determine compliance with all procedures and requirements. DAQ has determined this facility is complying or will achieve compliance, as specified in the permit, with all requirements that are applicable to the affected sources. DAQ recommends the issuance of Air Permit No. 10859R00.

APPENDICES

"For the purposes of this subpart, the date that construction commences is the date the engine is ordered by the owner or operator."

Emission Source	Emission Source Description	Manufactured Dates	Construction Dates							
ID No.										
ES-1 through ES-7	Seven (7) No.2 fuel oil-fired emergency	2020	2020							
NSPS IIII	generator engines (917 horsepower									
MACT ZZZZ	engine output, 625-kilowatt generator									
	output, each)									
ES-8 through ES-	Four (4) No.2 fuel oil-fired emergency	2014	2014							
11	generator engines (917 horsepower									
NSPS-IIII	engine output, 600 kW generator									
MACT ZZZZ	output, each)									
ES-12	One (1) No.2 fuel oil-fired emergency	2002	2002							
MACT ZZZZ	generator engine (2,172 horsepower									
	engine, 1,500-kilowatt generator									
	output)									
ES-13	One (1) No.2 fuel oil-fired emergency	2002	2002							
MACT ZZZZ	generator engine (2,172 horsepower									
	engine, 1,500 kW generator output)									
ES-14	One (1) No. 2 fuel oil-fired emergency	4/12/2005	2006							
MACT ZZZZ	generator engine (2,520 horsepower									
	engine, 1,750 kW generator outputh)									
ES-15	One (1) No. 2 fuel oil-fired emergency	3/24/2006	2006							
MACT ZZZZ	generator engine (2,520 horsepower									
	engine, 1,750 kW generator output)									
ES-16	One (1) No.2 fuel oil-fired emergency	2019	2019							
NSPS-IIII	generator engine (2,584 horsepower									
MACT ZZZZ	engine, 1,750 kW generator output)									
ES-17	One (1) No.2 fuel oil-fired emergency	2005	2005							
MACT ZZZZ	generator engine (2,520 horsepower									
	engine, 1,800 kW generator output)									
ES-18 through	Nine (9) No.2 fuel oil-fired emergency	2025	2026							
EES-26	generator engine (3,399 horsepower									
NSPS-IIII	engine, 2,500 kW generator output,									
MACT ZZZZ	each)									
ES-27 through ES-	No.2 fuel oil-fired emergency generator	2025	2026							
30	engine (4,079 horsepower engine, 3,000									
NSPS-IIII	kW generator output, each)									
MACT ZZZZ										

Table Appendix-1

Table Appendix-2: DAQ PTE for NSPS IIII Engines (ES-1 through ES-11, ES-16, and ES-18 through ES-30)

Large Diesel and All Dual-Fuel Engines Emissions Calculator LGD2012 Revision J - 6/22/2015 Instructions: Please provide the information shown in blue below. The applicability of this spreadsheet is limited to diesel engines larger than 000 he and all dual-fuel (dieselinatural gas) engines. Please note hat, when used in conjunction with permit applications, any value entered for annual operations of these engines may become a permit limit.

For annual emissions enter either (1) Engine Output (hp) and Annual Operation (hours) or (2) Generator Output (kW) and Annual Operation (hours).

User Input		This section can be used to calculate kW-hr output from hours of operation and engine hp output. This can be useful for operators with hour meters but	from hours of operation and engine hp output.			
		no Watt-hour meters. It assumes full load operation resulting in conservative emission estimates.		responsibility to be aware of the most current information available. DENR is responsible for errors or omissions that may be contained herein.		
	10000	resulting in conservative emission estimates.				
Diesel Fuel Sulfur Content (%):	0.0015	Annual Operation (hours):	500			
NG Fuel Sulfur Content (gr/mm cu ft):	0					
Engine Output (hp):	57702	Generator Output (kW):				
Annual Electrical Output (kW-hr):	0	Annual Output (kW-hr):				
Annual Output (hp-hr):	28,851,000					

		Single G	enerator (1)			
Emissions Output for D	iesel Engines				Emission	Factor
Criteria Pollutants		T T			Factor	Quality
Dallatari	Ibhr Ibyr tpy Ibhp-hr 18.97 9,488.16 4.74 3.29E-04 18.97 9,488.16 4.74 3.29E-04 18.97 9,488.16 4.74 3.29E-04 18.97 9,488.16 4.74 3.29E-04 607.11 303,558.97 151.78 1.05E-02 40.88 20,339.96 10.17 7.05E-04 32.02 18,609.38 9.25 6.42E-04 32.02 186,007.72 8300 5.75E-03 0.70 350.11 0.18 121E-05 3.13E-01 156.72 0.078 5.43E-08 vtants CAS Number Ib/tr Ib/day Ib/tr			Rating		
Pollutant PM						Raung
PM		18.97	9,480.10	4./4	3.296-04	
PM-10		18.97	9,486,16	4.74	3.29E-04	
PM-2.5		18.97	9,486,16	4.74	3.29E-04	from NSPS IIII
		6. S.				
NO, uncont.		607.11	303,556.97	151.78	1.05E-02	from NSPS IIII
						from NSPS IIII
TOC (as CH ₄)		40.68	20 339 98	10 17	7.055-04	C
NMTOC						F
CO						from NSPS IIII
SO.						B
Total HAP						D
Largest HAP (benzene)						
Pollutant Acetaldehyde	CAS Number 75070				1.76E-07	#N/A
Acrolein	107028					#N/A
Arsenic unlisted compour	ASC-Other	1.6E-03	3.9E-02	8.08E-01	2.80E-08	E
Benzene	71432	3.1E-01	7.5E+00	1.57E+02	5.43E-06	#N/A
Benzo (a) pyrene	50328	1.0E-04	2.5E-03	5.19E-02	1.80E-09	#N/A
Beryllium metal (unreacte	7440417	1.2E-03	2.9E-02	6.06E-01	2.10E-08	E
Cadmium metal (element	7440439	1.2E-03	2.9E-02	6.06E-01	2.10E-08	E
Chromic Acid (VI)	7738945	1.2E-03	2.9E-02	6.06E-01	2.10E-08	E
Formaldehyde	50000	3.2E-02	7.6E-01	1.59E+01	5.52E-07	#N/A
Lead unlisted compounds		3.6E-03	8.7E-02	1.82E+00	6.30E-08	E
Manganese unlisted com		2.4E-03	5.8E-02	1.21E+00	4.20E-08	E
Mercury vapor	7439976	1.2E-03	2.9E-02	6.06E-01	2.10E-08	E
Napthalene	91203	5.3E-02	1.3E+00	2.63E+01	9.10E-07	#N/A
Nickel metal	7440020	1.2E-03	2.9E-02	6.06E-01	2.10E-08	E
Selenium compounds	SEC	6.1E-03	1.5E-01	3.03E+00	1.05E-07	#N/A
Total PAH Toluene	108883	8.6E-02 1.1E-01	2.1E+00 2.7E+00	4.28E+01 5.67E+01	1.48E-06 1.97E-06	E #N/A
	108883	1.1E-01 7.8E-02	2.7E+00 1.9E+00	5.6/E+01 3.90E+01	1.9/E-06 1.35E-06	#N/A #N/A
Xylenes	1330207	7.8E-02	1.9E+00	3.9UE+01	1.30E-06	#N/A
		methods consistent w			Emission	Factor
	but not with EP/	A Mandatory Reporting			Factor	Quality
	1		lb/yr	tpy	(lb/hp-hr)	Rating
			32,574,805,78	16,287.40	0.31	NA
Pollutant Carbon Dioxide (CO ₂)						
			45,764.90	22.88	0.0001	NA
Carbon Dioxide (CO ₂)			45,764.90 79,622.36	22.88 39.81	0.0001	NA

ote: Do not use greenhouse gas emission estimates from this spreadsheet for PSD (Prevention of Significant Deterioration) purposes.

Criteria Pollutants				
Pollutant		lb/hr	lb/yr	tpy
PM		18.97	9,486.16	4.74
PM-10		18.97	9,488.16	4.74
PM-2.5		18.97	9,486.16	4.74
NO ₂ , uncont.		607.11	303,556.97	151.78
TOC (as CH ₄)		40.68	20,339.96	10.17
NMTOC		37.02	18,509.36	9.25
co		332.02	166,007.72	83.0
SO,		0.70	350.11	0.1
Total HAP		0.71	354.03	0.1
Largest HAP (benzene)	82	0.31	156.72	0.0
Toxic/Hazardous Air Pollu Pollutant	CAS Number	lb/hr	lb/day	lb/yr
Acetaldehyde	75070	1.02E-02	2.44E-01	5.09E+0
Acrolein Arsenic unlisted compound	107028	3.18E-03 1.62E-03	7.64E-02 3.88E-02	1.59E+0 8.08E-0
Arsenic unlisted compound Benzene	71432	3.13E-01	3.88E-02 7.52E+00	1.57E+0
Benzo (a) pyrene	50328	1.04E-04	2.49E-03	5.19E-02
Beryllium metal (unreacted)		1.21E-03	2.91E-02	6.06E-01
Cadmium metal (elemental		1.21E-03	2.91E-02	6.06E-01
Chromic Acid (VI)	7738945	1.21E-03	2.91E-02	6.06E-0
Formaldehyde	50000	3.19E-02	7.65E-01	1.59E+01
Lead unlisted compounds	PBC-Other	3.64E-03	8.72E-02	1.82E+00
Manganese unlisted compo	MNC-Other	2.42E-03	5.82E-02	1.21E+00
Mercury vapor	7439976	1.21E-03	2.91E-02	6.06E-01
Napthalene	91203	5.25E-02	1.26E+00	2.63E+01
Nickel metal	7440020	1.21E-03	2.91E-02	6.06E-01
	SEC	6.06E-03	1.45E-01	3.03E+00
		8.56E-02	2.06E+00	4.28E+01
Selenium compounds Total PAH			2.72E+00	5.67E+0
	108883	1.13E-01 7.80E-02	1.87E+00	3.90E+0

Greenh	Emission Factor	Factor Quality			
Pollutant		lb/yr	tpy	(lb/hp-hr)	Rating
Carbon Dioxide (CO ₂)	99	32,574,805.78	16,287.40	0.31	NA
Methane (CH ₄)		45,764.90	22.88	0.0001	NA
Nitrous Oxide (N ₂ O)		79,622.36	39.81	0.00001	NA
	Total:	32,700,193.04	16,350.10	8.5	

Generators ES 1-7

NO, control is via ignition timing retard. Pollutants in red are federally regulated hazardous air pollutants (HAPs) only. All other toxio/hazardous air pollutants are regulated as both HAPs and TAPs. Factor quality ratings containing "<" indicate an AP-42 emission factor based on test results being below detection. Emission factors for oriteria pollutants are from AP-42 Chapter 3.4, Large Stationary Diesel and All Stationary Dual-fuel Engines (revised 10/96). Emission factors for arsenic, beryfium, cadmium, chromium, lead, manganese, mercury, nickel, and selenium are from AP-42 Chapter 1.3, Fuel Oli Combustion (revised 5/10). All other toxio/hazardous pollutants are from AP-42 Chapter 3.4, Large Stationary Diesel and All Stationary Dual-fuel Engines (revised 10/96). Emission factors for arsenic, beryfium, cadmium, chromium, lead, manganese, mercury, nickel, and selenium are from AP-42 Chapter 1.3, Fuel Oli Combustion (revised 5/10). All other toxio/hazardous pollutants are from AP-42 Chapter 3.4, Large Stationary Dias-Haud R1 Stationary Dual-fuel Engines (revised 10/96). Emission factors for green/house gases are from DAO's Green/house Gas Emission Guidelines: Stationary Combustion Sources, June 2008, except for CH4, which uses AP-42, Chapter 3.4, Large Stationary Dual-fuel Engines (revised 10/96). Cathon dioxide emission factor for dual-fuel engines is calculated based on offse functing as and 6% diesel, per AP-42 Chapter 3.4, p. 3.4-5 (revised 10/96). Hourly emission rates for all pollutants are based on the hourly fuel usage. Annual emissions are based on operation at the hourly input rate for 24 hours.	NCDENR
---	--------

Table Appendix-3: DAQ PTE for Non-NSPS IIII Engines (ES-12 through ES-15 and ES-16)

Instructional Disease provide the inference	obourp in black 1						ator LGD2012 Revision		ana pata			
Instructions: Please provide the information that, when used in conjunction with permit a	pplications, any v	alue entered for ann	nual operations of the	se engines may	become a permit	limit.		ai gas) engines. Ple	ase note			
For annual emissions enter either (1) Engine	e Output (hp) an	d Annual Operation	n (hours) or (2) Gener	ator Output (kW								
User Input							calculate kW-hr output	DISCLAIMER: Thi	s spreadsheet is	for your use only	ly and should	
Company Name:		Hot ICE Compan	У								not guarantee the readsheet is sub	
Plant County:		Wake						continual revision	and updating It	is your responsi	ibility to be	
Plant City:		Raleigh					umes full load operation		aware of the most			
Permit Number:		NA			resulting in cons	servative er	nission estimates.		responsible for err			
User:		V. Hot										
Diesel Fuel Sulfur Content (%):		0.00			Annual Operation	on (hours):		500				
NG Fuel Sulfur Content (gr/mm cu ft):		0						_				
Engine Output (hp):		11212			Generator Outp			0				
Annual Electrical Output (kW-hr):		0			Annual Output	(kW-hr):		0				
Annual Output (hp-hr): 5,606,000												
<u>Emissions Output for Diesel Engines</u> Criteria Pollutants					Emission Factor	Factor Quality	Emissions Output for I Criteria Pollutants	Dual-fuel Engines	2]	Emission Factor	Factor Quality
Pollutant		lb/hr	lb/yr	tpy	lb/hp-hr	Rating	Pollutant	lb/hr	lb/yr	tpy	(lb/hp-hr)	Rating
PM		7.85	3.924.20	<u>ψy</u> 1.96	7.00E-04	B	PM	NA	NA	NA	ND	NA
PM-10		7.85	3,924.20	1.96	7.00E-04		PM-10	NA	NA	NA	ND	NA
PM-2.5		7.85	3,924.20	1.96	7.00E-04		PM-2.5	NA	NA	NA	ND	NA
NO _x , uncont.		269.09	134,544.00	67.27	2.40E-02		NO _x , uncont.	201.82	100,908.00	50.45	1.80E-02	D
NO _x , cont.		145.76	72,878.00	36.44	1.30E-02		NO _x , cont.	NA	NA	NA	ND	NA
TOC (as CH ₄)		7.90	3,952.23	1.98	7.05E-04	С	TOC (as CH ₄)	59.31	29,655.74	14.83	5.29E-03	D
NMTOC		7.19	3,596.53	1.80	6.42E-04		NMTOC	14.80	7,399.92	3.70	1.32E-03	E
00		61.67	30,833.00	15.42	5.50E-03		CO	84.09	42,045.00	21.02	7.50E-03	D
SOx		0.14	68.03	0.03	1.21E-05	В	SOx	0.01	3.41	0.00	6.09E-07	В
Total HAP		1.38E-01	68.79	0.034	1.23E-05							
Largest HAP (benzene)		6.09E-02	30.45	0.015	5.43E-06							
Toxic/Hazardous Air Pollutants							There are no Toxic/Hazaro	dous Air Pollutant o	mission factors for du	al-fuel engines		
Pollutant	CAS Number	lb/hr	lb/day	lb/yr			more are no roxic/Fid2al0	adda Air Foiluidht ei	maaion ractors for du	ander engines.		
Acetaldehyde	75070	2.0E-03	4.7E-02	9.89E-01	1.76E-07	E						
Acrolein	107028	6.2E-03	1.5E-02	3.09E-01	5.52E-08							
Arsenic unlisted compounds	ASC-Other	3.1E-04	7.5E-03	1.57E-01	2.80E-08							
Benzene	71432	6.1E-02	1.5E+00	3.05E+01	5.43E-06							
Benzo (a) pyrene	50328	2.0E-05	4.8E-04	1.01E-02	1.80E-09							
Beryllium metal (unreacted)	7440417	2.4E-04	5.7E-03	1.18E-01	2.10E-08	È						
Cadmium metal (elemental unreacted)	7440439	2.4E-04	5.7E-03	1.18E-01	2.10E-08							
Chromic Acid (VI)	7738945	2.4E-04	5.7E-03	1.18E-01	2.10E-08							
Formaldehyde	50000	6.2E-03	1.5E-01	3.10E+00	5.52E-07	E						
Lead unlisted compounds	PBC-Other	7.1E-04	1.7E-02	3.53E-01	6.30E-08	E						
Manganese unlisted compounds	MNC-Other	4.7E-04	1.1E-02	2.35E-01	4.20E-08	E						
Mercury vapor	7439976	2.4E-04	5.7E-03	1.18E-01	2.10E-08							
Napthalene Nickel metal	91203 7440020	1.0E-02 2.4E-04	2.4E-01 5.7E-03	5.10E+00 1.18E-01	9.10E-07 2.10E-08	E						
Selenium compounds	SEC	2.4E-04 1.2E-03	2.8E-02	5.89E-01	2.10E-08 1.05E-07	E, <						
Total PAH		1.2E-03 1.7E-02	2.0E-02 4.0E-01	5.09E-01 8.32E+00	1.48E-06							
Toluene	108883	2.2E-02	5.3E-01	0.32E+00 1.10E+01	1.40E-06 1.97E-06							
Xylenes	1330207	1.5E-02	3.6E-01	7.57E+00	1.35E-06							
			0.02 01									
		ds consistent with atory Reporting R			Emission Factor	Factor Quality	Greenhouse Gases - r	methods consiste Mandatory Repo		not with EPA	Emission Factor	Factor Quality
Pollutant	Andrug	I I I I I I I I I I I I I I I I I I I	lb/yr	tpy	(lb/hp-hr)	Rating	Pollutant	lb/hr	lb/yr	tpy	(lb/hp-hr)	Rating
Carbon Dioxide (CO ₂)			6,329,567.82	φy 3,164.78	(ID/IIp-III) 0.31	NA	Carbon Dioxide (CO ₂)	10/111	4,677,852.03	2,338.93	0.23	NA
				-								
Methane (CH ₄)			8,892.52	4.45	0.0001	NA	Methane (CH ₄)		529,987.74	264.99	0.004	NA
Nitrous Oxide (N ₂ O)			15,471.32	7.74	0.00001	NA	Nitrous Oxide (N ₂ O)		15,471.32	7.74	0.00001	NA
		Total:		3,176.97				Total:	5,223,311.08	2,611.66		
Note: Do not use greenhouse gas emission es	stimates from this	spreadsheet for PSD	(Prevention of Signification	ant Deterioration) purposes.							
NO _x control is via ignition timing retard.												
Pollutants in red are federally regulated I	hazardous air p	ollutants (HAPs) or	alv All other toxic/b	azardous air p	ollutants are regu	ilated as br	th HAPs and TAPs				A	7A
Factor guality ratings containing "<" indic						allou do Du	anna a ann 170 a.					
Emission factors for criteria pollutants an						es (revised	10/96)					
Emission factors for arsenic, beryllium, c								ised 5/10).			NCDE	NR
All other toxic/hazardous pollutants are												
Emission factors for greenhouse gases a												
which uses AP-42, Chapter 3.4, Large S	stationary Diese	I and All Stationary	/ Dual-fuel Engines (revised 10/96								
which uses AP-42, Chapter 3.4, Large S Carbon dioxide emission factor for dual-	fuel engines is o	alculated based or	n 95% natural gas ar	nd 5% diesel, p	per AP-42 Chapte	er 3.4, p. 3.	4-5 (revised 10/96).					
which uses AP-42, Chapter 3.4, Large S	fuel engines is o re based on the	alculated based or hourly fuel usage.	n 95% natural gas ar Annual emissions a	nd 5% diesel, p	per AP-42 Chapte	er 3.4, p. 3. age.	4-5 (revised 10/96).					

Table Appendix-4: DA	AO Total PTE for TAI	PS for engines ES-1	through ES-30
Tuble ippendin it bi	TY TOWNT THE TOT THE	S IOI engines ES I	un ougn Lo oo

Toxic/Hazardous Air Pollutants		Total	for ES-1 through	ES-30
Pollutant	CAS Number	lb/hr	lb/day	lb/yr
Acetaldehyde	75070	0.0128	0.31	6.39
Acrolein	107028	0.0040	0.10	2.00
Arsenic unlisted compounds	ASC-Other	0.0020	0.05	1.01
Benzene	71432	0.3933	9.44	196.64
Benzo (a) pyrene	50328	0.0001	0.00	0.07
Beryllium metal (unreacted)	7440417	0.0015	0.04	0.76
Cadmium metal (elemental unreacte	7440439	0.0015	0.04	0.76
Chromic Acid (VI)	7738945	0.0015	0.04	0.76
Formaldehyde	50000	0.0400	0.96	19.99
Lead unlisted compounds	PBC-Other	0.0046	0.11	2.28
Manganese unlisted compounds	MNC-Other	0.0030	0.07	1.52
Mercury vapor	7439976	0.0015	0.04	0.76
Napthalene	91203	0.0659	1.58	32.94
Nickel metal	7440020	0.0015	0.04	0.76
Selenium compounds	SEC	0.0076	0.17	3.80
Total PAH		0.1074	2.5786	53.72
Toluene	108883	0.1424	3.42	71.20
Xylenes	1330207	0.0978	2.35	48.91

Table Appendix-5: Duke Energy PTE for ES-1 through ES-30

Criteria Compounds:	tpy	tpy								
TSP	0.45	0.67	0.31	0.20	0.20	0.11	0.11	0.07	0.07	2.19
PM-10	0.45	0.67	0.31	0.20	0.20	0.11	0.11	0.07	0.07	2.19
PM-2.5	0.45	0.67	0.31	0.20	0.20	0.11	0.11	0.07	0.07	2.19
SO2	0.04	0.08	0.03	0.01	0.01	0.01	0.01	0.01	0.01	0.19
NOX	50.63	89.70	22.80	8.14	8.14	14.65	14.65	10.71	7.33	226.74
VOC	0.36	1.69	0.45	0.49	0.49	0.06	0.06	0.28	0.17	4.03
co	5.93	7.08	Saved to this I	PC 1.80	1.80	1.96	1.96	0.13	0.74	23.05
Metal Compounds:	lb/yr	lb/yr								
Antimony										, , .
Arsenic	2.28E-01	4.28E-01	3.24E-02	3.04E-02	3.04E-02	3.53E-02	3.53E-02	3.50E-02	3.62E-02	0.89
Barium										0.00
Beryllium	1.71E-01	3.21E-01	2.43E-02	2.28E-02	2.28E-02	2.65E-02	2.65E-02	2.62E-02	2.71E-02	0.67
Cadmium	1.71E-01	3.21E-01	2.43E-02	2.28E-02	2.28E-02	2.65E-02	2.65E-02	2.62E-02	2.71E-02	0.67
Chromium (Total)	1.71E-01	3.21E-01	2.43E-02	2.28E-02	2.28E-02	2.65E-02	2.65E-02	2.62E-02	2.71E-02	0.67
Chromium VI										0.00
Cobalt										0.00
Copper	3.43E-01	6.42E-01	4.86E-02	4.55E-02	4.56E-02	5.29E-02	5.29E-02	5.25E-02	5.43E-02	1.34
Lead	5.14E-01	9.64E-01	7.29E-02	6.83E-02	6.84E-02	7.94E-02	7.94E-02	7.87E-02	8.14E-02	2.01
Manganese	3.43E-01	6.42E-01	4.86E-02	4.55E-02	4.56E-02	5.29E-02	5.29E-02	5.25E-02	5.43E-02	1.34
Mercury	1.71E-01	3.21E-01	2.43E-02	2.28E-02	2.28E-02	2.65E-02	2.65E-02	2.62E-02	2.71E-02	0.67
Molybdenum										0.00
Nickel	1.71E-01	3.21E-01	2.43E-02	2.28E-02	2.28E-02	2.65E-02	2.65E-02	2.62E-02	2.71E-02	0.67
Selenium	8.57E-01	1.61E+00	1.21E-01	1.14E-01	1.14E-01	1.32E-01	1.32E-01	1.31E-01	1.36E-01	3.34
Zinc	2.28E-01	4.28E-01	3.24E-02	3.04E-02	3.04E-02	3.53E-02	3.53E-02	3.50E-02	3.62E-02	0.89
Organic Compounds:	lb/yr	lb/yr								
Acetaldehyde	1.44E+00	2.70E+00	2.04E-01	1.91E-01	1.92E-01	2.22E-01	2.22E-01	2.20E-01	2.28E-01	5.62
Acetophenone										
Acrolein	4.50E-01	8.44E-01	6.38E-02	5.98E-02	5.99E-02	6.95E-02	6.95E-02	6.89E-02	7.13E-02	1.76
Benzene	4.43E+01	8.31E+01	6.29E+00	5.89E+00	5.90E+00	6.84E+00	6.84E+00	6.79E+00	7.02E+00	172.97
Benzidine										
Formaldehyde	4.51E+00	8.45E+00	6.39E-01	5.99E-01	6.00E-01	6.96E-01	6.96E-01	6.90E-01	7.14E-01	17.59
Naphthalene	7.42E+00	1.39E+01	1.05E+00	9.86E-01	9.88E-01	1.15E+00	1.15E+00	1.14E+00	1.18E+00	28.98
Toluene	1.60E+01	3.01E+01	2.28E+00	2.13E+00	2.14E+00	2.48E+00	2.48E+00	2.46E+00	2.54E+00	62.63
Xylenes	1.10E+01	2.07E+01	1.56E+00	1.46E+00	1.47E+00	1.70E+00	1.70E+00	1.69E+00	1.75E+00	43.02
Polycyclic Organic Matter/PAH:	lb/yr	lb/yr								
Acenaphthene	2.67E-01	5.01E-01	3.79E-02	3.55E-02	3.56E-02	4.13E-02	4.13E-02	4.09E-02	4.23E-02	1.04
Acenaphthylene	5.27E-01	9.88E-01	7.48E-02	7.00E-02	7.02E-02	8.14E-02	8.14E-02	8.07E-02	8.35E-02	2.06
Anthracene	7.02E-02	1.32E-01	9.96E-03	9.33E-03	9.35E-03	1.08E-02	1.08E-02	1.08E-02	1.11E-02	0.27
Benz(a)anthracene	3.55E-02	6.66E-02	5.04E-03	4.72E-03	4.73E-03	5.49E-03	5.49E-03	5.44E-03	5.63E-03	0.14
Benzo(b)fluoranthene	6.34E-02	1.19E-01	8.99E-03	8.42E-03	8.44E-03	9.79E-03	9.79E-03	9.71E-03	1.00E-02	0.25
Benzo(k)fluoranthene	1.24E-02	2.33E-02	1.77E-03	1.65E-03	1.66E-03	1.92E-03	1.92E-03	1.91E-03	1.97E-03	0.05
Benzo(g,h,i)perylene	3.17E-02	5.95E-02	4.50E-03	4.22E-03	4.23E-03	4.90E-03	4.90E-03	4.86E-03	5.03E-03	0.12
Benzo(a)pyrene	1.47E-02	2.75E-02	2.08E-03	1.95E-03	1.95E-03	2.27E-03	2.27E-03	2.25E-03	2.32E-03	0.06
Chrysene	8.74E-02	1.64E-01	1.24E-02	1.16E-02	1.16E-02	1.35E-02	1.35E-02	1.34E-02	1.38E-02	0.34
Dibenzo(a,h)anthracene	1.98E-02	3.70E-02	2.80E-03	2.63E-03	2.63E-03	3.05E-03	3.05E-03	3.03E-03	3.13E-03	0.08
Fluoranthene	2.30E-01	4.31E-01	3.26E-02	3.06E-02	3.06E-02	3.55E-02	3.55E-02	3.52E-02	3.64E-02	0.90
Fluorene	7.31E-01	1.37E+00	1.04E-01	9.71E-02	9.73E-02	1.13E-01	1.13E-01	1.12E-01	1.16E-01	2.85
Indeno(1,2,3-cd)pyrene	2.36E-02	4.43E-02	3.35E-03	3.14E-03	3.15E-03	3.65E-03	3.65E-03	3.62E-03	3.74E-03	0.09
manner 1,2,5 cupprone	7.42E+00	1.39E+01	1.05E+00	9.86E-01	9.88E-01	1.15E+00	1.15E+00	1.14E+00	1.18E+00	28.98
Naphthalene				0.002 01						
	2 33E+00	4 37E+00	3 30E-01	3 10E-01	3 10E-01	3 60E-01	3 60E-01	3 57E-01	3 69E-01	9.09
Phenanthrene	2.33E+00 2.12E-01	4.37E+00	3.30E-01 3.01E-02	3.10E-01 2.82E-02	3.10E-01 2.82E-02	3.60E-01	3.60E-01	3.57E-01	3.69E-01	9.09
Naphthalene Phenanthrene Pyrene Total POM/PAH	2.33E+00 2.12E-01 1.21E+01	4.37E+00 3.97E-01 2.27E+01	3.30E-01 3.01E-02 1.72E+00	3.10E-01 2.82E-02 1.61E+00	3.10E-01 2.82E-02 1.61E+00	3.60E-01 3.27E-02 1.87E+00	3.60E-01 3.27E-02 1.87E+00	3.57E-01 3.24E-02 1.85E+00	3.69E-01 3.36E-02 1.92E+00	9.09 0.83 47.25