



Ditch Spacing For 12 Inch Silt Sock/Wattle	
Channel Slope (%)	Space Between Silt Socks/ Wattles (Feet)
1	100
2	50
3	33
4	25
5	20

**NOTES:**

1. Other materials providing equivalent protection against erosive velocities may be substituted for use in silt socks or wattles.
2. Use a minimum 12 inch diameter silt sock/wattle.
3. Fill silt sock/wattle netting uniformly to the desired length such that logs do not deform.
4. Use 24 inch long wooden stakes with a 2 inch x 2 inch nominal cross section.
5. Install silt sock/wattle(s) to a height on slope so flow will not wash around silt sock/wattle and scour slopes, or as directed.
6. Install a minimum of two upslope stakes and four downslope stakes at an angle to wedge silt sock/wattle to ground at bottom ditch.
7. The use of Polyacrylamide (PAM) is recommended. Apply 2-3 ounces of anionic PAM on top of sock/wattle. Apply 1-2 ounces to matting on either side of sock/wattle. Reapply after each 1.0 inch rainfall.

**MAINTENANCE:**

1. Inspect silt sock/wattle(s) weekly and after each rain of 1 inch or greater. Remove accumulated sediment and any debris.
2. Silt sock/Wattle(s) must be replaced if clogged or torn.
3. If ponding becomes excessive, the silt sock/wattle may need to be replaced with a larger diameter or a different measure.
4. Reinstall if damaged or dislodged.
5. Silt socks/Wattles shall be inspected until land disturbance is complete and the area above the measure is permanently stabilized.

