## **Determination of Minor Construction Activity**

## North Carolina Division of Water Infrastructure

Project Applicant: Greenville Utilities Commission

Date: August 28, 2014
Project Number: CS370487-11
Estimated Project Cost: \$3,519,000
Estimated Funding Amount: \$3,450,000

Project Description: The proposed project will make repairs and improvements to the Southside Pump Station. Planned improvements include the following: (1) in-place replacement of the existing junction box with a 12-foot by 16-foot by 28-foot junction box, including bypass pumping and site piping modifications as required to connect existing sewer mains and proposed equipment (bar screen and odor control); (2) 40 million gallons per day (MGD) design-flow bar screen consisting of two 20 MGD screens (one per channel) and one bypass channel, along with associated piping; (3) 5,000 standard cubic feet per minute odor control system for the proposed junction box and the proposed bar screen structure; and (4) site improvements to address safety and operational hazards resulting from drainage issues.

The above named applicant intends to apply for assistance from the State Revolving Fund program to construct the wastewater facilities described above. The North Carolina Division of Water Infrastructure (DWI) has conducted a review of the project in accordance with the procedures (NCAC 15A Subchapter 1C) for conformance with the North Carolina Environmental Policy Act. The DWI has determined that this project is below the minor construction activities threshold outlined in 15A NCAC 01C .0408; therefore, the project is exempt from inter-agency review, and the preparation of additional environmental documents is not required.

This determination shall become effective upon its distribution by DWI and will be available on the DWI's website (<a href="http://portal.ncdenr.org/web/wq/ifs/er/fonsis">http://portal.ncdenr.org/web/wq/ifs/er/fonsis</a>). This determination can be revoked at any time adverse information is made available. The documentation to support this decision will be on file with the North Carolina Department of Environment and Natural Resources, Division of Water Infrastructure, and is available for public scrutiny upon request.

Comments concerning this decision may be addressed to Ms. Jennifer Haynie, Environment and Special Projects Unit, Division of Water Infrastructure, 1633 Mail Service Center, Raleigh, North Carolina 27699, or she can be reached by phone at (919) 707-9173.

Sincerely,

Kim H. Colson, P.E., Director Division of Water Infrastructure