

Underground Storage Tanks (USTs) Public Record - Summary Information

General Information

Public Record Posted Date: 1/26/2026

Total Number Of Active UST Facilities: 7,139
 Total Number Of USTs: 23,395

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 2,080
 Inspection Period Dates: 10/1/2024 To: 9/30/2025
 Percent Compliance (Combined Measure): 59%

Summary Information For Releases

Number Of Confirmed UST Releases: 169
 Release Reporting Period Dates 10/1/2024 To: 9/30/2025

Summary Information For Release Sources And Causes

| Source | | | Cause | | | | | | | | | | | | | | |
|------------------|-----|------|-------|-----|----------|----|-----------|-----|------------------|-----|-----------------|----|-------|----|---------|-----|---|
| | | | Spill | | Overfill | | Corrosion | | Phys/Mech Damage | | Install Problem | | Other | | Unknown | | |
| | # | % | # | # | % | # | % | # | % | # | % | # | % | # | % | # | % |
| Tank | 97 | 57% | 32 | 19% | 0 | 0% | 24 | 14% | 3 | 2% | 0 | 0% | 1 | 1% | 37 | 22% | |
| Piping | 8 | 5% | 1 | 1% | 0 | 0% | 1 | 1% | 3 | 3% | 0 | 0% | | 0% | 3 | 2% | |
| Dispenser | 21 | 12% | 2 | 1% | 0 | 0% | 1 | 1% | 6 | 4% | 0 | 0% | 1 | 1% | 11 | 7% | |
| STP** | 4 | 2% | 0 | 0% | 0 | 0% | 0 | 0% | | 0% | 0 | 0% | | 0% | 4 | 2% | |
| Delivery Problem | 0 | 0% | 0 | 0% | 0 | 0% | 0 | 0% | | 0% | 0 | 0% | | 0% | 0 | 0% | |
| Other | 15 | 9% | 9 | 5% | 0 | 0% | 0 | 0% | 2 | 1% | 0 | 0% | | 0% | 4 | 2% | |
| Unknown | 24 | 14% | 0 | 0% | 0 | 0% | 0 | 0% | | 0% | 0 | 0% | 1 | 1% | 23 | 14% | |
| Totals | 169 | 100% | 44 | 26% | 0 | 0% | 26 | 15% | 14 | 10% | 0 | 0% | 3 | 2% | 82 | 49% | |

*Additionally, there were 203 confirmed releases from non-regulated USTs, primarily heating oil tanks. There are also 250 confirmed releases from non-usts during the reporting period.

**STP - Submersible Turbine Pump

To obtain site-specific information on UST releases contact the Regional DEQ Office for the county in which the release occurred. To obtain UST compliance information contact the UST Section Central Office, Permits and Inspection Branch