



NORTH CAROLINA
Environmental Quality

ROY COOPER

Governor

MICHAEL S. REGAN

Secretary

MICHAEL SCOTT

Director

February 15, 2019

Danny Brevard
Ac'cent Corporate Offices
PO Box 3289
Lufkin, TX 75903-3289

Re: Dri-sump™ testing method

Dear Mr. Brevard:

The North Carolina Department of Environmental Quality (NCDEQ) – Underground Storage Tank (UST) Section has reviewed the Dri-sump™ testing method and third-party certification. Based on a review of Title 15A North Carolina Administrative Code, Subchapter 2N “Criteria and Standards Applicable to Underground Storage Tanks” (15A NCAC 2N), we have concluded that the Dri-sump™ integrity testing method is an acceptable method of testing single wall and double-wall spill buckets and containment sumps to meet the triennial integrity testing requirements listed in the regulation. Testing companies using this method must use the applicable page of the NC DEQ UST-23A, *Triennial UST Spill Bucket Integrity Testing*, and/or UST-23B, *Triennial UST Containment Sump/UDC Integrity Testing*, form (<https://deq.nc.gov/about/divisions/waste-management/ust/forms>) to document the test results.

If you have any questions, please contact me at the letterhead address, (919) 707-8299 or ruth.strauss@ncdenr.gov.

Sincerely,

Ruth Strauss, Permits and Inspection Branch Head
Division of Waste Management, NC DEQ

cc: Files



North Carolina Department of Environmental Quality | Division of Waste Management
217 West Jones Street | 1646 Mail Service Center | Raleigh, North Carolina 27699-1646
919.707.8171