



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Michael Phelps
Environmental Supervisor
Michael.phelps@deq.nc.gov
(336)406-5003

Michael,

~18,000 Gallon GLASTEEL II Underground Storage Tank
(120" OD x 31'-2")

Annular Space: 5.0 Gallons

3" Monitoring Tube: 3 Gallons

Total: 8.0 Gallons

Per Ken Wilcox Report: 1-2012

Test: $(8.0 \text{ gallons} / 5.0 \text{ Gallons}) \times 11.0 = 17 \text{ Hours \& 45 minutes}$ of test
time required.