



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Michael Phelps
Environmental Supervisor
Michael.phelps@deq.nc.gov
(336)406-5003

Michael,

~19,400 Gallon GLASTEEL II Underground Storage Tank
(126" OD x 30'-0")

Annular Space: 5.2 Gallons

3" Monitoring Tube: 3.3 Gallons

Total: 8.5 Gallons

Per Ken Wilcox Report: 1-2012

Test: (8.5 gallons/ 5.0 Gallons) x 11.0 = 19.0 Hours of test time required.

Hours of test time required.

Murray Hiller
VP/ Plant Manager
Mhiller@modweldco.com
(706) 421-1387
(706) 564-5677