



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Michael Phelps
Environmental Supervisor
Michael.phelps@deq.nc.gov
(336)406-5003

Michael,

~26,000 Gallon GLASTEEL II Underground Storage Tank
(126" OD x 40'-6")

Annular Space: 6.3 Gallons

3" Monitoring Tube: 3.3 Gallons

Total: 9.3 Gallons

Per Ken Wilcox Report: 1-2012

Test: $(9.6 \text{ gallons} / 5.0 \text{ Gallons}) \times 11.0 = 21.5 \text{ Hours of test time required.}$