



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Matt Wagner
Environmental Engineer
matt.wagner@ncdenr.gov
(919)707-8163

DEC. 1ST 2020

Matt,

We have run the calculations per your request for STOP N GO #5 1900 E.
Williams St. 27359 Per the KWC report the calculations are as follows:

~30,000 Gallon GLASTEEL II Underground Storage Tank
(120" OD x 51'-9")

Annular Space: 8.9 Gallons

3" Monitoring Tube: 3 Gallons

Total: 11.30 Gallons

Per Ken Wilcox Report: 1-2012

Test: $(10.90 \text{ gallons} / 5.0 \text{ Gallons}) \times 11.0 = 26.0$ Hours of test time
required.

R. Murray Hiller
Atmospheric Tank Dept.
Mhiller@modweldco.com
(706) 421-1384
(706) 564-5677