



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Matt Wegner
Environmental Engineer
Mattwegner@ncdenr.gov
(919)707-8163

Matt,

We have ran the calculations per you request for SAM'S MART #106 4235
Providence Rd. Charlotte, NC. Per the KWC report the calculations are as follows:

4,000 Gallon GLASTEEL II Underground Storage Tank
(96" OD x 11'-1")

Annular Space : 2 Gallons

3" Monitoring Tube: 3 Gallons

Total : 5 Gallons

Per Ken Wilcox Report: 1-2012

Test: (5 gallons/ 5.0 Gallons) x 11.0 = ~11.0 Hours of test time required.

R. Murray Hiller
Atmospheric Tank Dept.
Mhiller@modweldco.com
(706) 421-1384
(706) 564-5677