



Modern Welding Company of Georgia, Inc.
300 Prep Phillips Drive
Augusta, GA 30901
Fabricators of Quality Metal Products for Over 75 Years!
706-722-3411; Fax: 706-724-8133

Matt Wegner
Environmental Engineer
Mattwegner@ncdenr.gov
(919)707-8163

Matt,

We have ran the calculations per you request for Breeze Thru40374 NC HWY 12, Avon, NC. 27915(0-021113). Per the KWC report the calculations are as follows:

7,500 Gallon GLASTEEL II Underground Storage Tank
(72" OD x35'-10")

Annular Space : 4 Gallons

3" Monitoring Tube: 2 Gallons

Total : 6 Gallons

Per Ken Wilcox Report: 1-2012

Test: (6 gallons/ 5.0 Gallons) x 11.0 = 13.2 Hours of test time required.

R. Murray Hiller
Atmospheric Tank Dept.
Mhiller@modweldco.com
(706) 421-1384
(706) 564-5677