

Agenda Item H-3. Drinking Water Applications: Project Descriptions

Blue rows = proposed full or partial funding in the scenario [preliminary]

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
1	Yes	No	299336	Aqua North Carolina, Inc.	Cumberland	No	14,021	0	NA	Brookwood Community Well #11 Rehab	Install a radium removal system to address radium contamination exceeding the MCL.	No	Ardurra Group North Carolina	\$998,500	\$998,500	71	71	
2	Yes	No	299342	Aqua North Carolina, Inc.	Cumberland	No	14,021	0	NA	Brookwood Community Well #19 Rehab	Install a radium removal system for well #19 in the Brookwood Community.	No	Ardurra Group North Carolina	\$998,500	\$998,500	71	71	
3	Yes	No	299354	Milton, Town of	Caswell	Yes	97	2	\$2,351,800	Milton DeW- Water for Tomorrow	Replace 11 water meters, approximately 5,750 LF of waterline, and well pump. Repair elevated tank repair. Install 2 new generators.	Yes	Piedmont Triad Regional Council	\$4,703,600	\$4,703,600	63	66	3.A.2.Lost 2 points due to award of 3.A.1.
4	Yes	No	298613	Elm City, Town of	Wilson	Yes	608	0	NA	DW THM Removal System Project	Install TTHM removal system at elevated tank structure.	Yes	Mack Gay Associates	\$1,460,628	\$1,460,628	79	58	1.C.1. Lost 8 points due to insufficient documentation. 2.E.2. Lost 3 points due to award of 2.E.1. 3.A. Lost 10 points due to insufficient narrative. 4.C.4. Lost 5 points due to insufficient narrative.
5	Yes	No	299468	Spring Lake, Town of	Cumberland	Yes	3,877	0	NA	Drinking Water System Improvements	Replace approximately 6,000 LF of 6-in deteriorating water mains with new C-900 PVC in the Mack Street area and inoperable valves and adding new valves to improve isolation of the distribution system.	No	McGill Associates	\$1,554,750	\$1,554,750	58	57	2.J. Lost 3 points due to insufficient documentation. 3.A.2. Lost 2 points due to award of 3.A.1. 3.B. Awarded 5 points due to data provided in application.
6	No	Yes	275625	Seaboard, Town of	Northampton	Yes	276	0	NA	2025 Water System Improvements	Replace pre-WWII era 75,000-galon riveted water tank at location 1200 feet north of existing tank.	Yes	McDavid Associates, Inc.	\$2,500,000	\$2,500,000	60	56	3.D. Lost 10 points due to lack of adequate leak detection program. 4.C.4. Lost 5 points due to area including entire service area rather than subsections.
7	Yes	No	298466	Pilot Mountain, Town of	Surry	Yes	1,025	0	NA	Pilot Mtn Water Line Replacement	Replace approximately 8,079 LF of 2-inch, 6-inch, and 10-inch cast iron and asbestos cement water lines; (2) valves, hydrants, and associated service reconnections; and (3) approximately 42 broken water meters in the areas where waterlines are to be replaced. Construct new SCADA for the Pilot Center water tank and install cybersecurity for the distribution system's existing SCADA.	No	WithersRavenel, Inc.	\$5,099,796	\$4,999,800	58	55	2.J. Lost 3 points as Water audit data do not match with LWSP data. 3.A.2. Lost 2 points due to award of 3.A.1.
8	Yes	No	299441	TriRiver Water	Lee	No	2,512	0	NA	Sanford-Pittsboro Water Transmission	Costruct 55,800 LF of 36-inch waterline and an 8 MGD pump station with 2 1 MG ground storage tanks.	No	Freese & Nichols, Inc.	\$101,189,060	\$25,000,000	64	51	2.F.1. Lost 10 points as 2 years has passed since the merger date 2.T. Lost 3 points as new equipment requiring back up power is not eligible
9	No	No	298843	Seaboard, Town of	Northampton	Yes	276	0	NA	Water Treatment Plant Improvements	Replace approximately 2,400 LF of galvanized and cast iron waterlines and filter media (sand to greensand) at the WTP to improve iron removal efficiency and backwash/regeneration cycles.	Yes	McDavid Associates, Inc.	\$776,000	\$776,000	57	50	3.A.2. Lost 2 points due to insufficient documentation. 3.C. Lost 5 points due to insufficient documentation. 3.D. Lost 5 points due to insufficient documentation.
10	Yes	No	299517	Nash County	Nash	Yes	1,302	300	\$45,691	Northern Nash Water System Phase 3	Extend water main with approximately 85,420 LF of new water main and associated appurtenances to connect residences in disadvantaged and underserved communities. Install 2 new 100-gpm groundwater wells at 2 different sites. Install approximately 300 new water service connections will be added to the system.	No	The Wooten Company	\$13,707,370	\$13,707,370	49	49	

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
11	Yes	No	298321	Graham, City of	Alamance	No	6,384	0	NA	Graham-Mebane WTP Reliability	Install new air scour system for solids management, a new backwash line and a new electrical distribution system out of the 500 year flood plain after Tropical Storm Chantal. Rehabilitate a corrosion inhibitor feed system.	No	Hazen and Sawyer	\$28,028,000	\$28,028,000	51	48	2.I. Lost 3 points due to insufficient documentation.
12	Yes	No	299385	Newport, Town of	Carteret	Yes	1,920	0	NA	WTP Improvements- Replacement Water Plant	Replace WTP, Well No. 3. Install approximately 2,000 LF of 8-inch raw water line to connect existing Well No. 6 to the WTP.	No	The East Group	\$13,420,000	\$13,420,000	63	48	2.D. Lost 10 points due to the ineligibility of PFAS construction study & construction projects to receive these points. 2.H.4 Lost 5 points due to insufficient documentation.
13	No	No	299303	Whitakers, Town of	Nash	Yes	325	0	NA	Cast Iron Waterline Replacement	Replace approximately 9,100 LF of 6-inch cast iron water lines.	Yes	McDavid Associates, Inc.	\$1,450,000	\$1,450,000	55	48	3.A.2. Lost 2 points due to insufficient documentation. 3.D. Lost 5 points due to insufficient documentation.
14	Yes	No	299499	East Bend, Town of	Yadkin	Yes	396	0	NA	Flowing Forward: East Bend DW Upgrades	Replace 12,362 LF of water service lines, of which 10,019 are made of asbestos cement and 567 water meters with AMR.	Yes	Piedmont Triad Regional Council	\$4,980,455	\$4,980,455	59	48	#REF!
15	Yes	No	299513	Carolina Water Service of North Carolina	Gaston	No	36,646	0	NA	Beechbrook Water Main Replacement	Replace 4,000 LF of 4-inch water main, 900 LF of 3-inch water main and 900 LF of 2-inch water main.	No	Kimley-Horn and Associates, Inc.	\$1,677,918	\$1,677,918	48	48	#REF!
16	No	No	299346	Aqua North Carolina, Inc.	Warren	No	67,745	0	NA	Mill Creek Landing Waterline Rehab	Replace approximately 7,800 LF of 2 and 4-inch waterline with 2-, 4-, and 6-inch waterline.	No	Ardurra Group North Carolina	\$2,107,000	\$2,107,000	47	47	
17	Yes	No	298765	TriRiver Water (applied as Siler City, Town of)	Chatham	No	3,478	0	NA	Siler City PFAS Treatment Construction	Install GAC facility that includes 6 pressure vessel contactors, GAC waste equilization tank and backwash storage.	No	Hazen and Sawyer	\$23,722,800	\$23,722,800	47/47	47	
18	No	No	299477	Robersonville, Town of	Martin	Yes	741	0	NA	2026 Water System Improvements	Replace approximately 5,000 LF of 2-in and 6-in cast iron water lines with new 6-in water lines along Broad Street, Green Street, Margaret Street, Main Street, and Academy Street and applicable service connections replacements.	Yes	The Wooten Company	\$1,608,800	\$1,608,800	52	46	3.A.2. Lost 2 points due to insufficient documentation.
19	No	No	298789	Goldsboro, City of	Wayne	Yes	12,276	0	NA	PFAS Treatment Improvement Project	Improve post-filter treatment by addressing PFAS, including pump station upgrades to provide capacity and pressure to contactor vessels and associated piping.	No	CDM Smith	\$65,264,000	\$65,264,000	49/43	46	2.T. Lost 3 points due to not meeting requirements of guidance.
20	Yes	Yes	275440	South Granville Water & Sewer Authority	Granville	No	5,275	0	NA	Post-Filter PFAS Treatment Improvements	Design and construct post-filter PFAS treatment improvements, including pressure contact vessels, GAC/IX pressure contractors and media, a pump station to pump filtered water to contactors, yard piping to convey filtered water, and electrical instrumentation and controls for operation of the new equipment.	No	CDM Smith	\$26,793,000	\$21,868,000	48	45	2.T. Lost 3 points due to not meeting requirements of guidance.
21	No	No	299299	Tryon, Town of	Polk	Yes	2,017	0	NA	2027 Water System Improvements	Rehabilitate raw water pump station;replace 200,000-gallon concrete clearwell at WTP; install new additional backwater pump and building at WTP; rehabilitate booster pump station	Yes	Summit Engineering Group of NC, Inc.	\$4,503,700	\$4,463,700	44	44	
22	No	Yes	275649	Fayetteville Public Works Commission	Cumberland	No	91,740	0	NA	PWC PO Hoffer GL GAC	Design and construct new post-filtration GAC units at both the Hoffer WTP and the Glenville Lake WTP for PFAS removal.	No	Fayetteville Public Works Commission	\$146,312,600	\$62,380,000	43	43	

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
23	No	Yes	275904	Hendersonville, City of	Henderson	No	29,200	0	NA	WTF Sludge Transfer & Bwash Pump Upgrade	Upgrade to sludge transfer and backwash systems to improve energy efficiency and resiliency at WTP. Construct new backwash pump building with new backwash system pump to replace current with redundant back-up pump and replace existing sludge transfer pump with dry-pit submersible pump (same capacity) withaddition of back-up pump in same location.	No	McKim & Creed, Inc.	\$7,022,992	\$7,022,992	42	42	
24	No	No	299518	Carolina Water Service of North Carolina	Craven	No	36,646	0	NA	Fairfield Harbour - WM Leak Detect/Repl.	Conduct a system-wide leak detection study; complete a targeted replacement of water mains by installing new water mains and valves.	No	Kimley-Horn and Associates, Inc.	\$16,112,766	\$16,112,766	55	42	2.J. Lost 3 points due to not enough unaccounted for water. 3.A.1. Lost 10 points due to insufficient narrative and CIP. 3.A.2. Lost 2 points due to insufficient CIP. 3.D. Lost 5 points due to insufficient documentation.
25	No	No	299139	Grifton, Town of	Lenoir	Yes	1,328	0	NA	2026 Water System Improvements	Replace approximately 4,350 LR of existing 2-inch galvanized iron with new 6-inch PVC and replace approximately 2,900 LF of existing 6-inch cast iron with new 6-inch PVC .	No	The Wooten Company	\$3,696,000	\$3,696,000	47	42	
26	No	No	299350	Roanoke Rapids Sanitary District	Halifax	No	8,082	0	NA	Drinking Water EC Construction Project	Install post-filter GAC facility, including intermediate pump station and multiple gravity contactors.	No	Hazen and Sawyer	\$49,739,000	\$41,739,000	41/41	41	
27	No	Yes	275675	Fayetteville Public Works Commission	Cumberland	No	91,740	0	NA	PO Hoffer WTF Phase 3 Residuals	Construct new dewatering facility using belt filter press technology, a loadout and storage area, polymer and feed systems, and the addition of a third 100-ft gravity thickener to improve hydraulic capacity and storage.	No	Hazen and Sawyer	\$49,663,318	\$48,635,606	43	41	
28	No	No	299183	Harkers Island Sanitary District	Carteret	No	998	50	\$119,110	Water System Improvements	Add a backup well (350 gpm, 10" VTP well with associated well head piping, treatment and control) and waterline extension along Oak Hammock Dr. (2,100 LF of 10-inch, 3,200 LF of 8-inch, 400 LF of 2-inch) and Rush Point Dr. (1,118 LF of 6-inch) with associated valve and appurtenances.	No	Green Engineering, PLLC	\$5,955,503	\$5,955,503	47	41	2.N.1. Lost 8 points due to not following guidance. 2.N.2. Added 5 points due to rolldown from 2.N.1. 2.T. Lost 3 points due to insufficient narrative.
29	No	No	299528	Carolina Water Service of North Carolina	Watauga	No	36,646	0	NA	Misty Mountain - Main Replacement	Replace approximately 6,000 LF of 2-inch galvanized stell waterlines from the 1970's with 2-inch PVC piping.	No	Kimley-Horn and Associates, Inc.	\$2,357,817	\$2,357,817	48	38	3.A.1. Lost 10 points due to lack of documentation related to CIP. 3.D. Lost 5 points due to lack of documentation.
30	No	No	299524	Carolina Water Service of North Carolina	Watauga	No	36,646	0	NA	Hound Ears - Water Main Replacement	Replace 6,700 LF of 2-inch galvanized water mains with new 2-inch PVC piping and other appurtenances.	No	Kimley-Horn and Associates, Inc.	\$2,083,257	\$2,083,257	48	38	3.A.1. Lost 10 points due to insufficient documentation. 3.A.2. Lost 2 points due to insufficient documentation.. 3.D. Lost 5 points due to insufficient documentation..
31	No	No	299300	Kinston, City of	Lenoir	No	10,750	0	NA	Grove Park Water Line Replacement	Replace waterlines in the disadvantaged Grove Park area, including approximately 4,147LF of 2-inch watelrine, 11,049 LF of 6-inch waterline, 559 LF of 8-inch watelrine, 443 service replacements, 20 hydrant assemblies, 15 6-inch GV's, and 11 2-inch GV's.	No	City of Kinston	\$2,834,347	\$2,834,347	45	38	4.A. Lost 2 points due to residential connections > 10,000.
32	No	Yes	275954	Graham, City of	Alamance	No	6,384	0	NA	Graham-Mebane WTP PFAS Improvements	Install GAC filters downstream of current treatment train in order to remove PFAS compounds.	No	Hazen and Sawyer	\$30,250,000	\$30,250,000	37	37	

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
33	No	No	299152	Thomasville, City of	Davidson	No	11,501	0	NA	2028 Water Lines Project	Replace 2-inch galvanized waterlines with 10,000 LF of 6-inch ductile iron pipe.	No	LaBella Associates	\$6,785,142	\$6,652,100	36	36	
34	No	No	298915	Johnston County	Johnston	No	72,805	0	NA	Cleveland Water Supply Improvements	Construct approximately 42,400 LF of transmission waterlines and expand booster pump station to improve system resiliency and meet growing water needs.	Yes	Johnston County	\$45,292,190	\$44,151,000	43	36	2.F.2. Lost 5 points due to lack of documentation. 3.C. Lost 5 points due to lack of documentation.
35	No	No	298920	Johnston County	Johnston	No	72,805	0	NA	Cleveland Water District 1 MG Tank	Construct 1 MG EST and SCADA controls to provide reliability and pressure to current and planned residential developments.	Yes	Johnston County	\$9,690,000	\$9,500,000	43	36	2.F.2. Lost 5 pointes due to lack of documentation. 3.C. Lost 5 points due to lack of documentation
36	No	No	299157	Johnston County	Johnston	No	72,805	0	NA	US 70 Bus Water Transmission Improvement	Construct new 24-inch watermain along US-70 corridor to parellel existing line and decrease chloramines in the system.	No	Johnston County	\$5,799,312	\$5,685,600	43	36	2.F.2. Lost 5 points due to insufficient documentation. 3.C. Lost 5 points due to insufficient documentation.
37	No	Yes	275951	Valdese, Town of	Burke	No	5,038	0	NA	Raw Water Intake Relocation	Replace Town of Valdese's existing raw water intake screens, pipes, and pump station building and an existing electrical substation located on the WTP site.	No	McGill Associates	\$30,361,090	\$20,361,090	35	35	
38	No	No	299470	Sweepsonville, Town of	Alamance	No	1,387	0	NA	Carolina Street Waterline	Replace 1,200 LF of 2-inch waterline with a new 6-inch ductile iron watermain; 183 LF of 8-inch and 284 LF of 10-inch CI waterline with 8-inch ductile iron watermain to connect to the proposed 6-inch watermain along Carolina St.	Yes	Alley, Williams, Carmen & King, Inc	\$957,000	\$957,000	37	35	3.A.2. Lost 2 points due to insufficient documentation.
39	No	No	298961	Stanly County	Stanly	Yes	5,186	0	NA	West Stanly Water Feed	Install approximately 17,500 LF of 18-inch waterline along Millingport Rd and 2 550-GPM inline booster pump stations. Replace approximately 1,650 LF 6-inch line with 12-inch line along NC 200	Yes	Chambers Engineering, PA	\$8,919,364	\$8,919,364	52	32	1.D.1. Lost 2 points due to insufficient narrative. 2.G. Lost 10 points due to insufficient documentation. 3.A.2. Lost 2 points due to insufficient documentation.
40	No	No	299429	Tryon, Town of	Polk	Yes	1,827	0	NA	Lake Lanier Dam Project	Repair, rehabilite, and upgrade the existing dam structure, including dam slope flattening, spillway repair, installation of new fuse gates, and other miscellaneous work to address cracking, seepage, and deterioration.	No	Water Funding Financial	\$8,854,326	\$8,142,545	57	30	1.C.1. Lost 8 points due to lack of reference to old age requirement for dams in PRS guidance. 2.E.2. Lost 3 points due to insufficient documentation. 2.F.2. Lost 5 points due to insufficient partnership between 2 systems. 2.N.1. Lost 8 points due to lack of criteria in PRS guidance related to dam upgrades. 2.T. Lost 3 points due to lack of criteria in PRS guidance related to dam upgrades.
41	No	Yes	275654	Burlington, City of	Alamance	No	26,520	0	NA	PFAS Drinking Water Treatment Upgrades	Install end-of-treatment train PFAS removal technology, including ion exchange, novel sorbent, and GAC absorbers.	No	Hazen and Sawyer	\$51,672,000	\$51,672,000	29	29	
42	No	No	298309	Lenoir, City of	Caldwell	No	9,366	0	NA	Lenoir-Valdese Water Interconnect	Construct a water pump station with generator, over 4 miles of transmission main, major crossing of Lake Rhodhiss, a master meter station, connections to the Valdese and Lenoir water systems, and valves and all related appurtenances.	Yes	McGill Associates	\$24,796,000	\$4,550,000	29	29	2.K.3. Lost 5 points due to award of 2.K.1 points.

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
43	No	No	299511	Columbia, Town of	Tyrrell	Yes	382	0	NA	Advanced Meter Infrastructure Project	Replace approximately 400 aging water meters with AMI.	Yes	McDavid Associates, Inc.	\$795,190	\$795,190	56	26	1.C. Lost 12 points due to insufficient documentation. 1.C.1. Lost 8 points due to insufficient documentation. 2.B.2. Lost 10 pointes due to insufficient documentation.
44	No	Yes	275887	Drexel, Town of	Burke	No	1,310	0	NA	Morganton-Valdese-Drexel Interconnect	Interconnect water treatment systems of Drexel, Valdese, and Morganton for emergency resiliency purposes. Construct approximately 8,100 LF of 12-inch watermain, 12,900 LF of 16-inch watermain, a master meter vault, and associated appurtenances.	No	McGill Asso	\$10,481,390	\$5,361,850	50	25	1.C. Lost 12 points due to not meeting criteria guidance. - Does not meet criteria per guidance 1.D. Lost 2 points due to not being an expansion. 2.F.2. Lost 5 points due to receiving 2.K.2 points. 2.K.3. Lost 5 points due to receiving 2.K.2 points. 2.N.1. Lost 8 points due to not reducing susceptibility to flooding.
45	No	No	299032	Johnston County	Johnston	No	72,805	0	NA	Lower Neuse Water Supply	Install new run-on-river intake on the Neuse river (upstream of the Richardson Bridge crossing); raw water pump station with a 29.2 MGD withdrawal capacity; and approximately 61,000 LF of raw water transmission lines of 42-inch diameter.	Yes	Johnston County	\$164,076,127	\$160,858,948	43	24	1D. Lost 2 points due to new infrastructure. 2.F.2. Lost 5 points due to insufficient documentation. 2.K.2. Lost 10 points due to insufficient documentation. 3.C. Lost 5 points due to insufficient documentation.
46	No	No	299178	Pender County	Pender	No	11,944	0	NA	Membrane WTP and Associated Improvements	Construct a new membrane WTP.	No	CDM Smith	\$150,000,000	\$76,250,000	48	23	2.E.2. Lost 3 points due to insufficient documentation. 2.G. Lost 10 points due to insufficient documentation. 2.H.4. Lost 5 points due to insufficient documentation. 3.D. Lost 5 points due to insufficient documentation. 3.A.2. Lost 2 points due to insufficient documentation..
47	No	No	299402	Landis, Town of	Rowan	No	2,095	0	NA	Two New Water Tanks	Install new 150,000 gallon tanks named East Landis Tank and Fifth Street Tank.	Yes	Municipal Engineering	\$8,971,134	\$8,971,134	30	21	1.D. Lost 2 pointes due to insufficient documentation. 3.A.1. Lost 10 points due to insufficient narrative and no CIP. 3.D. Lost 5 points due to insufficient narrative and documentation.
48	No	No	298952	Johnston County	Johnston	No	72,805	0	NA	Water Transmission SCADA, Smart Metering	Install SCADA controls and high-gain radio antennas at 10 locations within the distribution system; approximately 20,000 individual meters;and additional security features, including at SCADA platform.	No	Johnston County	\$3,897,000	\$3,624,500	35	21	1.C. Lost 12 pointesdue to ineligible project type. 3.C. Lost 5 pointes due to insufficient documentation.

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
49	No	No	298903	Johnston County	Johnston	No	72,805	0	NA	TGB WTP PFAS Treatment Addition	Install PAC feed system to treat 18 MGD of the expanded WTP.	Yes	Johnston County	\$4,182,000	\$4,100,000	62/35	21	1.D. Lost 2 points due to new infrastructure. 1.J.1 Lost 12 points due to insufficient documentation for 2.H.4. 2.B.1.Lost 20 points due to not following guidance. 2H4. Required documenation to earn points not provided. 3C. Required documentation not provided.
50	No	Yes	276013	Stanly County	Stanly	Yes	9,231	47	\$85,329	Tyson Road Waterline	Install approximately 14,220 LF of 8inch PVC waterline along Tyson Road.	No	Chambers Engineering PA	\$4,010,450	\$4,010,450	34	20	1.D. Lost 2 points due to new waterline. 2.K.2. Lost 10 points due to insufficient documentation. 3.A.2. Lost 2 points due to lack of resolution or board meeting minutes as well as old CIP (2022).
51	No	No	299394	Landis, Town of	Rowan	No	2,095	0	NA	Mount Moriah Waterline Revisions	Replace approximately 3,905 LF of 6-inch along Mount Moriah Church Road.	Yes	Municipal Engineering	\$1,473,873	\$1,473,873	45	20	1.C. Lost 12 points due to insufficient documentation. 1.C.1. Lost 8 points due to insufficient documentation. 3.A.1. Lost 10 points due to insufficient narrative.
52	No	Yes	275631	Lenoir, City of	Caldwell	No	9,366	0	NA	Whitnel Transmission Main Replacement	Install approximately 15,500 LF of 24-inch DIP to replace 20-inch SSP installed in the 1950's from the WTP along Waterworks Road and Sawmills School Road.	No	McGill Associates	\$8,364,000	\$8,200,000	22	19	2.T. Lost 3 points due to infrastructure not qualifying for redundancy.
53	No	Yes	275892	Wilkesboro, Town of	Wilkes	Yes	1,205	0	NA	Brown Fords Loop Waterline Project	Constr approximately 2,500 LF of 8-inch ductile iron pipe, 135 LF of 16-inch steel encasement pipe, hydrants, and associated appurtenances to better equalize the pressure in areas of the town and rearrange the interconnection with West Wilkes Water Association.	No	Municipal Engineering, Inc.	\$1,890,600	\$1,890,600	41	19	1.C. Lost 12 points due to project being considered expansion. 1.D. Gained 2 points due to roll-down from Line Item 1.C. 2.G. Lost 10 points due to insufficient documentation.
54	No	Yes	275612	Carolina Water Service of North Carolina	Carteret	No	35,782	0	NA	Brandywine Bay - Ion Exchange	Install a ion exchange at two well sites to treat hardness to improve water quality.	No	Kimley-Horn	\$629,709	\$629,709	28	18	3.A.1. Lost 10 points due to project not listed in CIP. 3.D. Lost 5 points due to lack of documentation.
55	No	No	298940	Lower Cape Fear Water And Sewer Authority	Brunswick	No	157,048	0	NA	Control Panel & Surge Tank Improvements	Install 4th surge tank and control panel upgrades at KBPS.	Yes	McKim & Creed	\$1,450,000	\$1,450,000	17	15	3.A.2. Lost 2 points due to award of 3.A.1 points.

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Requested per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Difference in Points Claimed and Verified
56	No	Yes	275614	Carolina Water Service of North Carolina	Mecklenburg	No	35,782	0	NA	PFAS Priority Sites	Install and rehabilitate equipment to remove PFAS.	No	Kimley-Horn	\$3,325,000	\$3,325,000	45	15	2.H.4. lab test results prior to 12 months before application deadline 1.J.1. Lost 12 points due to lack of insufficient documentation for Line Items 2.H.3 or 2.H.4. 2.H.4. Lost 5 points due to insufficient documentation. 2.I. Lost 3 points due to lack of calculations. 3.A.1. Lost 10 points due to lack of projected costs for near-term projects. 3.A.2. Lost 2 points due to lack of projected costs for near-term projects. 3.D. Lost 5 points due to age of surveys and lack of mapping documentation.
57	No	No	299514	Lincolnton, City of	Lincoln	No	5,798	0	NA	Lincolnton Spring Water Project	Install approximately 10,600 LF of 8-inch PVC waterline, 3,310 LF of 6-inch PVC waterline, 3,830 LF of 2-inch PVC waterline; 25 fire hydrants, 123 short-side connections, 101 long-side connections and 55 reconnections to existing services.	No	Twiggs Planning Consultants	\$4,961,689	\$4,961,689	40	14	1.C. Lost 12 points due to insufficient documentation. 1.C.1. Lost points due to insufficient documentation. 3.A.1. Lost 10 points due to insufficient documentation. 3.A.2. Lost 2 points due to insufficient documentation. 4.B. Awarded 4 points due to calculation for bill per 5,000 gallons.

Ineligible/Incomplete Applications

Application Number	Proposed Funding in Scenario?	Reconsidered Appl. from Previous Round?	Instance ID	Applicant Name	County	Designated Distressed?	Residential Connections	New Connections in Project	Funding Request per New Connection	Project Name	Project Description	Additional Info. Added?	Application Preparer	Total Project Cost	Funding Requested	Points Claimed by Applicant (unadjusted for reconsid.)	Points Verified	Reason for Incompleteness/Ineligibility
N/A																		