WELL CONSTRUCTION RECORD (GW-1)

For Internal Use Only:

1. Well Contractor Information:

Well Contractor Name

NC Well Contractor Certification Number

Company Name

2. Well Construction Permit #: _____
List all applicable well construction permits (i.e. UIC, County, State, Variance, etc.)

3. Well Use (check well use):

Water Supply Well:

☐Agricultural ☐Municipal/Public
☐Geothermal (Heating/Cooling Supply) ☐Residential Water Supply (single)
☐Industrial/Commercial ☐Residential Water Supply (shared)
☐Irrigation ☐Wells > 100,000 GPD

Non-Water Supply Well:

☐Monitoring ☐Recovery

Injection Well:

☐Aquifer Recharge ☐Groundwater Remediation
☐Aquifer Storage and Recovery ☐Salinity Barrier
☐Aquifer Test ☐Stormwater Drainage
☐Experimental Technology ☐Subsidence Control
☐Geothermal (Closed Loop) ☐Tracer
☐Geothermal (Heating/Cooling Return) ☐Other (explain under #21 Remarks)

4. Date Well(s) Completed: _____ **Well ID#** _____

5a. Well Location:

Facility/Owner Name

Facility ID# (if applicable)

Physical Address, City, and Zip

County

Parcel Identification No. (PIN)

5b. Latitude (Lat) and longitude (Lon) (if well field, one lat/long is sufficient) **in Decimal Degrees (DD) or Degrees/Minutes/Seconds (DMS)**

Lat:(DD) _____ **(DMS)** ° ′ ″

Lon:(DD) _____ **(DMS)** ° ′ ″

6. **Is(are) the well(s):** ☒ **Permanent** **or** ☐ **Temporary**

7. **Is this a repair to an existing well:** ☐ **Yes** **or** ☒ **No**
If this is a repair, fill out known well construction information and explain the nature of the repair under #21 remarks section or on the back of this form.

8. **For Geoprobe/DPT or Closed-Loop Geothermal Wells** having the same construction, only 1 GW-1 is needed. Indicate TOTAL NUMBER of wells drilled: _____

9. Total well depth below land surface: _____ **(ft.)**
For multiple wells list all depths if different (example- 3@200' and 2@100')

10. Static water level below top of casing: _____ **(ft.)**
If water level is above casing, use "+"

11. Borehole diameter: _____ **(in.)**

12. Well construction method: _____
(i.e. auger, rotary, cable, direct push, etc.)

FOR WATER SUPPLY WELLS ONLY:

13a. Yield (gpm) _____ **Method of test:** _____

13b. Disinfection type: _____ **Amount:** _____

14. WATER ZONES

FROM	TO	DESCRIPTION
ft.	ft.	
ft.	ft.	

15. OUTER CASING (for multi-cased wells) OR LINER (if applicable)

FROM	TO	DIAMETER	THICKNESS	MATERIAL
ft.	ft.	in.		

16. INNER CASING OR TUBING (geothermal closed-loop)

FROM	TO	DIAMETER	THICKNESS	MATERIAL
ft.	ft.	in.		
ft.	ft.	in.		

17. SCREEN

FROM	TO	DIAMETER	SLOT SIZE	THICKNESS	MATERIAL
ft.	ft.	in.			
ft.	ft.	in.			

18. GROUT

FROM	TO	MATERIAL	EMPLACEMENT METHOD & AMOUNT
ft.	ft.		
ft.	ft.		
ft.	ft.		

19. SAND/GRAVEL PACK (if applicable)

FROM	TO	MATERIAL	EMPLACEMENT METHOD
ft.	ft.		
ft.	ft.		

20. DRILLING LOG (attach additional sheets if necessary)

FROM	TO	DESCRIPTION (color, hardness, soil/rock type, grain size, etc.)
ft.	ft.	
ft.	ft.	
ft.	ft.	
ft.	ft.	
ft.	ft.	
ft.	ft.	
ft.	ft.	

21. REMARKS

22. Certification:

Signature of Certified Well Contractor

Date

By signing this form, I hereby certify that the well(s) was (were) constructed in accordance with 15A NCAC 02C .0100 or 15A NCAC 02C .0200 Well Construction Standards and that a copy of this record has been provided to the well owner.

23. Site diagram or additional well details:
You may use the back of this page to provide additional well construction info (add 'See Over' in Remarks Box). You may also attach additional pages if necessary.

24. SUBMITTAL INSTRUCTIONS

Submit this GW-1 within 30 days of well completion per the following:

24a. For All Wells: Original form to Division of Water Resources (DWR), Information Processing Unit, 1617 MSC, Raleigh, NC 27699-1617

24b. For Injection Wells: Copy to DWR, Underground Injection Control (IUC) Program, 1636 MSC, Raleigh, NC 27699-1636

24c. For Water Supply and Open-Loop Geothermal Return Wells: Copy to the county environmental health department of the county where installed

24d. For Water Wells producing over 100,000 GPD: Copy to DWR, CCPCUA Permit Program, 1611 MSC, Raleigh, NC 27699-1611