

DEQ/DWR
FACT SHEET FOR NPDES PERMIT DEVELOPMENT
NPDES PERMIT NC0003433

Facility Information								
Applicant/Facility Name:	Duke Energy Progress LLC– Cape Fear Steam Electric Plant (decommissioned)							
Applicant Address:	500 CP&L Road, Moncure, NC 27599							
Facility Address:	500 CP&L Road, Moncure, NC 27599							
Permitted Flow:	Outfall 008 -1.93 Daily Maximum							
Type of Waste:	100% Industrial							
Facility/Permit Status:	Class II/Renewal and Major Modification				SIC 4911			
County:	Chatham							
Miscellaneous								
Receiving Stream			Index	7Q10s (cfs)	QA (cfs)			
Outfall 007 – Unnamed tributary to Cape Fear River			18-(1)	0	0			
Outfall 008 – Cape Fear River			18-(1)	-	-			
Outfall 009 – Shaddox Creek			16-43	0	0			
Outfall 010A, 010B – Unnamed tributary to Cape Fear River			18-(1)	0	0			
Outfalls 011A, 011B,011C, 011D – Cape Fear River			18-(1)	-	-			
Stream Classification:	WS-IV	Regional Office:	Raleigh					
303(d) Listed?:	No	USGS Topo Quad:	E22SE Moncure, NC					
HUC No.:	03030002	Permit Writer:	Ron Berry					
Subbasin:	03-06-07	Date:	10/3/16					
Cape Fear River Stream Statistics – 2016								
Drainage (mi ²):	-							
Summer – 7Q10 (cfs):	Not defined ¹							
Winter – 7Q10 (cfs):	Not defined ¹							
30Q2 (cfs):	Not defined ¹							
QA (cfs):	Not defined ¹							

Note:

1. Complex nature of this section of the Cape Fear River does not yield a definable 7Q10, 30Q2, QA stream statistics per USGS.

Current Status

Duke Energy's ceased operation of its combined 400 megawatts, coal-fire and combustion turbine, Cape Fear Steam Electric Plant in 2011. Except for a single small (less than 0.1 MGD) episodic discharge in February 2016 from a leaking valve, the last consistent discharge from this facility was in July 2014. The plant was dismantled and no longer withdraws water from the Cape Fear River nor discharges wastewater as defined for an active operation of a steam electric generation facility. Currently, there are five ash basins, three which contain a visible water level, and no treatment facilities. As part of the current active NPDES issued in 2011, storm water was separated and is covered under its own permit.

In July 2014 Duke Energy submitted a modification application to amend permit conditions to address operation changes and recently identified unpermitted seeps. Subsequent application amendments have been submitted to update data and to request additional modifications. In February 2016, a request was made by the Permittee to accept the permit modification application under review as the required permit renewal application. During the interim Duke continued to provided documents

and data associated with identified seeps as well as data associated with the ash basins bulk wastewater decanting/dewatering analyses. As part of the final August 2016 amended application Duke Energy requested:

- Activation of the former 1963/1970 ash basin stormwater Outfall 008 as an NPDES outfall for discharging ash basins treated decanting/dewatering and other treated wastewater from two proposed treatment facilities with a requested flow limit of 1.78 MGD.
- Provisions to allow for future on-site treated groundwater wastewater discharge to Outfall 008. The treatment systems will be modified as needed.
- Provisions to allow for future on-site treated ash landfill leachate wastewater discharge to Outfall 008 once all on-site ash basin decanting/dewatering activities are completed/terminated. The treatment systems will be modified as needed.
- Approval for repurposing existing Internal Outfalls 001 and 005 for emergency overflow discharges for East and West Ash Basins until completion of their decanting process (Outfall 001 and 005 discharge to Outfall 007 effluent channel).
- Approval for a new emergency overflow Internal Outfall 008A for 1963/1970 Ash Basin until completion of its decanting process (Outfall 008A will discharge to Outfall 008).
- Approval to collect and monitor AOWs (area of wetness) S-05, S-07, S-08, S-09, S-12 in the existing designated Outfall 007 effluent channel as contributing flows to Outfall 007.
- Approval not to require notification to the Division of any newly identified AOWs that contribute flow to any existing Outfalls.

In conjunction with the August 2016 application amendment, Duke Energy withdrew its previous request for NPDES coverage for AOWs S-01, S-02, S-03, S-06, S-11, S-13, S-14 based on the confirmation by sampling data of the lack of pollutants being released to waters of the state.

The facility can discharge to three stream locations, Shaddox Creek, unnamed tributaries to the Cape Fear River, and the Cape Fear River. All streams are classified as WS-IV. For this permit, based on the USGS 2016 review and recommendation, all three locations are considered undefined flow or “zero” flow streams. This facility is subject to EPA effluent guidelines 40 CFR 423 and to NC Senate Bill 729 (Coal Ash Management Act).

Outfall Description for Proposed Permit

Internal Outfall 001 - West Ash Basin

This existing outfall will be re-designated as requested by the Permittee as an emergency discharge only and will consist of ash basin comingled decanting wastewater and storm water. This will be limited to discharging excess wastewater above the available treatment plant capacity during an eminent threat of West Ash Basin overflow to the facility's effluent channel. The channel discharges through Outfall 007.

Internal Outfall 005 - East Ash Basin

This existing outfall will be re-designated as requested by the Permittee as an emergency discharge only and will consist of ash basin comingled decanting wastewater and storm water. This will be limited to discharging excess wastewater above the available treatment plant capacity during an eminent threat of East Ash Basin overflow to the facility's effluent channel. The channel discharges through Outfall 007.

Outfall 007 - Combined Wastewater

This existing outfall will discharge as requested by the Permittee the accumulated flows of designated seeps S-05, S-07, S-08, S-12, storm water, and episodic emergency flow from Internal Outfalls 001 and 005. Outfall 007 discharges to an unnamed tributary to the Cape Fear River.

Outfall 008 - Combined Wastewater

This outfall was a previous retired 1963/1970 Ash Basin storm water outfall and as requested by the Permittee will be re-activated as a NPDES discharge. It will be designated for the discharge of the combined flows of treated wastewater from the two proposed on-site treatment facilities, and for the episodic emergency flow from Internal Outfall 008A. Outfall 008 discharges to the Cape Fear River.

Internal 008A - 1963/1970 Ash Basin

This will be a new outfall requested by the Permittee and will be designated as an emergency discharge only, and will consist of ash basin comingled decanting wastewater and storm water. This will be limited to discharging excess wastewater above the available treatment plant capacity during an eminent threat of 1963/1970 Ash Basin overflow to Outfall 008.

Outfall 009 - Seep

This will be a new outfall required to address the discharge from designated seep S-04 associated with the East Ash Basin. Outfall 009 discharges into an existing ditch that discharges into Shaddox Creek.

Outfalls 010A and 010B – Seeps

These will be new outfalls required to address the discharge from designated seeps S-09, S-10 associated with the East Ash Basin. Outfalls 010A and 010B discharge into existing ditches that discharge into an unnamed tributary to the Cape Fear River.

Outfalls 011A, 011B, 011CD, 011D – Seeps

These will be new outfalls required to address the discharge from designated seeps S-15, S-16, S-17, S-18 associated with the 1963/1970 Ash Basin. Outfalls 011A, 011B, 011C, and 011D discharge to the Cape Fear River.

Compliance Review

During this permit cycle while operating as a steam electric generating facility up to shutting down in May 2014, the facility had two TSS limit violations on Internal Outfall 005 and some monitoring frequency violations. No fines were assessed.

A total of 11 chronic toxicity tests at 90% effluent concentration using ceriodaphnia dubia were performed and passed.

During this permit cycle samples were taken from 13 monitoring wells for 22 parameters 3/ Year. Groundwater violations were noted for Total Manganese, Total Iron, Total Boron, Total Vanadium, TSS, Total Cobalt, Sulfates, Total Selenium, Total Cadmium, Total Chromium, and Total Thallium. As required the Permittee is preparing an Action Plan to address groundwater remediation that will be submitted to the Groundwater Protection Branch for final approval.

Instream Monitoring

As part of the required site seep investigation and reporting, instream samples were taken in July 2014 in the Haw River at the mouth of Shaddox Creek, upstream in Shaddox Creek, in the Cape Fear River just upstream of the mouth of the unnamed tributary that receives flow from Outfall 007, and in the Cape Fear River approximately 1.9 miles downstream from the mouth of the unnamed tributary. There was a notable reduction in impact to the concentration of the measured constituents that entered Haw River from Shaddox Creek most likely from dilution. The Cape Fear River samples did not show any significant differences. There were no reported values that violated NC water quality standards or EPA criteria.

Fish Tissue Study Near Ash Basins

As required a fish tissue study was conducted in the Cape Fear River in May 2014 to evaluate the uptake of arsenic, mercury, and selenium by fish near the ash basin discharge. There were four fish tissue samples out of the thirty-six sample taken, three upstream and one downstream, that were \geq the Mercury 2006 NC Health Directors Action Advisory Level of 0.4 $\mu\text{g/g}$ fresh weight. The fish tissue samples Mercury levels ranged from < 0.04 to 0.68 $\mu\text{g/g}$ fresh weight. There was no exceedance of the arsenic or the selenium fish tissue fresh weight criteria for any fish tissue sampled.

Proposed Permitting Action

To implement the 2014 Coal Ash Management Act, this facility must decant and dewater the ash basins, and then excavate the ash to an approved landfill. Currently, there are three ash basins scheduled for decanting/dewatering at this site. The Permittee is planning on seeking approval to construct a lined ash landfill on-site and to construct and begin operation of a groundwater remediation system.

The Permittee proposes to install two ash basin treatment facilities for treatment of ash basin decanting and dewatering wastewater that will mix and discharge through Outfall 008. In addition, the Permittee proposes to add groundwater remediation wastewater as an influent to the ash basin treatment units at some point. Once all the ash basin decanting and dewatering is completed, the Permittee has requested the option to add on-site ash landfill leachate to the treatment units' influent in conjunction with groundwater remediation wastewater, and continue to be allowed to discharge treated wastewater from Outfall 008. For the purposes of determining the maximum permitted flow and daily limit for Outfall 008, the maximum treatment capacity of 1.93 MGD was calculated based on 600 GPM (groundwater) and 70 GPM (leachate) being sent to each treatment unit.

The East and West Ash Basins bulk water and interstitial water analyses was accepted as representing the bulk water and interstitial water characteristics for the 1963/1970 Ash Basin. The Permittee will be required to notify the Division when the initial ash basin decanting process begins, and when a change in the purpose and the wastewater sources occurs to Outfall 008, to ensure the appropriate requirements are applied. The change in wastewater sources will also require submittal of EPA Form 2C. The permit may be opened to implement additional requirements if warranted.

As a result of the decommissioning and removing of the steam and turbine components, removing of the domestic WWTP, and eliminating of other related on-site sources, the following current permit Special Conditions are no longer applicable and will be removed from this permit:

- A. (2.) Internal Outfall 003
- A. (6) Intake Screen Backwashing
- A. (7.) Biocide Condition
- A. (8.) Domestic Wastewater Treatment Plant
- A. (10.) Section 316 (b) of CWA

Internal Outfalls 001, 005, and 008A - Ash Basins Emergency Overflow Discharge

The Permittee requested internal outfalls be allowed for the three ash basins to address potential emergency overflow events. Currently, the East Ash Basin Internal Outfall 005 and the West Ash Basin Internal Outfall 001 will be adapted as emergency overflow discharging to the facility's effluent channel which discharges through Outfall 007. The 1963/1970 Ash basin will require a new emergency overflow outfall, Internal Outfall 008A. The emergency overflow wastewater from Internal Outfall 008A will mix with the treated ash basin treatment systems wastewater effluent and then can discharge through Outfall 008. Table 1 lists the monitoring requirements for the ash basin emergency overflow internal outfalls based on 40 CFR 423 effluent guidelines and NC water quality standards.

Table 1: Ash Basin Emergency Overflow Internal Outfalls

Parameter	Monitoring Requirements	Sample Requirements ^{1,2}	
		Daily during Episodic Event	Pump Logs, meters, or estimate
Flow	Monitor & Report, MGD		
pH	6.0 ≤ pH ≤ 9.0 S.U.	Weekly	Grab
Total Suspended Solids	30.0 mg/L MA 100.0 mg/L DM	Weekly	Grab
Oil and Grease	15.0 mg/L MA 20.0 mg/L DM	Weekly	Grab

Notes

1. During a discharge event, the flow shall be reported daily and the TSS, pH, Oil & Grease shall be monitored and reported weekly including at least once during a discharge event for an event duration of less than a week.
2. Effluent sampling shall be conducted on effluent from the Ash Basin emergency overflow discharge prior to mixing with any other waste stream.

Outfall 008 - Ash Basin Decanting

Treated ash basin decanting wastewater will be pumped and mixed from the two on-site ash basin treatment facilities before discharging from Outfall 008. Monitoring for ash basin decanting pollutants, and monitoring and limits for Flow, pH, TSS, Oil & Grease, and Chronic toxicity, and narratives will be applied based on the strategy for decanting.

Reasonable Potential (RP) Analyses

A RP analyses was conducted based on the highest July/August 2014 toxicant measurements from each East and West Ash Basins bulk water measurements and applying the new NC WQS and EPA criteria. Based on the analyses the following additional permitting actions are proposed for decanting:

- **Monitor with Limit**

The flowing parameters will receive a WQBEL requirement, since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Copper, Fluoride, Molybdenum, Nickel, Selenium, Sulfates, Thallium, Zinc

- **Monitor Only**

The following parameters will receive a monitoring only requirement since the predicted value \geq 50% of the Allowable Cw: Total Barium, Chlorides

The following parameter will receive a monitoring only requirement, since the MDL > Allowable Cw and > PQL: Cadmium

- **No Limit or Monitoring**

The following parameters will not receive a limit or monitoring requirement, since there were no detects and the MDL < WQBEL: Chromium VI, Chromium III, Total Chromium, Lead, Antimony

A spreadsheet of the RP Analyses is attached to this Fact Sheet.

Mercury TMDL

A mercury TMDL was approved by US EPA in October 2012 and will be implemented in this permit. All reported data was above the TBEL and the annual average WQBEL, in this case, the WQBEL as an annual average will be required. See RP Analyses spreadsheet for Mercury data.

Upon commencing of an ash basin dewatering process the terms and conditions associated with the dewatering process automatically supersede the decanting effluent page limitations. Table 2 summarizes the proposed Outfall 008 decanting requirements.

Table 2: Ash Basin Decanting Outfall 008

Parameter	Monitoring Requirements	DMR Monitoring Frequency	Basis
Flow	1.93 MGD DM	Daily	Decanting strategy, 15A NCAC 2B .0505
pH	6.0 ≤ pH ≤ 9.0 S.U. Continuous monitoring/auto shutoff	Monthly	Decanting strategy, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100 mg/L DM Continuous monitoring/auto shutoff	Monthly	Decanting strategy, EPA requirement, 40 CFR 423
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Monthly	Decanting strategy, 40 CFR 423
Total Arsenic	10.0 µg/L MA 10.0 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Copper	7.9 µg/L MA 10.5 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Mercury	12 ng/L, annual average	Monthly	Mercury TMDL
Total Molybdenum	160 µg/L MA 160 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Nickel	25.0 µg/L MA 25.0 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Selenium	5.0 µg/L MA 56.0 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Thallium	0.24 µg/L MA 0.24 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Total Zinc	125.7 µg/L MA 125.7 µg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Fluoride	1.8 mg/L MA 1.8 mg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Sulfates	250 mg/L MA 250 mg/L DM	Monthly	RP to exceed NC WQS and EPA criteria
Turbidity	Net Turbidity ≤ 50 NTU	Monthly	Decanting strategy, EPA requirement
Total Hardness	Monitor & Report, mg/L	Monthly	Collect data for RP analyses
Total Barium	Monitor & Report, mg/L	Monthly	Maximum predicted value ≥ allowable Cw
Total Cadmium	Monitor & Report, µg/L	Monthly	MDL > Allowable Cw and > PQL
Chlorides	Monitor & Report, mg/L	Monthly	Maximum predicted value ≥ allowable Cw
Nitrate/Nitrite as N	Monitor & Report, mg/L	Monthly	Decanting strategy, 40 CFR 423
Chronic Toxicity	90% concentration, P/F	Monthly	DEQ Toxicity Policy
Total Kjeldahl Nitrogen	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Total Nitrogen	Monitor & Report, mg/L	Quarterly	15A NCAC 02B .0500
Total Phosphorus	Monitor & Report, mg/L	Quarterly	15 A NCAC 02B .0500

Outfall 008 Ash Basin Dewatering (and/or combination Dewatering/Decanting)

Treated ash basin dewatering wastewater will be pumped and mixed from two on-site ash basin treatment facilities before discharging from Outfall 008. It may be possible to mix treated decanting and dewatering wastewater in which case Outfall 008 discharge is deemed dewatering. Monitoring for ash basin dewatering pollutants, and monitoring and limits for Flow, pH, TSS, Oil & Grease, and Chronic toxicity, and narratives will be applied based on the strategy for dewatering.

Reasonable Potential (RP) Analyses

A RP analyses was conducted based on the highest July/August 2014 toxicant measurement from the East and West Ash Basins interstitial water and applying the new NC WQS and EPA criteria. Based on the analyses the following additional permitting actions are proposed for watering:

- **Monitor with Limit**

The flowing parameters will receive a WQBEL requirement, since the RP exists to violate NC WQS and EPA criteria: Arsenic, Barium, Chromium VI, Chromium III, Total Chromium, Copper, Fluoride, Lead, Molybdenum, Nickel, Selenium, Sulfates, Thallium, Zinc

- **Monitor Only**

The following parameter will receive a monitoring only requirement since the predicted value \geq 50% of the Allowable Cw: Chlorides

The following parameters will receive a monitoring only requirement, since the MDL > Allowable Cw: Antimony, Cadmium

A spreadsheet of the RP Analyses is attached to this Fact Sheet.

Mercury TMDL

A mercury TMDL was approved by US EPA in October 2012 and will be implemented in this permit. All reported data was above the TBEL and the annual average WQBEL, in this case, the WQBEL as an annual average will be required. See RP Analyses spreadsheet for Mercury data.

In summary, the monitoring requirements for Ash Basin Dewatering are the same as Table 2 with the following modifications:

- Add limits for Barium, Copper
- Add monitoring and limits for Lead, Chromium VI, Chromium III
- Add monitoring for Antimony, Cadmium, and Total Chromium
- Increase DMR monitoring frequency to weekly for designated dewatering parameters

Outfall 008 Ash Basin Dewatering (and/or combination Dewatering/Decanting/Groundwater Remediation)

On-site groundwater remediation wastewater will be pumped and mixed with the ash basin dewatering wastewater, treated, and discharge from Outfall 008. A review of the existing site groundwater monitoring data was conducted, and several toxicants of concern were noted. The monitoring requirements will remain the same as the dewatering requirements with the following modifications to address additional groundwater remediation concerns:

- Add limits for Antimony, Cadmium, and Chlorides
- Add monthly monitoring for Aluminum, Manganese, TDS

Outfall 008 - Groundwater Remediation

Upon completion/termination of ash basin dewatering and continued or beginning of on-site groundwater remediation, the groundwater remediation wastewater will be pumped to the ash basin treatment systems, treated, mixed, and discharged from Outfall 008. The parameters of concern remain the same as the parameters of concern for the combined dewatering and groundwater remediation wastewater, but will be modified and implemented as a permitted Class II groundwater remediation facility as shown in Table 3.

Table 3: Outfall 008 – Groundwater Remediation

Parameter	Requirements/Limits	DMR Monitoring Frequency	Basis
Flow	Monitor & Report, MGD	Weekly	15A NCAC 2B .0505
pH	6.0 ≤ pH ≤ 9.0 S.U.	Weekly	15A NCAC 2B .0200
TSS	30.0 mg/L MA 30.0 mg/L DM	Weekly	Groundwater Remediation Strategy NCG510000
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	Weekly	Pollutant of concern, 40 CFR 423
Toxicants (Limits)	Same as Outfall 008 - dewatering/groundwater remediation	Weekly	Pollutants of concern, 15A NCAC 2B .0500
Toxicants (No Limits)		Monthly	Pollutants of interest 15A NCAC 2B .0500
Total Mercury		Monthly	Parameter of concern Mercury TMDL
Turbidity	Net Turbidity ≤ 50 NTU	Weekly	15A NCAC 2B .0200
Total Hardness	Monitor & Report, mg/L	Quarterly	Collect data for RP analyses
Nitrate/Nitrite as N	Monitor & Report, mg/L	Quarterly	Needed to calculate TN
Chronic Toxicity	90% concentration, P/F	Quarterly	DEQ Toxicity Policy

Outfall 008 - Groundwater Remediation/Ash Landfill Leachate

Upon completion/termination of ash basin dewatering and continued or beginning of groundwater remediation, and with the addition of on-site ash landfill leachate, the combined groundwater remediation wastewater and leachate wastewater will be mixed in the ash basin treatment systems' influent, treated, and discharged from Outfall 008. The Permittee provided an analyses of a similar ash basin landfill leachate from another facility for review, and several toxicants of concern were noted. The monitoring requirements will remain the same as the groundwater remediation requirements with the following modifications:

- Add weekly monitoring with limits for Silver
- Add weekly monitoring for Temperature
- Add monthly monitoring for Conductivity

Seep Outfalls

The facility identified 18 non-engineered discharges from seepage from the ash settling basins. However, 7 of the seeps do not need coverage under this permit based on the low concentration of the constituents associated with coal ash and/or absence of the discharge to the "Waters of the State". These seeps are not considered point source wastewater discharges under the Clean Water Act.

An effluent channel determination was completed by the Division on September 2, 2016. The seeps listed in Table 4 were identified as effluent channels and are depicted on the permit map. Seeps S-05, S-07, S-08, S-12 are tributaries through the facility's effluent channel to Outfall 007 which discharges to an unnamed tributary to the Cape Fear River. Outfall 009 discharges to Shaddox Creek. Outfalls 010A and 010B discharge to an unnamed tributary to the Cape Fear River. Outfalls 011A, 011B, 011C, and 011D discharge to the Cape Fear River.

Table 4: Seeps Discharge Coordinates and Assigned Outfall Numbers

Discharge ID	Latitude	Longitude	Outfall number
S-04	35° 35' 35" N	79° 2' 34" W	009
S-05	35° 35' 25" N	79° 2' 48" W	007
S-07	35° 35' 24" N	79° 2' 37" W	007
S-08	35° 35' 9" N	79° 2' 34" W	007
S-09	35° 35' 9" N	79° 2' 23" W	010A
S-10	35° 35' 9" N	79° 2' 19" W	010B
S-12	35° 35' 16" N	79° 2' 41" W	007
S-15	35° 35' 20" N	79° 3' 5" W	011A
S-16	35° 35' 25.2" N	79° 3' 5" W	011C
S-17	35° 35' 26" N	79° 3' 5" W	011D
S-18	35° 35' 24.9" N	79° 3' 5" W	011B

Within 180 days of the effective date of this permit, the permittee shall demonstrate, through instream sampling meeting the requirements of condition A. (23.), that the water quality standards in the receiving stream are not contravened.

Discharges from Seepage Identified After Permit Issuance

The facility shall comply with the "Plan for Identification of New Discharges" as contained in Attachment 2. For any discharge identified pursuant to this Plan, the facility shall, within 90 days of the seep discovery, determine if the discharge seep meets the state water quality standards established in 15A NCAC 2B .0200 and submit the results of this determination to the Division. If the standards are not contravened, the facility shall conduct monitoring for the parameters specified in A. (11.).

If any of the water quality standards are exceeded, the facility shall be considered in violation until one of the options below is fully implemented:

- 1) Submit a complete application for 404 Permit (within 30 days after determining that a water quality standard is exceeded) to pump the seep discharge to one of the existing outfalls, install a pipe to discharge the seep to the Cape Fear River, or install an *in-situ* treatment system. After the 404 Permit is obtained, the facility shall complete the installation of the pump, pipe, or treatment system within 180 days from the date of the 404 permit receipt and begin pumping/discharging or treatment.
- 2) Demonstrate through modeling that the decanting and dewatering of the ash basin will result in the elimination of the seep. The modeling results shall be submitted to the Division within 120 days from the date of the seep discovery. Within 180 days from the completion of the dewatering the facility shall confirm that the seep flow ceased. If the seep flow continues, the facility shall choose one of the other options in this Special Condition.

- 3) Demonstrate that the seep is discharging through the designated "Effluent Channel" and the water quality standards in the receiving stream are not contravened. This demonstration should be submitted to the Division no later than 180 days from the date of the seep discovery. The "Effluent Channel" designation should be established by the DEQ Regional Office personnel prior to the issuance of the permit. This permit shall be reopened for cause to include the "Effluent Channel" in a revised permit.

All effluent limits, including water quality-based effluent limits, remain applicable notwithstanding any action by the Permittee to address the violation through one of the identified options, so that any discharge in exceedance of an applicable effluent limit is a violation of the Permit as long as the seep remains flowing.

New Identified Seeps

If new seeps are identified, the facility shall follow the procedures outlined above. The deadlines for new seeps shall be calculated from the date of the seep discovery. The new identified seeps are not permitted until the permit is modified and the new seep included in the permit and the new outfall established for the seep.

Reasonable Potential (RP) Analyses For Proposed Seep-Based Outfalls

A RP analyses was conducted for each seep-based outfall using the reported 2014-2016 seeps measurements for Antimony, Arsenic, Barium, Cadmium, Chlorides, Chromium, Copper, Fluoride, Lead, Molybdenum, Nickel, Selenium, Sulfates, Thallium, and Zinc. The IWC was 100% for all seeps as no stream dilution was applicable. For summary purposes, the RP Analyses seep flows were multiplied by a safety factor of 10 but had no impact on the IWC. The seeps Mercury data was used to evaluate each seep-based outfall for implementation of the October 2012 Mercury TMDL. As a result of the RP Analyses and the Mercury TMDL, the following additional permitting actions are proposed in conjunction with continuing the seep's same monitoring parameters:

Outfall 007 - S-05, S-07, S-08, and S-12

- Monitor with Limit

WQBEL will be required since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Cadmium, Copper, Molybdenum, Nickel, Sulfates, Thallium

- No Limit or Monitoring

No limit or monitoring will be required since there were no detects and the MDL < WQBEL: Chromium VI, Chromium III, Antimony

- Mercury TMDL

All reported seep data was below the TBEL and the annual average WQBEL, in this case, monitoring only will be required.

Note: Since the estimated flow will be above 0.05 MGD, quarterly monitoring for Total Kjeldahl Nitrogen, TN, and TP will be required.

Outfall 009 - S-04

- Monitor with Limit

The following parameters will receive WQBEL requirements in conjunction with seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Cadmium, Chromium VI, Copper, Lead, Nickel, Selenium, Sulfates, Thallium

- No Limit or Monitoring

The following parameter will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Fluoride, Chromium III

- Mercury TMDL

All reported data was below the TBEL and the annual average WQBEL, in this case, monitoring only will be required.

Outfall 010A - S-09

- Monitor with Limit

The following parameters will receive WQBEL requirements in conjunction with seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Sulfates

- No Limit or Monitoring

The following parameter will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Antimony, Chromium VI, Chromium III

- Mercury TMDL

All reported data was below the TBEL and the annual average WQBEL, in this case, monitoring only will be required.

Outfall 010B - S-10

- Monitor with Limit

The following parameters will receive WQBEL requirements in conjunction with the seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Copper, Lead

- No Limit or Monitoring

The following parameters will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Antimony, Chromium VI, Chromium III, Fluoride

- Mercury TMDL

All reported data was below the TBEL but the annual average exceeds the WQBEL, in this case, monitoring with a WQBEL annual average will be required.

Outfall 011A – S-15

- Monitor with Limit

The following parameters will receive WQBEL requirements in conjunction with seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Molybdenum, Thallium, Sulfates

- No Limit or Monitoring

The following parameter will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Antimony, Chromium VI, Chromium III

- Mercury TMDL

All reported data was below the TBEL and the annual average WQBEL, in this case, monitoring only will be required.

Outfall 011B – S-18

There was no data available as there was insufficient flow to take a sample upon discovery and reporting by the Permittee. Adjacent seeps S-15, S-17, S-18 were considered representative so their RP Analyses and were used for determining S-18 requirements as follows:

- **Monitor with Limit**

The following parameters will receive WQBEL requirements in conjunction with seep monitoring: Arsenic, Fluoride, Molybdenum, Nickel, Sulfates, Thallium, Zinc

- **No Limit or Monitoring**

The following parameter will not receive a limit or monitoring: Antimony

- **Mercury TMDL**

With no sample there was no Mercury data. Mercury is a major parameter of concern for ash basin seeps, in this case, monitoring with a WQBEL annual average will be required.

Outfall 011C – S-16

- **Monitor with Limit**

The following parameters will receive WQBEL requirements in conjunction with the seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Arsenic, Fluoride, Nickel, Sulfates, Thallium, Zinc

- **No Limit or Monitoring**

The following parameters will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Antimony, Chromium VI, Chromium III

- **Mercury TMDL**

All reported data was below the TBEL but the annual average exceeds the WQBEL, in this case, monitoring with a WQBEL annual average will be required.

Outfall 011D – S-17

- **Monitor with Limit**

The flowing parameters will receive WQBEL requirements in conjunction with the seep monitoring, since the RP exists to violate NC WQS and EPA Criteria: Lead, Nickel, Sulfates, Zinc

- **No Limit or Monitoring**

The following parameters will not receive a limit or monitoring, since there were no detects and the MDL < WQBEL: Antimony, Fluoride, Chromium VI, Chromium III

- **Mercury TMDL**

All reported data was below the TBEL but the annual average exceeds the WQBEL, in this case, monitoring with a WQBEL annual average will be required.

Spreadsheets of the seeps RP Analyses are attached to this Fact Sheet and include Mercury data.

In addition to the requirements for each seep-based outfall, monitoring and limits will be required as listed in Table 5.

Table 5: Additional Proposed Seep-Based Outfall Requirements

Parameter	Limits/Monitoring Requirements	Basis
Flow, MGD	Monitor & Report	15A NCAC 2B .0505
pH	6.0 ≤ pH ≤ 9.0 S.U.	WQ, 15A NCAC 2B .0200
TSS	30.0 mg/L MA 100.0 mg/L DM	40 CFR 423.12(b)(4)
Oil & Grease	15.0 mg/L MA 20.0 mg/L DM	40 CFR 423.12(b)(4)
Aluminum, mg/L Nitrate/Nitrite as N, mg/l TDS, mg/L Temperature, °C Conductivity, µmho/cm	Monitor & Report	Parameters of Concern

Instream Monitoring

The current permit did not require instream monitoring. The proposed permit will require semiannual instream monitoring and reporting for Total Arsenic, Total Cadmium, Total Chromium, Total Copper, Total Lead, Total Hardness, Total Mercury (Method 1631E), Total Selenium, and Total Zinc at the locations listed in Table 6.

Table 6: Instream Monitoring Locations

Instream Sample Description	Location
Upstream Outfall 008	0.9 miles upstream from Outfall 008 in Cape Fear River
Upstream Outfall 008	50 ft upstream from Outfall 008 in Cape Fear River
Downstream Outfall 008	1.2 miles downstream from Outfall 008 in Cape Fear River
Upstream Outfall 009 (confluence with Shaddox Creek)	East side SR1916 Bridge, Shaddox Creek
Downstream Outfall 009 (confluence with Shaddox Creek)	CP&L Railroad Bridge, Shaddox Creek
Downstream 007	2,900 ft downstream from Outfall 007 in the unnamed tributary to the Cape Fear River

Summary of Proposed Changes

1. Eliminated Internal Outfall 003; Special Conditions A. (6.) Intake Screen Backwash, A. (7.) Biocide Condition, A. (8.) Domestic Wastewater Treatment Plant, A. (10.) Section 316(b) of CWA; as they are no longer applicable.
2. Modified Internal Outfalls 001 and 005 limitation pages to define the monitoring and limits requirements for the emergency overflow that may occur discharging from the West and East Ash Basins.
3. Modified Outfall 007 limitation page to define the monitoring and limit requirements for the identified seeps discharging from Outfall 007.
4. Modified Special Condition A. (19.) Chronic Toxicity Limit (Quarterly) to be re-assigned to Outfall 008.
5. Modified Supplement to Permit Cover Sheet to show the new outfalls' configuration.

6. Added new multiple Outfall 008 limitation pages to define special narratives, and the monitoring and limits requirements for various combination of treated wastewater sources of ash basin decanting, ash basin dewatering, on-site groundwater remediation, and on-site ash landfill leachate that will occur discharging from Outfall 008.
7. Added new Internal Outfall 008A limitation page to define the monitoring and limits requirements for the emergency overflow that may occur discharging from the 1963/1970 Ash Basin.
8. Added new seep-based Outfalls 009, 010A, 010B, 011A, 011B, 011C, 011D limitation pages to define the monitoring and limit requirements for identified seeps discharging to waters of the state.
9. Added instream monitoring to monitor the impact of the permitted discharges on the receiving streams.
10. Added Special Condition A. (18.) Chronic Toxicity Limit (Monthly) for decanting/dewatering activities from Outfall 008.
11. Added Special Condition A. (25.) Addition of Other Wastewater to Ash Basin Treatment Systems for submittal of EPA Form 2C upon addition of groundwater and ash landfill leachate wastewater to treatment systems.
12. Added Special Condition A. (24.) Applicable State Law narrative to meet requirements of Senate Bill 729 (Coal Ash Management Act).
13. Added Special Condition A. (26.) Discharge from Seepage to address requirements of future discovered seeps.
14. Added Special Condition A. (27.) Electronic Reporting of Discharge Monitoring Reports for electronic reporting of DMRs. Starting December 21, 2016, federal regulations require electronic submittal of all discharge monitoring reports (DMRs) and specify that, if a state does not establish a system to receive such submittals, then permittees must submit DMRs electronically to the Environmental Protection Agency (EPA).

Proposed Schedule

Draft Permit to Public Notice:	October 5, 2016
Public Hearing	November 28, 2016
Permit Scheduled to Issue:	December 2016

State Contact

If you have any questions on any of the above information or on the attached permit, please contact Ron Berry at (919) 807-6396 or ron.berry@ncdenr.gov.

Name: Ron Berry Date: 6-4-16

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

 REQUIRED DATA ENTRY

CHECK IF HQW OR ORW WQCs

Table 1. Project Information

Facility Name	WWT/WTP Class	Receiving Stream	HUC Number	Stream Class	7Q10s (cfs)	7Q10W (cfs)	30Q2 (cfs)	QA (cfs)	1Q10s (cfs)	Effluent Hardness	Upstream Hardness	Combined Hardness Chronic	Combined Hardness Acute	Data Source(s)	<input type="checkbox"/> CHECK TO APPLY MODEL
Cape Fear Steam Electric Plant	Class II	008 Ash Basin Decanting	1.930	Cape Fear River	03030002	WS-IV	0.00	0.00	0.00	25 mg/L (Avg)	25 mg/L (Avg)	25 mg/L	25 mg/L	Ash Basins 2014 - highest pollutant concentrations from each basin; default hardness: 600 GPM + 70 GPM per treatment train - two trains wih effluent mixing before discharging; USGS recommendation	<input type="checkbox"/>
	NC0003433														To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.
															To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.
															To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Table 2. Parameters of Concern

Name	wqs	Type	Chronic	Modifier	Acute	PQL	Units
Arsenic	Aquatic Life	C	150	FW	340		ug/L
Arsenic	Human Health Water Supply	C	10	HH/WS	N/A		ug/L
Beryllium	Aquatic Life	NC	6.5	FW	65		ug/L
Cadmium	Aquatic Life	NC	0.5899	FW	3.2396		ug/L
Chlorides	Water Supply	NC	250	WS			mg/L
Chlorinated Phenolic Compounds	Water Supply	NC	1	A			ug/L
Total Phenolic Compounds	Aquatic Life	NC	300	A			ug/L
Chromium III	Aquatic Life	NC	117.7325	FW	905.0818		ug/L
Chromium VI	Aquatic Life	NC	11	FW	16		ug/L
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A		ug/L
Copper	Aquatic Life	NC	7.8806	FW	10.4720		ug/L
Cyanide	Aquatic Life	NC	5	FW	22		ug/L
Fluoride	Aquatic Life	NC	1800	FW	22		ug/L
Lead	Aquatic Life	NC	2.9416	FW	75.4871		ug/L
Mercury	Aquatic Life	NC	12	FW	0.5		ng/L
Molybdate	Water Supply	NC	160	WS			ug/L
Nickel	Aquatic Life	NC	37.2313	FW	335.2087		µg/L
Nickel	Water Supply	NC	25.0000	WS	N/A		µg/L
Selenium	Aquatic Life	NC	5	FW	56		ug/L
Silver	Aquatic Life	NC	0.06	FW	0.2964		ug/L
Zinc	Aquatic Life	NC	126.7335	FW	125.7052		ug/L
Antimony	Water Supply	NC	5.6	WS			ug/L
Barium	Water Supply	NC	1	WS			mg/L
Sulfates	Water Supply	NC	250	WS			mg/L
Thallium	Water Supply	NC	0.24	WS			µg/L

Follow directions for data entry. In some cases a comment menu lists the available choices of a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Effluent Hardness				Upstream Hardness			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 Date default	25	25	Std Dev. 0.0000	1 Date default	25	25	Std Dev. 0.0000
2			Mean 25.0000	2			Mean 25.0000
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 1	4			n 1
5			10th Per value 25.00 mg/L	5			10th Per value 25.00 mg/L
6			Average Value 25.00 mg/L	6			Average Value 25.00 mg/L
7			Max. Value 25.00 mg/L	7			Max. Value 25.00 mg/L
8				8			
Arsenic				Cadmium			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	34.4	34.4	Std Dev. 3.4648	1 7/1/2014	< 1	0.5	Std Dev. 0.0000
2 10/10/2014	39.3	39.3	Mean 36.8500	2			Mean 0.5000
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 39.3 ug/L	6			Max. Value 0.500 ug/L
7			Max. Pred Cw 148.9 ug/L	7			Max. Pred Cw O DETECTS ug/L
Chlorides				Chromium III			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	33	33	Std Dev. 0.7071	1			Std Dev. NO DATA
2 10/10/2014	32	32	Mean 32.5	2			Mean NO DATA
3			C.V. (default) 0.6000	3			C.V. NO DATA
4			n 2	4			n 0
5			Mult Factor = 3.8	5			Mult Factor = N/A
6			Max. Value 33.0 mg/L	6			Max. Value N/A ug/L
7			Max. Pred Cw 125.1 mg/L	7			Max. Pred Cw N/A ug/L
8				8			
Chromium VI				Chromium, Total			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1			Std Dev. NO DATA	1 7/1/2014	< 1	0.5	Std Dev. 0.0000
2			Mean NO DATA	2 10/10/2014	< 1	0.5	Mean 0.5000
3			C.V. NO DATA	3			C.V. (default) 0.6000
4			n 0	4			n 2
5			Mult Factor = N/A	5			Mult Factor = N/A
6			Max. Value N/A ug/L	6			Max. Value N/A ug/L
7			Max. Pred Cw N/A ug/L	7			Max. Pred Cw N/A ug/L
8				8			
Copper				Fluoride			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	1.29	1.29	Std Dev. 1.5556	1 10/10/2015	299	299	Std Dev. 333.0473
2 10/10/2014	3.49	3.49	Mean 2.9300	2 10/10/2015	770	770	Mean 534.5000
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 3.49 ug/L	6			Max. Value 770.0 ug/L
7			Max. Pred Cw 13.23 ug/L	7			Max. Pred Cw 2918.3 ug/L
8				8			
Lead				Mercury			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	< 1	0.5	Std Dev. 0.0000	1 7/1/2014	< 1000	500	Std Dev. 727966.4312
2 10/10/2014	< 1	0.5	Mean 0.5000	2 10/10/2014	< 1E+06	1030000	Mean 515250.0000
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 0.500 ug/L	6			Max. Value 1030000.0 ng/L
7			Max. Pred Cw O DETECTS ug/L	7			Max. Pred Cw 3903700.0 ng/L
8				8			
Molybdenum				Nickel			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	192	192	Std Dev. 9.8995	1 7/1/2014	3.67	3.67	Std Dev. 28.1644
2 10/10/2014	178	178	Mean 185.0000	2 10/10/2015	43.5	43.5	Mean 23.5850
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 192.0 ug/L	6			Max. Value 43.5 ug/L
7			Max. Pred Cw 727.7 ug/L	7			Max. Pred Cw 164.9 ug/L
8				8			
Selenium				Zinc			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	65.7	65.7	Std Dev. 12.0915	1 7/1/2014	< 5	2.5	Std Dev. 192.5656
2 10/10/14	48.6	48.6	Mean 57.1500	2 10/10/2014	< 275	275	Mean 138.7500
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 65.7 ug/L	6			Max. Value 275.0 ug/L
7			Max. Pred Cw 249.0 ug/L	7			Max. Pred Cw 1042.3 ug/L
8				8			
Antimony				Barium			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	< 1	0.5	Std Dev. 0.0000	1 7/1/2014	0.179	0.179	Std Dev. 0.0127
2 10/10/2014	< 1	0.5	Mean 0.5000	2 10/10/2014	0.161	0.161	Mean 0.1700
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 0.500000 ug/L	6			Max. Value 0.178000 mg/L
7			Max. Pred Cw O DETECTS ug/L	7			Max. Pred Cw 0.678410 mg/L
8				8			
Sulfates				Thallium			
Date	Data	BDL=1/2DL	Results	Date	Data	BDL=1/2DL	Results
1 7/1/2014	91	91	Std Dev. 13.4350	1 7/1/2014	0.664	0.664	Std Dev. 0.4839
2 10/10/2014	110	110	Mean 100.5000	2 10/10/2014	1.32	1.32	Mean 0.9520
3			C.V. (default) 0.6000	3			C.V. (default) 0.6000
4			n 2	4			n 2
5			Mult Factor = 3.79	5			Mult Factor = 3.79
6			Max. Value 110.000000 mg/L	6			Max. Value 1.320000 ug/L
7			Max. Pred Cw 416.900000 mol/L	7			Max. Pred Cw 0.502800 ug/L
8				8			

Cape Fear Steam Electric Plant
NC00003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Q_w (MGD) = 1.93
1Q10S (cfs) = 0.00
7Q10S (cfs) = 0.00
7Q10W (cfs) = 0.00
30Q2 (cfs) = 0.00
Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: Cape Fear River HUC 0303030002

WWTP/WTP Class: Class II
IWC% @ 1Q10S = 100
IWC% @ 7Q10S = 100
IWC% @ 7Q10W = 100
IWC% @ 30Q2 = 100
IW%C @ QA = 100
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		# Det.	Max Pred Cw	REASONABLE POTENTIAL RESULTS		RECOMMENDED ACTION	
		Chronic	Applied Standard			# n	Acute (FW); Chronic (FW); No value > Allowable Cw Chronic (HH); 2 value(s) > Allowable Cw	Acute (FW); Chronic: Max MDL = 1 Acute: NO WQS	RP shown - apply Monthly Monitoring with Limit
Arsenic	C	150	FW	340	ug/L	2	2	148.9 Default C.V. Note: n ≤ 9 Limited data set	340.0
Arsenic	C	10	HH/W/S		ug/L				
Cadmium	NC	0.5899	FW	3.2396	ug/L	2	0	NO DETECTS	
Chlorides	NC	250	WS		mg/L	2	2	125.1 Default C.V. Note: n ≤ 9 Limited data set	0.590 No detects, MDL > Allowable Cw and > PQL - apply Monthly Monitoring required
Chromium III	NC	117.7325	FW	905.0818	μg/L	0	0	N/A Default C.V. Note: n ≤ 9 Limited data set	250.0 No RP, Predicted Max ≥ 50% of Allowable Cw - apply Monthly Monitoring
Chromium VI	NC	11	FW	16	μg/L	0	0	N/A Default C.V. Note: n ≤ 9 Limited data set	905.1 Acute: NO WQS
Chromium, Total	NC				μg/L	2	0	NO DETECTS	
Copper	NC	7.8806	FW	10.4720	ug/L	2	2	13.23 Default C.V. Note: n ≤ 9 Limited data set	10.47 Acute: NO WQS
Fluoride	NC	1800	FW		ug/L	2	2	2,918.3 Default C.V. Note: n ≤ 9 Limited data set	7.88 RP shown - apply Monthly Monitoring with Limit
Lead	NC	2.9416	FW	75.4871	ug/L	2	0	NO DETECTS Default C.V. Note: n ≤ 9 Limited data set	75.487 RP shown - apply Monthly Monitoring with Limit
									2.942 Max MDL = 1 No detects, MDL < Allowable Cw - No Monitoring required

Cape Fear Steam Electric Plant
NC0003433

Outfall 008 Ash Basin Decanting
Qw = 1.93 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Transators										
Mercury	NC	12	FW	0.5 ng/L	2	1	3,903,700.0 Default C.V.	Acute:	NO WQS	
Molybdenum	NC	160	WS	ug/L	2	2	727.7 Default C.V.	Chronic: 12.0 2 value(s) > Allowable C _W	All values > TBEL and WQBEL - apply Monthly monitoring with 12 ng/L WQBEL annual average	
Nickel	NC	37.2313	FW	335.2087	μg/L	2	2	164.9 Default C.V.	Acute: NO WQS	
Nickel	NC	25.0000	WS	μg/L	2	2	72.7 Default C.V.	Chronic (FW): 160.0 2 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit	
Selenium	NC	5	FW	56	ug/L	2	2	249.0 Default C.V.	Chronic (FW): 335.2 1 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit
Zinc	NC	126.7335	FW	125.7052	ug/L	2	1	1,042.3 Default C.V.	Chronic: 25.0 1 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit
Antimony	NC	5.6	WS	μg/L	2	0	NO DETECTS	Chronic: 5.0 1 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit	
Barium	NC	1	WS	mg/L	2	2	0.67841 Default C.V.	Chronic: 125.7 1 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit	
Sulfates	NC	250	WS	mg/L	2	2	416,90000 Default C.V.	Chronic: 126.7 1 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit	
Thallium	NC	0.24	WS	μg/L	2	2	5,00280 Default C.V.	Chronic: 250,00000 2 value(s) > Allowable C _W	RP shown - apply Monthly Monitoring with Limit	

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
WWTP/WTP Class	Cape Fear Steam Electric Plant	
NPDES Permit	Class II	
Outfall	NCC003433	
Flow, Qw (MGD)	008 - Ash Basin Dewatering	
Receiving Stream	1.930	
HUC Number	Cape Fear River	
Stream Class	03030002	
7Q10s (cfs)	WS-IV	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	25 mg/L (Avg)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	25 mg/L	
Combined Hardness Acute	25 mg/L	
Data Source(s)	Ash Basins Interstitial Water Data 2014 - highest pollutant concentration, default hardness 25 mg/L; 600 GPM + 70 GPM per treatment train; two trains with effluent mixed before discharging; USGS recommendation <input type="checkbox"/> CHECK TO APPLY MODEL	

C REQUIRED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Arsenic	Aquatic Life	C	150	FW	340	ug/L	
Arsenic	Human Health Water Supply	C	10	HHWS	N/A	ug/L	
Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L	
Cadmium	Aquatic Life	NC	0.5899	FW	3.2396	ug/L	
Chlorides	Water Supply	NC	250	WS		mg/L	
Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Chromium III	Aquatic Life	NC	117.7325	FW	905.0818	ug/L	
Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Copper	Aquatic Life	NC	7.8806	FW	10.4720	ug/L	
Cyanide	Aquatic Life	NC	5	FW	22	ug/L	
Fluoride	Aquatic Life	NC	1800	FW	22	ug/L	
Lead	Aquatic Life	NC	2.9416	FW	75.4871	ug/L	
Mercury	Aquatic Life	NC	12	FW	0.5	ng/L	
Molybdenum	Water Supply	NC	160	WS		ug/L	
Nickel	Aquatic Life	NC	37.2313	FW	335.2087	ug/L	
Nickel	Water Supply	NC	25,000	WS	N/A	ug/L	
Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Silver	Aquatic Life	NC	0.06	FW	0.2964	ug/L	
Zinc	Aquatic Life	NC	126.7335	FW	125.7052	ug/L	
Antimony	Water Supply	NC	5.6	WS		ug/L	
Barium	Water Supply	NC	1	WS		mg/L	
Sulfates	Water Supply	NC	250	WS		mg/L	
Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Arsenic									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	656	556	Std Dev.	0.0000	1/15/2015 <	10	BDL=1/2DL	Results	5 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Average Value	25.00 mg/L	10th Per Value	25.00 mg/L	7	Max Value	25.00 mg/L	Average Value	25.00 mg/L
8	Max Value	25.00 mg/L	10th Per Value	25.00 mg/L	9	Max Pred CW	4067.2 ug/L	Max Pred CW	4067.2 ug/L
Chromium III									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	29.97	29.97	Std Dev.	0.0000	1/15/2015	10	BDL=1/2DL	Results	5 Std Dev.
2	Mean C.V. (default)	0.30	CV. (default)	0.30	3	Mean C.V. (default)	0.30	CV. (default)	0.30
4	n	1	n	1	5	Mean C.V. (default)	0.30	CV. (default)	0.30
6	Max Value	N/A	Max Pred CW	185.6 mg/L	7	Min Factor	6.20	Max Pred CW	185.6 mg/L
8	Max Pred CW	185.6 mg/L	Min Factor	6.20	9	Max Value	252.90 ug/L	Max Pred CW	252.90 ug/L
Chromium, Total									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	ND DATA	ND DATA	Std Dev.	0.0000	1/15/2015	155	BDL=1/2DL	Results	155 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	N/A	Max Pred CW	981.0 ug/L	7	Min Factor	6.20	Max Pred CW	981.0 ug/L
8	Max Pred CW	981.0 ug/L	Min Factor	6.20	9	Max Value	2208.0 ug/L	Max Pred CW	2208.0 ug/L
Copper									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	408	408	Std Dev.	0.0000	1/15/2015	2208	BDL=1/2DL	Results	2208 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	N/A	Max Pred CW	981.0 ug/L	7	Min Factor	6.20	Max Pred CW	981.0 ug/L
8	Max Pred CW	981.0 ug/L	Min Factor	6.20	9	Max Value	252.90 ug/L	Max Pred CW	252.90 ug/L
Lead									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	112	112	Std Dev.	0.0000	1/15/2015	112	BDL=1/2DL	Results	112 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	9760000.0 ug/L	Max Pred CW	47420000.0 ug/L	7	Min Factor	6.20	Max Pred CW	9760000.0 ug/L
8	Max Pred CW	9760000.0 ug/L	Min Factor	6.20	9	Max Value	1120000 ug/L	Max Pred CW	1120000 ug/L
Molybdenum									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	316	316	Std Dev.	0.0000	1/15/2015	122	BDL=1/2DL	Results	122 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	1220000	Max Pred CW	1220000	7	Min Factor	6.20	Max Pred CW	1220000
8	Max Pred CW	1220000	Min Factor	6.20	9	Max Value	316000 ug/L	Max Pred CW	316000 ug/L
Selenium									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	426	426	Std Dev.	0.0000	1/15/2015	538	BDL=1/2DL	Results	538 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	538000	Max Pred CW	538000	7	Min Factor	6.20	Max Pred CW	538000
8	Max Pred CW	538000	Min Factor	6.20	9	Max Value	13958.2 ug/L	Max Pred CW	13958.2 ug/L
Antimony									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	441	441	Std Dev.	0.0000	1/15/2015	496	BDL=1/2DL	Results	496 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	4410000	Max Pred CW	4410000	7	Min Factor	6.20	Max Pred CW	4410000
8	Max Pred CW	4410000	Min Factor	6.20	9	Max Value	620000 ug/L	Max Pred CW	620000 ug/L
Barium									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	5000	5000	Std Dev.	0.0000	1/15/2015	148	BDL=1/2DL	Results	148 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	148000	Max Pred CW	148000	7	Min Factor	6.20	Max Pred CW	148000
8	Max Pred CW	148000	Min Factor	6.20	9	Max Value	62000 ug/L	Max Pred CW	62000 ug/L
Sulfates									
Date	Data	BDL=1/2DL	Results	Std Dev.	Date	Data	BDL=1/2DL	Results	Std Dev.
1/15/2015	441	441	Std Dev.	0.0000	1/15/2015	496	BDL=1/2DL	Results	496 Std Dev.
2	Mean C.V. (default)	0.6000	CV. (default)	0.6000	3	Mean C.V. (default)	0.6000	CV. (default)	0.6000
4	n	1	n	1	5	Mean C.V. (default)	0.6000	CV. (default)	0.6000
6	Max Value	4410000	Max Pred CW	4410000	7	Min Factor	6.20	Max Pred CW	4410000
8	Max Pred CW	4410000	Min Factor	6.20	9	Max Value	620000 ug/L	Max Pred CW	620000 ug/L

Cape Fear Steam Electric Plant

NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Outfall 008 - Ash Basin Dewatering

MAXIMUM DATA POINTS = 58

Qw (MGD) = 1.93

1Q10S (cfs) = 0.00

7Q10S (cfs) = 0.00

7Q10W (cfs) = 0.00

30Q2 (cfs) = 0.00

Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: Cape Fear River HUC 030300002
Stream Class: WS-IV

WWTP/WTP Class: Class I

IWC% @ 1Q10S = 100

IWC% @ 7Q10S = 100

IWC% @ 7Q10W = 100

IWC% @ 30Q2 = 100

IWC% @ QA = 100

Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

COMBINED HARDNESS (mg/L)
Acute = 25 mg/L
Chronic = 25 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		\overline{C}_d	S _{LIN}	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Applied Standard			Acute	# Det.	Max P-Ped C _w	
Arsenic	C	150	FW	340	ug/L	1	1	4,067.2	Acute (FW): 340.0 Chronic (FW): 150.0 1 value(s) > Allowable C _w Chronic (HH): 10.0 1 value(s) > Allowable C _w
Arsenic	C	10	HH/WS		ug/L	Note: n ≤ 9	Limited data set		RP shown - apply Weekly Monitoring with Limit
Cadmium	NC	0.5899	FW	3,2396	ug/L	1	0	NO DETECTS	Acute: 3,240 Chronic: 0.590 Max MDL = 10
Chlorides	NC	250	WS		mg/L	1	1	185.8	Acute: NO WQS Chronic: 250.0 No value > Allowable C _w
Chromium III	NC	117,7325	FW	905,0818	ug/L	0	0	N/A	Acute: 905.1 Chronic: 117.7
Chromium VI	NC	11	FW	16	μg/L	0	0	N/A	Acute: 16.0 Chronic: 11.0
Chromium, Total	NC				μg/L	1	1	Tot Cr value(s) > 50 with 1 Tot Cr value(s) ≥ Cr III Allowable C _w Note: n ≤ 9 Limited data set	RP shown - apply Weekly Monitoring with Limit d. Limit both Chromium III and Chromium VI when any Total Chromium sample is ≥ 50 ug/L, and ≥ to the Allowable C _w for Chromium III. Monitor for Total Chromium and Chromium VI, report the calculated Chromium III.
Copper	NC	7.8806	FW	10,4720	ug/L	1	1	2,529.60	Acute: 10.47 Chronic: 7.88 1 value(s) > Allowable C _w
Fluoride	NC	1800	FW		ug/L	1	1	13,689.6	Acute: NO WQS Chronic: 1,800.0 1 value(s) > Allowable C _w
Lead	NC	2.9416	FW	75,4871	ug/L	1	1	694,400	Acute: 75.487 Chronic: 2,942 1 value(s) > Allowable C _w

Cape Fear Steam Electric Plant

Outfall 008 - Ash Basin Dewatering

Qw = 1.93 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
NC0003433		Mercury		FW		0.5 ng/L		1	
	NC	12	FW						
	NC	160	WS						
Molybdenum	NC	160	WS	ug/L	1	1	1,959.2	Default C.V.	Chronic: 12.0 1 value(s) > Allowable C _w
Nickel	NC	37.2313	FW	335.2087	μg/L	1	1	756.4	Chronic (FW): 160.0 1 value(s) > Allowable C _w
Nickel	NC	25.0000	WS		μg/L	1	1	Default C.V.	Acute (FW): 335.2 RP shown - apply Weekly Monitoring with Limit
Selenium	NC	5	FW	56	ug/L	1	1	2,641.2	Chronic (FW): 37.2 1 value(s) > Allowable C _w
Zinc	NC	126.7335	FW	125.7052	ug/L	1	1	3,235.6	Chronic (FW): 25.0 1 value(s) > Allowable C _w
Antimony	NC	5.6	WS		μg/L	1	0	NO DETECTS	Acute: 56.0 RP shown - apply Weekly Monitoring with Limit
Barium	NC	1	WS		mg/L	1	1	9,17600	Chronic: 5.0 1 value(s) > Allowable C _w
Sulfates	NC	250	WS		mg/L	1	1	2,734.20000	Chronic: 126.7 1 value(s) > Allowable C _w
Thallium	NC	0.24	WS		μg/L	1	1	30.75200	Chronic: 126.7 1 value(s) > Allowable C _w

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

REQUERED DATA ENTRY

Table 1. Project Information

Facility Name	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
Cape Fear Steam Electric Plant		
WWTP/WTP Class	Class II	
NPDES Permit	NC0003433	
Outfall	011D Seep S-17	
Flow, Qw (MGD)	0.002	
Receiving Stream	Cape Fear River	
HUC Number	03030002	
Stream Class	WS-IV	
7Q10s (cfs)	0.00	
7Q10W (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	default 99 mg/L-WS (Eff Hard Avg = 1030 mg/L)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	99 mg/L	
Combined Hardness Acute	99 mg/L	
Data Source(s)	AOW data; USGS recommendation; Raleigh Regional Office evaluation	
<input type="checkbox"/> CHECK TO APPLY MODEL		

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifer	Acute	PQL	Units
Arsenic	Aquatic Life	C	150	FW	340	ug/L	
Arsenic	Human Health Water Supply	C	10	HHWS	N/A	ug/L	
Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L	
Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	ug/L	
Chlorides	Water Supply	NC	250	WS		mg/L	
Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Cyanide	Aquatic Life	NC	5	FW	22	10	ug/L
Fluoride	Aquatic Life	NC	1.800	FW		ug/L	
Lead	Aquatic Life	NC	13.5358	FW	347.3518	ug/L	
Mercury	Aquatic Life	NC	12	FW		0.5 mg/L	
Molybdenum	Water Supply	NC	160	WS		ug/L	
Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Nickel	Water Supply	NC	25.0000	WS	N/A	ug/L	
Selenium	Aquatic Life	NC	5	FW	66	ug/L	
Silver	Aquatic Life	NC	0.06	FW	3.1616	ug/L	
Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Antimony	Water Supply	NC	5.6	WS		ug/L	
Barium	Water Supply	NC	1	WS		mg/L	
Sulfates	Water Supply	NC	250	WS		mg/L	
Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

To follow directions for data entry: In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error messages occur if data entry does not meet input criteria.

Cape Fear Steam Electric Plant
NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.002

1Q10S (cfs) = 0.00

7Q10S (cfs) = 0.00

7Q10W (cfs) = 0.00

30Q2 (cfs) = 0.00

Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: Cape Fear River HUC 030300002

Outfall 011D Seep S-17
Qw = 0.002 MGD

WWTP/WWTP Class: Class II
IWC% @ 1Q10S = 100
IWC% @ 7Q10S = 100
IWC% @ 7Q10W = 100
IWC% @ 30Q2 = 100
IW%C @ QA = 100
Effluent Hard: 1 value > 100 mg/L
default 99 mg/L-W/S (Eff Hard Avg = 1030 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			# SAMPLES	n	# Det.	Max Pred Cw	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Acute	Applied Standard					Acute (FW):	Chronic (FW):	Acute (FW):	
Arsenic	C	150	FW	340	ug/L	1	0	NO DETECTS	Max MDL = 1	150.0	No detects, MDL < Allowable Cw - apply seep Monitoring	
Arsenic	C	10	HH/W/S		ug/L	Note: n ≤ 9	Limited data set	NO DETECTS	Max MDL = 1	10.0	No detects, MDL < Allowable Cw - apply seep Monitoring	
Cadmium	NC	1.6678	FW	10.7582	ug/L	1	0	NO DETECTS	Acute:	0.758		
Chlorides	NC	250	WS		mg/L	1	1	105.4	Chronic:	1,668	No detects, MDL < Allowable Cw - apply seep Monitoring	
Chromium III	NC	363.4201	FW	2793.8313	ug/L	0	0	N/A	Max MDL = 1	250.0	No RP , Predicted Max < 50% of Allowable Cw - apply seep Monitoring	
Chromium VI	NC	11	FW	16	ug/L	0	0	N/A	Acute:	2,793.8	No value > Allowable Cw	
Chromium, Total	NC				ug/L	1	0	NO DETECTS	Chronic:	363.4		
Copper	NC	25.5442	FW	38.2981	ug/L	1	0	NO DETECTS	Max MDL = 1	Acute:	38.30	
Fluoride	NC	1800	FW		ug/L	1	0	NO DETECTS	Chronic:	25.54	No detects, MDL < Allowable Cw - apply seep Monitoring	
Lead	NC	13.5358	FW	347.3518	ug/L	1	1	23.498	Default C.V.	1,800.0	No detects, MDL < Allowable Cw - No Monitoring required	
					Note: n ≤ 9	Limited data set	NO DETECTS	Acute:	Chronic:	347.352	Acute:	13.536
					NO DETECTS	Default C.V.	NO value > Allowable Cw	Chronic:	RP shown - apply seep Monitoring with Limit	No value > Allowable Cw	RP shown - apply seep Monitoring with Limit	

Cape Fear Steam Electric Plant
NC0003433

Outfall 011D Seep S-17
Qw = 0.002 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5	ng/L	1	0	NO DETECTS	Acute: NO WQS
					Note: n ≤ 9				Chronic: 12.0 Max MDL = 50
					Limited data set				No detects, MDL > TBEL - apply seep Monitoring with QBEL annual avg
Molybdenum	NC	160	WS	ug/L	1	0	NO DETECTS	Acute: NO WQS	
					Note: n ≤ 9				Chronic: 160.0
					Limited data set				No detects, MDL < Allowable Cw - apply seep Monitoring
Nickel	NC	119.2776	FW	1073.9039	µg/L	1	1	148.2	Acute (FW): 1,073.9
					Note: n ≤ 9				Chronic (FW): 119.3
					Limited data set				No value ≥ Allowable Cw
Nickel	NC	25.0000	WS	ug/L	1	1	148.2	Acute (FW): 1,073.9	Chronic (WS): 25.0
					Note: n ≤ 9				No value ≥ Allowable Cw
					Limited data set				RP shown - apply seep Monitoring with Limit
Selenium	NC	5	FW	56	ug/L	1	0	NO DETECTS	Acute: 56.0
					Note: n ≤ 9				Chronic: 5.0
					Limited data set				No detect, MDL < Allowable Cw - apply seep Monitoring
Zinc	NC	406.7415	FW	403.4414	ug/L	1	1	607.6	Acute: 403.4
					Note: n ≤ 9				Chronic: 406.7
					Limited data set				No value > Allowable Cw
Antimony	NC	5.6	WS	ug/L	1	0	NO DETECTS	Acute: NO WQS	
					Note: n ≤ 9				Chronic: 5.6000
					Limited data set				No RP, Predicted Max < 50% of Allowable Cw - required
Barium	NC	1	WS	mg/L	1	1	0.11160	Acute: NO WQS	
					Note: n ≤ 9				Chronic: 1.00000
					Limited data set				No detect, MDL < Allowable Cw - No Monitoring required
Sulfates	NC	250	WS	mg/L	1	1	8,680.00000	Acute: NO WQS	
					Note: n ≤ 9				Chronic: 250.00000
					Limited data set				RP shown - apply seep Monitoring with Limit
Thallium	NC	0.24	WS	µg/L	1	0	NO DETECTS	Acute: NO WQS	
					Note: n ≤ 9				Chronic: 0.24000
					Limited data set				No detect, MDL < Allowable Cw - apply seep Monitoring
									Max MDL = 0.2

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
WWTP/WWTP Class	Cape Fear Steam Electric Plant	
NPDES Permit	Class II	
Outfall	NCC003433	
Flow, Qw (MGD)	011C Seep S-16	
Receiving Stream	0.009	
HUC Number	Cape Fear River	
Stream Class	03030002	
7Q10s (cfs)	WS-IV	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	default 99 mg/L-WS (Eff Hard Avg = 1165 mg/L)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	99 mg/L	
Combined Hardness Acute	99 mg/L	
Data Source(s)	AOW data; USGS recommendation; Raleigh Regional Office evaluation	
	<input type="checkbox"/> CHECK TO APPLY MODEL.	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message will appear if data entry does not meet input criteria.

REQUERED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01 Aromatic	Aquatic Life	C	150	FW	340	ug/L	
Par02 Arsenic	Human Health Water Supply	C	10	HHWS	N/A	ug/L	
Par03 Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L	
Par04 Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	ug/L	
Par05 Chlorides	Water Supply	NC	250	WS		mg/L	
Par06 Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Par07 Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Par08 Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Par09 Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Par10 Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Par11 Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Par12 Cyanide	Aquatic Life	NC	5	FW	22	ug/L	
Par13 Fluoride	Aquatic Life	NC	1,800	FW	56	ug/L	
Par14 Lead	Aquatic Life	NC	13.5358	FW	347.3518	ug/L	
Par15 Mercury	Aquatic Life	NC	12	FW	0.5	ng/L	
Par16 Molybdenum	Water Supply	NC	160	WS		ug/L	
Par17 Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Par18 Nickel	Water Supply	NC	25,000	WS	N/A	ug/L	
Par19 Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Par20 Silver	Aquatic Life	NC	0.06	FW	3,1616	ug/L	
Par21 Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Par22 Antimony	Water Supply	NC	5.6	WS		ug/L	
Par23 Barium	Water Supply	NC	1	WS		mg/L	
Par24 Sulfates	Water Supply	NC	250	WS		mg/L	
Par25 Thallium	Water Supply	NC	0.24	WS		ug/L	

Effluent Hardness											
Upstream Hardness											
Cadmium											
Chromium III											
Chromium VI											
Copper											
Lead											
Mercury											
Molybdenum											
Selenium											
Zinc											
Antimony											
Barium											
Boron											
Cadmium											
Chromium											
Copper											
Iron											
Manganese											
Nickel											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											
Sulfur											

Cape Fear Steam Electric Plant

NC00003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

$$Q_w (\text{MGD}) = 0.009$$

$$1Q10S (\text{cfs}) = 0.00$$

$$7Q10S (\text{cfs}) = 0.00$$

$$7Q10W (\text{cfs}) = 0.00$$

$$30Q2 (\text{cfs}) = 0.00$$

$$\text{Avg. Stream Flow, QA (cfs)} = 0.00$$

Receiving Stream: Cape Fear River HUC 0303030002

Outfall 011C Seep S-16

$Q_w = 0.009 \text{ MGD}$

COMBINED HARDNESS (mg/L)
 Acute = 99 mg/L
 Chronic = 99 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
 Effluent Hard: 2 value > 100 mg/L
 default 99 mg/L-WS (Eff Hard Avg = 1165 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			S _{INT}	n	# Det.	Max Pred C _w	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION			
		Chronic	Applied Standard	Acute					\overline{C}_d	Chronic (FW): 2 value(s) > Allowable C _w Chronic (HH): 5 value(s) > Allowable C _w	Acute (FW): 2 value(s) > Allowable C _w Chronic (HH): 5 value(s) > Allowable C _w	Chronic (FW): 2 value(s) > Allowable C _w Chronic (HH): 5 value(s) > Allowable C _w	Acute: 10.758	Chronic: 1.668	No detects, 4 of 5 MDLs < Allowable C _w - apply seep Monitoring
Arsenic	C	150	FW	340	ug/L	5	5	591.6	Default C.V. Note: n ≤ 9 Limited data set	Chronic (FW): 2 value(s) > Allowable C _w Chronic (HH): 5 value(s) > Allowable C _w	Acute (FW): 2 value(s) > Allowable C _w Chronic (HH): 5 value(s) > Allowable C _w	Acute: 340.0	Chronic: 150.0	RP shown - apply seep Monitoring with Limit	
Arsenic	C	10	HH/WS		ug/L										
Cadmium	NC	1.6678	FW	10.7582	ug/L	5	0	NO DETECTS							
Chlorides	NC	250	WS		mg/L	5	5	34.8	Default C.V. Note: n ≤ 9 Limited data set	Chronic: 250.0 No value > Allowable C_w	Acute: 2,793.8	Chronic: 250.0 No value > Allowable C_w	Acute: 2,793.8	Chronic: 250.0 No RP, Predicted Max < 50% of Allowable C_w - apply seep Monitoring	No WQS
Chromium III	NC	363.4201	FW	2793.8313	μg/L	0	0	N/A							
Chromium VI	NC	11	FW	16	μg/L	0	0	N/A							
Chromium, Total	NC				μg/L	5	0	NO DETECTS							
Copper	NC	25.5442	FW	38.2981	ug/L	5	2	11.60	Default C.V. Note: n ≤ 9 Limited data set	Chronic: 25.54 No value > Allowable C_w	Acute: 38.30	Chronic: 25.54 No value > Allowable C_w	Acute: 38.30	Chronic: 25.54 No RP, Predicted Max < 50% of Allowable C_w - apply seep Monitoring	No WQS
Fluoride	NC	1800	FW		ug/L	3	3	7,800.0	Default C.V. Note: n ≤ 9 Limited data set	Chronic: 1,800.0 3 value(s) > Allowable C_w	Acute: 347.352	Chronic: 1,800.0 3 value(s) > Allowable C_w	Acute: 347.352	Chronic: 1,800.0 RP shown - apply seep Monitoring with Limit	No WQS
Lead	NC	13.5358	FW	347.3518	ug/L	5	0	NO DETECTS							

Cape Fear Steam Electric Plant
NC0003433

Outfall 011C Seep S-16
Qw = 0.009 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5 ng/L	4	3	2.9	Default C.V.	Acute: NO WQS
				Note: n ≤ 9					Chronic: 12.0 All values < WQBEL and < TBEL - apply seep Monitoring
Molybdenum	NC	160	WS	ug/L	5	2	16.8	Default C.V.	Acute: NO WQS
				Note: n ≤ 9					Chronic: 160.0 No value > Allowable Cw - apply seep Monitoring
Nickel	NC	119.2776	FW	1073.9039	μg/L	5	5	582.3	Acute (FW): 1,073.9
				Note: n ≤ 9				Default C.V.	Chronic (FW): 119.3 5 value(s) > Allowable Cw Chronic (WS): 25.0 5 value(s) > Allowable Cw
Nickel	NC	25.0000	WS		μg/L				RP shown - apply seep Monitoring with Limit
Selenium	NC	5	FW	56	ug/L	5	0	NO DETECTS	Acute: 56.0
				Note: n ≤ 9					No detects, 4 of 5 MDLs < Allowable Cw - apply seep Monitoring
				Limited data set				Max MDL = 10	Chronic: 5.0 Acute: 403.4
Zinc	NC	406.7415	FW	403.4414	ug/L	5	5	1,480.2	Chronic: 406.7 5 value(s) > Allowable Cw
				Note: n ≤ 9					RP shown - apply seep Monitoring with Limit
Antimony	NC	5.6	WS		μg/L	5	0	NO DETECTS	Acute: NO WQS
				Note: n ≤ 9					Chronic: 5.60000 No detects, 4 of 5 MDLs < Allowable Cw - No Monitoring required
Barium	NC	1	WS		mg/L	5	4	0.08584	Acute: NO WQS
				Limited data set				Max MDL = 10	Chronic: 1,00000 No value > Allowable Cw
Sulfates	NC	250	WS		mg/L	5	5	6,264.00000	Acute: NO WQS
				Note: n ≤ 9				Default C.V.	Chronic: 250.00000 5 value(s) > Allowable Cw
Thallium	NC	0.24	WS		μg/L	5	4	2.32000	Acute: NO WQS
				Note: n ≤ 9				Default C.V.	Chronic: 0.24000 5 value(s) > Allowable Cw
				Limited data set					RP shown - apply seep Monitoring with Limit

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Table 1. Project Information

Project Information		<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
Facility Name	Cape Fear Steam Electric Plant	WQS	Type
WWTP/WTP Class	Class II	Chronic	Modifier
NPDES Permit	NC0003433	Acute	PQL
Outfall	011A Seep S-15	FW	Units
Flow, Qw (MGD)	0.009	HHWS	ug/L
Receiving Stream	Cape Fear River	N/A	ug/L
HUC Number	03030002	6.5	ug/L
Stream Class	WS-IV	1.6678	ug/L
7Q10s (cfs)	0.00	250	mgl/L
7Q10w (cfs)	0.00	WS	ug/L
30Q2 (cfs)	0.00	1	ug/L
QA (cfs)	0.00	A	ug/L
1Q10s (cfs)	0.00	300	ug/L
Effluent Hardness	default 99 mg/L-WS (Eff Hard Avg = 327 mg/L)	NC	ug/L
Upstream Hardness	25 mg/L (Avg)	363.4201	ug/L
Combined Hardness Chronic	99 mg/L	FW	ug/L
Combined Hardness Acute	99 mg/L	2793.8313	ug/L
Data Source(s)	AOW data, USGS recommendation; Raleigh Regional Office evaluation	FW	ug/L
<input type="checkbox"/> CHECK TO APPLY MODEL			

REQUIRED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01 Aarsenic	Human Health Water Supply	C	150	FW	340	ug/L	
Par02 Arsenic	Aquatic Life	C	10	HHWS	N/A	ug/L	
Par03 Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L	
Par04 Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	ug/L	
Par05 Chlorides	Water Supply	NC	250	WS		mgl/L	
Par06 Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Par07 Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Par08 Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Par09 Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Par10 Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Par11 Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Par12 Cyanide	Aquatic Life	NC	5	FW	22	10 ug/L	
Par13 Fluoride	Aquatic Life	NC	1.800	FW		ug/L	
Par14 Lead	Aquatic Life	NC	13.5358	FW	347.3518	ug/L	
Par15 Mercury	Aquatic Life	NC	12	FW	0.5	ug/L	
Par16 Molybdenum	Water Supply	NC	160	WS		ug/L	
Par17 Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Par18 Nickel	Water Supply	NC	25.0000	WS	N/A	ug/L	
Par19 Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Par20 Silver	Aquatic Life	NC	0.06	FW	3.1616	ug/L	
Par21 Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Par22 Antimony	Water Supply	NC	5.6	WS		ug/L	
Par23 Barium	Water Supply	NC	1	WS		mg/L	
Par24 Sulfates	Water Supply	NC	250	WS		mg/L	
Par25 Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Cape Fear Steam Electric Plant

NC00003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Q_w (MGD) = 0.01

1Q10S (cfS) = 0.00

7Q10S (cfS) = 0.00

7Q10W (cfS) = 0.00

3Q2 (cfS) = 0.00

Avg. Stream Flow, QA (cfS) = 0.00

Receiving Stream: Cape Fear River HUC 030300002

Outfall 011A Seep S-15 Q_w = 0.009 MGD

WWTP/WTP Class: Class II
IWC% @ 1Q10S = 100
IWC% @ 7Q10S = 100
IWC% @ 7Q10W = 100
IWC% @ 3Q2 = 100
IW%C @ QA = 100
Stream Class: WS-IV

Acute = 99 mg/L
Chronic = 99 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 3 value > 100 mg/L
default 99 mg/L-W/S (Eff Hard Avg = 327 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			# Det.	Max Pred Cw	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			\overline{C}_d	$S_{\overline{C}_d}$	Allowable Cw	
Arsenic	C	150	FW	340	ug/L	5	5	232.0	Acute (FW): Chronic (FW): 150.0	
Arsenic	C	10	HH/WS		ug/L	Note: n ≤ 9 Limited data set	Default C.V.		No RP shown - apply seep Monitoring with Limit	
Cadmium	NC	1,6678	FW	10,7582	ug/L	5	0	NO DETECTS	RP shown - apply seep Monitoring with Limit	
Chlorides	NC	250	WS		mg/L	Note: n ≤ 9 Limited data set	Default C.V.		Acute: 10.758 Chronic: 1,668 Max MDL = 1	No detects, MDL < Allowable Cw - apply seep Monitoring
Chromium III	NC	363,4201	FW	2793,8313	µg/L	0	0	N/A	Acute: NO WQS Chronic: 250.0 No RP , Predicted Max ≥ 50% of Allowable Cw - apply seep Monitoring	
Chromium VI	NC	11	FW	16	µg/L	0	0	N/A	Acute: 2,793.8 Chronic: 363.4	
Chromium, Total	NC				µg/L	5	1	5.8	Tot Cr value(s) < 50 and < Cr VI Allowable Cw Max reported value = 2.5	a. All Total Chromium samples are < the Chromium VI Allowable Cw - apply seep monitoring
Copper	NC	25,5442	FW	38,2981	ug/L	5	1	5.80	Acute: 38.30 Chronic: 25.54 No value > Allowable Cw	b. Predicted Max < 50% of Allowable Cw - apply seep Monitoring
Fluoride	NC	1800	FW		ug/L	5	3	1,763.2	Acute: NO WQS Chronic: 1,800.0 No RP , Predicted Max ≥ 50% of Allowable Cw - apply seep Monitoring	
Lead	NC	13,5358	FW	347,3518	ug/L	5	1	2.390	Acute: 347.352 Chronic: 13,536 No RP . Predicted Max < 50% of Allowable Cw - apply seep Monitoring	

Cape Fear Steam Electric Plant

Outfall 011A Seep S-15

Qw = 0.009 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5 ng/L	3	2	17.2	Acute:	NO WQS
				Note: n ≤ 9			Default C.V.		
Molybdenum	NC	160	WS	ug/L	5	5	283.0	Chronic:	12.0
				Note: n ≤ 9			Default C.V.	All values < WQBEL and < TBEL - apply seep Monitoring	
Nickel	NC	119.2776	FW	1073.9039	ug/L	5	4	Acute:	NO WQS
				Note: n ≤ 9			Default C.V.	No value > Allowable C _w	
Nickel	NC	25.0000	WS	ug/L	5	4	16.0	Chronic (FW):	1,073.9
				Note: n ≤ 9			Default C.V.	No value > Allowable C _w	
Selenium	NC	5	FW	56	ug/L	5	0	Acute:	56.0
				Note: n ≤ 9			NO DETECTS	No RP , Predicted Max ≥ 50% of Allowable C _w - apply seep Monitoring	
Zinc	NC	406.7415	FW	403.4414	ug/L	5	1	Chronic:	5.0
				Note: n ≤ 9			Default C.V.	Max MDL = 1	No detects, MDL < Allowable C _w - apply seep Monitoring
Antimony	NC	5.6	WS	ug/L	5	0	NO DETECTS	Acute:	403.4
				Note: n ≤ 9				Chronic:	406.7
Barium	NC	1	WS	mg/L	5	5	0.37352	No value > Allowable C _w	No RP , Predicted Max < 50% of Allowable C _w - apply seep Monitoring
				Note: n ≤ 9			Default C.V.	Max MDL = 1	No detects, MDL < Allowable C _w - No Monitoring required
Sulfates	NC	250	WS	mg/L	5	5	417.60000	Acute:	NO WQS
				Note: n ≤ 9			Default C.V.	No value > Allowable C _w	No RP , Predicted Max < 50% of Allowable C _w - apply seep Monitoring required
Thallium	NC	0.24	WS	ug/L	4	1	1.25615	Chronic:	250.00000
				Note: n ≤ 9			Default C.V.	No value > Allowable C _w	RP shown - apply seep Monitoring with Limit
				Limited data set				Acute:	NO WQS
								Chronic:	0.24000
								1 value(s) > Allowable C _w	RP shown - apply seep Monitoring with Limit

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

REQUIRED DATA ENTRY

Table 1. Project Information

Facility Name	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
WWTP/WTP Class	Cape Fear Steam Electric Plant	
NPDES Permit	Class II	
Outfall	NC0003433	
Flow, Qw (MGD)	010B - Seep S10	
Receiving Stream	0.001	
HUC Number	UT to Cape Fear River	
Stream Class	03030002	
7Q10s (cfs)	WS-IV	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	25 mg/L (Avg)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	25 mg/L	
Combined Hardness Acute	25 mg/L	
Data Source(s)	AOW data; USGS data; Raleigh Regional Office evaluation	
<input type="checkbox"/> CHECK TO APPLY MODEL		

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Arsenic	Aquatic Life	C	150	FW	340	ug/L	
Arsenic	Human Health Water Supply	C	10	HHWS	N/A	ug/L	
Beryllium	Aquatic Life	NC	6.5	FW	6.5	ug/L	
Cadmium	Aquatic Life	NC	0.5899	FW	3.2396	ug/L	
Chlorides	Water Supply	NC	250	WS		mg/L	
Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Chromium III	Aquatic Life	NC	117.7325	FW	905.0818	ug/L	
Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Copper	Aquatic Life	NC	7.8806	FW	10.4720	ug/L	
Cyanide	Aquatic Life	NC	5	FW	22	10	
Fluoride	Aquatic Life	NC	1,800	FW		ug/L	
Lead	Aquatic Life	NC	2.9416	FW	75.4871	ug/L	
Mercury	Aquatic Life	NC	12	FW		ng/L	
Molybdenum	Water Supply	NC	160	WS		ug/L	
Nickel	Aquatic Life	NC	37.2313	FW	335.2087	ug/L	
Nickel	Water Supply	NC	25,0000	WS	N/A	ug/L	
Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Silver	Aquatic Life	NC	0.06	FW	0.2964	ug/L	
Zinc	Aquatic Life	NC	126.7335	FW	125.7052	ug/L	
Antimony	Water Supply	NC	5.6	WS		ug/L	
Barium	Water Supply	NC	1	WS		mg/L	
Sulfates	Water Supply	NC	250	WS		mg/L	
Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria

Cape Fear Steam Electric Plant
NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Q_w (MGD) = 0.001
1Q10S (cfs) = 0.00
7Q10S (cfs) = 0.00
7Q10W (cfs) = 0.00
30Q2 (cfs) = 0.00
Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: UT to Cape Fear River HUC 03030002

WWTP/WTP Class: Class II

IWC% @ 1Q10S = 100

IWC% @ 7Q10S = 100

IWC% @ 7Q10W = 100

IWC% @ 30Q2 = 100

IWC% @ QA = 100

Stream Class: WS-IV

COMBINED HARDNESS (mg/L)
Acute = 2.5 mg/L
Chronic = 2.5 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 0 value > 100 mg/L
Effluent Hard Avg = 25 mg/L

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA		# DET.	#	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION	
		Chronic	Applied Standard			Acute	Max Pred C _w	Allowable C _w	Acute (FW):	Chronic (FW):
Arsenic	C	150	FW	340	ug/L	2	1	10.0	Default C.V.	No value > Allowable C _w
Arsenic	C	10	HH/WS		ug/L	Note: n ≤ 9	Limited data set		Chronic (HH):	No value > Allowable C _w
Cadmium	NC	0.5399	FW	3.2396	ug/L	2	0	NO DETECTS	Acute:	3.240
Chlorides	NC	250	WS		mg/L	2	2	121.3	Chronic:	0.590
Chromium III	NC	117.7325	FW	905.0818	μg/L	0	0	N/A	Max MDL = 1	No detects, MDL < Allowable C _w - apply seep Monitoring
Chromium VI	NC	11	FW	16	μg/L	0	0	N/A	Acute:	NO WQS
Chromium, Total	NC				μg/L	2	1	7.2	Tot Cr value(s) < 50 and < Cr VI Allowable C _w	Max reported value = 1.91
Copper	NC	7.8806	FW	10.4720	ug/L	2	2	10.04	Default C.V.	Acute: 10.47
Fluoride	NC	1800	FW		ug/L	1	0	NO DETECTS	Chronic:	7.88
Lead	NC	2.9416	FW	75.4871	ug/L	2	1	7.391	No value > Allowable C _w	RP shown - apply seep Monitoring with Limit
									Acute:	75.487
									Chronic:	2.942
									No value > Allowable C _w	RP shown - apply seep Monitoring with Limit

Cape Fear Steam Electric Plant
NC0003433

Outfall 010B - Sleep S10
Qw = 0.001 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5	ng/L	2	2	66.3	Acute: NO WQS
				Note: n ≤ 9				Default C.V.	Chronic: 12.0 1 value(s) > Allowable C _w
				Limited data set					Annual avg > WQBEL, all values < TBEL - apply WQBEL with sleep Monitoring
Molybdenum	NC	160	WS	ug/L	2	0	NO DETECTS	Acute: NO WQS	Chronic: Max MDL = 1
				Note: n ≤ 9					Acute (FW): 335.2
				Limited data set					Chronic (FW): 37.2
Nickel	NC	37.2313	FW	335.2087	μg/L	2	2	10.1	Acute: NO value > Allowable C _w
				Note: n ≤ 9				Default C.V.	Chronic (WS): 25.0
				Limited data set					No value > Allowable C _w
Nickel	NC	25.0000	WS	μg/L	2	0	NO DETECTS	Acute: 56.0	No RP, Predicted Max < 50% of Allowable C _w - apply sleep Monitoring
				Note: n ≤ 9					Acute: 5.0
				Limited data set					No detects, MDL < Allowable C _w - apply sleep Monitoring
Selenium	NC	5	FW	56	ug/L	2	0	NO DETECTS	Chronic: Max MDL = 1
				Note: n ≤ 9					Acute: 125.7
				Limited data set					Chronic: 126.7
Zinc	NC	126.7335	FW	125.7052	ug/L	2	2	45.5	Acute: NO value > Allowable C _w
				Note: n ≤ 9				Default C.V.	Chronic: No RP, Predicted Max < 50% of Allowable C _w - apply sleep Monitoring
				Limited data set					Acute: NO WQS
Antimony	NC	5.6	WS	μg/L	2	0	NO DETECTS	Chronic: Max MDL = 1	Chronic: 5.60000
				Note: n ≤ 9					No detects, MDL < Allowable C _w - No Monitoring required
				Limited data set					Acute: NO WQS
Barium	NC	1	WS	mg/L	2	2	0.45101	Chronic: 1.00000	No RP, Predicted Max < 50% of Allowable C _w - apply sleep Monitoring
				Note: n ≤ 9				Default C.V.	Acute: NO WQS
				Limited data set					Chronic: 250.00000
Sulfates	NC	250	WS	mg/L	2	2	212.24000	No value > Allowable C _w	No RP, Predicted Max ≥ 50% of Allowable C _w - apply sleep Monitoring
				Note: n ≤ 9				Default C.V.	Acute: NO WQS
				Limited data set					Chronic: 0.24000
Thallium	NC	0.24	WS	μg/L	2	0	NO DETECTS	Chronic: Max MDL = 0.2	No detects, MDL < Allowable C _w - apply sleep Monitoring
				Note: n ≤ 9					Acute: NO WQS
				Limited data set					

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Table 1. Project Information

Facility Name	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
Cape Fear Steam Electric Plant		
WWTP/WTP Class	Class II	
NPDES Permit	NC0003433	
Outfall	010A - Seep S09	
Flow, Qw (MGD)	0.001	
Receiving Stream	UT to Cape Fear River	
HUC Number	03030002	
Stream Class	WS-IV	
7Q10s (cfs)	0.00	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	default 99 mg/L-WS (Eff Hard Avg = 226 mg/L)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	99 mg/L	
Combined Hardness Acute	99 mg/L	
Data Source(s)	AOW data; USGS recommendation; Raleigh Regional evaluation	
<input type="checkbox"/> CHECK TO APPLY MODEL		
Par20	Silver	Aquatic Life
Par21	Zinc	Aquatic Life
Par22	Antimony	Aquatic Life
Par23	Barium	Water Supply
Par24	Sulfates	Water Supply
Par25	Thallium	Water Supply

REQUIRED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Arsenic	Aquatic Life	IC	150	FW	340	ug/L	
Arsenic	Human Health Water Supply	C	10	HH/WS	N/A	ug/L	
Beryllium	Aquatic Life	NC	6.6	FW	65	ug/L	
Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	ug/L	
Chlorides	Water Supply	NC	250	WS		mg/L	
Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Cyanide	Aquatic Life	NC	5	FW	22	ug/L	
Fluoride	Aquatic Life	NC	1800	FW	10	ug/L	
Lead	Aquatic Life	NC	13.5358	FW	347.3518	ug/L	
Mercury	Aquatic Life	NC	12	FW	0.5	ng/L	
Molybdenum	Water Supply	NC	160	WS		ug/L	
Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Nickel	Water Supply	NC	25.0000	WS	N/A	ug/L	
Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Silver	Aquatic Life	NC	0.06	FW	3.1616	ug/L	
Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Antimony	Water Supply	NC	5.6	WS		ug/L	
Barium	Water Supply	NC	1	WS		mg/L	
Sulfates	Water Supply	NC	250	WS		mg/L	
Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

To follow directions for data entry. In some cases a comment menu lists the available choices or a dropdown menu will provide a list you may select from. Enter message occur if data entry does not meet input criteria.

Cape Fear Steam Electric Plant

NC00003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.001
 1Q10S (cfs) = 0.00
 7Q10S (cfs) = 0.00
 7Q10W (cfs) = 0.00
 7Q10W (cfs) = 0.00
 3QQ2 (cfs) = 0.00
 Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: UT to Cape Fear River HUC 030300002

WWTP/WTP Class: Class II

Acute = 99 mg/L

Chronic = 99 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard: 2 value > 100 mg/L

default 99 mg/L-W5 (Eff Hard Avg = 226 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			# Det.	Max Pred Cw	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			S _{LIN}	C _d	Acute (FW): 340.0	
Arsenic	C	150	FW	340	ug/L	4	1	2.8	Acute (FW): 340.0	
Arsenic	C	10	HH/WS		ug/L			Default C.V.	Chronic (FW): 150.0	
Cadmium	NC	1.6678	FW	10.7582	ug/L	4	0	NO DETCTS	No value > Allowable Cw	
Chlorides	NC	250	WS		mg/L	4	4	54.4	Chronic: Max MDL = 1	
Chromium III	NC	363.4201	FW	2793.8313	µg/L	0	0	NO DETCTS	No value > Allowable Cw	
Chromium VI	NC	11	FW	16	µg/L	0	0	N/A	Chronic: 250.0	
Chromium, Total	NC				µg/L	4	0	NO DETCTS	No value > Allowable Cw	
Copper	NC	25.5442	FW	38.2981	ug/L	4	0	NO DETCTS	Chronic: Max MDL = 5	
Fluoride	NC	1800	FW		ug/L	3	1	1,500.0	Acute: 38.30	
Lead	NC	13.5358	FW	347.3518	ug/L	4	0	NO DETCTS	Chronic: 25.54	
									Acute: NO WQS	
									Chronic: Max MDL = 5	
									Acute: 1,800.0	
									No RP, Predicted Max ≥ 50% of Allowable Cw - apply seep Monitoring	
									Acute: 347.352	
									Chronic: 13.536	
									Acute: Max MDL = 1	
									No detects, MDL < Allowable Cw - apply seep Monitoring	

Cape Fear Steam Electric Plant

Outfall 010A - Seep S09 Qw = 0.001 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

NC0003433		Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5	ng/L	2	2	16.1	Default C.V.	Acute:	NO WQS
Molybdenum	NC	160	WS	ug/L	4	0	NO DETECTS	Chronic:	12.0	All values < WQBEL and < TBEI - apply seep Monitoring	No value > Allowable Cw
Nickel	NC	119.2776	FW	1073.9039	µg/L	4	4	13.0	Default C.V.	Acute:	NO WQS
Nickel	NC	25.0000	WS	ug/L	4	4	NO DETECTS	Chronic (FW):	119.3	Acute (FW): 1,073.9	Max MDL = 1
Selenium	NC	5	FW	56	ug/L	4	0	NO DETECTS	No value > Allowable Cw	Chronic (FW):	119.3
Zinc	NC	406.7415	FW	403.4414	ug/L	4	2	20.7	No value > Allowable Cw (WS):	Chronic:	25.0
Antimony	NC	5.6	WS	ug/L	4	0	NO DETECTS	No value > Allowable Cw	No RP , Predicted Max ≥ 50% of Allowable Cw - apply seep Monitoring	Acute:	56.0
Barium	NC	1	WS	mg/L	4	4	0.18389	Default C.V.	Chronic:	5.0	No detects, MDL < Allowable Cw - apply seep Monitoring
Sulfates	NC	250	WS	mg/L	4	4	414.40000	Default C.V.	Chronic:	403.4	Max MDL = 1
Thallium	NC	0.24	WS	µg/L	4	0	NO DETECTS	No value > Allowable Cw	Chronic:	406.7	No RP, Predicted Max < 50% of Allowable Cw - apply seep Monitoring
					Note: n ≤ 9	Limited data set		Acute:	Chronic:	Acute:	NO WQS
					Note: n ≤ 9	Limited data set		Chronic:	1.00000	Chronic:	NO WQS
					Note: n ≤ 9	Limited data set		No value > Allowable Cw	1.00000	No RP, Predicted Max < 50% of Allowable Cw - apply seep Monitoring	NO WQS
					Note: n ≤ 9	Limited data set		Acute:	250.00000	RP shown - apply seep Monitoring with Limit	NO WQS
					Note: n ≤ 9	Limited data set		Chronic:	0.24000	Chronic:	NO WQS
								Max MDL = 0.2	0.24000	No detects, MDL < Allowable Cw - apply seep Monitoring	NO WQS

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58



Table 1. Project Information

Facility Name	Cape Fear Steam Electric Plant	
	<input type="checkbox"/> CHECK IF HQW OR ORW WQS	
WWTP/WWT Class	Class II	
NPDES Permit	NC0003433	
Outfall	007 Seep - (S-05, S-07, S-08, S-12)&001&005	
Flow, Qw (MGD)	0.600	
Receiving Stream	UT to Cape Fear River	
HUC Number	03030002	
Stream Class	WS-IV	
7Q10s (cfs)	0.00	
7Q10w (cfs)	0.00	
30Q2 (cfs)	0.00	
QA (cfs)	0.00	
1Q10s (cfs)	0.00	
Effluent Hardness	default 99 mg/L-W/S (Eff Hard Avg = 159.66 mg/L)	
Upstream Hardness	25 mg/L (Avg)	
Combined Hardness Chronic	99 mg/L	
Combined Hardness Acute	99 mg/L	
Data Source(s)	AOW data, highest concentration for each seep; lowest hardness for each seep; episodic discharge from 001 & 005 ; Raleigh Reginal Office evaluation	
<input type="checkbox"/> CHECK TO APPLY MODEL		

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01 Arsenic	Aquatic Life	C	150	FW	340	ug/L	
Par02 Arsenic	Human Health Water Supply	C	10	HHWS	N/A	ug/L	
Par03 Beryllium	Aquatic Life	NC	6.5	FW	65	ug/L	
Par04 Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	ug/L	
Par05 Chlorides	Water Supply	NC	250	WS		mg/L	
Par06 Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Par07 Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Par08 Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Par09 Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Par10 Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Par11 Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Par12 Cyanide	Aquatic Life	NC	5	FW	22	ug/L	
Par13 Fluoride	Aquatic Life	NC	1,800	FW	10	ug/L	
Par14 Lead	Aquatic Life	NC	13,5338	FW	347.3518	ug/L	
Par15 Mercury	Aquatic Life	NC	12	FW	0.5	ng/L	
Par16 Molybdenum	Water Supply	NC	160	WS		ug/L	
Par17 Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Par18 Nickel	Water Supply	NC	25,0000	WS	N/A	ug/L	
Par19 Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Par20 Silver	Aquatic Life	NC	0.06	FW	3.1616	ug/L	
Par21 Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Par22 Antimony	Water Supply	NC	5.8	WS		ug/L	
Par23 Barium	Water Supply	NC	1	WS		mg/L	
Par24 Sulfates	Water Supply	NC	250	WS		mg/L	
Par25 Thallium	Water Supply	NC	0.24	WS		ug/L	

To apply a Model IWC %: Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Follow directions for data entry. In some cases a comment menu list the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

Cape Fear Steam Electric Plant
NC0003433

Freshwater RPA - 95% Probability95% Confidence Using Metal Translators
MAXIMUM DATA POINTS = 58

Outfall 007 Seep - (S-05,S-07,S-08,S-12)&001&005
Qw = 0.6 MGD

Qw (MGD) = 0.60
1Q10S (cf\\$) = 0.00
7Q10S (cf\\$) = 0.00
7Q10W (cf\\$) = 0.00
30Q2 (cf\\$) = 0.00
Avg. Stream Flow, QA (cf\\$) = 0.00

Receiving Stream: UT to Cape Fear River HUC 03030002

WWTP/WTP Class: Class II
Acute = 99 mg/L
Chronic = 99 mg/L
YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY
Effluent Hard: 3 value > WS (Eff Hard Avg = 159.65 mg/L)
default 99 mg/L-WS (Eff Hard Avg = 159.65 mg/L)

Receiving Stream: UT to Cape Fear River HUC 03030002

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			# Det.	# n	REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Applied Standard	Acute			# Pred C _w	Allowable C _w		
Arsenic	C	150	FW	340	ug/L	4	2	12.2	Acute (FW): 340.0	
Arsenic	C	10	HH/WS		ug/L	Note: n ≤ 9 Limited data set		Default C.V.	Chronic (FW): 150.0 No value > Allowable C _w	
Cadmium	NC	1.6678	FW	10.7382	ug/L	4	1	3.134	Chronic: 10.0 No value > Allowable C _w	RP shown - apply seep Monitoring with Limit
Chlorides	NC	250	WS		mg/L	4	4	85.5	Acute: 10.738	
Chromium III	NC	363.4201	FW	2793.8313	µg/L	0	0	N/A	Chronic: 1.668 No value > Allowable C _w	RP shown - apply seep Monitoring with Limit
Chromium VI	NC	11	FW	16	µg/L	0	0	N/A	Acute: 2,793.8	
Chromium, Total	NC				µg/L	4	0	NO DETECTS	Chronic: 363.4 Acute: 11.0	No detects, MDL < Allowable C _w - apply seep Monitoring
Copper	NC	25.5442	FW	38.2981	ug/L	4	4	69.15	Max MDL = 5 Chronic: 25.54 Acute: 38.30	
Fluoride	NC	1800	FW		ug/L	4	2	1,372.7	1 value(s) > Allowable C _w Chronic: 1,800.0 Acute: 347.352	RP shown - apply seep Monitoring with Limit
Lead	NC	13.3358	FW	347.3518	ug/L	4	1	9.713	Chronic: 13.336 No value > Allowable C _w	No RP ; Predicted Max ≥ 50% of Allowable C _w - apply seep Monitoring

Cape Fear Steam Electric Plant
NC0003433

Outfall 007 Seep - (S-05,S-07,S-08,S-12)&001&005
Qw = 0.6 MGD

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5	ng/L	4	4	17.6	Default C.V.
				Note: n ≤ 9	Limited data set				Chronic: 12.0
Molybdenum	NC	160	WS	ug/L	4	1	167.8	No value > Allowable C _w	Acute: NO WQS
				Note: n ≤ 9	Limited data set				RP shown - apply seep Monitoring with Limit
Nickel	NC	119.2776	FW	1073.9039	µg/L	4	4	95.1	Chronic (FW): 119.3
	NC	25.0000	WS	µg/L	4	4	95.1	No value > Allowable C _w	Acute (FW): 1,073.9
Nickel	NC	5	FW	56	ug/L	4	0	NO DETECTS	Chronic (VS): 25.0
				Note: n ≤ 9	Limited data set				1 value(s) > Allowable C _w
Selenium	NC	406.7415	FW	403.4414	ug/L	4	4	328.9	Acute: 56.0
				Note: n ≤ 9	Limited data set				Max MDL = 1
Zinc	NC	5.6	WS	mg/L	4	0	NO DETECTS	Chronic: 5.0	No detects, MDL < Allowable C _w - apply seep Monitoring
				Note: n ≤ 9	Limited data set				RP shown - apply seep Monitoring with Limit
Antimony	NC	1	WS	mg/L	4	4	0.19166	Chronic: 403.4	Acute: NO WQS
				Note: n ≤ 9	Limited data set				Max MDL = 1
Barium	NC	250	WS	mg/L	4	4	854.70000	Chronic: 5.60000	No detect, MDL < Allowable C _w - no Monitoring required
				Note: n ≤ 9	Limited data set				No RP, Predicted Max ≥ 50% of Allowable C _w - apply seep Monitoring
Sulfates	NC	0.24	WS	µg/L	4	2	2.43978	Chronic: 1.00000	Acute: NO WQS
				Note: n ≤ 9	Limited data set				1 value(s) > Allowable C _w
Thallium	NC							Chronic: 250.00000	RP shown - apply seep Monitoring with Limit
									2 value(s) > Allowable C _w
									RP shown - apply seep Monitoring with Limit

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58



Table 1. Project Information

Facility Name	WWTP/WTP Class	NPDES Permit	Outfall	Flow, Qw (MGD)	Receiving Stream	HUC Number	Stream Class	7Q10s (cfs)	7Q10w (cfs)	30Q2 (cfs)	QA (cfs)	1Q10s (cfs)	Effluent Hardness	Upstream Hardness	Combined Hardness Chronic	Combined Hardness Acute	Data Source(s)	<input type="checkbox"/> CHECK TO APPLY MODEL
Cape Fear Steam Electric Plant	Class II	NC0003433	009 seep S-04	0.001	sw ditch to Shaddock Creek	03030002	WS-IV	0.00	0.00	0.00	0.00	0.00	default 99 mg/L-WIS (Eff Hard Avg = 271 mg/L)	25 mg/L (Avg)	99 mg/L	99 mg/L	AOW data; USGS recommendation; Raleigh Regional office evaluation	
<input type="checkbox"/> CHECK IF HQW OR ORW WQS																		

REQUIRED DATA ENTRY

Table 2. Parameters of Concern

Name	WQS	Type	Chronic	Modifier	Acute	PQL	Units
Par01 Arsenic	Aquatic Life	C	150	FW	340	ug/L	
Par02 Arsenic	Human Health	C	10	HW/S	N/A	ug/L	
Par03 Beryllium	Water Supply	NC	6.5	FW	65	ug/L	
Par04 Cadmium	Aquatic Life	NC	1.6678	FW	10.7582	mg/L	
Par05 Chlorides	Water Supply	NC	250	WS		ug/L	
Par06 Chlorinated Phenolic Compounds	Water Supply	NC	1	A		ug/L	
Par07 Total Phenolic Compounds	Aquatic Life	NC	300	A		ug/L	
Par08 Chromium III	Aquatic Life	NC	363.4201	FW	2793.8313	ug/L	
Par09 Chromium VI	Aquatic Life	NC	11	FW	16	ug/L	
Par10 Chromium, Total	Aquatic Life	NC	N/A	FW	N/A	ug/L	
Par11 Copper	Aquatic Life	NC	25.5442	FW	38.2981	ug/L	
Par12 Cyanide	Aquatic Life	NC	5	FW	22	10	
Par13 Fluoride	Aquatic Life	NC	1400	FW		ug/L	
Par14 Lead	Aquatic Life	NC	13.5358	FW	347.3518	ug/L	
Par15 Mercury	Aquatic Life	NC	12	FW	0.5	ng/L	
Par16 Molybdenum	Water Supply	NC	160	WS		ug/L	
Par17 Nickel	Aquatic Life	NC	119.2776	FW	1073.9039	ug/L	
Par18 Nickel	Water Supply	NC	25.0000	WS	N/A	ug/L	
Par19 Selenium	Aquatic Life	NC	5	FW	56	ug/L	
Par20 Silver	Aquatic Life	NC	0.06	FW	3.1616	ug/L	
Par21 Zinc	Aquatic Life	NC	406.7415	FW	403.4414	ug/L	
Par22 Antimony	Water Supply	NC	5.6	WS		ug/L	
Par23 Barium	Water Supply	NC	1	WS		mg/L	
Par24 Sulfates	Water Supply	NC	250	WS		mg/L	
Par25 Thallium	Water Supply	NC	0.24	WS		ug/L	

Follow directions for data entry. In some cases a comment menu lists the available choices or a dropdown menu will provide a list you may select from. Error message occur if data entry does not meet input criteria.

To apply a Model MVC %. Once the "Flow, Qw (MGD)" and the "CHRONIC DILUTION FACTOR = " values are entered, the 7Q10s (cfs) flow is calculated and displayed. Enter the calculated "7Q10s (cfs)" flow value in Table 1.

Cape Fear Steam Electric Plant

NC0003433

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

MAXIMUM DATA POINTS = 58

Qw (MGD) = 0.001

1Q10S (cfs) = 0.00

7Q10S (cfs) = 0.00

7Q10W (cfs) = 0.00

30Q2 (cfs) = 0.00

Avg. Stream Flow, QA (cfs) = 0.00

Receiving Stream: sw ditch to Shaddock Creek HUC 030300002

WWTP/WTP Class: Class II

IWC% @ 1Q10S = 100

IWC% @ 7Q10S = 100

IWC% @ 7Q10W = 100

IWC% @ 30Q2 = 100

IWC% @ QA = 100

Stream Class: WS-IV

COMBINED HARDNESS (mg/L)

Acute = 99 mg/L

Chronic = 99 mg/L

YOU HAVE DESIGNATED THIS RECEIVING STREAM AS WATER SUPPLY

Effluent Hard. 2 value > 100 mg/L

default 99 mg/L-W/S (Eff Hard Avg = 271 mg/L)

PARAMETER	TYPE (1)	NC STANDARDS OR EPA CRITERIA			REASONABLE POTENTIAL RESULTS			RECOMMENDED ACTION
		Chronic	Applied Standard	Acute	# Det.	Max Pred C _w	Allowable C _w	
Arsenic	C	150	FW	340	ug/L	4	3	Acute (FW): 340.0
Arsenic	C	10	HH/W/S		ug/L	Note: n ≤ 9 Limited data set	1,056.7 Default C.V.	Chronic (FW): 150.0 1 value(s) > Allowable C _w Chronic (HH): 10.0 2 value(s) > Allowable C _w
Cadmium	NC	1,6678	FW	10,7582	ug/L	4	1	Acute: 10.758 Chronic: 1,668 2 value(s) > Allowable C _w
Chlorides	NC	250	WS		mg/L	4	4	Acute: NO WQS Chronic: 250.0 No value > Allowable C _w
Chromium III	NC	363,4201	FW	2793,8313	μg/L	0	0	Acute: 2,793.8 Chronic: 363.4
Chromium VI	NC	11	FW	16	μg/L	0	0	Acute: 16.0 Chronic: 11.0
Chromium, Total	NC				μg/L	4	1	Tot Cr value(s) >50 with 1 Tot Cr value(s) ≥ Cr VI Allowable Max reported value = 69.4 Max MDL = 1000 Acute: 38.30 Chronic: 25.54 2 value(s) > Allowable C _w
Copper	NC	25,5442	FW	38,2981	ug/L	4	2	1,209.53 Default C.V. Limited data set
Fluoride	NC	1800	FW		ug/L	3	0	NO DETECTS Chronic: 1,800.0 Max MDL = 1000 Acute: 347.352 Chronic: 1,353.6 1 value(s) > Allowable C _w
Lead	NC	13,5358	FW	347,3518	ug/L	4	1	197.358 Default C.V. Limited data set

Cape Fear Steam Electric Plant

Outfall 009 seep S-04

Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators

NC0003433 Freshwater RPA - 95% Probability/95% Confidence Using Metal Translators									
Mercury	NC	12	FW	0.5	ng/L	2	25.8	Acute:	NO WQS
					Note: n ≤ 9	Default C.V.		Chronic:	12.0
					Limited data set		No value > Allowable Cw	All values < WQBEL and < TBEL - apply seep monitoring	
Molybdenum	NC	160	WS	ug/L	4	0	NO DETECTS	Acute:	NO WQS
					Note: n ≤ 9	Limited data set		Chronic:	160.0
					Limited data set		Max MDL = 10	No defects, MDL < Allowable Cw - apply seep Monitoring	
Nickel	NC	119.2776	FW	1073.9039	µg/L	4	1,344.2	Acute (FW):	1,073.9
					Note: n ≤ 9	Default C.V.	Chronic (FW):	119.3	
					Limited data set		2 value(s) > Allowable Cw		
Nickel	NC	25.0000	WS	ug/L	4	4	Chronic (WS):	25.0	
					Limited data set		2 value(s) > Allowable Cw	RP shown - apply seep Monitoring with Limit	
Selenium	NC	5	FW	56	ug/L	4	1	Acute:	56.0
					Note: n ≤ 9	Default C.V.		Chronic:	5.0
					Limited data set		1 value(s) > Allowable Cw	RP shown - apply seep Monitoring with Limit	
Zinc	NC	406.7415	FW	403.4414	ug/L	4	84.7	Acute:	403.4
					Note: n ≤ 9	Default C.V.		Chronic:	406.7
					Limited data set		No value > Allowable Cw	No RP, Predicted Max < 50% of Allowable Cw - apply seep Monitoring	
Antimony	NC	5.6	WS	µg/L	4	0	NO DETECTS	Acute:	NO WQS
					Note: n ≤ 9	Limited data set		Chronic:	5,60000
					Limited data set		Max MDL = 10	No defects, MDL > Allowable Cw - apply seep Monitoring	
Barium	NC	1	WS	mg/L	3	3	0.67800	Acute:	NO WQS
					Note: n ≤ 9	Default C.V.		Chronic:	1,00000
					Limited data set		No value > Allowable Cw	No RP, Predicted Max ≥ 50% of Allowable Cw - apply seep Monitoring	
Sulfates	NC	250	WS	mg/L	3	3	1,530.00000	Acute:	NO WQS
					Note: n ≤ 9	Default C.V.		Chronic:	250.00000
					Limited data set		1 value(s) > Allowable Cw	RP shown - apply seep Monitoring with Limit	
Thallium	NC	0.24	WS	µg/L	3	1	15.39000	Acute:	NO WQS
					Note: n ≤ 9	Default C.V.		Chronic:	0.24000
					Limited data set		2 value(s) > Allowable Cw	RP shown - apply seep Monitoring with Limit	