



ROY COOPER

Governor

WILLIAM G. ROSS, JR.

Acting Secretary

S. JAY ZIMMERMAN

Director

January 17, 2017

Ms. Jane D. Wastewater, PE
Director of Public Utilities
Town of Typicalville
PO Box 1234
Typicalville, NC 21234

Subject: Pretreatment Review of Headworks Analysis (HWA)
Program: Town of Typicalville
WWTP: Typicalville WWTP - NC0012345
Typical County

Dear Ms. Wastewater:

The Pretreatment, Emergency Response, and Collection Systems Unit (PERCS) of the Division of Water Resources has reviewed the Headworks Analysis (HWA) for the Town of Typicalville WWTP - NC0012345. This HWA was received by the Division on January 3, 2017.

The Division **concurs** with the HWA calculations for all pollutants of concern, **with the observations** discussed below. These approved Maximum Allowable Headworks Loadings (MAHL), Maximum Allowable Industrial Loadings (MAIL), and the basis for these values are found on the last page of the enclosed HWA spreadsheet. The results of the HWA are also listed in the bottom section of the enclosed Allocation Table.

Next HWA Due Date: The HWA was based primarily on 2015 - 2016 data. Unless conditions at the POTW change significantly and thus warrant an earlier submittal (see *Comprehensive Guide, Section B*), the POTW must submit an updated HWA on or before **February 1, 2022**.

Thank you for your continued cooperation with the Pretreatment Program. If you have any questions or comments, please contact Deborah Gore at (919) 807-6383, or via email (deborah.gore@ncdenr.gov).

Sincerely,

Deborah Gore

PERCS Unit Supervisor

Typicalville_hwa_010

Enclosures: HWA and AT spreadsheets

Cc with enclosures:

PERCS Unit File
Winston-Salem Regional Office Pretreatment File
Central Files

1A

TOWN OF TYPICALVILLE, NC
"WE'RE ANYTHING BUT TYPICAL"

January 5, 2017

SEND CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Deborah Gore, Supervisor
NC DWR – PERCS – Pretreatment
1617 Mail Service Center
Raleigh, NC 27699-1617

Subject: Town of Typicalville NC 0012345 Headworks Analysis

Dear Ms. Gore:

As required by the above NPDES permit, enclosed is the Town of Typicalville's Wastewater Treatment Plant Headworks Analysis (HWA).

Our four industrial user permits (IUPs) have been renewed effective January 31, 2017. The permit limits were based on this new HWA and have been submitted to your office under separate cover.

If you have any questions regarding this information, please contact me at 555-123-4567 or jane.wastewater@typicalville.com. Or you may contact John Basin, Pretreatment Coordinator at 123-4576.

Sincerely,

Jane D. Wastewater, PE

Director of Public Utilities

Cc: Mayor
ORC

Enclosure: HWA Narrative, spreadsheets and other supporting information

Town of Typicalville
PO Box 1234
Typicalville, NC 21234
555-123-4567

Typicalville WWTP
1234 Carolina Road (NCSR1000)
Typicalville, NC 21234
555-123-4576

1B

2017 HWA Narrative:

HWA Data Time Period:

Monthly sampling for all long term monitoring plan pollutants of concern was performed December 2015 through November 2016 at the WWTP influent and effluent. SIUs monitor quarterly and the Town once per year. Three years of monitoring data was used for the mass balance giving 15 data points for permit limited parameters and 6 data points for all other POCs.

WWTP Design Criteria:

We have elected to use Option 2 of PERCS February 2007 letter, the 1.5 multiplier. Our WWTP meets all the conditions specified in PERCS December 2007, letter. We have not had any violations in the previous 2 years and the design calculations are older than 8 years.

Removal Rate Calculations:

All available DMR & LTMP data was used. We recalculated any DMR monthly averages using $\frac{1}{2}$ DL for all BDLs. The resultant site-specific removal rates were used in the HWA except for several of the metals where the data was greater than 50 % below detection in which case we used the EPA literature.

Water Quality Standards:

The recent NPDES permit renewal used the Freshwater RPA Using Metal Translators to evaluate the data to determine if permit limits were required. The Total Metal Allocated to the Permittee were used in the HWA spreadsheet as the water quality standards. The more stringent human health criteria was used for arsenic; chromium was evaluated using the more stringent Cr VI criteria; the water supply criteria for molybdenum was included; the more stringent water supply criteria was used for nickel; and the more stringent acute total metal allocated was used for zinc. It is understood that only the shaded parameters on the calculator spreadsheet are hardness dependent and make use of EPA translators to calculate the total metal allocated.

Inhibition Calculations:

We do have an NH₃ limit and the data indicates that the treatment plant nitrifies. The literature criteria for activated sludge and nitrification was used.

Our LTMP aeration basin data did show values greater than literature for copper, cyanide, and zinc. Review of our DMRs for all basin sampling time periods show these concentrations did not inhibit our activated sludge or our nitrifiers. We decided to use the average of all the aeration basin data at both basins for copper and zinc to be a little conservative. For cyanide, we used the average of the highest values at each basin. These values are representative of both basins.

Sludge Calculations:

There were several parameters for which the sludge ceiling was the most limiting factor: arsenic, copper, lead, molybdenum, selenium and zinc. All have over 70% of the MAHL remaining.

Uncontrollable Mass Balance:

We used the calculated mass balance concentrations. Note that the detection level for silver was improved in November 2016 from 5 ug/l to 0.5 ug/l. All effluent data was BDL. There was a detection at the influent in November of 0.63 ug/l. Therefore, we did not use zero for the uncontrollable. This created an over allocation for silver. Only one SIU has a silver limit. The SIU data was reviewed and the silver limit reduced to 0.05 mg/l. This leaves 14% of the MAHL. We intend to continue monthly sampling for silver at the influent and effluent to determine if a lower uncontrollable value can be used to increase the industrial allowable load.

Workbook Name: 3A_3_HWA_spreadsheet_1.5_design.xlsx; Worksheet Name: HWA

Page 1 of 5
Printed 1/17/2017, 7:07 AM

A	B	C	D	E	F	G	H	I	J	K
1 Headworks Analysis Spreadsheet										
2 POTW Name:	Typicallyville									
3 Date:	1/4/2017									
4 POTW NPDES # =>	NC0012345									
5 POTW Sludge Permit # =>	WQ0001234									
6 POTW NPDES Permitted Flow(MGD)=	6	<=used in AT only								
7 POTW Average Flow(MGD)=	2,809	<=used in HWA calculations								
8 Uncontrollable Flow(MGD)=	2,535									
9 7Q10 Stream Flow(MGD)=	38.76									
10 Stream Classification =	WS-V									
11										
12										
13 Class of Sludge generated (A, or B)	B									
14 Sludge to Digester Flow(MGD)=										
15 Sludge to Disposal Flow(MGD)=	0.0119									
16 %Solids to Disposal=	4.4									
17 Sludge Site Area(acres)=	1164.9									
18 Sludge Site Lifeyrs=	75									
19 Age of Sludge Sietelyrs=	5									
20										
21 Pass-Through Loading Calculations										
22										
23 Pollutant	NPDES LIMIT (mg/l)	Plant Removal Rate (%)	Removal Source	NPDES Loading (lbs/day)	Stream Standard (mg/l)	Stream Standard Source	Stream Standard Loading (lbs/day)	Design Criteria Loading (lbs/day)	Permitted Flow	Through calc. for different POTW flows
24 BOD	30	97.37	DMR	26,723					1140.7	534.0
25 TSS	30	97.71	DMR	30,690					1310.0	613.3
26 Ammonia	6	96.8	DRM & LTMP	4,393					187.5	87.8
27 Arsenic	45	literature			0.01	Water supply	6,3034			6,3034
28 Cadmium	67	literature			0.0006	Aquatic Life	0.6303			0.6303
29 Chromium	82	literature			0.0111	Aquatic Life	21.1863			21.1863
30 Copper	92.87	LTMP data			0.0079	Aquatic Life	38.4126			38.4126
31 Cyanide	58.03	LTMP data			0.005	Aquatic Life	4.1302			4.1302
32 Lead	92.37	LTMP data			0.0029	Aquatic Life	13.1768			13.1768
33 Mercury	86.75	LTMP data			0.000012	Aquatic Life	0.03140			0.03140
34 Molybdenum	33	literature			0.16	Water supply	82.7906			82.7906
35 Nickel	42	literature			0.025	Water supply	14.9433			14.9433
36 Selenium	50	literature			0.005	Aquatic Life	3,4669			3,4669
37 Silver	75	literature			0.00006	Aquatic Life	0.0832			0.0832
38 Zinc	77.35	LTMP data			0.1257	Aquatic Life	192.3990			192.3990
39 Total Nitrogen										
40 Total Phos.										
41 c										
42 d										
43 e										
44 f										
45 g										
46 h										
47 i										

Workbook Name: 3A_3_HWA_spreadsheet_1.5_design.xlsx; Worksheet Name: HWA

Page 2 of 5
Printed 1/17/2017, 7:07 AM

	A	B	C	D	E	F	G	H	I	J	K											
49	Average Influent NH ₃ (mg/l)																					
50	Average Anaerobic Digester NH ₃ (mg/l)																					
51 Inhibition Loading Calculations																						
only enter when have ANAEROBIC digester																						
52 Pollutant	Primary Removal Rate (%)	Primary Removal Rate Source	A.S./Nit/T.F. Inhibition Concentration (mg/l)	A.S./Nit/T.F. Inhibition Concentration Source	A.S./Nit/T.F. Inhibition Loading (lbs/day)	A.S./Nit/T.F. Inhibition Loading (lbs/day)	Digester Inhibition Concentration (mg/l)	Digester Inhibition Cone. Source	Digester Inhibition Loading (lbs/day)	Minimum Inhibition Loading (lbs/day)	Minimum Inhibition Loading Source											
53 BOD																						
54 TSS																						
55 Ammonia																						
56 Arsenic																						
57 Cadmium																						
58 Chromium																						
59 Copper																						
60 Cyanide																						
61 Lead																						
62 Mercury																						
63 Molybdenum																						
64 Nickel																						
65 Selenium																						
66 Silver																						
67 Zinc																						
68 Total Nitrogen																						
69 Total Phos.																						
70 c																						
71 d																						
72 e																						
73 f																						
74 g																						
75 h																						
76 l																						
3																						

77	A	B	C	D	E	F	G	H	I	J	K
78	Sludge Loading Calculations										
	Pollutant	Sludge Ceiling Concentration Limit (mg/kg)	Sludge Ceiling Load (lbs/day)	Sludge Ceiling Load - HASL Calc. - (lbs/day)	Cumulative Sludge Rate Limit (lbs/acre/life)	Cumulative Sludge Loading (lbs/day)	Class A Limits Monthly Average Rate Limit (mg/kg)	Class A Limits Monthly Avg. Loading (lbs/day)	Class A Limits HASL Calc. - (lbs/day)	Mon. Avg. Load. - (lbs/day)	Minimum Sludge Loading (lbs/day)
79	BOD										
80	TSS										
81	Ammonia										
82	Arsenic	75	0.7278		36	3,4021	41				
83	Cadmium	85	0.5540		34	2,1581	39				
84	Chromium										
85	Copper	4300	20,2190		1338	61,2691	1500				
86	Cyanide										
87	Lead	840	3,9711		267	12,2925	300				
88	Mercury	57	0.2869		15	0.7353	17				
89	Molybdenum	75	0.9925								
90	Nickel	420	4,3668		374	37,8689	420				
91	Selenium	100	0.8734		89	7,5697	100				
92	Silver										
93	Zinc	7500	42,3415		2498	137,3387	2800				
94	Total Nitrogen										
95	Total Phos.										
96	c										
97	d										
98	e										
99	f										
100	g										
101	h										
102	i										
103	j										
104	k										

4

Workbook Name: 3A_3_HWA_spreadsheet_1.5_design.xlsx; Worksheet Name: HWA

Page 4 of 5
Printed 1/17/2017, 7:07 AM

A	B	C	D	E	F	G	H	I	J	K
105 Maximum Allowable Headworks Loading Calculations										
106	Minimum Pass Through Loading (lbs/day)	Pass Through Source	Minimum Inhibition Loading (lbs/day)	Minimum Inhibition Source	Minimum Loading (lbs/day)	Minimum Sludge Loading (lbs/day)	Minimum Sludge Loading Source	Maximum Allowable Headworks Loading (lbs/day)	Maximum Allowable Headworks Loading Source	
107 BOD	19890.9 Design							19890.9	Design	
108 TSS	24019.2 Design							24019.2	Design	
109 Ammonia	2627.1 Design		11244.9888 AS/Nit/TF inhibiti	2.3427 AS/Nit/TF inhibiti	0.7278 Sludge Ceiling			2627.1	Design	
110 Arsenic	6.3034 Stream Std		23.4271 AS/Nit/TF inhibiti	0.5540 Sludge Ceiling				0.7278	Sludge Ceiling	
111 Cadmium	0.6303 Stream Std		9.2303 AS/Nit/TF inhibiti	163.9894 AS/Nit/TF inhibiti	20.2190 Sludge Ceiling			0.5540	Sludge Ceiling	
112 Chromium	21.1863 Stream Std		163.9894 AS/Nit/TF inhibiti	3.2564 AS/Nit/TF inhibiti				9.2303	AS/Nit/TF inhibition	
113 Copper	38.4126 Stream Std		1.1302 Stream Std	11.7135 AS/Nit/TF inhibiti	3.9711 Sludge Ceiling			20.2190	Sludge Ceiling	
114 Cyanide				2.3427 AS/Nit/TF inhibiti				3.2564	AS/Nit/TF inhibition	
115 Lead	13.1768 Stream Std		0.03140 Stream Std	5.8368 AS/Nit/TF inhibiti	4.3668 Sludge Ceiling			3.9711	Sludge Ceiling	
116 Mercury			82.7906 Stream Std	5.4669 Stream Std	0.8734 Sludge Ceiling			0.03140	Stream Std	
117 Molybdenum			14.9433 Stream Std	0.0832 Stream Std	0.8734 Sludge Ceiling			0.9925	Sludge Ceiling	
118 Nickel				192.3990 Stream Std	54.8193 AS/Nit/TF inhibiti	42.3415 Sludge Ceiling			4.3668	Sludge Ceiling
119 Selenium									0.8734	Sludge Ceiling
120 Silver									0.8734	Sludge Ceiling
121 Zinc									0.0832	Stream Std
122 Total Nitrogen									42.3415	Sludge Ceiling
123 Total Phos.										
124 c										
125 d										
126 e										
127 f										
128 g										
129 h										
130 i										
131										
5										

Workbook Name: 3A_3_HWA_spreadsheet_1.5_design.xlsx; Worksheet Name: HWA

A	B	C	D	E	F	G	H	I	J	K
132 Maximum Allowable Industrial Loadings Calculations										
133 Maximum Allowable Industrial Loadings										
	Maximum Allowable Headworks Loading (lbs/day)	MAHL Basis	Check to Use HASL Calc (x)	Uncontrollable Concentration (mg/l)	Uncontrollable Source	Uncontrollable Load (lbs/day)	Maximum Allowable Industrial Load (lbs/day)	Design vs. Pass-Thru Warning		
134 Pollutant	19890.9000 Design			248 Mass Balance		5243.1912	14647.7088			
135 BOD	24019.2000 Design			273 Mass Balance		5771.7387	18247.4613			
136 TSS	2627.1000 Design			288 Mass Balance		608.8867	2018.2133			
137 Ammonia	0.7278 Sludge Ceiling			0.0052 Mass Balance		0.1099	0.6179			
138 Arsenic	0.5540 Sludge Ceiling			0.0005 Mass Balance		0.0106	0.5434			
139 Cadmium	9.2303 AS/Ni/TF Inhibit	N/A		0.0008 Mass Balance		0.0169	9.2133			
140 Chromium	20.2190 Sludge Ceiling			0.0425 Mass Balance		0.8985	19.3204			
141 Copper	3.2564 AS/Ni/TF inhibit	N/A		0.0106 Mass Balance		0.2241	3.0323			
142 Cyanide	3.9711 Sludge Ceiling			0.003 Mass Balance		0.0634	3.9077			
143 Lead	0.03140 Stream Std			0.00018 Mass Balance		0.00381	0.02759			
144 Mercury	0.9925 Sludge Ceiling			0.0027 Mass Balance		0.0571	0.9354			
145 Molybdenum	4.3668 Sludge Ceiling			0.0022 Mass Balance		0.0465	4.3203			
146 Nickel	0.8734 Sludge Ceiling	N/A		0.0052 Mass Balance		0.1099	0.7634			
147 Selenium	0.0832 Stream Std	N/A		0.0024 Mass Balance		0.0507	0.0325			
148 Silver	42.3415 Sludge Ceiling			0.4251 Mass Balance		8.9874	33.3541			
150 Total Nitrogen										
151 Total Phos.										
152 c										
153 d										
154 e										
155 f										
156 g										
157 h										
158 i										

Workbook Name : 3A_3_HWA_spreadsheet_1.5_design.xlsx, Worksheet Name: AT

Printed: 1/14/2017, 3:04 PM
Page 1 of 4

Allocation Table

Headworks last approved:	<input type="text"/>
Allocation Table updated:	01/05/17
Permits last modified:	01/31/17
POTW=>	Typicalville
NPDES#=>	NC0012345

Spreadsheet Instructions: 1) Applicable Values should be entered in the Heavy Bordered cells. Rest of worksheet is protected, password is "2". 2) Formulas are discussed in the Comprehensive Guidance, Chapter 6, Section C. 3) HWA and AT worksheets in this workbook are linked. Pollutant Names, MAHLs, Basis, and Uncontrollable load in this AT worksheet are automatically entered from the HWA spreadsheet. This includes pollutant names in columns AT through BK.									
---	--	--	--	--	--	--	--	--	--

7

IUP Count	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number	Type of Industry	Renewal Effective Date	Modification Effective Date	Date Permit Expires	FLOW MGD	BOD mg/day	TSS mg/l
1	Carolina Dye House	1008	0001	textile	01/31/17		01/31/22	0.1000	100,000	300.00
2	Flying Carpet Co	1005	0001	textile	01/31/17		01/31/22	0.0500	50,000	300.00
3	Big Time Textiles	1006	0001	textile	01/31/17		01/31/22	0.3000	300,000	300.00
4	Metals Extraordinaire	1012	0001	433	01/31/17		01/31/22	0.0500	50,000	
5										
6										
7										
8										
9										
Column Totals =>								0.5000	500,000	1126
										844

Basis=>

MAHL from HWA (lbs/day) =>
Uncontrollable Loading (lbs/day) =>
Total Allowable for Industry (MAIL) (lbs/day) =>
Total Permitted to Industry (lbs/day) =>
MAIL left (lbs/day) =>
Percent Allow. Ind. (MAIL) still available (%) =>
Percent MAHL still available (%) =>
5 Percent MAHL (lbs/day) =>

NPDES

Design NPDES Permitted Flow=>	6.0000
	2.5350
	3.4650
	0.5000
	2.9650
	85.6 %
	49.4 %
	0.3000

Design	19891
	5243
	14648
	1126
	13522
	92.3 %
	68.0 %
	995

Allocation Table

Headworks last approved:

01/05/17
Allocation Table updated:
Permits last modified: 01/31/17

Typical Iville	
POTW=>	NPDES#=>
NC0012345	

IUP Count	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number	Ammonia Permit Limits	Arsenic Permit Limits	Cadmium Permit Limits	Chromium Permit Limits	Copper Permit Limits	Cyanide Permit Limits
1	Carolina Dye House	1008	0001	0.0750	0.0626				
2	Flying Carpet Co	1005	0001	0.0750	0.0313				
3	Big Time Textiles	1006	0001	0.0750	0.1877				
4	Metals Extraordinaire	1012	0001			0.0700	0.0292	1.7100	0.7131
5									
6									
7									
8									
9									
Column Totals =>				0	0.2815	0.0292	0.7131	2.7397	0.7214

Basis=>

MAHL from HWA (lbs/day) =>
Uncontrollable Loading (lbs/day) =>
Total Allowable for Industry (MAIL) (lbs/day) =>
Total Permitted to Industry (lbs/day) =>
MAIL left (lbs/day) =>
Percent Allow. Ind. (MAIL) still available (%) =>
Percent MAHL still available (%) =>
5 Percent MAHL (lbs/day) =>

Design

Sludge Ceiling

Sludge Ceiling

AS/Nit/TF inhibition

AS/Nit/TF inhibition

2627.10	0.7278	0.5540	0.2303	20.2190
608.89	0.1099	0.0106	0.0169	0.8985
2018.21	0.6179	0.5434	9.2133	19.3204
0.00	0.2815	0.0292	0.7131	2.7397
2018.21	0.3364	0.5142	8.5003	16.5807
100.0 %	54.4 %	94.6 %	92.3 %	2.3108
76.8 %	46.2 %	92.8 %	92.1 %	76.2 %
131.36	0.0364	0.0277	0.4615	82.0 %
			1.0109	71.0 %
				0.1628

Allocation Table

Headworks last approved:
Allocation Table updated:
Permits last modified:

01/05/17
01/31/17

POTW=>
NPDES#=>
Typicalville
NC0012345

IUP Count	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number	Lead Permit Limits	Mercury Permit Limits	Molybdenum Permit Limits	Nickel Permit Limits	Selenium Permit Limits	Silver Permit Limits
				Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l
1	Carolina Dye House	1008	0001						
2	Flying Carpet Co	1005	0001						
3	Big Time Textiles	1006	0001						
4	Metals Extraordinaire	1012	0001	0.6900	0.2877	2.3800	0.9925		
5									
6									
7									
8									
9									
	Column Totals =>			0.2877	0.000000	0.000000	0.9925	0.0000	0.0209

Basis=>
MAHL from HW/A (lbs/day) =>
Uncontrollable Loading (lbs/day) =>
Total Allowable for Industry (MAIL) (lbs/day) =>
Total Permitted to Industry (lbs/day) =>
MAIL left (lbs/day) =>
Percent Allow. Ind. (MAIL) still available (%) =>
Percent MAHL still available (%) =>
5 Percent MAHL (lbs/day) =>

Industry Permit number	Pipe number	Lead Permit Limits	Mercury Permit Limits	Molybdenum Permit Limits	Nickel Permit Limits	Selenium Permit Limits	Silver Permit Limits
		Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l	Conc. mg/l
1	1008	0001					
2	1005	0001					
3	1006	0001					
4	1012	0001	0.6900	0.2877	2.3800	0.9925	
5							
6							
7							
8							
9							
		0.2877	0.000000	0.000000	0.9925	0.0000	0.0209

Sludge Ceiling	Stream Std	Sludge Ceiling	Stream Std	Sludge Ceiling	Stream Std
0.9925	0.031398	0.9925	0.031398	0.8734	0.0832
0.0571	0.003806	0.0465	0.003806	0.1099	0.0507
0.9354	0.027592	0.7634	0.027592	0.7634	0.0325
0.000000	0.000000	0.000000	0.000000	0.0000	0.0209
0.9354	0.027592	3.3279	0.027592	0.7634	0.0116
100.0 %	92.6 %	77.0 %	91.2 %	100.0 %	36 %
94.2 %	87.9 %	76.2 %	87.9 %	94.2 %	14 %
0.1986	0.001570	0.0496	0.001570	0.2183	0.0437

Allocation Table

Headworks last approved:
Allocation Table updated: 01/05/17
Permits last modified: 01/31/17

POTW=>
NPDES#=>
Typicalville
NC0012345

IUP Count	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number	Zinc		Total Nitrogen		Total Phos.		d			
				Permit Limits mg/l	Conc. mg/l	Load lbs/day	Conc. mg/l	Load lbs/day	Permit Limits mg/l	Conc. mg/l	Load lbs/day		
1	Carolina Dye House	1008	0001										
2	Flying Carpet Co	1005	0001										
3	Big Time Textiles	1006	0001										
4	Metals Extraordinaire	1012	0001	1.4800	0.6172								
5													
6													
7													
8													
9													
				Column Totals =>		0.6172	0.00	0.00	0.0000	0.0000	0.0000		
Sludge Ceiling													
MAHL from HWA (lbs/day) =>													
Uncontrollable Loading (MAIL) (lbs/day) =>													
Total Permitted to Industry (lbs/day) =>													
MAIL left (lbs/day) =>													
Percent Allow. Ind. (MAIL) still available (%) =>													
Percent MAHL still available (%) =>													
5 Percent MAHL (lbs/day) =>													

Allocation Table

Headworks last approved: 01/05/17
Allocation Table updated: 01/31/17
Permits last modified: 01/31/17

POTW=>	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number
NPDES#=>	NC0012345		
1	Carolina Dye House	1008	0001
2	Flying Carpet Co	1005	0001
3	Big Time Textiles	1006	0001
4	Metals Extraordinaire	1012	0001
5			
6			
7			
8			
9			
	Column Totals =>		0.2877

11

IUP Count	INDUSTRY NAMES (please list alphabetically)	Industry Permit number	Pipe number
1	Carolina Dye House	1008	0001
2	Flying Carpet Co	1005	0001
3	Big Time Textiles	1006	0001
4	Metals Extraordinaire	1012	0001
5			
6			
7			
8			
9			

Basis=>	MAHL from HWA (lbs/day) =>	3.9711	0.031398	Sludge Ceiling	0.8734
	Uncontrollable Loading (MAIL) (lbs/day) =>	0.0634	0.003806	Sludge Ceiling	0.0465
	Total Allowable for Industry (MAIL) (lbs/day) =>	3.9077	0.027592	Sludge Ceiling	0.1099
	Total Permitted to Industry (lbs/day) =>	0.2877	0.000000	Sludge Ceiling	0.9354
		3.6200	0.027592	Sludge Ceiling	4.3203
	MAIL left (lbs/day) =>	92.6 %	100.0 %	Sludge Ceiling	0.7634
	Percent Allow. Ind. (MAIL) still available (%) =>	91.2 %	87.9 %	Sludge Ceiling	0.000000
	Percent MAHL still available (%) =>			Sludge Ceiling	-0.0676
	5 Percent MAHL (lbs/day) =>	0.1986	0.001570	Sludge Ceiling	100.0 %
			0.0496	Sludge Ceiling	-208 %
			0.001570	Sludge Ceiling	-81 %
			0.2183	Sludge Ceiling	87.4 %
			0.0437	Sludge Ceiling	0.0042