

Appendix F: Technical Memorandum for OASIS Hydrologic Model of Cape Fear and Neuse River Basins for Interbasin Transfer



Hazen and Sawyer
4011 WestChase Blvd, Suite 500
Raleigh, NC 27607 • 919.833.7152
Firm License No. C-0381

TECHNICAL MEMORANDUM

To:
Mike Wagner
Public Utilities Director
Town of Fuquay-Varina

Copies:
File

From:
Hazen and Sawyer

Date:
August 2025

Subject:
Cape Fear-Neuse Combined River Basin Hydrologic Model (OASIS) Evaluation
Town of Fuquay-Varina Water Supply and Interbasin Transfer Project
Appendix to Environmental Impact Statement

1. Introduction

General Statute § 143-355(o) compels the Division of Water Resources (DWR) to develop hydrologic models for each of the 17 major river basins in North Carolina with approval and modification responsibilities granted to the Environmental Management Commission (EMC). The models must include water uses in the basin and any other withdrawal, ecological flow, instream flow requirements, future withdrawal projections, and local water supply plan (LWSP) data. DWR is the steward of these hydrologic models.

The hydrologic basin models typically use an OASIS hydrologic model platform. OASIS is a computer program designed to simulate surface water flows through a river basin considering watershed runoff (inflows), withdrawals, discharges, and water management protocols. DWR has developed detailed river basin hydrologic models for long-term water supply planning, management, and regulatory decision-making, especially during drought conditions. For this Environmental Impact Statement (EIS), the Cape Fear-Neuse Combined River Basin (CFNCRB) model was used for the evaluation of alternatives.

The original Cape Fear and Neuse River Basin hydrologic models were developed initially in 2004 and 2008 for separate use in the Cape Fear and Neuse River basins. A single combined OASIS model of the Cape Fear and Neuse River basins was developed in 2011 for the purpose of water supply planning, drought management in the Cape Fear and Neuse River basins, and to evaluate the significant interbasin movement of water in the urbanized upper reaches of the basins, particularly in the Research Triangle area (DWR, 2016a). The combined OASIS model, the CFNCRB model, extends geographically from the headwaters of the Deep and Haw Rivers to the mouth of the Cape Fear River and from the headwaters of the Eno, Flat, and Little Rivers to the mouth of the Neuse River. The CFNCRB model has been used to evaluate Jordan Lake water supply allocation requests and the Towns of Cary and Apex interbasin transfer request in 2014.

The CFNCRB model was updated in this EIS to evaluate the impact of the Town of Fuquay-Varina's proposed interbasin transfer. This Technical Memorandum documents the model development, assumptions, and results of the CFNCRB model used to evaluate the water supply alternatives covered in the EIS. This Technical Memorandum will provide basic background on the model, describe the model inputs and assumptions, and the results of the modeled alternatives. Attachments to this Technical Memorandum are as follows:

- Attachment A: Future Climate Scenarios for Town of Fuquay-Varina Interbasin Transfer Study (Tetra Tech, 2020)
- Attachment B: Summary of Withdrawals and Discharges in Cape Fear-Neuse River Combined River Basin Model
- Attachment C: Fayetteville Public Works Commission Water Shortage Response Trigger Flow Mapping
- Attachment D: Cape Fear-Neuse River Combined River Basin Model OCL Code

2. Model Development

The CFNCRB model was used as a foundation for the existing water supply and demands in the Cape Fear and the Neuse River basins. The purpose of the CFNCRB model is to simulate present day or potential future water management operations and assess impacts to streamflow, reservoir storage, water supply reliability, and other metrics of interest. The model was updated with current information from LWSP data. All known, proposed, and approved developments to the water supply to be completed by 2055 (the planning period for this EIS) were added as new information to the model in the form of nodes, junctions, and/or reservoirs.

The model uses a hydrologic and climatic dataset developed from a 90-year historical period. The period of record starts on January 1, 1930 and extends through September 30, 2020. The data set developed for the model used a comprehensive approach, as follows:

1. The model uses data from over 60 United States Geological Survey (USGS) streamflow gages in the Cape Fear and Neuse River basins. The model also uses historical weather station data to develop information on precipitation and evaporation that is applied to reservoirs in the model.
2. The model accounts for direct human-caused flow alterations, or impairments, from reservoir regulation and net water consumption. The model corrects for these influences so that current or future conditions may be simulated using the adjusted historical hydrologic information.
3. Statistical techniques were used to complete missing hydrologic records for the streamflow gages.

2.1 Significant Updates to CFNCRB Model

For this EIS, the CFNCRB model was significantly updated since the last update by DWR in 2014. The most significant changes include the following:

- The Falls Lake Conservation Pool Reallocation was completed in 2019 to expand the

water supply pool for Raleigh Water (USACE, 2018). The CFNCRB model reflects the Falls Lake reallocation in both the 2025 and 2055 scenarios.

- It was assumed Johnston County would meet its future supply needs by developing a raw water intake on the lower Neuse River in accordance with the 2009 Environmental Assessment (CH2M Hill, 2009).
- It was assumed the Western Intake Partnership (WIP), comprised of Durham, Pittsboro, OWASA, and Chatham County, could collectively meet their future needs via use of their Jordan Lake allocations. Each member utility owns and operates separate supply systems, which are expected to remain online in the future. The proposed WIP water treatment facility will supplement existing water supply for the WIP members. Except for the City of Durham, the exact nature of WIP member's future participation is somewhat uncertain, as follows:
 - Chatham County's North System demand forecast has been revised downward during the WIP planning process. At present, it is unclear whether Chatham would need to draw on the proposed WIP WTP in the 2055 scenario. All model scenarios are set up such that Chatham County's North System meets its entire need via Jordan Lake. For modeling purposes, it will not matter whether Chatham County's water is treated at their existing WTP or the proposed WIP WTP, since all of this water will be sourced from Jordan Lake.
 - OWASA does not anticipate a shortfall in 2055 even without Jordan Lake as a supply. Therefore, Jordan Lake is not assumed to be a regular supply source for OWASA over the planning horizon.
- Jordan Lake allocations were updated in the model to reflect the final Round 4 allocation approvals per the Environmental Management Commission (EMC) in 2017. The one exception is Raleigh Water. Raleigh Water rescinded their allocation from Jordan Lake in March 2019 as a result of the Falls Lake Reallocation Process for additional storage in the Falls Lake reservoir.
- The model assumes that the City of Durham's Teer Quarry Storage Project is on-line and draws on that storage beginning at the first stage of their Water Shortage Response Plan (WSRP).
- The City of Greensboro's North Buffalo Creek Wastewater Treatment Plant (WWTP) was removed from the model as this facility was decommissioned in 2017.

Several other changes were made to update the CFNCRB model. Minor deficiencies in water supply operations and wastewater discharge locations were corrected. Annual withdrawal and discharge patterns were updated and currently known inter-utility wholesale purchase arrangements were also added to the model. Water shortage response protocols were updated per LWSPs submitted to DWR.

Updated water demand projection data from current LWSPs were used in the model. It was noted that a few communities expressed overly optimistic forecasting of future water needs, which were substantially out of alignment with the Office of State Budget and Management (OSBM) population estimates. Nevertheless, unless noted as follows, the demand forecasts used in the CFNCRB model originated from

the 2022 LWSP for each utility. The CFNCRB model updates incorporated recent work with several communities, as follows:

- Water demand projections used for Pittsboro and Chatham County North were from recent work for the Triangle Water Partnership (TWP) (HDR and Hazen, unpublished).
- Water demand projections for Raleigh Water were based on the 25th percentile water demand projection curves from the Integrated Master Plan (HDR, 2021).
- Water demand projections for the Town of Holly springs were from recent work for the TWP (HDR and Hazen, unpublished).
- Projections of water sales were included in the total water demand for any water utility whose sales partner(s) were not already represented in the model.
- Water demand and interbasin transfer projections for the Town of Fuquay-Varina were based on the technical analysis per Section 2 of the EIS.

2.2 Climate Variability

The potential impacts of future climate variability were evaluated in this EIS. Climate variability impacts were applied to Alternatives 1 to 9 for the planning year 2055. Hazen subcontracted with Tetra Tech for a climate variability screening and to produce synthetic hydrology for three selected climate variability scenarios. Tetra Tech's work involved taking outputs from global climate models (GCMs) and running the relevant outputs through a rainfall-runoff model to arrive at basin hydrology that could be incorporated into the CFNCRB model. A detailed report (Tetra Tech, 2020) is provided in Attachment A.

The climate assessment covers a scientifically supported range of future climate variability. As a measure of conservatism, the climate assessment scenarios skew somewhat toward a more severe change (i.e., high emissions scenarios and therefore higher temperatures). Future climate projections remain uncertain, in particular for precipitation (there is less uncertainty for future temperature) and are best used to describe a range of possible future conditions to which adaptation may be needed. To select a set of scenarios that bound the likely range of potential climate futures with respect to water supply, the relative change in mean annual temperature and mean annual precipitation was assessed across a range climate models (over 30 models) paired with two of the more severe but commonly studied greenhouse gas emissions trajectories.

Greenhouse emissions trajectories are standardized by the Intergovernmental Panel on Climate Change (IPCC) and referred to as representative concentration pathways (RCPs) (van Vuuren, 2011). The two RCPs used in this study are RCP 4.5 and RCP 8.5. The number following the RCP (4.5 or 8.5) refers to the climate forcing condition of the emissions trajectory in watts per meter squared (W/m^2) for the year 2100 relative to the pre-industrial year of 1750. The higher the number, the greater the degree of warming expected. A paper published after the scenario screening analysis was conducted suggests that, at present, the most likely warming scenarios are similar to RCP 3.4 (Pielke, 2021). For reference, Table 1 summarizes the currently studied RCPs and the range of global mean temperature increase expected relative to the pre-industrial baseline.

Figure 1 illustrates the relative change in temperature and precipitation predicted by different GCMs and forcing conditions (e.g., RCPs) specific to central North Carolina in a commonly used future climate

scenario dataset. Climate variability scenarios likely to predict higher runoff (and therefore water supply) are located in the upper-left quadrant of Figure 1. These scenarios predict a greater increase in mean annual precipitation and a relatively moderate increase in air temperature and associated evapotranspiration compared to their model peers. Conversely, scenarios likely to predict the less runoff are located in the bottom-right quadrant of Figure 1. These scenarios predict a small increase in mean annual precipitation and a relatively large increase in mean annual air temperature. Three climate future scenarios were selected to develop a quantitative climate assessment that covers a scientifically supported range of future climate variability. The three selected scenarios are listed as follows with the model name first followed by the RCP and the purpose for selecting the scenario.

- CNRM-CM5, RCP 4.5 (higher runoff potential)
- MIROC-ESM-CHEM, RCP 8.5 (lower runoff potential)
- GFDL-ESM2M, RCP 8.5 (approximates ensemble mean)

Table 1: Representative Concentration Pathway Scenarios and Temperature Change Projections

Scenario	Range of Global Mean Temperature Increase for Year 2100 relative to Pre-Industrial Baseline
RCP 1.9	1 to 1.5°C
RCP 2.6	1.5 to 2°C
RCP 3.4	2 to 2.4°C
RCP 4.5 ¹	2.5 to 3°C
RCP 6.0	3 to 3.5°C
RCP 7.5	~ 4°C
RCP 8.5 ¹	~ 5°C

¹ RCPs used in this assessment.

Timeseries output were then downloaded from the archive for the three selected scenarios. A watershed runoff model, the National Hydrologic Model (NHM) with the Precipitation-Runoff Modeling System (PRMS), was then used to convert GCM output (temperature and precipitation in particular) to a hydrologic runoff timeseries and evaporation timeseries for use in the CFNCRB model. A detailed explanation of the selection and processing of the climate scenario data is included in Attachment A.

Hydrologic timeseries associated with each climate future scenario are compared to a historical “hindcast” model run covering 1950 to 2005. Hindcasting is conducted using the GCM with historical forcing conditions (i.e., past atmospheric greenhouse gas concentrations) to simulate the 1950 to 2005 period and evaluate the GCM’s accuracy in reproducing historical climate conditions. When coupled with a future climate forecast, hindcasting provides an apples-to-apples indication of relative change in any number of climatic factors. The relative change is used to adjust the inputs to the CFNCRB model using a bias-adjustment technique. The bias adjustment accounts for systematic differences that may be present between the PRMS model and historically observed flows. The target future year of 2055 is based upon the assumption of a 30-year IBT certificate issued around 2025. Since a 30-year period is typically used to evaluate statistical climate normals, the climate variability scenarios used outputs from the GCM from 2040 to 2070, the mid-point of which is 2055. The 30-year timeseries for each of the three climate variability scenarios was then inserted into the CFNCRB model for evaluation.




Figure 1: Relative change from historical (1950-2005) for future (2040-2070) average (or mean) annual precipitation and mean annual air temperature for global climate models and greenhouse gas representative concentration pathways (RCP 4.5 and RCP 8.5) for the Central Piedmont Region of North Carolina. Note: Selected scenarios have a green box around the model name (from Attachment A, Tetra Tech 2020).

2.3 Water Supply Alternatives

After completing the model updates required for the 2025 and 2055 baseline conditions, the CFNCRB model was further developed to simulate each of the water supply alternatives considered in the EIS for the year 2055. The models used monthly demand data in the calculations of the deliveries to each demand node. Refer to Section 3 of the EIS for a detailed description and evaluation of alternatives. The CFNCRB model for each alternative was evaluated using the historical hydrologic record contained in the model (1930 to 2020) as well as with each of the three climate variability scenarios (2040 to 2070). A summary of the added CFNCRB model inputs and operational changes to accommodate the alternatives analysis is provided in Table 2. A summary of the withdrawals and discharges in the CFNCRB model are provided in Attachment B. The CFNCRB model inputs and operational changes are described as follows:

- No Action Alternative
 - The demand years of 2025 and 2055 were modeled to show hydrology and supply shortages without any changes to the existing systems, approved or in construction capital improvement projects, or sales contracts.
- Alternative 1 – Surface Water, Purchase Finished Water from Raleigh Water
 - A new reservoir node was created to model Middle Creek Reservoir including storage-area-elevation (SAE) data developed to simulate the manmade

reservoir. The reservoir was sized to meet demand from both Raleigh Water and the Town of Fuquay-Varina. A new connection from the reservoir to the Town of Fuquay-Varina was added.

- Alternative 2 – Surface Water, Purchase Finished Water from Johnston County
 - No new model nodes were added. Water is supplied to the Town of Fuquay-Varina via a new connection from the future Johnston County Quarry Reservoir and WTP.
- Alternative 3 – Surface Water, Town of Fuquay-Varina Independent Water Supply in Neuse River Basin
 - A new reservoir node was created to model Middle Creek Reservoir including SAE data developed to simulate the man-made reservoir. The reservoir was sized to meet demand for the Town of Fuquay-Varina independently. A new connection from the reservoir to the Town of Fuquay-Varina was added. This alternative also assumes a new WTP would be constructed.
- Alternative 4 – Surface Water, Purchase Finished Water from City of Dunn
 - A new connection from the City of Dunn to the Town was added.
- Alternative 5 – Surface Water, Purchase Finished Water from Harnett County
 - The maximum sales from Harnett County was increased to meet the Town of Fuquay-Varina's projected demand.
- Alternative 6 – Surface Water, Raw Water from Jordan Lake (Cary/Apex)
 - A new connection from Jordan Lake to the Town of Fuquay-Varina was added. Alternatives 6 and 7 are identical in simulation. A new WTP would be constructed by the Town of Fuquay-Varina to produce finished water.
- Alternative 7 – Surface Water, Raw Water from Jordan Lake (Western Intake Partnership)
 - A new connection from Jordan Lake to the Town of Fuquay-Varina was added. Alternatives 6 and 7 are identical in simulation.
- Alternative 8A – Surface Water, Town of Fuquay-Varina Intake on the Cape Fear with Return of Water to Cape Fear River Basin (Cape Fear River)
 - A new connection from the Cape Fear River at the Lillington gage to the Town of Fuquay-Varina was added and a new connection from the Town of Fuquay-Varina to the Cape Fear River downstream of the Lillington gage for wastewater discharge.
- Alternative 8B – Surface Water, Town of Fuquay-Varina Intake on the Cape Fear with Return of Water to Cape Fear River Basin (Kenneth Creek)
 - A new connection from the Cape Fear River at the Lillington gage to the Town of Fuquay-Varina was added as was a new connection from the Town of Fuquay-Varina to Kenneth Creek for wastewater discharge upstream of the Lillington gage.

- Alternative 9 – Surface Water, Purchase Finished Water from City of Sanford
 - For all sub-alternatives A-D, a new connection to the City of Sanford's water supply was added to the Town of Fuquay-Varina. WTP process loss was factored in for this alternative.
 - The City of Sanford's raw water intake was modeled as a run-of-river intake and does not include storage from the Buckhorn Dam impoundment. Buckhorn Dam is a relatively small impoundment, so the buffering capacity of storage behind the dam is minimal, but the Buckhorn dam impoundment stores approximately one week of withdrawals for the City of Sanford and its partners under the 2055 condition. Therefore, modeling this alternative as a run-of-river withdrawal is conservative.
- Alternatives 9 A/B – Surface Water, Purchase Finished Water from City of Sanford
 - Wastewater is treated and discharged to the basin used by the Town of Fuquay-Varina's retail customers. Wastewater produced in the Neuse River Basin is assumed to be treated and discharged at the Terrible Creek WWTP. Wastewater produced in the Cape Fear Basin is assumed to be treated and discharged at Harnett County's Regional North Harnett Regional WWTP.
- Alternative 9C – Surface Water, Purchase Finished Water from City of Sanford with Return of Water to Cape Fear River
 - This alternative has common components with Alternative 9 A/B plus a new connection from the Town of Fuquay-Varina to the Cape Fear River downstream of the Lillington gage for wastewater discharge.
- Alternative 9D – Surface Water, Purchase Finished Water from City of Sanford with Return of Water to Cape Fear River
 - This alternative has common components with Alternative 9 A/B plus a new connection from the Town of Fuquay-Varina to pump untreated wastewater from the Town's Terrible Creek WWTP service area in the Neuse River basin to the Western Wake WRF.

Table 2: Summary of Modeling Inputs for Cape Fear-Neuse River Hydrologic OASIS Model

	No-action		Raleigh	Johnston County	Independent Reservoir	Dunn	Harnett	Jordan Lake, A	Jordan Lake, B	Fuquay-Varina Intake and Return to Cape Fear River	Fuquay-Varina Intake and Return to Kenneth Creek	Sanford (No Return)	Sanford (With Return)	Sanford (With Return)
Alternative	----		1	2	3	4	5	6	7	8A	8B	9A/B	9C	9D
Model Year	2025	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055
New nodes	N/A	N/A	Middle Creek Reservoir, node 1475, sized for Raleigh and Town use	None	Middle Creek Reservoir, node 1475, sized for Town use only	N/A	N/A	N/A	N/A	N/A	New discharge point	N/A	N/A	N/A
New connections	N/A	N/A	Middle Creek Reservoir to Town, node 1475 to 1706, and Middle Creek to Raleigh, Node 1475 to 1306	Johnston County Quarry Reservoir to Town, node 1648 to 1706	Middle Creek Reservoir to Town, node 1475 to 1706	Dunn Supply to Town, node 662 to 1706	N/A	Jordan Lake to Town, node 0470 to 1706	Jordan Lake to Town, node 0470 to 1706	Cape Fear Lillington Gage to Town, node 0550 to 1706, and Town to downstream of Lillington gage, 1706 to 0650	Cape Fear Lillington Gage to Town, node 0550 to 1706, and Town to Kenneth Creek, 1706 to 0554 (upstream of Lillington)	Sanford Cape Fear withdrawal point to Town, nodes 0489/0492 to 1706 (incorporating process loss)	Sanford Cape Fear withdrawal point to Town, nodes 0489/0492 to 1706, and Town to downstream of Lillington gage, 1706 to 0650	Sanford Cape Fear withdrawal point to Town, nodes 0489/0492 to 1706, and Town to Western Wake WRF, 1706 to 0930
Operational changes	N/A	N/A	Set Town operations to receive from Raleigh for Neuse demand before exceeding Harnett	Set Town operations to receive from Johnston County for Neuse demand before exceeding	Set Town operations to receive from Middle Creek Res. for Neuse demand before exceeding	Set Town operation to receive from Dunn Water Supply once exceeding Harnett	Set all Town demand to be supplied by Harnett County	Set Town operation to use Jordan Lake once exceeding Harnett contract	Set Town operation to use Jordan Lake once exceeding Harnett contract	Set Town operations to use the Cape Fear, adjust wastewater returns to return to	Set Town operations to use the Cape Fear, adjust wastewater returns to return to	Set Town operations to receive water from Sanford once exceeding Harnett Contract	Set Town operations to receive from Sanford once exceeding Harnett Contract, adjust	Set Town operations to receive from Sanford once exceeding Harnett Contract, adjust

Table 2: Summary of Modeling Inputs for Cape Fear-Neuse River Hydrologic OASIS Model

	No-action		Raleigh	Johnston County	Independent Reservoir	Dunn	Harnett	Jordan Lake, A	Jordan Lake, B	Fuquay-Varina Intake and Return to Cape Fear River	Fuquay-Varina Intake and Return to Kenneth Creek	Sanford (No Return)	Sanford (With Return)	Sanford (With Return)
Alternative	----		1	2	3	4	5	6	7	8A	8B	9A/B	9C	9D
Model Year	2025	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055	2055
			contract	Harnett contract	Harnett contract	contract				Cape Fear	Cape Fear		waste-water returns to Cape Fear	wastewater returns to Cape Fear
Max. Month Sales from Harnett County, mgd	2	2	2	2	2	2	9.9	2	2	2	2	2	2	2
Max. Month Sales from Johnston County, mgd	1.5	0	0	7.9	0	0	0	0	0	0	0	0	0	0
Max. Month Sales from the City of Raleigh, mgd	1.75	0	7.9	0	0	0	0	0	0	0	0	0	0	0
Additional Max. Month Sales, mgd	N/A	N/A	N/A	N/A	N/A	7.9	N/A	7.9, from Cary	N/A	N/A	N/A	7.9, from Sanford	7.9, from Sanford	7.9 from Sanford
Wastewater return routing	Existing	Existing	Existing	Existing	Existing	Existing	Existing	Existing	Existing	Discharge 0.5 miles downstream of proposed intake	Discharge at Kenneth Creek at old plant outflow	Existing	Discharge at Cape Fear River	Discharge to Western Wake WRF (to Cape Fear River)

3. Analysis of CFNCRB Model Simulation Results

The modeling results are summarized with the no-action baseline alternative in 2025 and 2055 in comparison with Alternatives 1 through 9 in the planning year 2055. The modeling results for the historic hydrologic record are presented along with the three selected climate variability scenarios for each alternative, including the no-action alternative. Many of the metrics presented are consistent with the metrics presented in the 2014 Cary-Apex IBT analysis in the Cape Fear. The CFNCRB model results were evaluated using three broad classes of model output, as follows:

1. Municipal water supply reliability.
2. Performance of Jordan Lake and Falls Lake in Meeting Flow Targets and Recreational Criteria.
3. Low-flow discharge in the Cape Fear River and Neuse River:
 - a. Potential climate change impact to hydrology.
 - b. Cumulative impact related to Cape Fear River basin development (i.e., water demand increase between 2025 and 2055).
 - c. Project-related impacts to 7Q10.
 - d. Gage accuracy and model precision.

3.1 Municipal Water Supply Reliability

The ability of municipal purveyors to meet water supply needs is a key consideration for long-term planning. This section describes model results related to the ability to achieve this goal. The frequency, in percent of days, for meeting nominal (i.e., unrestricted) water demand for each alternative and climate scenario is summarized in Table 3. The nominal demand does not include reductions produced by conservation measures (i.e., when a water shortage response stage is triggered). For example, a frequency of 100 percent indicates that all of the water demand is met over the entire simulation period and no conservation was triggered for that utility. Frequency values less than 100 percent indicate the nominal demand is not always met. This phenomenon occurs for two reasons: 1) water conservation has been invoked, and/or 2) not enough water is available to meet the demand. For those systems whose triggers can be modeled, water demand is reduced according to the utility's WSRP proscribed conservation schedule when appropriate (i.e., a 10 percent reduction in water use in Stage 1 conservation).

An example is Cary-Apex which meets the conditions for triggering its WSRP at various points in all 2055 scenarios. Per Table 3, simulations using the historic inflow record show 100 percent delivery for Cary-Apex in year 2025 for the No-Action alternative and then decreasing to 93.5 percent in 2055. In 2055, the increased water demand on Jordan Lake prompts activation of Cary-Apex's drought plan on approximately 6.5 percent of the days in the model record (1930 to 2020 hydrology representing 33,000 days). Therefore, delivery of water supply in 2055 would meet Cary-Apex's unrestricted demand on 93.5 percent of days. For the other 6.5 percent of days, the model indicates the reduced demand (i.e., triggering the Cary-Apex's WSRP) would be met 100 percent of the time.

Many of the water systems summarized in Table 3 do not have drought (i.e., WSRP) triggers that are quantifiable in the CFNCRB model. For these systems, water demand is not reduced under water shortage conditions. These systems all follow the statutory requirements for water shortage response; however, the triggers for entering the mandatory stages of the water shortage response are not specific enough to model. A failure to meet the unrestricted demands is due to a shortage of water (i.e., insufficient water on some days in the model to meet the full demand). This unrestricted demand scenario includes the Town of Fuquay-Varina. The model indicated that the Town of Fuquay-Varina would have a 0 percent supply reliability in 2055 in the No-Action alternative, as additional supply is not considered to meet the Town's projected 2055 needs.

Shortages due to absolute insufficiency of supply occur for only two other demand nodes in the model (at a single withdrawal point) and are limited to two of the three climate change scenarios. These shortages due to climate change occur for the Cape Fear Public Utility Authority (CFPUA) and Lower Cape Fear Water and Sewer Authority (LCFWSA) raw water intakes at the downstream end of the Cape Fear River basin. Using historical inflows, the 2055 demands are always met for CFPUA and LCFWSA across every modeled alternative. The frequency of shortages under the two more adverse climate change scenarios is extremely small. The period of record for the climate change runs (2040 to 2070) contains 11,000 days. Therefore, a 0.01 percent result equals approximately 1 day of water supply shortage. These rare instances are highlighted as blue cells in Table 3. All of the modeled shortages for CFPUA and LCFWSA were short, intermittent, infrequent, and did not include mitigation from a WSRP with quantifiable demand reductions by WSRP stage. Additionally, the shortages occurred during significant additional demand-side water stress. The municipal surface water demands for Fayetteville Public Works Commission (PWC), CFPUA and LCFWSA are projected to increase by over 57 mgd between 2025 and 2055 per the respective LWSPs submitted by these utilities, which is a 90 percent increase in water demand at these locations over the 30-year planning horizon. Shortages for CFPUA and LCFWSA are described further in Section 4.

For systems that do have quantifiable WSRP triggers, additional information on the nature of WSRP performance is provided in Table 4A and Table 4B. There are four water utilities (Cary-Apex, Raleigh Water, City of Dunn, and Town of Benson) whose WSRPs were activated in the CFNCRB model. In July 2023, PWC adopted changes to their WSRP that included quantifiable shortage response triggers based on water elevation in the Cape Fear River at the PWC raw water intake. The PWC WSRP was adopted after the updates to the CFNCRB model. Drought response operations for PWC were modeled similarly to the operation for the City of Dunn. The City of Dunn's drought response rules are based off Cape Fear River discharges. The PWC WSRP elevation triggers were mapped to the flow output from the CFNCRB simulations using historical stage-discharge data at the Fayetteville NC USGS gage and the state HEC-RAS model for this section of the Cape Fear River, further detail is provided in Attachment C. Tables 4A and 4B provide the percent of years in which the WSRP is activated, the median length of time the WSRPs are active once activated (i.e., the length of water use restrictions), the worst case event length, and the highest (i.e., most restrictive) WSRP stage reached during the entire model run.

When evaluating the results in Tables 4A and 4B, it should be noted that the historical hydrologic record is approximately three times as long as each climate change scenario. When comparing the results for any of these utilities by water supply alternative, there is very little difference between the alternatives. There are differences between the climate scenarios, but the most significant difference is simply due to the cumulative change between 2025 and 2055. Both Raleigh Water and Cary-Apex have WSRP

activation frequencies of less than 1 in 3 years for all alternatives and climate outcomes. Using historical hydrology, the median restriction periods extend approximately 2 months for Raleigh Water and about 3.5 months for Cary-Apex. In the most severe historical drought, Cary/Apex spends just over 3 months in Stage 2 of their WSRP and Raleigh Water spends 6 months in Stage 3 of their WSRP. For the City of Dunn and the Town of Benson, the activation frequencies are less than once in ten years and the median restrictions have a one week duration. In the worst case these extend to just under three weeks. For Fayetteville PWC, there is little to no change between the 2025 and 2055 conditions under historical hydrology and the median and maximum event lengths remain the same plus or minus a day across all scenarios within the respective hydrology.

Table 3: Summary of Frequency of Achieving Nominal (Unrestricted) Demand (% of Days)

Water Supply Alternative	Year	Inflows	Cape Fear River Basin Model Nodes						Neuse River Basin Model Nodes						
			Cary-Apex	Sanford ¹	Harnett County ¹	Dunn	Fayetteville	CFPUA / LCFWSA ¹	Raleigh	Johnston County ¹	Smithfield ¹	Fuquay-Varina ¹	Benson	Goldsboro ¹	Neuse-WASA ¹
No action (baseline)	2025	Historic	100.00%	100.00%	100.00%	99.15%	98.92%	100.00%	100.00%	100.00%	100.00%	100.00%	99.15%	100.00%	100.00%
	2055	Historic	93.53%	100.00%	100.00%	99.83%	98.84%	100.00%	97.72%	100.00%	100.00%	0.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	100.00%	96.68%	100.00%	100.00%	0.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	0.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.35%	96.17%	99.98%	96.90%	100.00%	100.00%	0.00%	99.35%	100.00%	100.00%
Alternative 1	2055	Historic	93.46%	100.00%	100.00%	99.83%	98.88%	100.00%	97.73%	100.00%	100.00%	100.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	99.98%	96.72%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.35%	96.23%	100.00%	96.91%	100.00%	100.00%	100.00%	99.35%	100.00%	100.00%
Alternative 2	2055	Historic	93.56%	100.00%	100.00%	99.83%	98.88%	100.00%	97.72%	100.00%	100.00%	100.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	99.90%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.37%	96.23%	99.86%	96.90%	100.00%	100.00%	100.00%	99.37%	100.00%	100.00%
Alternative 3	2055	Historic	93.46%	100.00%	100.00%	99.83%	98.88%	100.00%	97.72%	100.00%	100.00%	100.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	100.00%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.35%	96.23%	100.00%	96.90%	100.00%	100.00%	100.00%	99.35%	100.00%	100.00%
Alternative 4	2055	Historic	93.48%	100.00%	100.00%	99.83%	98.74%	100.00%	97.72%	100.00%	100.00%	100.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.33%	99.96%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.60%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.35%	95.98%	99.97%	96.90%	100.00%	100.00%	100.00%	99.35%	100.00%	100.00%

Table 3: Summary of Frequency of Achieving Nominal (Unrestricted) Demand (% of Days)

Water Supply Alternative	Year	Inflows	Cape Fear River Basin Model Nodes						Neuse River Basin Model Nodes						
			Cary-Apex	Sanford ¹	Harnett County ¹	Dunn	Fayetteville	CFPUA / LCFWSA ¹	Raleigh	Johnston County ¹	Smithfield ¹	Fuquay-Varina ¹	Benson	Goldsboro ¹	Neuse-WASA ¹
Alternative 5	2055	Historic	93.44%	100.00%	100.00%	99.77%	98.74%	100.00%	97.72%	100.00%	100.00%	100.00%	99.77%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.41%	98.46%	99.89%	96.68%	100.00%	100.00%	100.00%	99.41%	100.00%	100.00%
		GFDL	92.37%	100.00%	100.00%	99.98%	99.66%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.13%	96.23%	99.91%	96.90%	100.00%	100.00%	100.00%	99.13%	100.00%	100.00%
Alternative 6	2055	Historic													
		CNRM	Identical to Alternative 7 (withdrawal from Jordan Lake)												
		GFDL													
		MIROC													
Alternative 7	2055	Historic	93.46%	100.00%	100.00%	99.83%	98.87%	100.00%	97.72%	100.00%	100.00%	100.00%	99.83%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	100.00%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.38%	100.00%	100.00%	99.98%	99.81%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.76%	100.00%	100.00%	99.37%	96.23%	99.94%	96.90%	100.00%	100.00%	100.00%	99.37%	100.00%	100.00%
Alternative 8A	2055	Historic	93.44%	100.00%	100.00%	99.77%	98.92%	100.00%	97.72%	100.00%	100.00%	100.00%	99.77%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.41%	98.54%	99.97%	96.68%	100.00%	100.00%	100.00%	99.41%	100.00%	100.00%
		GFDL	92.37%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.13%	96.28%	99.87%	96.90%	100.00%	100.00%	100.00%	99.13%	100.00%	100.00%
Alternative 8B	2055	Historic	93.46%	100.00%	100.00%	99.78%	98.87%	100.00%	97.72%	100.00%	100.00%	100.00%	99.78%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.55%	99.90%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.66%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.23%	96.23%	99.94%	96.90%	100.00%	100.00%	100.00%	99.23%	100.00%	100.00%

Table 3: Summary of Frequency of Achieving Nominal (Unrestricted) Demand (% of Days)

Water Supply Alternative	Year	Inflows	Cape Fear River Basin Model Nodes						Neuse River Basin Model Nodes						
			Cary-Apex	Sanford ¹	Harnett County ¹	Dunn	Fayetteville	CFPUA / LCFWSA ¹	Raleigh	Johnston County ¹	Smithfield ¹	Fuquay-Varina ¹	Benson	Goldsboro ¹	Neuse-WASA ¹
Alternative 9A/B	2055	Historic	93.44%	100.00%	100.00%	99.77%	98.74%	100.00%	97.72%	100.00%	100.00%	100.00%	99.77%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.41%	98.46%	99.89%	96.68%	100.00%	100.00%	100.00%	99.41%	100.00%	100.00%
		GFDL	92.37%	100.00%	100.00%	99.98%	99.66%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.13%	96.23%	99.91%	96.90%	100.00%	100.00%	100.00%	99.13%	100.00%	100.00%
Alternative 9C	2055	Historic	93.46%	100.00%	100.00%	99.77%	98.91%	100.00%	97.72%	100.00%	100.00%	100.00%	99.77%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.41%	98.54%	99.98%	96.68%	100.00%	100.00%	100.00%	99.41%	100.00%	100.00%
		GFDL	92.37%	100.00%	100.00%	99.98%	99.69%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.11%	96.31%	99.92%	96.90%	100.00%	100.00%	100.00%	99.11%	100.00%	100.00%
Alternative 9D	2055	Historic	93.44%	100.00%	100.00%	99.78%	98.87%	100.00%	97.72%	100.00%	100.00%	100.00%	99.78%	100.00%	100.00%
		CNRM	90.23%	100.00%	100.00%	99.57%	98.52%	99.89%	96.68%	100.00%	100.00%	100.00%	99.57%	100.00%	100.00%
		GFDL	92.41%	100.00%	100.00%	99.98%	99.66%	100.00%	100.00%	100.00%	100.00%	100.00%	99.98%	100.00%	100.00%
		MIROC	87.75%	100.00%	100.00%	99.23%	96.23%	99.93%	96.90%	100.00%	100.00%	100.00%	99.23%	100.00%	100.00%

¹ These systems do not have quantifiable drought triggers that can be modeled in OASIS, so only the unrestricted demand is considered for these systems. Instances when unrestricted demand for these systems cannot be met are highlighted in blue. The only systems subject to this condition, other than Fuquay-Varina in the No-Action alternative, are CFPUA and LCFWSA.

Table 4A: Detailed WSRP Statistics for Cary-Apex, City of Dunn, and Fayetteville PWC

Water Supply Alternative	Year	Inflows ¹	Cape Fear River Basin Model Nodes for Cary-Apex						Cape Fear River Basin Model Nodes for Dunn						Cape Fear River Basin Model Nodes for Fayetteville					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
No action (baseline)	2025	Historic	0	0	0	0	0	0	0	0	0	0	0	0	15.4	13	33	2	1.1	26
	2055	Historic	25.3	102.5	236	2	1.1	96	3.3	7.5	19	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	2	3.2	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	16	37	2	16.1	35
Alternative 1	2055	Historic	25.3	106	236	2	1.1	96	3.3	7.5	19	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	1	12.9	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	16	36	2	12.9	31
Alternative 2	2055	Historic	25.3	106	236	2	1.1	96	3.3	7.5	19	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	1	12.9	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	16	36	2	12.9	31
Alternative 3	2055	Historic	25.3	106	236	2	1.1	96	3.3	7.5	19	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	1	12.9	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	16	36	2	12.9	31

Table 4A: Detailed WSRP Statistics for Cary-Apex, City of Dunn, and Fayetteville PWC

Water Supply Alternative	Year	Inflows ¹	Cape Fear River Basin Model Nodes for Cary-Apex						Cape Fear River Basin Model Nodes for Dunn						Cape Fear River Basin Model Nodes for Fayetteville					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
Alternative 4	2055	Historic	25.3	104.5	236	2	1.1	96	3.3	7.5	19	2	1.1	19	17.6	13	34	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	19.4	9	22	2	3.2	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	17.5	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	17	37	2	16.1	35
Alternative 5	2055	Historic	25.3	106	236	2	1.1	96	5.5	9	20	2	1.1	19	18.7	13	34	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	9.7	10	13	1	9.7	13	12.9	9.5	22	2	6.5	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	9.7	8.5	13	1	9.7	13	32.3	16	36	2	19.4	35
Alternative 6	2055	Historic																		
		CNRM	Identical to Alternative 7 (Jordan Lake Withdrawal)																	
		GFDL																		
		MIROC																		
Alternative 7	2055	Historic	25.3	106	236	2	1.1	96	3.3	7.5	19	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	1	12.9	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	3.2	9	9	1	3.2	9
		MIROC	32.3	144	249	2	19.4	131	6.5	8	13	1	6.5	13	32.3	16	36	2	12.9	31
Alternative 8A	2055	Historic	25.3	106	236	2	1.1	96	5.5	9	20	2	1.1	19	14.3	14.5	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	9.7	10	13	1	9.7	13	12.9	9	22	2	6.5	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	9.7	8.5	13	1	9.7	13	32.3	16	36	2	19.4	35

Table 4A: Detailed WSRP Statistics for Cary-Apex, City of Dunn, and Fayetteville PWC

Water Supply Alternative	Year	Inflows ¹	Cape Fear River Basin Model Nodes for Cary-Apex						Cape Fear River Basin Model Nodes for Dunn						Cape Fear River Basin Model Nodes for Fayetteville					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
Alternative 8B	2055	Historic	25.3	106	236	2	1.1	96	5.5	8.5	20	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	2	3.2	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8.5	13	1	6.5	13	32.3	16	36	2	16.1	35
Alternative 9A/B	2055	Historic	25.3	106	236	2	1.1	96	5.5	9	20	2	1.1	19	18.7	13	34	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	9.7	10	13	1	9.7	13	12.9	9.5	22	2	6.5	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	9.7	8.5	13	1	9.7	13	32.3	16	36	2	19.4	35
Alternative 9C	2055	Historic	25.3	106	236	2	1.1	96	5.5	9	20	2	1.1	19	14.3	14.5	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	9.7	10	13	1	9.7	13	12.9	9	22	2	6.5	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	9.7	8.5	13	1	9.7	13	32.3	16	36	2	19.4	35
Alternative 9D	2055	Historic	25.3	106	236	2	1.1	96	5.5	8.5	20	2	1.1	19	16.5	13	33	2	1.1	26
		CNRM	22.6	136.5	516	2	9.7	436	6.5	11.5	13	1	6.5	13	12.9	9.5	22	2	3.2	22
		GFDL	29	82	184	1	29	184	0	0	0	0	0	0	6.5	14	19	1	6.5	19
		MIROC	32.3	145	249	2	19.4	131	6.5	8.5	13	1	6.5	13	32.3	16	36	2	16.1	35

¹ Note that the historical hydrologic record in OASIS spans 91 years whereas the length of record for each of the CNRM-CM5, GFDL-ESM2M, and MIROC-EMS-CHEM hydrologic scenarios is 31 years.

Table 4B: Detailed WSRP Statistics for Raleigh Water and Town of Benson

Water Supply Alternative	Year	Inflows ¹	Neuse River Basin Model Nodes for Raleigh Water						Neuse River Basin Model Nodes for Benson					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
No action (baseline)	2025	Historic	0	0	0	0	0	0	0	0	0	0	0	0
	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 1	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	385	385	3	3.2	150	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 2	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 3	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 4	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 5	2055	Historic	20.9	67	211	3	2.2	181	5.5	9	20	2	1.1	19
		CNRM	6.5	386	386	3	6.5	174	9.7	10	13	1	9.7	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	9.7	8.5	13	1	9.7	13

Table 4B: Detailed WSRP Statistics for Raleigh Water and Town of Benson

Water Supply Alternative	Year	Inflows ¹	Neuse River Basin Model Nodes for Raleigh Water						Neuse River Basin Model Nodes for Benson					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
Alternative 6	2055	Historic												
		CNRM ²	Identical to Alternative 7 (Jordan Lake Withdrawal)											
		GFDL												
		MIROC												
Alternative 7	2055	Historic	20.9	67	211	3	2.2	181	3.3	7.5	19	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8	13	1	6.5	13
Alternative 8A	2055	Historic	20.9	67	211	3	2.2	181	5.5	9	20	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	9.7	10	13	1	9.7	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	9.7	8.5	13	1	9.7	13
Alternative 8B	2055	Historic	20.9	67	211	3	2.2	181	5.5	8.5	20	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8.5	13	1	6.5	13
Alternative 9A/B	2055	Historic	20.9	67	211	3	2.2	181	5.5	9	20	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	9.7	10	13	1	9.7	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	9.7	8.5	13	1	9.7	13
Alternative 9C	2055	Historic	20.9	67	211	3	2.2	181	5.5	9	20	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	9.7	10	13	1	9.7	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	9.7	8.5	13	1	9.7	13

Table 4B: Detailed WSRP Statistics for Raleigh Water and Town of Benson

Water Supply Alternative	Year	Inflows ¹	Neuse River Basin Model Nodes for Raleigh Water						Neuse River Basin Model Nodes for Benson					
			% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)	% of Years with WSRP Events ¹	Median Event Length (days)	Max Event Length (days)	Max Stage	% of Years with Max Stage	Max Event Length of Max Stage (days)
Alternative 9D	2055	Historic	20.9	67	211	3	2.2	181	5.5	8.5	20	2	1.1	19
		CNRM ²	6.5	386	386	3	6.5	174	6.5	11.5	13	1	6.5	13
		GFDL	0	0	0	0	0	0	0	0	0	0	0	0
		MIROC	29	68	150	2	6.5	77	6.5	8.5	13	1	6.5	13

¹ Note that the historical hydrologic record in OASIS spans 91 years whereas the length of record for each of the CNRM-CM5, GFDL-ESM2M, and MIROC-EMS-CHEM hydrologic scenarios is 31 years.

² For each alternative using CNRM-CM5 inflows, Raleigh Water experiences a singular water shortage event that spans two years reaching up to shortage response Stage 3 for 150 to 174 days, thus the mean and median event length are equal.

3.2 Performance of Jordan Lake and Falls Lake in Meeting Flow Targets and Recreational Criteria

The second class of modeling results described in this report pertain to the frequency (in percent of days) that an alternative does not meet storage, lake elevation, or flow metrics at specific locations, as summarized in Table 5. These results generally pertain to the ability of Falls Lake and Jordan Lake to meet their authorized purposes. These metrics are consistent with the metrics presented in the 2014 Cary/Apex IBT analysis in the Cape Fear River. Similar metrics were developed for Falls Lake. The specific metrics used in the analysis include the following:

- Jordan Lake < 210 feet
- Jordan Lake < 210 feet Memorial to Labor Day
- Jordan Lake water quality storage < 80%, < 60%, < 40%, and < 20%
- Jordan Lake water supply storage < 50%
- Lillington gage flow < 550 cfs
- Fayetteville intake flow < 600 cfs
- Falls Lake < 242.5 feet
- Falls Lake < 242.5 feet Memorial to Labor Day
- Jordan Lake water quality storage < 80%, < 60%, < 40%, and < 20%
- Jordan Lake water supply storage < 50%
- Falls Lake gage flow < seasonal target at Falls Lake (April to October at 100 cfs; 60 cfs otherwise).
- Clayton gage flow < seasonal target at Clayton gage (April to October at 254 cfs; 184 cfs otherwise).

The 210 feet pool elevation in Jordan Lake and the 242.5 feet pool elevation in Falls Lake (USACE, 2018) represent lake levels at which boat access (i.e., the recreation purpose authorized for both federal projects) are anticipated to be adversely impacted. The normal pool for Jordan Lake is 216 feet. The normal pool elevation for Falls Lake is 251.5 feet. The following is a summary of the key conclusions:

- Jordan Lake drops to less than 210 feet less than 0.8 percent of the time for nearly all alternatives and climate change scenarios and 0.2 percent or less in the key summer recreational period. The singular exception is for the MIROC climate scenario for Alternatives 6 and 7 where the numbers are 1.2 percent and 0.4 percent, respectively.
- Jordan Lake water quality storage never drops less than 20 percent (i.e., equivalent to the Stage 4 trigger) in any alternative using either historic or climate change inflows. The water quality storage declines to less than 40 percent infrequently (i.e., less than 2.4 percent of the time) for all 2055 scenarios.
- The amount of time the Jordan Lake Water Quality Pool contains less than 80 percent storage (i.e., the Stage 1 drought trigger) ranges from approximately 9 percent of days up to 20 percent of days. The results for the historical hydrology generally indicate approximately 15 percent of days in 2055, which is notably a 40 percent reduction in the

amount of time at or below 80 percent storage as compared to the baseline results for 2025 (i.e., 25 percent in 2025 versus 15 percent in 2055). This owes to the contribution that treated wastewater makes toward meeting the flow target in Lillington in 2055 as compared to projections in 2025.

- The results for Jordan Lake Drought Stage 1 are highly correlated to the amount of time that the full flow target at Lillington (550 cfs) is not met. The discharge at Lillington is less than 550 cfs approximately 14.5 percent of the time for the alternatives using the historical inflow record. The discharge at Lillington is less than 550 cfs approximately 9.3 to 18.8 percent across all the climate change scenarios. The variation across the modeled alternatives is very low with the greatest difference between any two alternatives (and the same hydrology) of only 0.5 percent. The 14.5 percent in 2055 compares to 19.5 percent under 2025 conditions, so there is a relative reduction of over 25 percent of days spent in a Stage 1 event or worse.
- The model demonstrates that approximately 5.5 percent of the days the flow at Fayetteville of 600 cfs would not be met using historical inflows, which is a 50 percent reduction in days with discharge upstream of the PWC intake under 600 cfs as compared to the 2025 baseline. The variation under the climate change inflows is modest except for the MIROC (MIROC-EMS-CHEM) scenario, which produces low runoff periods that increase the percentage from 12 to 12.6 percent. Nevertheless, like the other metrics, the variance across alternatives under this climate scenario is small.
- Falls Lake drops to less than 242.5 feet less than 0.4 percent of the time for all alternatives and climate change scenarios, and never does in the key summer recreational period.
- The Falls Lake water quality storage declines to less than 40 percent infrequently (i.e., less than 2.5 percent of the time and 1.5 percent of the time using historical hydrology). Falls Lake storage almost never declines to less than 20 percent. The lowest modeled storage reached 16.9 percent during one event in the historical hydrology (i.e., in late 2007) and never under the climate change scenarios.
- The Falls Lake minimum release and Clayton gage seasonal flow targets are never impacted.

Table 5: Frequency (% of Days) Alternatives Do Not Meet Storage and Flow Metrics at Select Locations in Cape Fear and Neuse River Basins

Alternative	Year	Inflows	Jordan Lake < 210 feet	Jordan Lake < 210 feet Memorial to Labor Day	Jordan Lake Water Quality Storage < 80%	Jordan Lake Water Quality Storage < 60%	Jordan Lake Water Quality Storage < 40%	Jordan Lake Water Quality Storage < 20%	Jordan Lake Water Supply Storage < 50%	Lillington Gage Flow < 550 cfs	Fayetteville Intake Flow < 600 cfs	Falls Lake < 242.5 feet	Falls Lake < 242.5 feet Memorial to Labor Day	Falls Lake Water Quality Storage < 80%	Falls Lake Water Quality Storage < 60%	Falls Lake Water Quality Storage < 40%	Falls Lake Water Quality Storage < 20%	Falls Lake Water Supply Storage < 50%	Falls Lake Release < Seasonal target ¹	Clayton Flow < Seasonal target ²
No action (baseline)	2025	Historic	0.0%	0.0%	25.2%	17.0%	5.7%	0.0%	0.0%	19.0%	11.2%	0.0%	0.0%	13.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
	2055	Historic	0.1%	0.0%	15.0%	5.7%	0.6%	0.0%	0.0%	14.2%	5.6%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.2%	7.1%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.3%	1.6%	0.0%	0.0%	0.0%	9.3%	2.9%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.4%	8.5%	1.9%	0.0%	0.0%	18.5%	12.2%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
1	2055	Historic	0.1%	0.0%	15.0%	5.7%	0.6%	0.0%	0.0%	14.2%	5.5%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.2%	7.0%	0.2%	0.0%	14.5%	6.4%	1.5%	0.0%	3.4%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.2%	1.6%	0.0%	0.0%	0.0%	9.3%	2.9%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.3%	8.5%	1.8%	0.0%	0.0%	18.5%	12.0%	0.0%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
2	2055	Historic	0.1%	0.0%	15.0%	5.7%	0.6%	0.0%	0.0%	14.2%	5.5%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.3%	7.0%	0.4%	0.0%	14.6%	6.4%	1.7%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.1%	1.6%	0.0%	0.0%	0.0%	9.3%	2.9%	0.0%	0.0%	11.8%	1.1%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.4%	8.6%	1.9%	0.0%	0.0%	18.5%	12.0%	0.1%	0.0%	23.9%	10.3%	2.5%	0.0%	6.3%	0.0%	0.0%
3	2055	Historic	0.1%	0.0%	15.0%	5.7%	0.6%	0.0%	0.0%	14.2%	5.5%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.2%	7.0%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.1%	1.6%	0.0%	0.0%	0.0%	9.3%	2.9%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.4%	8.6%	2.0%	0.0%	0.0%	18.5%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%

Table 5: Frequency (% of Days) Alternatives Do Not Meet Storage and Flow Metrics at Select Locations in Cape Fear and Neuse River Basins

Alternative	Year	Inflows	Jordan Lake < 210 feet	Jordan Lake < 210 feet Memorial to Labor Day	Jordan Lake Water Quality Storage < 80%	Jordan Lake Water Quality Storage < 60%	Jordan Lake Water Quality Storage < 40%	Jordan Lake Water Quality Storage < 20%	Jordan Lake Water Supply Storage < 50%	Lillington Gage Flow < 550 cfs	Fayetteville Intake Flow < 600 cfs	Falls Lake < 242.5 feet	Falls Lake < 242.5 feet Memorial to Labor Day	Falls Lake Water Quality Storage < 80%	Falls Lake Water Quality Storage < 60%	Falls Lake Water Quality Storage < 40%	Falls Lake Water Quality Storage < 20%	Falls Lake Water Supply Storage < 50%	Falls Lake Release < Seasonal target ¹	Clayton Flow < Seasonal target ²
4	2055	Historic	0.1%	0.0%	15.0%	5.7%	0.6%	0.0%	0.0%	14.2%	5.9%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.3%	7.3%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.3%	1.6%	0.0%	0.0%	0.0%	9.3%	3.2%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.4%	8.5%	1.9%	0.0%	0.0%	18.5%	12.6%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
5	2055	Historic	0.1%	0.0%	15.7%	6.2%	0.8%	0.0%	0.0%	14.6%	5.7%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.8%	5.7%	1.4%	0.0%	0.0%	12.7%	7.3%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.7%	1.7%	0.0%	0.0%	0.0%	9.8%	3.2%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.8%	0.2%	20.0%	9.1%	2.4%	0.0%	0.0%	18.8%	12.2%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
6	2055	Historic																		
		CNRM	Identical to Alternative 7 (withdrawal from Jordan Lake)																	
		GFDL																		
		MIROC																		
7	2055	Historic	0.2%	0.0%	15.0%	5.8%	0.6%	0.0%	0.0%	14.4%	5.5%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.4%	0.0%	12.4%	5.5%	1.2%	0.0%	0.0%	12.4%	7.0%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.1%	1.4%	0.0%	0.0%	0.0%	9.8%	2.9%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	1.2%	0.4%	19.4%	8.5%	1.9%	0.0%	0.0%	18.7%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%

Table 5: Frequency (% of Days) Alternatives Do Not Meet Storage and Flow Metrics at Select Locations in Cape Fear and Neuse River Basins

Alternative	Year	Inflows	Jordan Lake < 210 feet	Jordan Lake < 210 feet Memorial to Labor Day	Jordan Lake Water Quality Storage < 80%	Jordan Lake Water Quality Storage < 60%	Jordan Lake Water Quality Storage < 40%	Jordan Lake Water Quality Storage < 20%	Jordan Lake Water Supply Storage < 50%	Lillington Gage Flow < 550 cfs	Fayetteville Intake Flow < 600 cfs	Falls Lake < 242.5 feet	Falls Lake < 242.5 feet Memorial to Labor Day	Falls Lake Water Quality Storage < 80%	Falls Lake Water Quality Storage < 60%	Falls Lake Water Quality Storage < 40%	Falls Lake Water Quality Storage < 20%	Falls Lake Water Supply Storage < 50%	Falls Lake Release < Seasonal target ¹	Clayton Flow < Seasonal target ²
8A	2055	Historic	0.1%	0.0%	15.7%	6.2%	0.8%	0.0%	0.0%	14.7%	5.4%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.9%	5.8%	1.4%	0.0%	0.0%	12.7%	7.0%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.7%	1.7%	0.0%	0.0%	0.0%	9.8%	3.0%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.8%	0.2%	19.9%	9.1%	2.4%	0.0%	0.0%	18.8%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
8B	2055	Historic	0.1%	0.0%	15.2%	5.9%	0.7%	0.0%	0.0%	14.3%	5.6%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.6%	5.5%	1.3%	0.0%	0.0%	12.4%	7.1%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.4%	1.5%	0.0%	0.0%	0.0%	9.6%	3.1%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.5%	8.8%	2.0%	0.0%	0.0%	18.6%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
9A/B	2055	Historic	0.1%	0.0%	15.7%	6.2%	0.8%	0.0%	0.0%	14.6%	5.7%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.8%	5.7%	1.4%	0.0%	0.0%	12.7%	7.3%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.7%	1.7%	0.0%	0.0%	0.0%	9.8%	3.2%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.8%	0.2%	20.0%	9.1%	2.4%	0.0%	0.0%	18.8%	12.2%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%
9C	2055	Historic	0.1%	0.0%	15.7%	6.2%	0.8%	0.0%	0.0%	14.6%	5.4%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.8%	5.7%	1.4%	0.0%	0.0%	12.7%	7.0%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.7%	1.7%	0.0%	0.0%	0.0%	9.8%	3.0%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.8%	0.2%	20.0%	9.1%	2.4%	0.0%	0.0%	18.8%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%

Table 5: Frequency (% of Days) Alternatives Do Not Meet Storage and Flow Metrics at Select Locations in Cape Fear and Neuse River Basins

Alternative	Year	Inflows	Jordan Lake < 210 feet	Jordan Lake < 210 feet Memorial to Labor Day	Jordan Lake Water Quality Storage < 80%	Jordan Lake Water Quality Storage < 60%	Jordan Lake Water Quality Storage < 40%	Jordan Lake Water Quality Storage < 20%	Jordan Lake Water Supply Storage < 50%	Lillington Gage Flow < 550 cfs	Fayetteville Intake Flow < 600 cfs	Falls Lake < 242.5 feet	Falls Lake < 242.5 feet Memorial to Labor Day	Falls Lake Water Quality Storage < 80%	Falls Lake Water Quality Storage < 60%	Falls Lake Water Quality Storage < 40%	Falls Lake Water Quality Storage < 20%	Falls Lake Water Supply Storage < 50%	Falls Lake Release < Seasonal target ¹	Clayton Flow < Seasonal target ²
9D	2055	Historic	0.1%	0.0%	15.2%	5.9%	0.7%	0.0%	0.0%	14.3%	5.6%	0.3%	0.0%	20.2%	8.3%	1.5%	0.1%	5.2%	0.0%	0.0%
		CNRM	0.3%	0.0%	12.5%	5.5%	1.3%	0.0%	0.0%	12.3%	7.1%	0.4%	0.0%	14.5%	6.4%	1.5%	0.0%	3.7%	0.0%	0.0%
		GFDL	0.0%	0.0%	9.4%	1.5%	0.0%	0.0%	0.0%	9.6%	3.1%	0.0%	0.0%	11.7%	1.0%	0.0%	0.0%	0.2%	0.0%	0.0%
		MIROC	0.7%	0.1%	19.5%	8.8%	2.0%	0.0%	0.0%	18.6%	12.0%	0.1%	0.0%	23.8%	10.2%	2.3%	0.0%	6.3%	0.0%	0.0%

¹ Falls Lake flow target: April to October, 100 cfs; 60 cfs otherwise.

² Clayton flow target: April to October, 254 cfs; 184 cfs otherwise.

3.3 Low-Flow Discharge in the Cape Fear River and Neuse River

The third class of output metrics pertains to low flow conditions at various key locations along the Cape Fear and Neuse Rivers. A statistical summary of streamflow impacts was developed to assess and evaluate the alternatives in the Neuse and Cape Fear River basins, focusing on the 7Q10, which is the lowest 7-day flow that occurs on average once every 10 years.

Table 6 summarizes the 7Q10 flow statistics at various nodes in the CFNCRB model. The evaluated 7Q10 locations are illustrated in Figure 2. The locations where the 7Q10 is reported include the Lillington gage, upstream of Fayetteville PWC's raw water intake in the Cape Fear basin, upstream of the CFPWA/LCFWSA raw water intake in the Cape Fear basin, at the Cayton Gage in the Neuse River basin, the confluence of the Neuse and Little Rivers in the Neuse River basins, and upstream of NRWASA's raw water intake in the Neuse River basin. Alternative 9A/B is the Town of Fuquay-Varina partnering with the City of Sanford for finished water supply. Alternatives 9C and 9D are similar, but also include a return of treated wastewater to the Cape Fear River.

The CFNCRB model provided results for four categories of change that could influence future low flow conditions to include the following:

1. Potential climate change impact to hydrology.
2. Cumulative impact related to Cape Fear River basin development (i.e., water demand increase between 2025 and 2055).
3. Project-related impacts to 7Q10.
4. USGS gage accuracy and CFNCRB model precision.

These impacts can be distinguished by comparing the low flows that result from the array of 45 different model runs and observing how an alternative, climate scenario, or target year demand (2025 vs 2055) affects the 7Q10 compared to other model runs. The magnitude of impacts to low flows were compared across the three aforementioned categories. The model suggests that the impact due to climate change would potentially incur the largest impact followed by cumulative impacts from increased water demand in the basin unrelated to a specific alternative. The selection of a water supply alternative for the Town of Fuquay-Varina resulted in minimal impact.

Figures 3 and 4 illustrate the model run comparisons. The chart for each location begins at the 2025 No Action baseline and progresses to indicate the relative impact of development through 2055, then the range of impacts across all the water supply alternatives (removing the baseline No Action climate effect) and finally shows the cumulative range of impacts due to the three climate scenarios evaluated. Where there is a range shown (water supply alternatives and climate scenarios), the green bar represents the median of the dataset and the whiskers at the top and bottom of the bar represent the entire range for that location.

3.3.1 Potential Climate Change Impact to Hydrology

The climate models selected for use in this EIS are not consistent with respect to the direction of change (increasing or decreasing) to future low flow conditions in central North Carolina. However, the magnitude

of the forecasted changes from the climate models are significant. The low flow magnitude of change is 5 to 20 times greater than the change predicted from increased water demand through 2055 or the preferred alternative 9A/B. In the following summaries, the percent value describes the change between the historical hydrology runoff and the indicated climate change scenario for an alternative. Ranges are provided at a fixed location as the magnitude of the impact varies depending on the alternative. For example, the GFDL model suggests the Lillington gage 7Q10 would increase by 23.5 percent in the No-Action alternative but only increase by 18.7 percent for Alternative 9C. Therefore, the range in this scenario is between 19 and 24 percent.

In the Cape Fear River basin, the CNRM and MIROC climate models suggest a decrease in the 7Q10. Both models also suggest the changes are more severe further downstream. This may be a function of more severe hydrologic impacts further south and east in the basin, but it is also a function of how Jordan Lake is managed (refer to Section 4). Compared to the historical hydrology and 2055 water demand, the CFNCRB model 7Q10 results for 2055 are 12 to 20 percent less at Lillington, reduced by 20 percent upstream of PWC's intake, and reduced by 32 to 36 percent at the CFPWA/LCFWSA intake. For the MIROC model the comparative changes are a 35 to 40 percent reduction at Lillington, slightly over a 40 percent reduction at PWC's intake, and a reduction of 60 percent at the CFPWA/LCFWSA intake. The GFDL model suggests the 7Q10 results in the Cape Fear will increase 19 to 24 percent at Lillington, 15 to 18 percent at PWC's intake, and 17 to 19 percent at the CFPWA intake. Ranges are provided as an attempt to characterize the climate impacts broadly across all 12 alternatives.

In the Neuse River basin, all three climate models suggest a decline in the 7Q10. The exception is the GFDL-ESM2M, RCP 8.5 model result at the Clayton gage (+1.5 percent). The MIROC-EMS-CHEM model is the most conservative and resulted in a reduction of 12 percent at Clayton, 19 to 22 percent at the confluence of the Little River and Neuse River, and 24 to 27 percent at the NRWASA intake. The CNRM-CM5, RCP 4.5 model suggests a reduction of 4 percent at Clayton, 1 to 4 percent at the Neuse-Little River confluence, and 2 to 5 percent at the NRWASA intake in Kinston. The GFDL-ESM2M, RCP 8.5 model resulted in a 1.4 percent increase at Clayton, a 5 to 8 percent reduction at the Neuse-Little River confluence, and an 8 to 12 percent reduction at the NRWASA intake. The low flow reductions in the Neuse are more modest than the predicted reductions in the Cape Fear in part due to the consistency of the flow target at Clayton regardless of the hydrologic scenario.

3.3.2 Cumulative Impact Related to Cape Fear River Basin Development

The cumulative impacts from the increase in water demand between 2025 and 2055 in the Cape Fear basin (excluding the Town of Fuquay-Varina) is forecast to reduce the 7Q10 at the Lillington gage, upstream of PWC's Intake, and upstream of the CFPWA/LCFWSA intake by 4.7 percent, 2.1 percent, and 3.8 percent, respectively. The impact at the Lillington gage is larger and potentially misleading. The Lillington 7Q10 result is reported at the gage location, which is downstream of Harnett County's Regional WTP withdrawal and upstream of the effluent discharge from the North Harnett Regional WWTP. Since Harnett County and partners plan for significant growth between 2025 and 2055, the impact is greater in the one-mile stretch between Harnett County's raw water intake and the effluent discharge than elsewhere along this stretch of the Cape Fear River.

The cumulative impacts due to growth in water demand between 2025 and 2055 in the Neuse Basin are mixed depending on location. At the Clayton gage, the 7Q10 is forecast to rise by nearly 20 percent due

to increased use and discharge at Raleigh's Neuse Regional Resource Recovery Facility (NRRRF) and the Town of Clayton's Sam's Branch WRF. Further downstream at the confluence of the Neuse and Little River in Goldsboro, the models predict a reduction of 2.8 percent in the future 7Q10 and 1.3 percent at NRWASA's raw water intake. The confluence of the Neuse and Little Rivers is downstream of Goldsboro's raw water intake and upstream of the City of Goldsboro's wastewater discharge, so approximately one-half of the impact at this location (between no change and -2.8 percent) is due to the increase in the City of Goldsboro's water demand over the planning horizon.

The CFNCRB model suggests the upstream increase in 7Q10 at Clayton may be counteracted further downstream by growth in Johnston County combined with conservative model assumptions about Johnston County's wastewater return to water demand ratio. The wastewater return to water demand ratio for Johnston County will increase with urbanization similar to other urbanizing areas across the state. The wastewater return to water demand ratio is increasing in urban areas but has not been subject to extensive research and therefore is difficult to forecast. The CFNCRB model reflects the present day wastewater to water demand ratio in the 2055 demand scenario.

3.3.3 *Project-related Impacts to 7Q10*

The following 7Q10 comparative statistics apply to the historical basin runoff (e.g., hydrology) using the 2055 water demand scenario:

- The 7Q10 difference between the No-Action alternative in 2055 and Alternative 9A/B (no return of wastewater to the Cape Fear River basin) is a reduction of 4.6 cfs (-1.1 percent) for Alternative 9A/B at the PWC raw water intake and 3.1 cfs (-0.8 percent) at the CFPUA raw water intake. In the No-Action alternative, the majority of the Town of Fuquay-Varina's demand is unmet as additional supply options are not considered. In Alternative 9A/B, the Town of Fuquay-Varina's water demand is met with a withdrawal from the Cape Fear River near Sanford, which results in an approximate 1 percent reduction in the 7Q10 downstream of Sanford's intake.
- The 7Q10 difference between the 2055 No-Action alternative and Alternative 9C (return of water to Cape Fear) is an increase of 3.4 cfs (+0.8 percent) at PWC's raw water intake and 4.6 cfs (+1.2 percent) at the CFPUA raw water intake. The difference between the No-Action alternative and Alternative 9D (i.e., Western Wake WRF) is an increase of 0.8 cfs and 0.5 cfs at the same respective downstream locations. The smaller change with Alternative 9D is due to the fact the wastewater is returned upstream of the Lillington gage and the releases from Jordan Lake are adjusted accordingly in the model.
- The difference between Alternatives 9A/B (i.e., no return of water) and 9C (i.e., return of water) is an increase of 8 cfs (+2 percent) at PWC's raw water intake and 7.9 cfs (+2 percent) at the CFPUA raw water intake.
- The difference between Alternatives 9A/B and 9D is an increase of 5.4 cfs (+1.3 percent) at PWC's raw water intake and an increase of 3.9 cfs (+1 percent) at the CFPUA raw water intake.
- The model predicts small differences in 7Q10 downstream of the confluence of Middle Creek and the Neuse River depending on the source of the Town of Fuquay-Varina's future water supply and the location of the Town's discharged wastewater (i.e., Terrible

Creek in the Neuse River basin or returned to the Cape Fear River). The impact to the 7Q10 reported at the confluence of the Neuse and Little Rivers and at the NRWASA intake can be reduced by approximately 7 cfs for Alternative 1 over the 2055 No Action alternative or supplemented by up to nearly 6 cfs for Alternatives 4, 5, 6, 7, and 9A/B. For either Alternatives 9C or 9D, the impact at both locations is a very small reduction of 1.6 cfs compared to the 2055 No Action Alternative.

3.3.4 USGS Gage Accuracy and CFNCRB Model Precision

Models allow a high precision comparison of scenario outputs and relative changes as a result of modifying model variables. Modifying a model variable allows a relational cause and effect to be identified. The CFNCRB model has produced accurate and precise output results for the comparison of alternatives in this EIS. However, the ability to discern marginal changes in the field is a separate issue. The USGS gages used to measure streamflow are not nearly as precise in consistency and reproducibility as results from a mathematical model.

The USGS provides ratings for all installed stream gages. An assessment of gage accuracy is found in the “Remarks” Section in the station description (USGS, 2023). A gage station with an “Excellent” rating indicates that approximately 95 percent of the daily flow records are within 5 percent of the true value. A “Good” rating indicates that flow records are within 10 percent of the true flow value and a “Fair” rating indicates that the daily flow record is within 15 percent of the daily flow value. Stations with a “Poor” rating have daily discharge records of less than “Fair” accuracy. Per USGS, the gage station at Lillington has a “Good” rating, the gage station at Fayetteville has a “Poor” rating, and the gage station at Cape Fear Lock 1 NR Kelly has a “Good” rating. At the Lillington gage, a “Good” rating in the low-flow range of 250 to 600 cfs translates to a margin of error of +/- 25 to 60 cfs.

The modeled 7Q10 differences between any two alternatives using the historical hydrology are less than 10 cfs at Lillington and at the other gage sites reported in Table 6. The difference in the 7Q10 flow values between the evaluated water supply alternatives are substantially less than the station margin of error (i.e., accuracy) for daily discharge for all three gaging stations in the Cape Fear River. Since a 7Q10 event is statistically an event that lasts seven days, it is possible that the gage margins of error are reduced over this longer time period versus an instantaneous flow event. However, even with the potential for a lower margin of error, the CFNCRB model predict differences in streamflow that will most likely not be captured at the USGS gage stations.




Figure 2: Model Nodes Used for Hydrologic Analysis




Figure 3: Comparison of Low Flow Impacts at Select Points in the Cape Fear River




Figure 4: Comparison of Low Flow Impacts at Select Points in the Neuse River

Table 6: Summary of 7Q10 Flow Statistics at Select Nodes in the Neuse and Cape Fear River Basins

Water Supply Alternative	Demand Year	Inflows	Lillington Flow, cfs	Fayetteville Intake, cfs	Cape Fear PUA Intake, cfs	Clayton Flow, cfs	Neuse River / Little River Confluence, cfs	Neuse River WASA Intake, cfs
No-Action (baseline)	2025	Historic	278.9	415.2	407.2	198.8	224.7	244.9
	2055	Historic	265.8	406.5	391.9	238.1	218.4	241.6
		CNRM	233.8	326.7	248.6	228	216.1	236.1
		GFDL	328.2	477.5	462.8	241.4	204.2	218.6
		MIROC	170.7	238.1	164.4	209.8	176.8	183.6
Alternative 1	2055	Historic	266.3	410.3	395.8	238.1	211.2	234.3
		CNRM	233.8	330.5	272.1	230.8	207.3	226.5
		GFDL	319.2	475	466.4	241.4	195.1	209.5
		MIROC	170.9	241.8	169.7	209.8	172.4	181.5
Alternative 2	2055	Historic	266	410.3	396	236.6	217.4	240.7
		CNRM	233.8	330.5	260.7	226.6	215.1	235.1
		GFDL	319.2	474.9	466.2	240.6	205.5	220.5
		MIROC	170.7	241.7	165.4	208	176.3	183.6
Alternative 3	2055	Historic	266.3	410.4	395.8	238.1	212.3	235.3
		CNRM	233.9	330.6	280.2	228	209.5	228.5
		GFDL	319.2	475	466.4	241.4	195.6	210
		MIROC	170.9	241.8	167.8	209.8	173.2	180.1
Alternative 4	2055	Historic	265.8	399.2	384.1	238.1	224.3	247.5
		CNRM	233.8	318.1	273.3	228	220.2	240.7
		GFDL	328.2	470.1	455	241.4	210.1	224.6
		MIROC	170.7	230.8	160.8	209.8	181.5	188.8

Table 6: Summary of 7Q10 Flow Statistics at Select Nodes in the Neuse and Cape Fear River Basins

Water Supply Alternative	Demand Year	Inflows	Lillington Flow, cfs	Fayetteville Intake, cfs	Cape Fear PUA Intake, cfs	Clayton Flow, cfs	Neuse River / Little River Confluence, cfs	Neuse River WASA Intake, cfs
Alternative 5	2055	Historic	258	401.9	388.7	238.1	224.3	247.5
		CNRM	213	313.7	251.2	228	220.8	241.2
		GFDL	315.7	469	461.4	241.4	210.1	224.6
		MIROC	157.3	226.4	158.4	209.8	181.5	188.8
Alternative 6/7	2055	Historic	265.9	409.6	395	238.1	224.3	247.5
		CNRM	233.9	330.6	255	228	220.2	240.7
		GFDL	328.2	481.2	466.4	241.4	210.1	224.6
		MIROC	170.9	241.9	167	209.8	181.5	188.8
Alternative 8A	2055	Historic	258	412.3	399.9	238.1	216.8	240
		CNRM	213	322	269.8	228	214.7	234.5
		GFDL	315.7	476.6	468.8	241.4	202.6	217.1
		MIROC	157.2	234	158	209.8	175	181.9
Alternative 8B	2055	Historic	263.9	407.5	392.9	238.1	216.8	240
		CNRM	230.9	326.7	257.1	228	214.7	234.5
		GFDL	316.6	470.7	463	241.4	202.6	217.1
		MIROC	163.7	234.1	163.4	209.8	175	181.9
Alternative 9A/B	2055	Historic	258	401.9	388.7	238.1	224.3	247.5
		CNRM	213	313.7	251.2	228	220.8	241.2
		GFDL	315.7	469	461.4	241.4	210.1	224.6
		MIROC	157.3	226.4	158.4	209.8	181.5	188.8

Table 6: Summary of 7Q10 Flow Statistics at Select Nodes in the Neuse and Cape Fear River Basins

Water Supply Alternative	Demand Year	Inflows	Lillington Flow, cfs	Fayetteville Intake, cfs	Cape Fear PUA Intake, cfs	Clayton Flow, cfs	Neuse River / Little River Confluence, cfs	Neuse River WASA Intake, cfs
Alternative 9C	2055	Historic	258	409.9	396.6	238.1	216.8	240
		CNRM	213	322	267.9	228	214.7	234.5
		GFDL	315.7	476.6	468.8	241.4	202.6	217.1
		MIROC	157.3	234	155.6	209.8	175	181.9
Alternative 9D	2055	Historic	263.9	407.3	392.6	238.1	216.8	240
		CNRM	230.9	326.7	257.1	228	214.7	234.5
		GFDL	316.5	470.7	463	241.4	202.6	217.1
		MIROC	163.8	234.2	165.1	209.8	174.8	181.8

4. Interpretation of Future Climate Simulation Results


The climate variability scenarios results need to be interpreted with caution as discussed in Section 2.2. Climate models are typically run for hundreds of years to collect statistics on the frequency and intensity of weather events. One variable is changed and the model simulations are re-run to assess the global change in the statistics (Lerner, 2022). When climate models are used to predict the average future surface temperature for a given greenhouse gas emissions scenario, the majority of the models tend to agree (i.e., the models converge). The climate models do not converge as well for precipitation scenarios and struggle particularly with predicting the magnitude and frequency of extreme weather events.

Figure 5 illustrates the improvement of climate models over the course of several generations and also indicates the weaker capability of these models to reproduce precipitation patterns (Flato, 2013). The models used in this evaluation come from the CMIP5 archive. The improvement in skill of CMIP5 models over prior iterations (i.e., CMIP2 and CMIP3) to predict temperature and precipitation is shown in Figure 5. The lesser ability of these models to predict precipitation magnitude and timing will have implications for the hydrologic conditions assumed for these scenarios. Preparing for future climate variability is widely recognized as an important planning consideration for water supply infrastructure and therefore merits attention in this EIS despite continued uncertainty in the timing, magnitude, and patterns.

Shifts in the overall hydrologic productivity and timing of runoff for the three climate scenarios were evaluated with respect to the future water supply reliability in the Cape Fear and Neuse River basins. Table 7 summarizes the median unit runoff for four broad geographic areas in the Cape Fear and Neuse River basins. The median unit runoff provides additional quantitative context on the overall impact to the region's hydrology. The four geographical areas are as follows:

1. Neuse basin upstream of Falls Lake Dam
2. Neuse basin downstream of Falls Lake Dam
3. Cape Fear basin upstream of Jordan Lake Dam
4. Cape Fear basin downstream of Jordan Lake Dam (includes Rocky/Deep River watersheds)

Unit runoff results are presented for both 2010 to 2040 and 2040 to 2070 for the three climate variability scenarios even though the former period was not modeled in the CFNCRB model. The unit runoff results between 2010 and 2040 provide context for how the climate scenarios unfold over the next decades. Both historical observations and climate variability scenarios demonstrate greater unit runoff for the downstream portions of each basin as compared to the upstream portions. Runoff originating in the upper portions of the basins flowing into the lower basins was not included in the runoff statistics for the lower basins. The unit runoff in the Cape Fear basin is marginally higher than for the Neuse River basin. It is also notable that the unit runoff for the MIROC-ESM-CHEM model between 2040 and 2070 indicates a marked reduction compared to the historical runoff and runoff from the other two climate scenarios. The suitability of any of these scenarios is difficult to assess; however, one indication that there are challenges in plausibility of the MIROC-ESM-CHEM model is that the model has a known warm temperature bias at mid-latitudes, including the southeastern United States (Watanabe, 2011). Nevertheless, the MIROC-ESM-CHEM model was selected as a worst-case bounding condition despite this model flaw.



FAQ 9.1, Figure 1 | Model capability in simulating annual mean temperature and precipitation patterns as illustrated by results of three recent phases of the Coupled Model Intercomparison Project (CMIP2, models from about year 2000; CMIP3, models from about 2005; and CMIP5, the current generation of models). The figure shows the correlation (a measure of pattern similarity) between observed and modelled temperature (upper panel) and precipitation (lower panel). Larger values indicate better correspondence between modelled and observed spatial patterns. The black symbols indicate correlation coefficient for individual models, and the large green symbols indicate the median value (i.e., half of the model results lie above and the other half below this value). Improvement in model performance is evident by the increase in correlation for successive model generations.

Figure 5: Generalized comparison of GCM accuracy for temperature and precipitation outputs over the course of 3 generations of the CMIP project (models used for this EIS analysis are from CMIP5).

Table 7: Median Unit Runoff by Inflow Scenario in the Neuse and Cape Fear Upstream and Downstream of Major Basin Reservoir Nodes

Time Period	Climate Change Scenario	Neuse Upstream Falls Lake, cfs/mi ²	Neuse Downstream Falls Lake, cfs/mi ²	Cape Fear Upstream Jordan Lake, cfs/mi ²	Cape Fear Downstream Jordan Lake, cfs/mi ²
Historic (1930 to 2020)	N/A	0.35	0.63	0.47	0.69
2010 to 2040	MIROC-ESM-CHEM	0.36	0.63	0.48	0.70
	GFDL-ESM2M	0.34	0.61	0.45	0.78
	CNRM-CM5	0.40	0.74	0.51	0.80
2040 to 2070	MIROC-ESM-CHEM	0.24	0.44	0.35	0.48
	GFDL-ESM2M	0.30	0.57	0.40	0.66
	CNRM-CM5	0.34	0.64	0.44	0.74

The hydrologic changes modeled in MIROC-ESM-CHEM and CNRM-CM5 produce rare shortages for a single major municipal water supply withdrawal, CFPUA and LCFWSA, at the last freshwater withdrawal point on the Cape Fear River. Per the aforementioned discussion, climate models have difficulty reproducing precipitation patterns under historical conditions, so similar challenges should be anticipated for future predictions. There are six events in the MIROC scenario and three events in the CNRM scenario that produce supply shortages at the CFPUA/LCFWSA intake over a 30-year hydrologic period. These events are typically a single day in length; however, the longest duration event is 11 days.

Table 8 summarizes key system conditions during the months of water supply shortages for CFPUA and LCWSA. In each case, there are several factors or opportunities that would either naturally mitigate these events or could be leveraged to prevent the water supply shortages from occurring. The following are factors and opportunities that will mitigate these shortages:

The monthly average discharge at the intake is well in excess of the raw water need.

The average monthly discharge in the Cape Fear River at the point of withdrawal, even in a severe drought, is well in excess of the magnitude of the water supply withdrawal needed to satisfy CFPUA and LCFWSA demands. This result is demonstrated by comparing the column “Monthly Mean River Discharge at Intake” with the adjacent column, “Monthly Mean Water Withdrawal” in Table 8. The data suggests that the river discharge may not decline to the low daily discharges observed in the CFNCRB model to cause the observed shortages. In reality the runoff (and consequently flow) in the Lower Cape Fear may be more stable than the daily fluctuations in these climate scenarios suggest.

The storage behind Lock and Dam #1 is not part of the OASIS model.

The CFNRBM model assumes the CFPUA /LCFWSA intake points are “run-of-river” and that there is no storage in the Cape Fear River. However, backwater from Lock & Dam 1 runs upstream to Lock and Dam 2 (Palmer, 2024), a distance of 32 miles. Combined with an average river width between 200 and 300 feet and a navigation channel of 8 feet deep, over a billion gallons is stored in this reach of the Cape Fear River. Each inch of backwater storage is equivalent to 20 to 30 million gallons. This storage may be sufficient to mitigate the longest modeled shortage timeframe of 11 days. This storage could be a

mitigating factor for an actual sustained shortage, should a shortage occur, particularly when combined with other management factors to help alleviate and buffer low flow events.

CFPUA/LCFWSA do not have target demand reductions in WSRPs or a quantifiable source water trigger condition.

Neither CFPUA nor LCFWSA have WSRPs with quantifiable triggers and target demand reductions in the CFNCRB model. Demand curtailment would undoubtedly accompany the response to drought events of this magnitude. However, the CFNCRB model assumes no water demand reduction for CFPUA nor LCFWSA unlike several other utilities in the Cape Fear River basin.

Modified management of Jordan Lake.

Modified or improved management of Jordan Lake could eliminate the rare shortages observed at the CFPUA/LCFWSA intake with or without consideration of the three aforementioned mentioned mitigation opportunities. The management of Jordan Lake under the current Drought Contingency Plan (DCP) in the CFNCRB model plays a role in causing these rare shortages. In each shortage provided in Table 8, there is sufficient storage in Jordan Lake to mitigate downstream shortages with releases from the Water Quality Pool.

Jordan Lake operations are not explicitly managed to meet needs downstream of Lillington. The release protocol for Jordan Lake was established to help meet downstream water quality needs while maintaining water supply storage in the reservoir. The drought plans for Jordan Lake allow for reductions in this minimum flow target at Lillington. In the Stage 3 and Stage 4 drought protocol, there is no flow target at Lillington but there is a specified maximum release from Jordan Lake. The CFNCRB model uses these operating conditions by limiting the maximum Jordan Lake release to 200 cfs. For example, when a Jordan Lake Stage 3 drought is invoked, there is far less protection remaining for downstream uses. It is only under Stage 3 conditions (Stage 4 is never reached in any scenario) when the CFPUA/LCFWSA shortages occur. Historically, the runoff downstream of Jordan Lake has been sufficient to meet water demands and have not required flow augmentation from Jordan Lake during low-flow periods. However, if water demand growth in the lower portions of the Cape Fear River basin is achieved as forecasted by LWSPs and climate change is severe, there will be a need to change the Jordan Lake operational approach.

Using the Jordan Lake Water Quality Pool to consider water supply needs in the Cape Fear River downstream of Lillington appears to be a viable means of ensuring water supply reliability per the CFNCRB model results. For reference, Jordan Lake drought Stages 1 through 4 are triggered when the Water Quality Pool storage drops below 80 percent, 60 percent, 40 percent, and 20 percent, respectively. The USACE operates Jordan Lake to meet the following flow targets:

- Drought level 0: Flow target at Lillington remains at 600 +/- 50 cfs
- Drought level 1: Flow target at Lillington ranges from 450 to 600 +/- 50 cfs
- Drought level 2: Flow target at Lillington ranges from 300 to 450 +/- 50 cfs
- Drought level 3: No flow target set at Lillington. A maximum release rate of 200 cfs from Jordan Lake, plus any required water supply releases downstream to Lillington.

- Drought level 4: No flow target set at Lillington. A maximum release rate of 100 to 200 cfs from Jordan Lake plus any required water supply releases downstream to Lillington.

The 2008 Jordan Lake DCP indicates the USACE may engage in a range of flow targets at Lillington during drought Stages 1 and 2. The target flow in Stages 1 and 2 is establish via collaboration and coordination on a variety of parameters such as stakeholder input, short and long-term weather outlook, gate status, influences on stream flows downstream, and local inflows to both Jordan Lake and reaches downstream of the dam. When Jordan Lake is in drought Stages 3 and 4, the DCP does not specify how far downstream water supply needs should be fulfilled. Flexibility in adjusting dam releases has some limits under the DCP. When Jordan Lake contains water in the conservation pool (as has always been the case), Jordan Lake will be operated to meet water supply requirements and water quality low flow releases. Utilities using Jordan Lake as a water supply will be unaffected by this change in DCP operating protocol.

The few shortages for the CFPWA/LCFWSA, which only occur in two of the climate variability scenarios, are due to extremely low inflows projected for this downstream portion of the Cape Fear River. The aggregate water supply need for utilities downstream of Lillington are not satisfied by the modest release from Jordan Lake because the shortages occur under significant additional water demand stress. The municipal surface water demands for PWC, CFPWA and LCFWSA are projected to increase by over 57 mgd between 2025 and 2055 per the respective LWSPs submitted by these systems, which is approximately a 90 percent increase in water demand at these locations over the 30-year planning period. The water supply shortages for CFPWA/LCFWSA disappear when the climate models are rerun with a modification to the Jordan Lake Stage 3 minimum release to mimic a Stage 2 release. Adjusting the Jordan Lake releases from the water quality pool to consider downstream water supply needs will require coordination between the State and USACE as specified in the Jordan Lake DCP. The authority to modify releases appears to be vested in the State under the current DCP as described on pages 6-9 of the Jordan Lake DCP.

Given the various mitigation options, it seems reasonable to conclude that if climate impacts of the magnitude suggested by the CNRM and MIROC scenarios occur, there are available options to mitigate the emergency. Per the discussion in Section 3, it is clear that the selection of a water supply alternative for the Town of Fuquay-Varina does not significantly exacerbate the water supply shortages in the Cape Fear River basin nor does the Town of Fuquay-Varina's preferred water supply alternative prevent mitigation strategies from being implemented.

Table 8: Key System Conditions During Months with Shortages for CFPUA and LCWSA

Alternative	Climate Scenario	Month and Year	Jordan Lake		CFPUA / LCFWSA			
			Minimum Water Quality Storage, MG (%)	Average Release (mgd)	Monthly Mean River Discharge at Intake (mgd)	Monthly Mean Water Withdrawal (mgd)	Days with Shortage ¹	Average Shortage (mgd) ¹
No Action	MIROC-ESM-CHEM	August, 2043	12,036 (39%)	129	304	68.5	----	----
		September, 2043	9,804 (32%)	119	347	61.3	----	----
		October, 2050	10,631 (34%)	92	352	54.0	1	16.4
		August, 2051	12,056 (39%)	195	218	66.9	----	----
		September, 2056	10,051 (33%)	140	153	60.5	1	30.2
		September, 2063	10,620 (34%)	143	269	58.7	4	16.2
	CNRM-CM5	September, 2057	8,930 (29%)	124	121	61.3	----	----
		August, 2058	10,671 (35%)	141	306	59.7	9	34.3
		September, 2058	11,676 (38%)	136	1,862	61.3	1	7.5
9A/B	MIROC-ESM-CHEM	August, 2043	12,034 (39%)	129	304	62.7	1	0.4
		September, 2043	9,741 (32%)	119	348	60.3	----	----
		October, 2050	10,631 (34%)	92	357	54.6	2	12.6
		August, 2051	12,055 (39%)	195	224	67.6	1	51.2
		September, 2056	10,053 (33%)	140	158	61.1	1	26.2
		September, 2063	10,620 (34%)	143	270	57.2	4	19.8
	CNRM-CM5	September, 2057	8,930 (29%)	124	124	59.8	----	----
		August, 2058	10,671 (35%)	141	317	67.7	11	24.8
		September, 2058	11,676 (38%)	136	1,866	60.4	----	----
9C	MIROC-ESM-CHEM	August, 2043	12,312 (40%)	130	310	68.5	7	26
		September, 2043	10,023 (33%)	119	349	61.3	5	6.5
		October, 2050	10,808 (35%)	92	357	54.6	1	4.9
		August, 2051	12,238 (40%)	196	224	66.7	1	27.7
		September, 2056	10,225 (33%)	141	159	61.1	1	5.8
		September, 2063	11,070 (36%)	147	272	57.1	5	24.7

Table 8: Key System Conditions During Months with Shortages for CFPUA and LCWSA

Alternative	Climate Scenario	Month and Year	Jordan Lake		CFPUA / LCFWSA			
			Minimum Water Quality Storage, MG (%)	Average Release (mgd)	Monthly Mean River Discharge at Intake (mgd)	Monthly Mean Water Withdrawal (mgd)	Days with Shortage ¹	Average Shortage (mgd) ¹
9D	CNRM-CM5	September, 2057	9,088 (29%)	124	123	59.8	1	44.9
		August, 2058	10,907 (35%)	147	316	61.7	2	13.4
		September, 2058	11,918 (39%)	133	1,863	60.5	1	29.1
	MIROC-ESM-CHEM	August, 2043	12,443 (40%)	152	321	68.5	1	0.4
		September, 2043	9,400 (30%)	122	355	61.3	----	----
		October, 2050	10,973 (36%)	92	356	54.3	1	4.9
		August, 2051	12,325 (40%)	205	230	68.5	2	29.1
		September, 2056	10,196 (33%)	145	162	60.3	1	8.2
		September, 2063	11,254 (37%)	146	272	59.2	5	25.2
		September, 2057	9,280 (30%)	124	125	61.3	1	45.4
	CNRM-CM5	August, 2058	11,010 (36%)	145	312	58.6	9	23.6
		September, 2058	11,981 (39%)	131	1,862	61.1	1	26.2

¹ The number of days and average shortage quantities are for both CFPUA and LCFWSA as they share a common intake location in the model.

² One of the two shortage days averaged was 26.3 mgd for CFPUA, the demand for this node on this day was 33.0 mgd.

5. References

CH2M Hill. 2009. Final Environmental Assessment Water Supply and Water Storage Alternatives. Prepared for Johnston County, North Carolina.

Flato, G., J. Marotzke, B. Abiodun, P. Braconnot, S.C. Chou, W. Collins, P. Cox, F. Driouech, S. Emori, V. Eyring, C. Forest, P. Gleckler, E. Guilyardi, C. Jakob, V. Kattsov, C. Reason and M. Rummukainen, 2013: Evaluation of Climate Models. In: Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change [Stocker, T.F., D. Qin, G.-K. Plattner, M. Tignor, S.K. Allen, J. Boschung, A. Nauels, Y. Xia, V. Bex and P.M. Midgley (eds.)]. Cambridge University Press, Cambridge, United Kingdom and New York, NY, USA.

Jacobs. 2018. Long Range Water Resources Plan Update. Prepared for the Towns of Cary, Morrisville, and Apex and Wake County.

Hazen and Sawyer. 2022. Technical Memorandum for Western Intake Partnership Water Intake and Transmission Infrastructure: Water Capacity Requirements. Prepared for Western Intake Partnership.

Hazen and Sawyer. Unpublished. Long Range Water Supply Planning. Prepared for Johnston County Department of Public Utilities.

HDR. 2021. Integrated Master Plan, Service Area Planning Forecast Probabilistic Analysis. Prepared for Raleigh Water.

IPCC, 2013: Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change.
<https://www.ipcc.ch/report/ar5/wg1/>.

Lerner, L. 2022. New Study Lays Out Hidden Backstory Behind Deadly Pacific Northwest Heat Wave.
<https://phys.org/news/2022-05-hidden-backstory-deadly-pacific-northwest.html>

Palmer, R. Reed Palmer. January 30, 2024. Personal communication with Michael (Tony) Young, USACE.

Maycock, and B.C. Stewart (eds.). U.S. Global Change Research Program, Washington, DC, USA, 1515 pp. doi: 10.7930/NCA4.2018.

North Carolina Department of Environmental Quality Division of Water Resources. 2016a. Round 4 Jordan Lake Water Supply Allocation Recommendations. Prepared for the North Carolina Environmental Management Commission.

North Carolina Department of Environmental Quality Division of Water Resources. 2016. Cape Fear River Surface Water Supply Evaluation. Revised March 2017. Prepared for the North Carolina Environmental Management Commission.

Pielke, R., Jr, Burgess, M. G., & Ritchie, J. (2021, March 23). Most plausible 2005-2040 emissions scenarios project less than 2.5 degrees C of warming by 2100. <https://doi.org/10.1088/1748-9326/ac4ebf>

Reidmiller, D.R., C.W. Avery, D.R. Easterling, K.E. Kunkel, K.L.M. Lewis, T.K. 2018. Impacts, Risks, and Adaptations in the United States: Fourth National Climate Assessment, Volume II. U.S. Global Change Research Program.

Tetra Tech and Hazen and Sawyer, 2020. Future Climate Scenarios for Town of Fuquay-Varina Interbasin Transfer Study.

United States Army Corps of Engineers Wilmington District. 2018. Final Integrated Water Supply Reallocation Feasibility Study and Environmental Assessment.

van Vuuren, D.P., Edmonds, J., Kainuma, M. et al. The representative concentration pathways: an overview. *Climatic Change* 109, 5 (2011). <https://doi.org/10.1007/s10584-011-0148-z>

Watanabe, S., Hajima, T., Sudo, K., Nagashima, T., Takemura, T., Okajima, H., Nozawa, T., Kawase, H., Abe, M., Yokohata, T., Ise, T., Sato, H., Kato, E., Takata, K., Emori, S., and Kawamiya, M.: MIROC-ESM 2010: model description and basic results of CMIP5-20c3m experiments, *Geosci. Model Dev.*, 4, 845–872, <https://doi.org/10.5194/gmd-4-845-2011>, 2011.



ATTACHMENT A

**Future Climate Scenarios for Town of Fuquay-Varina
Interbasin Transfer Study (Tetra Tech, 2020)**

Future Climate Scenarios for Town of Fuquay-Varina Interbasin Transfer Study

November 30, 2020

PREPARED FOR

Town of Fuquay-Varina

and

Hazen and Sawyer

PREPARED BY

Tetra Tech

One Park Drive, Suite 200

PO Box 14409

Research Triangle Park, NC 27709

Tel 919-485-8278

Fax 919-485-8280

tetrattech.com

In collaboration with:

Hazen and Sawyer

4011 Westchase Blvd, Suite 500

Raleigh, NC 27607



The primary authors of this report are Saumya Sarkar, Jonathan Butcher, and Michelle Schmidt, Tetra Tech, Inc., Research Triangle, NC

CONTENTS

1.0 INTRODUCTION.....	1
2.0 RAINFALL-RUNOFF MODEL	3
2.1 NHM/PRMS Model	3
2.2 Model Development and Hydrologic Response Units (HRUs)	3
3.0 WEATHER AND CLIMATE	5
3.1 PRMS Meteorology	5
3.2 Selection of Climate Scenarios.....	5
3.3 Climate Scenario Processing	10
4.0 NHM/PRMS APPLICATION	11
4.1 Model Corroboration.....	11
4.2 Application to Future Climate Scenarios	17
4.3 Comparison of PRMS and NCCV for Future Climate.....	17
4.4 Bias Correction for Flow	18
5.0 RESULTS	21
5.1 Water Budget Summary and Average Monthly Output	21
5.2 Lake Evaporation Timeseries	26
5.3 Database	26
6.0 REFERENCES.....	29
ACKNOWLEDGMENTS	30

TABLES

Table 1. Precipitation percentiles (in/month) and annual average totals for historic (1981-2010) and future (2050-2074) climate for Neuse River Basin case study.....	8
Table 2. Comparison of gaged flow to the Cape Fear River PRMS model	15
Table 3. Comparison of gaged flow to the Neuse River PRMS model	16
Table 4. Simulated water budgets for Cape Fear PRMS model for the historic and future (ca. 2055) conditions for the selected climate scenarios	21
Table 5. Simulated water budgets for Neuse PRMS model for the historic and future (ca. 2055) conditions for the selected climate scenarios	24

FIGURES

Figure 1. Workflow for creating future runoff timeseries	2
Figure 2. PRMS model HRUs and reaches for the Cape Fear and Neuse River	4
Figure 3. Relative change in hindcast (1950-2005) and future (2050-2080) average annual precipitation and mean annual air temperature for global climate models and greenhouse gas representative concentration pathways (RCP 4.5 and RCP 8.5) for Neuse River Case Study, NC.	7
Figure 4. Relative Change in hindcast (1950-2005) and future (2041-2070) Mean Annual Precipitation and Mean Annual Air Temperature for Global Climate Models and Representative Concentration Pathways (RCP 4.5 and RCP 8.5) for the Cape Fear and Neuse River Basins.....	9
Figure 5. PRMS model HRUs and USGS stream gages for the Neuse and Cape Fear basins	12
Figure 6. Simulated long-term water budget for the (a) Cape Fear PRMS model compared to the generalized water budgets for the (b) Coastal Plain and (c) Piedmont regions of the Cape Fear River Basin.....	13
Figure 7. Simulated long-term water budget for the Neuse PRMS model.....	13
Figure 8. Annual runoff (in/yr) simulated by PRMS vs. NCCV estimates from 1951 to 2099 for the Cape Fear River basin	18
Figure 9. Annual runoff (in/yr) simulated by PRMS vs. NCCV estimates from 1951 to 2099 for the Neuse River basin	18
Figure 10. Cumulative distribution functions for node 0820, July, for OASIS historical data and bias-corrected CNRM-CM5 (RCP 4.5) model output centered at 2055	20
Figure 11. Cumulative distribution functions for node 0820, July, for OASIS historical data and bias-corrected CNRM-CM5 (RCP 4.5) model output centered at 2055, replotted on logit scale	20
Figure 12. Simulated water budgets for Cape Fear PRMS model for the historic (1951-2005) and future (2041-2070) conditions for the selected climate scenarios.....	22
Figure 13. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for CNRM-CM5, RCP 4.5, for historic (1951-2005; left) and future (2041-2070; right) conditions	22
Figure 14. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for GFDL-ESM2M RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions	23
Figure 15. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for MIROC-ESM-CHEM RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions.....	23
Figure 16. Simulated water budgets for Neuse PRMS model for the historic (1951-2005) and future (2041-2070) conditions for the selected climate scenarios.....	24
Figure 17. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for CNRM-CM5 RCP 4.5, for historic (1951-2005; left) and future (2041-2070; right) conditions	25
Figure 18. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for GFDL-ESM2M RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions ..	25
Figure 19. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for MIROC-ESM-CHEM RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions.....	26

1.0 Introduction

Hazen & Sawyer (“Hazen”) is supporting the Town of Fuquay-Varina (“Town”) in developing an Environmental Impact Statement (EIS) in support of an Inter-basin Transfer (IBT) application. The proposed IBT will transfer water from the Cape Fear River basin to the Neuse River basin. Impacts of the proposed IBT will be evaluated using the OASIS Cape Fear - Neuse Combined Hydrologic Model. The potential impact of climate change on the hydrologic status of the Cape Fear and Neuse River basins as a result of the proposed transfer must be evaluated in the EIS. This technical evaluation requires estimating how natural hydrologic inputs to both basins may change over time.

Hazen has subcontracted with Tetra Tech to assess climate variability via the development of quantitative daily timestep hydrology for the Neuse River Cape Fear River basins. Specifically, runoff for all areas upstream of New Bern, NC in the Neuse River Basin, and all areas upstream of Lock and Dam #1 in the Cape Fear River basin were requested. The required estimates are natural flows (i.e., without consideration of dams) at the subbasin scale. The influence of dams, discharges, and flow withdrawals in the basins will be simulated within the OASIS model.

To develop the analysis covering these two large drainage basins and still retain sufficient spatial resolution, the USGS National Hydrology Model (NHM) was used. The NHM Model incorporates a calibrated Precipitation Runoff Modeling System (PRMS) rainfall runoff model (Regan et al., 2018). The NHM and PRMS hydrologic modeling tools are described in Section 2.0.

To provide an assessment that covers a scientifically supported range of future climate variability, timeseries output (statistically downscaled to local conditions) was selected from three global climate models (GCMs) that represent the spectrum of future conditions. Selection and processing of the climate model data is described in Section 3.2. A watershed runoff model (NHM/PRMS) is then used to convert weather to runoff timeseries. Section 4.0 describes the application of the watershed model, including examination of the performance of the model relative to historic streamflow.

Results of the modeling are provided for a 30-year future climate run centered at 2055 (i.e., 2041 – 2070). Flow timeseries associated with each GCM are compared to a historical “hindcast”¹ model run spanning 1950 to 2005 (as recommended by Abatzoglou and Brown [2012], the developers of the downscaled climate dataset). Hindcasting provides an “apples to apples” indication of relative change that is used to adjust the observed inputs to OASIS using a bias-adjustment technique described in Section 4.4. The bias adjustment accounts for systematic differences that may be present between the PRMS model and observed flows.

The workflow for creating future climate-adjusted runoff timeseries is summarized in Figure 1

The results of the modeling are provided in an electronic database compatible with OASIS model inputs and summarized in Section 5.0.

¹ A hindcast is a model produced estimate of all outputs (e.g. runoff, PET, etc.) using historical input conditions (e.g. temperature and precipitation), which can be used to evaluate model performance.




Figure 1. Workflow for creating future runoff timeseries

2.0 Rainfall-Runoff Model

2.1 NHM/PRMS Model

The USGS National Hydrologic Model (NHM) infrastructure supports the efficient construction of local-, regional-, and national-scale hydrologic models. The NHM infrastructure consists of 1) an underlying geospatial fabric of modeling units with an associated parameter database, 2) a model input data archive, and 3) a repository of the physical model simulation code bases. The PRMS model is the rainfall-runoff component of the NHM. Adaptation of PRMS for use in the NHM is described in Regan et al. (2018).

The National Geospatial Fabric for the NHM is based on the National Land Cover Database (NLCD) for 2001. This land use representation is used for simulation of both historic and future conditions and no attempt has been made to simulate future changes in land use. Approximately 10,000 square miles (mi²) of drainage area in the source and receiving basins are included in the model. Areas with significant recent growth are mostly confined to the Triangle, Triad, and Fayetteville urban areas and represent a small fraction of the source and receiving basin drainage area. It is not anticipated that changes to the small fraction of urbanization in the source and receiving basins will significantly change the findings of the hydrologic analysis. Assuming a constant land cover will allow the model to discern the direction and relative magnitude of hydrologic impacts from climate variability, which are then applied to the OASIS input timeseries calculated from observed gage records. Further, the analysis required for the IBT primarily considers the impacts to the source and receiving basins during low-flow periods. Therefore, use of the 2001 baseline was determined to be adequate for the purpose of this task to evaluate *relative* changes to hydrology that may occur as a result of climate change.

2.2 Model Development and Hydrologic Response Units (HRUs)

Subwatersheds in the NHM (referred to as hydrologic response units or “HRUs” by the model developers) are similar in scale to HUC10 boundaries, but do not follow the HUC10 breakpoints exactly. The geospatial fabric is based on an aggregation of the spatial features associated with NHDPlus version 1. The more than two million catchments in the U.S. in the NHDPlus version 1 dataset were aggregated to approximately 110,000 HRUs. The NHM subwatersheds or HRUs for the Cape Fear and Neuse are displayed in Figure 2 and range in size from 0.02 to 242 square miles with a median of 9.4 and average of 18.6 square miles. These subwatersheds were reviewed with Hazen and determined to be sufficient for providing input to the OASIS model. Aggregated local flows (not including flows from upstream subwatersheds) as well as evaporation rates are provided for each subwatershed. The OASIS model is responsible for aggregating the flows from each HRU along tributaries and the main stems of both river systems as well as simulating operations.

The PRMS model for the Cape Fear consists of 296 HRUs and 168 stream segments while the Neuse model is comprised of 228 HRUs and 127 stream segments. A description of the NHM PRMS modeling system including a discussion of the modules and parameterization is provided in Regan et al. (2018). The parameters in the Cape Fear and Neuse PRMS models (described in Appendix I of Regan et al., 2018) have not been changed from the USGS-provided values for this study.




Figure 2. PRMS model HRUs and reaches for the Cape Fear and Neuse River

3.0 Weather and Climate

Estimation of runoff under historic conditions requires daily time step weather series. Prediction of potential future conditions is based on re-estimation of daily weather time series consistent with the projected changes in climate in accordance with climate modeling efforts.

3.1 PRMS Meteorology

The NHM PRMS models require daily precipitation, potential evapotranspiration (PET), and daily maximum and minimum air temperature as meteorological forcing. PET may be supplied as an external time series; however, the PRMS model also has provisions for calculating PET internally using the Jensen-Haise, Hamon, Hargreaves-Samani, Priestley-Taylor, or Penman-Monteith methods. Several of these PET methods require additional meteorological inputs, including solar radiation, relative humidity, and wind travel (total wind movement per unit time independent of direction). For the national NHM PRMS models, USGS estimated PET using the Jensen-Haise method, which uses air temperature and solar radiation as inputs and the calibrated runoff parameters are conditional on this choice for PET. Section 4.1 includes a comparison of model performance using the Penman-Monteith energy balance method for PET that demonstrates that a switch to the Penman-Monteith method degrades model performance and is not advisable.

The meteorological forcing in the national PRMS models is obtained from Daymet, gridMET and other gridded climate datasets. In this study the meteorological inputs are replaced by gridded data from downscaled hindcast and forecast runs of climate models to evaluate expected changes in runoff in the future.

3.2 Selection of Climate Scenarios

Global average air temperatures are rising due to human activities and GCM projections are in general agreement that temperature increases will continue throughout the 21st century. GCM predictions regarding future precipitation patterns are less certain and more variable. Effective water resources planning needs to consider the risks associated with these potential changes to help ensure reliability and resiliency of the water sector.

Assuming that the future will resemble the past is insufficient in the presence of a changing climate, and decisions made today can exacerbate or mitigate a community's vulnerability to change. The risks and impacts of future climate on water resources will vary by location and sector and will depend on complex interactions between precipitation frequency, precipitation intensity, and increases in evaporation associated with warmer temperatures.

Potential climate-related impacts and risks to the Southeast region of the U.S. are summarized as part of the Fourth National Climate Assessment Report (USGCRP, 2018). Daytime and nighttime temperatures in the Southeast for the present decade (2010-present) have been warmer than previous decades on record, extending the freeze-free season length by about 1.5 weeks compared to the early 1900s, and nearly three-quarters of precipitation monitoring locations have recorded more frequent extreme precipitation events (> 3 inches). GCM simulations predict warmer air temperatures and more extreme precipitation events for the Southeast over the 21st century. These changes are predicted across Representative Concentration Pathway (RCP) trajectories that represent anticipated greenhouse gas

concentrations and radiative forcing based on different levels of anthropogenic emissions and greenhouse gas accumulation in the atmosphere produced as part of the Intergovernmental Panel on Climate Change (IPCC) Coupled Model Intercomparison Project, round 5 (CMIP5), completed in 2014 in support of the most recent IPCC Fifth Assessment Report. RCP 4.5 and RCP 8.5 represent lower and higher levels of end-of-century radiative forcing (4.5 and 8.5 W/m², respectively), and are believed to bound the likely trajectories that may occur as a result of human economic, political, and climate mitigation activities. Increases in global temperatures are predicted to be more severe for the higher radiative forcing (8.5 W/m²) scenario. Recent trends in fossil fuel consumption and carbon emissions have been more in line with the trajectory of the higher radiative forcing scenario (RCP 8.5), although both are examined to support planning efforts. Temperature predictions from the two RCPs are not expected to deviate strongly until after the middle of the 21st century, while rainfall predictions vary more between different GCMs than between different RCPs.

If realized, rising air temperatures are anticipated to lengthen the freeze-free growing season in the Southeast by more than a month by the late 21st century as compared to the late 20th century. Daytime high and nighttime low temperatures are expected to increase. Central and Eastern North Carolina are assessed as having a particularly high future heat wave risk. Increasing water demands in urban centers and prolonged dry periods that limit supply replenishment and enhance watershed and reservoir evapotranspiration may stress water supplies. Nevertheless, conservation practices among water users and the increased efficiency of water-using devices have been counteracting these risks in many areas over the past two decades. Changes in ecosystem composition are also expected, potentially including the loss and replacement of local plant species, and such changes may alter the hydrology of water supply watersheds and, ultimately, water availability. Droughts are a primary concern for water supply planning, but increased flooding from extreme rainstorms and hurricanes will put communities simultaneously at risk for inland flooding, infrastructure damage (e.g., water supply reservoir dams), and potentially loss of life.

Results for a large number of GCMs and greenhouse gas scenarios are available from CMIP5. No one climate scenario is predictive of the future because the models have uncertainties and the greenhouse gas emission scenarios that drive these scenarios depend on assumptions about future economic activity and political decisions, all of which are uncertain. To define the range of futures to which adaptation may be needed at a reasonable level of effort, it is appropriate to define a set of bounding scenarios that encompass the likely range of future conditions.

In previous work conducted in the Piedmont region of the Neuse River basin, Tetra Tech identified a set of reasonable bounding climate scenarios for analysis of future impacts on water supply. The future climate conditions assessed for this project are generally applicable throughout the Piedmont region and inland Coastal Plain of North Carolina; therefore, the same set of scenarios were selected for evaluating potential impacts to the broader areas of the Cape Fear and Neuse River basins relevant to the proposed IBT. The reasonableness of this selection is verified in the following paragraphs.

Future climate projections are uncertain and are best used to describe a probability envelope of potential future conditions (an “ensemble of opportunity”; Mote et al., 2011) to which adaptation may be needed. To select a set of GCMs that bound the likely range of potential climate futures with respect to water supply, predicted relative change in mean annual temperature and mean annual precipitation was assessed using USEPA’s LASSO (Locating and Selecting Scenarios On-line) tool (<http://lasso.epa.gov>). The tool performs automated annual and seasonal summaries of monthly-level spatially downscaled (4 km) GCM output from the Multivariate Constructed Analogs (MACA v2) CMIP5 archive (<http://maca.northwestknowledge.net/>).

GCMs predict future climate as a function of large-scale forcing, not date-specific weather series. Climate is defined as weather at a place averaged over a long period of time, generally multiple decades, and GCM output must similarly be analyzed over a multi-decadal period. The bi-plot produced by LASSO, represents the future climate as the change in mean annual air temperature and mean annual precipitation for the future-cast period of 2050 to 2080 (centered at 2065) relative to the hind-cast period (1950-2005). The results of the case study in the Neuse are shown in Figure 3. The different model-RCP scenario pairs show a wide range of changes in average annual precipitation for the watershed containing the water supply reservoirs, although all but one predicts some increase. All scenarios also predict an increase in average annual temperature of between 2 and 9° F, which will increase evapotranspiration rates.




Figure 3. Relative change in hindcast (1950-2005) and future (2050-2080) average annual precipitation and mean annual air temperature for global climate models and greenhouse gas representative concentration pathways (RCP 4.5 and RCP 8.5) for Neuse River Case Study, NC.

Note: Green boxes Identify selected scenarios

Scenarios that are likely to predict the maximum runoff (and therefore water supply) are in the upper-left quadrant – these scenarios predict a greater increase in mean annual precipitation and a relatively moderate increase in air temperature and associated evapotranspiration. Conversely, scenarios that are likely to predict the minimum runoff are in the bottom-right quadrant. These scenarios predict a small increase in mean annual precipitation and a relatively large increase in mean annual air temperature. While both temperature and precipitation changes play a role in future water supply, the changes in precipitation are likely to have the greater impact.

To evaluate the risk associated with possible futures, it is advisable to look at scenarios that span the general range of climate change. However, some GCMs that produce outlying results may not be realistic for this region. Accordingly, scenarios were selected that approximate the mean, 10th percentile, and 90th percentile results of available CMIP5 GCMs across both RCPs for further analysis. Specifically, the GCM CNRM-CM5 under RCP 4.5 was selected as a plausible high runoff potential scenario (e.g., large increase in precipitation with moderate increase in air temperature) and MIROC-ESM-CHEM RCP 8.5 is applied as a plausible low runoff potential scenario (e.g., low increase in precipitation with large increase in air temperature). The CNRM-CM5 model was also ranked highest for its ability to reproduce observed historical climate for the Southeast U.S. (Rupp, 2016), although there is no guarantee that accurately predicting past climate will mean that the model will best predict future climate. The full ensemble average, which combines both the RCP 4.5 and RCP 8.5 scenarios across all GCMs, is designated in the plot by a black cross. The scenario that aligns closest to the ensemble average is GFDL-ESM2M, RCP 8.5, and it is applied as the moderate climate scenario.

To summarize, the following three scenarios were selected for the climate assessment screening based on the aforementioned analysis:

- CNRM-CM5, RCP 4.5 (higher runoff potential)
- MIROC-EMS-CHEM, RCP 8.5 (lower runoff potential)
- GFDL-ESM2M, RCP 8.5 (approximates ensemble mean)

Average annual statistics for the three selected scenarios for the Neuse River basin case study are summarized in Table 1. Note that the results for the case study are centered at 2065, whereas the requested output for this proposed IBT is centered at 2055; however, little change in relative ranking is expected between 2065 and 2055.

Table 1. Precipitation percentiles (in/month) and annual average totals for historic (1981-2010) and future (2050-2074) climate for Neuse River Basin case study

Period	Precipitation Percentile (in/month)					Annual Average (in/yr)
	10%	25%	50%	75%	90%	
MIROC-ESM-CHEM (RCP 8.5)						
1981-2010	1.7	2.5	3.6	4.8	6.6	46.3
2050-2080	1.6	2.5	3.7	5.0	6.4	46.8
Relative Change	-5.4%	2.3%	2.1%	3.2%	-2.6%	1.1%
GFDL-ESM2M (RCP 8.5)						
1981-2010	1.6	2.4	3.6	4.9	6.3	46.2
2050-2080	1.8	2.6	3.8	5.3	7.0	50.5
Relative Change	12.8%	7.0%	4.1%	8.0%	10.4%	8.4%
CNRM-CM5 (RCP 4.5)						

1981-2010	1.7	2.5	3.6	4.8	6.5	46.2
2050-2080	1.8	2.6	3.7	5.2	7.1	50.9
Relative Change	6.0%	3.3%	1.6%	8.7%	7.5%	9.1%

To confirm that the GCMs selected for the Neuse River basin case study remain reasonable for the entire Cape Fear and Neuse River basins when applied to a slightly earlier future time period (2041-2070 instead of 2050-2080), the LASSO tool was re-run for those conditions (Figure 4). While there are some small changes in the relative positioning of the GCM scenarios, the three selected scenarios remain appropriate, representing a median scenario, a hotter and drier scenario, and a wet scenario with moderate temperature increase.




Figure 4. Relative Change in hindcast (1950-2005) and future (2041-2070) Mean Annual Precipitation and Mean Annual Air Temperature for Global Climate Models and Representative Concentration Pathways (RCP 4.5 and RCP 8.5) for the Cape Fear and Neuse River Basins

Note: Green boxes Identify selected scenarios.

3.3 Climate Scenario Processing

Hindcast and forecast downscaled GCM output were obtained from the MACAv2-Metdata archive. A Python script was developed to transform the gridded MACA data to meteorological forcing time-series for the PRMS model. The sequential processes implemented within the Python script include -

- 1) Generate a reference grid to determine grid cells that intersect each of the PRMS model HRUs.
- 2) Extract time-series data for grid cells that intersect the PRMS model HRUs from the MACA files for required meteorological parameters (daily precipitation, maximum air temperature, and minimum air temperature).
- 3) Spatially aggregate gridded climate data to the PRMS model HRUs scale using an area-weighting approach.
- 4) Generate meteorological forcing files formatted for the PRMS model from the HRU-scale time-series data. Unique time-series for each HRU are supplied to PRMS via the “climate-by-HRU” (CBH) files for each meteorological variable.

4.0 NHM/PRMS Application

The NHM PRMS model is calibrated nationally and comes with a parameter database. The assumption for this project is that the model can be used “as is.” However, it is also desirable to document and corroborate model performance.

Such corroboration is challenging because the model is being applied here to generate natural, unregulated flows. Many of the stream gages in the region are strongly affected by water supply reservoirs and dams (most notably Falls Lake and Jordan Lake, but also including many smaller impoundments), water withdrawals, and major and minor wastewater discharges. Even for watersheds that do not have major impoundments, the model does not explicitly represent factors such as well withdrawals, onsite wastewater disposal via septic systems, and irrigation, which together can have a strong effect on baseflow. However, the NHM PRMS model output is an intermediate product that will be used, in conjunction with the OASIS model, to estimate relative changes between historic and future flow. The OASIS model can and will account for withdrawals, discharges, and impoundments and therefore the disregard for these influences at this stage of the analysis is considered acceptable.

4.1 Model Corroboration

The existing NHM PRMS models are configured to simulate watershed hydrology from water year 1981 to 2016. Qualitative corroboration of the Cape Fear and Neuse PRMS models for historic hydrology was done by evaluating components of the water balance against peer-reviewed literature and comparing simulated streamflow against USGS measurements at multiple locations on the mainstems and tributaries. The USGS streamflow monitoring locations used for the corroboration of the Cape Fear and Neuse models are shown in Figure 5.




Figure 5. PRMS model HRUs and USGS stream gages for the Neuse and Cape Fear basins

The simulated water budget for the Cape Fear PRMS model (Figure 6) is consistent with the generalized water budgets for the Cape Fear River Basin reported by the North Carolina Department of Natural Resources (NCDENR) in the Cape Fear River Basin Plan (NCDENR, 2009). The simulated water budget for the Neuse PRMS model (Figure 7) is similar to the Cape Fear model and comparable to the water budget for the Piedmont region for the Cape Fear River Basin reported by NCDENR. Note that the groundwater outflow for the PRMS models shown in the water budgets include interflow (i.e., lateral flow through unsaturated soil zones). The changes in storage (not shown in the water budget summaries) simulated for the Cape Fear and Neuse models are negligible, approximately 0.1% of the average annual precipitation.

The ratio of average annual simulated evapotranspiration to precipitation for the Cape Fear and Neuse PRMS models are 0.65 and 0.67, respectively. These ratios are consistent with the range of 0.60 to 0.69 reported by Sanford and Selnick (2012) for this region.




Figure 6. Simulated long-term water budget for the (a) Cape Fear PRMS model compared to the generalized water budgets for the (b) Coastal Plain and (c) Piedmont regions of the Cape Fear River Basin




Figure 7. Simulated long-term water budget for the Neuse PRMS model

Comparison of streamflow predicted by PRMS to USGS gages along the Cape Fear River and major tributaries such as the Deep and Haw Rivers, suggest that streamflow is generally over-predicted by the PRMS model relative to gaged flows (Table 2). Much of the over-prediction occurs during low flow periods. On the main-stem Cape Fear, peak flows are generally over-predicted in addition to the low flows.

The majority of these discrepancies are believed to be due to the influence of dams and associated water withdrawals (including Jordan Lake on the Cape Fear, Randleman Lake and the former Carbonton Dam (removed in 2006) on the Deep River, and various smaller dams in the Haw drainage.)

At many gages, including some not strongly influenced by dams, the PRMS model appears to over-predict summer low flows. This suggested possible issues with the calculation of PET. As noted earlier, the NHM PRMS models use a modified version of the Jensen-Haise PET method. The influence of this method choice was checked through comparison to alternative simulations undertaken with the Penman-Monteith energy balance method. This required estimates of daily relative humidity and wind speed time-series, which were obtained from the National Land Data Assimilation System (NLDAS) version 2 forcing data (<https://ldas.gsfc.nasa.gov/nldas/nldas-2-forcing-data>). As implemented in PRMS, the Penman-Monteith method yields much higher estimates of PET that result in a large under-estimation of runoff when compared to gaged streamflow. As PRMS parameters were regionally calibrated using Jensen-Haise PET, it appears that a switch to Penman-Monteith PET is not advisable as it would require significant additional effort for detailed recalibration of the NHM PRMS model. Instead, a bias correction approach, described in Section 4.4, is used to compensate for uncertainties present in the PRMS model.

For the Cape Fear basin, the monthly Nash-Sutcliffe coefficients of model fit efficiency (NSEs) at the larger-scale USGS gages are generally between 0.6 and 0.7, which falls within the category rated as “Satisfactory” to “Good” as recommended by Moriasi et al. (2007) despite the influence of many dams. A poorer match was found at some of the smaller area gages. Nevertheless, the model performance is believed to be sufficient for the intended purpose of evaluating relative change in local runoff between historic changes and potential future climate.

The match between gaged streamflow and PRMS predictions for Neuse basin is generally better than for the Cape Fear (Table 3). Like the Cape Fear model, the Neuse model also systematically over-predicts of low flows and baseflow, but the comparisons are affected by numerous dams and water withdrawals. The low-flow statistics at the USGS gages for streams not impacted by major water withdrawals or impoundments such as Contentnea Creek and Little River are better than for the main-stem Neuse. Evaluation of incremental flows for Neuse River downstream of Falls Lake to the Goldsboro and Kinston gages demonstrates better agreement for low flow periods, strengthening the hypothesis that the influence of water withdrawals and impoundments is negatively affecting the PRMS to USGS gage comparison at low flows. However, the OASIS model will account for these influences. Based on the magnitude of streamflow error and monthly NSE, the performance of the Neuse PRMS model is rated as “Good” for major USGS streamflow gage locations.

Table 2. Comparison of gaged flow to the Cape Fear River PRMS model

USGS Gage Name	South Buffalo Creek near Greensboro, NC		Buffalo Creek near Greensboro, NC		Buffalo Creek at SR2819 near McLeansville, NC		Reedy Fork near Gibbonsville, NC		Haw River near Haw River, NC		Morgan Creek near Chapel Hill, NC		New Hope Creek near Blands, NC		Deep River near Randleman, NC		Deep River at Ramseur, NC		Haw River near Bynum, NC		Deep River at Moncure, NC		Buckhorn Creek near Corinth, NC		Cape Fear River at Lillington, NC		Rockfish Creek at Raeford, NC		Cape Fear River at Wilmington, NC		Cape Fear River at Lock #1, NC	
USGS Gage Id	02095000		02095500		0206553650		02094500		02096500		02097517		02097314		02099500		02100500		02096960		02102000		02102192		02102500		02104220		02105500		02105769	
Drainage Area	34.0		37.1		88.5		131.0		606.0		41.0		75.9		125.0		349.0		1275.0		1434.0		76.3		3464.0		93.1		4852.0		5255.0	
Analysis Period	8/1/1998 to 9/30/2016		10/1/1981 to 9/30/2016		8/1/1998 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		11/1/1982 to 9/30/2016		10/1/1982 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		7/1/1988 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016	
Constituent	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)
Total flow	19.8	-27.6	17.6	-28.4	23.7	-28.2	9.4	140.9	14.0	33.9	13.5	17.2	17.0	12.3	15.2	37.2	13.2	40.4	12.6	34.1	12.3	39.2	8.6	102.1	12.1	40.5	15.9	-28.0	12.6	32.7	13.1	27.1
Total lowest 50% flows	1.3	33.0	3.2	-43.1	4.6	-43.0	0.5	680.9	1.8	91.4	2.2	-60.6	1.7	-10.5	1.6	41.8	1.4	82.6	1.4	108.2	1.0	190.7	0.2	759.4	1.4	115.0	4.7	-73.5	1.8	77.1	1.9	76.9
Total highest 10% flows	13.7	-54.0	8.5	-37.8	11.6	-43.3	6.3	44.8	7.0	-1.2	6.8	30.3	9.3	5.6	8.4	13.3	7.2	-0.5	6.4	-3.6	7.1	-11.8	4.9	81.1	5.4	12.3	3.9	44.8	5.1	11.0	4.9	11.1
Summer flow volume (months 7-9)	5.2	-23.5	4.0	-20.1	5.8	-22.6	1.3	232.6	2.3	61.8	2.1	23.9	2.5	29.8	2.5	63.4	1.8	91.2	1.8	90.5	1.5	116.3	1.1	196.3	1.7	99.2	3.6	-45.7	1.9	73.4	2.0	66.5
Fall flow volume (months 10-12)	4.7	-38.6	4.2	-42.1	5.6	-38.3	1.8	149.9	2.9	22.4	2.7	-5.2	3.4	-9.3	2.9	22.7	2.8	24.3	2.6	22.0	2.5	18.6	1.2	111.0	2.3	28.5	4.0	-27.3	2.4	16.5	2.5	9.8
Winter flow volume (months 1-3)	5.3	-32.5	5.1	-33.0	6.5	-32.5	3.9	92.5	5.3	14.2	5.6	17.8	7.1	8.4	6.0	19.9	5.4	19.3	5.2	9.6	5.7	11.6	4.0	68.7	5.3	14.9	4.7	-0.7	5.3	11.2	5.4	6.3
Spring flow volume (months 4-6)	4.7	-15.7	4.4	-17.6	5.8	-19.0	2.4	162.5	3.4	55.8	3.1	31.2	4.0	26.2	3.8	58.8	3.2	62.0	3.1	52.7	2.8	72.7	2.3	112.8	2.9	62.9	3.6	-46.8	2.9	58.0	3.1	51.7
Monthly NSE		0.49		0.38		0.45		-0.88		0.61		0.63		0.67		0.54		0.53		0.63		0.61		0.11		0.63		-0.87		0.65		0.68

Notes: “Obs” represents the gaged flow, converted to inches per year. “Err” is percentage difference between PRMS and the gaged flow. A positive value of Err indicates over-prediction.

Table 3. Comparison of gaged flow to the Neuse River PRMS model

USGS Gage Name	Flat River at Bahama, NC		Eno River near Durham NC		Little River at SR1461 near Orange Factory, NC		Neuse River near Falls, NC		Crabtree Creek at US1 at Raleigh, NC		Walnut Creek at Sunnybrook Drive near Raleigh, NC		Contentnea Creek near Lucama, NC		Neuse River near Clayton, NC		Neuse River near Clayton, NC (incremental)		Middle Creek near Clayton		Little River near Princeton, NC		Neuse River near Goldsboro, NC		Neuse River near Goldsboro, NC (incremental)		Contentnea Creek at Hookerton, NC		Neuse River at Kinston, NC		Neuse River at Kinston, NC (incremental)		Swift Creek at Hwy 43 near Streets Ferry, NC	
USGS Gage Id	02085500		02085070		020852134		02087183		02087324		02087359		02090380		02087500		02087500		02088000		02088500		02089000		02089000		02091500		02089500		02089500		0209205053	
Drainage Area	149.0		141.0		78.2		771.0		121.0		29.8		161.0		1150.0		1150.0		83.5		232.0		2399.0		2399.0		733		2692.0		2692.0		269.0	
Analysis Period	10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1987 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1990 to 9/30/2016		10/1/1996 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1981 to 9/30/2016		10/1/1996 to 9/30/2007	
Constituent	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)	Obs (in)	Err (%)
Total flow	12.5	23.5	11.9	68.4	11.9	45.7	10.7	60.4	16.9	17.9	16.6	0.5	13.0	34.1	12.4	39.9	13.8	28.4	14.9	30.7	13.9	30.6	13.5	23.9	14.4	15.5	14.6	14.1	13.8	21.5	14.5	15.2	16.6	-40.3
Total lowest 50% flows	0.8	61.2	0.9	149.1	0.7	98.2	1.1	123.9	2.2	37.2	1.9	10.4	1.1	217.1	1.9	52.2	2.5	2.7	1.7	24.2	1.2	73.7	1.9	53.1	2.1	31.4	1.8	75.8	2.2	38.6	2.3	18.3	2.0	-62.9
Total highest 10% flows	7.8	-1.0	6.9	34.3	7.3	15.8	5.6	21.9	8.3	4.5	9.5	-29.6	6.8	1.2	5.0	30.2	5.7	24.0	7.4	22.1	6.8	18.9	4.9	18.6	5.3	13.2	5.9	6.4	4.8	19.7	5.0	19.5	8.0	-28.0
Summer flow volume (months 7-9)	1.5	98.9	1.5	151.7	1.5	103.0	1.4	127.0	4.0	2.2	4.2	-11.1	2.2	67.7	2.1	63.1	2.9	27.2	2.6	46.8	2.4	57.1	2.3	45.6	2.58	32.5	2.7	34.7	2.4	40.3	2.7	29.9	4.5	-41.3
Fall flow volume (months 10-12)	2.4	4.0	2.2	58.1	2.4	21.1	1.8	58.8	3.8	7.4	3.8	-8.6	2.2	50.2	2.3	30.5	2.8	11.0	2.9	1.8	2.5	22.5	2.5	10.2	2.7	1.1	2.7	14.4	2.6	6.1	2.7	-0.9	4.0	-50.2
Winter flow volume (months 1-3)	5.6	-2.9	5.3	41.8	5.2	24.6	4.6	34.4	5.5	33.1	4.8	14.0	5.8	7.3	4.9	29.1	4.8	30.1	6.0	27.2	6.0	14.6	5.4	11.9	5.7	5.3	5.8	-3.7	5.4	12.0	5.5	7.5	4.8	-35.1
Spring flow volume (months 4-6)	3.0	52.0	3.0	81.9	2.8	74.9	2.8	70.5	3.6	23.0	3.9	5.2	2.8	50.2	3.2	48.3	3.3	41.7	3.4	49.2	3.0	48.1	3.3	39.1	3.4	31.6	3.4	28.0	3.4	35.1	3.5	29.0	3.3	-34.7
Monthly NSE		0.69		0.20		0.57		0.42		0.68		0.72		0.71		0.53		0.25		0.54		0.75		0.77		0.80		0.82		0.77		0.78		0.62

Notes: “Obs” represents the gaged flow, converted to inches per year. “Err” is percentage difference between PRMS and the gaged flow. A positive value of Err indicates over-prediction. “Incremental” flows for the USGS gages near Clayton, Goldsboro and Kinston are obtained by subtracting the gaged records at Neuse River near Falls, NC.

4.2 Application to Future Climate Scenarios

The NHM PRMS models for the Cape Fear and Neuse were simulated from 1/1/1950 through 12/31/2070 using HRU level daily precipitation, and maximum and minimum air temperature time-series data developed for the MACA-downscaled output from the following climate models and RCPs.

- CNRM-CM5 (RCP 4.5)
- GFDL-ESM2M (RCP 8.5)
- MIROC-ESM-CHEM (RCP 8.5)

Meteorological time-series development for the climate scenario simulations is discussed in 3.3. The only changes made to the PRMS models for the climate scenario simulations are the meteorological forcing time-series (precipitation and air temperature) and the simulation time-period. The PRMS runoff outputs for the climate scenarios simulations were compared against the USGS National Climate Change Viewer (NCCV) estimates, discussed in the following sections. The water budgets and average monthly total runoff and actual evapotranspiration for the historic (1950-2005) and target future period (2041-2070) are summarized in the subsequent sections.

4.3 Comparison of PRMS and NCCV for Future Climate

Model performance for future climate cannot, of course, be checked against observations. However, a general check for consistency was performed by comparing the PRMS output to predictions obtained from the USGS National Climate Change Viewer (NCCV; Alder and Hostettler, 2013). The NCCV uses a different statistical downscaling method and computes runoff based on a simplified monthly water balance calculation. The results for a given GCM are thus not expected to match PRMS but should show strong correlation.

Annual runoff simulated by the Cape Fear and Neuse PRMS models for the CNRM-CM5 (RCP 4.5), GFDL-ESM2M (RCP 8.5) and MIROC-ESM-CHEM (RCP 8.5) climate scenarios from 1951 to 2099 were compared against estimates of runoff reported by the USGS NCCV. The annual runoff time-series simulated by the PRMS model shows good agreement with the NCCV estimates, as shown in Figure 8 and Figure 9 for the Neuse and Cape Fear rivers. Interestingly, this comparison also suggests that PRMS may be biased high during low flow periods.




Figure 8. Annual runoff (in/yr) simulated by PRMS vs. NCCV estimates from 1951 to 2099 for the Cape Fear River basin




Figure 9. Annual runoff (in/yr) simulated by PRMS vs. NCCV estimates from 1951 to 2099 for the Neuse River basin

4.4 Bias Correction for Flow

The PRMS model provides an imperfect match to gaged flows, including for gages that are not affected by major dams, withdrawals, or discharges. This suggests the presence of some biases in the PRMS output. Comparison of statistics for the incremental inflow timeseries specified for the historical period in OASIS to PRMS output for the same period also reveals differences, typically on the order of 10-20%. These differences suggest that a bias correction step is needed before using PRMS to predict the future water balance in OASIS. Specifically, rather than using the PRMS output directly in OASIS it is preferable to modify the existing OASIS input timeseries based on the difference in runoff distributions between the historical and future time windows in PRMS.

The bias correction for the future incremental inflow timeseries is accomplished using the method of empirical quantile mapping (eQM). The eQM approach (Amengual et al., 2012) is a method developed

and frequently used for adjusting biases in climate model precipitation series. However, it makes no assumption of a specific parametric form of statistical distribution and is applicable to bias adjustment of any time series. Given a model output timeseries for the historical training period (H), a model output timeseries for a future prediction period (F), and a timeseries of local observations for the historical period (O), the approach locates the quantile of the prediction F within the cumulative distribution function of the training data H , then transfers this position to the same quantile within the cumulative distribution function of the local observations, O , thus creating a prediction (P) that is bias-corrected to the local observations. In our application, O is the historical timeseries of incremental inflows currently used in OASIS, while H and F are the historic and future periods, respectively, in the PRMS output for the same drainage area. The general method developed by Amengual et al. expresses the quantile adjustment or shift as $P_i = O_i + g \bar{\Delta} + f \Delta_i$, where $\bar{\Delta}$ is the mean regime shift and Δ_i is the difference between the future and historic i th quantile. The parameters g and f allow for adjustments that weight the influence between the overall regime shift and the shift in individual quantiles. Typical applications of eQM where a parametric form of the cumulative distribution function is not specified use $g = f = 1$, in which case the equation for P_i is equivalent to applying the quantile shift directly.

A Python implementation of this method is available in `bias_correction.py` (https://svn.oss.deltares.nl/repos/openearthtools/trunk/python/applications/hydrotools/hydrotools/statistics/bias_correction.py), in turn based on the R package `downscaleR`, ([https://github.com/SantanderMetGroup/downscaleR/wiki/Bias-Correction-and-Model-Output-Statistics-\(MOS\)](https://github.com/SantanderMetGroup/downscaleR/wiki/Bias-Correction-and-Model-Output-Statistics-(MOS))). The method is highly efficient and automatable.

For application to the OASIS inflow timeseries an initial approach evaluated applying the bias correction on a regional basis for efficiency (e.g., Neuse Basin, Piedmont geographic province); however, this causes problems because many of the drainage areas intersect the Piedmont and Coastal Plain areas and does not consider specific local variations in runoff conditions. Therefore, the eQM method was applied individually to each of the 61 locations with OASIS inflow timeseries in the Neuse and Cape Fear study areas. The calculations were also done by individual month to account for any seasonal effects. The eQM application used 1,000 bins to characterize the historical cumulative distribution functions, which is near the maximum feasible for a 56-year training data set. Using a large number of bins is desirable to ensure that the high and low tails of the distribution are adequately covered. The large number of bins means that there will be a small number of observations in each bin (average of a little less than 2) and that many bins will be empty. However, the method relies on comparing the cumulative distribution functions, so the presence of empty bins does not cause problems. A large number of bins (even sparsely populated) just gives a more refined step-function approximation of the underlying continuous cumulative distribution.

One modification was made to the bias correction code to address the situation where a future predicted flow falls outside of the range of bins in the historic training data. (This is a rare event with 1,000 bins in use). The original Python and R codes provide two options when this occurs. One is to use the constant value associated with the largest (or smallest) bin of the observed data; the other is to apply the difference between the largest (or smallest) bin in the observed data and the training data. The original R code indicates that the developers also considered a linear extrapolation, but that this was rejected “due to lack of robustness.”

Neither of these approaches is satisfactory for extrapolation of extreme high flow events. Accordingly, the tails of the distribution are addressed by re-introducing a linear extrapolation in which the simulated result is multiplied by the ratio of the highest bins in the training and observed data. This appears to provide

reasonable results and avoids an implausible flattening out of the extreme upper end of the cumulative distribution function.

An example of the resulting shifts in the cumulative distribution function are shown for July for OASIS input node 0820 (downstream end of the Cape Fear River) in Figure 10. This shows a large increase in the biggest runoff events associated with summer convective storm activity. (Less change is predicted for winter months.) Figure 11 shows the same points plotted on a logit scale ($\text{LN}[p/(1-p)]$), which expands the tails of the distribution.




Figure 10. Cumulative distribution functions for node 0820, July, for OASIS historical data and bias-corrected CNRM-CM5 (RCP 4.5) model output centered at 2055




Figure 11. Cumulative distribution functions for node 0820, July, for OASIS historical data and bias-corrected CNRM-CM5 (RCP 4.5) model output centered at 2055, replotted on logit scale

5.0 Results

5.1 Water Budget Summary and Average Monthly Output

The simulated water budgets for historic and future conditions for the Cape Fear PRMS model for the three climate scenarios are summarized in Table 4 and shown in Figure 12. The simulations suggest that the proportions of the components of the overall water budget will not change dramatically between the historic and future (ca. 2055) conditions due to predictions of increased precipitation being balanced by increased evapotranspiration (Figure 17 to Figure 19).

The simulated water budgets for historic and future conditions for the Neuse PRMS model for the three climate scenarios are summarized in Table 5 and shown in Figure 16. The simulation results for the Neuse are similar to the Cape Fear. The proportions of the components of the overall water balance for the future and historic conditions do not show significant difference. Higher evapotranspiration is simulated for the spring and summer months while runoff is higher for the winter months for future compared to the historic time-period (Figure 17 to Figure 19).

Table 4. Simulated water budgets for Cape Fear PRMS model for the historic and future (ca. 2055) conditions for the selected climate scenarios

Constituent	Average Annual Values (inches/year)					
	CNRM-CM5, RCP 4.5		GFDL-ESM2M, RCP 8.5		MIROC-ESM-CHEM, RCP 8.5	
	Historic	Future	Historic	Future	Historic	Future
Precipitation	45.4	50.0	45.4	49.8	45.6	46.9
Evapotranspiration	30.9	33.5	30.6	33.8	31.2	34.0
Runoff	7.0	8.0	7.1	7.8	7.0	6.9
Interflow	2.0	2.5	2.0	2.6	1.9	1.6
Groundwater Outflow	5.6	5.8	5.7	5.8	5.5	4.5




Figure 12. Simulated water budgets for Cape Fear PRMS model for the historic (1951-2005) and future (2041-2070) conditions for the selected climate scenarios




Figure 13. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for CNRM-CM5, RCP 4.5, for historic (1951-2005; left) and future (2041-2070; right) conditions




Figure 14. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for GFDL-ESM2M RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions




Figure 15. Average monthly simulated evapotranspiration and total runoff for the Cape Fear PRMS model for MIROC-ESM-CHEM RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions

Table 5. Simulated water budgets for Neuse PRMS model for the historic and future (ca. 2055) conditions for the selected climate scenarios

Constituent	Average Annual Values (inches/year)					
	CNRM-CM5, RCP 4.5		GFDL-ESM2M, RCP 8.5		MIROC-ESM-CHEM, RCP 8.5	
	Historic	Future	Historic	Future	Historic	Future
Precipitation	42.8	47.5	42.9	46.5	43.1	43.7
Evapotranspiration	30.0	32.6	29.9	32.5	30.2	32.3
Runoff	6.8	8.1	6.8	7.6	6.9	6.3
Interflow	1.7	2.2	1.7	2.1	1.6	1.5
Groundwater Outflow	4.3	4.6	4.4	4.5	4.3	3.6




Figure 16. Simulated water budgets for Neuse PRMS model for the historic (1951-2005) and future (2041-2070) conditions for the selected climate scenarios




Figure 17. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for CNRM-CM5 RCP 4.5, for historic (1951-2005; left) and future (2041-2070; right) conditions




Figure 18. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for GFDL-ESM2M RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions




Figure 19. Average monthly simulated evapotranspiration and total runoff for the Neuse PRMS model for MIROC-ESM-CHEM RCP 8.5, for historic (1951-2005; left) and future (2041-2070; right) conditions

5.2 Lake Evaporation Timeseries

The OASIS model estimates lake evaporation rates by applying pan coefficients to continuous measurements of pan evaporation recorded by the Orange Water and Sewer Authority (OWASA) in Carrboro, NC. For application to future climate, lake evaporation could be estimated in OASIS directly from the PET estimates from the Jensen-Haise method used by the PRMS model; however, there is no guarantee that the resulting estimates would be fully consistent with the approach currently used in OASIS. In addition, the PRMS estimates of PET differ across the watersheds. Therefore, an alternative approach to adjust lake evaporation for future climate was adopted.

Adjusted lake evaporation timeseries were calculated using a bias correction method similar to that described for future runoff timeseries in Section 4.4. Specifically, the eQM method was applied to map the relative changes from historic to future conditions in the Jensen-Haise PET estimates at each lake onto the cumulative distribution function of the historic estimate of lake evaporation rates. As with the runoff timeseries, the eQM quantile mapping approach adjusts for systematic differences that are present between observed pan evaporation and Jensen-Haise PET. The revised lake evaporation timeseries were then converted to the net evaporation timeseries (the difference between evaporation and precipitation on the lake surface) used by OASIS, preserving the temporal match between evaporation and precipitation.

5.3 Database

The historic and future, bias-corrected daily simulated runoff and evapotranspiration time-series for each of the HRUs in the Cape Fear and Neuse NHM PRMS models are provided for use in the respective OASIS models to evaluate the impacts on future water supply. The climate-adjusted estimates of lake

evaporation rates along with net evaporation adjusted for precipitation (Section 5.2) are also included in separate files.

The OASIS model requires time-series data in the U.S. Army Corps of Engineers Data Storage System- (DSS) format. A Python script was developed that uses the “pyhecdss” module (<https://github.com/CADWRDeltaModeling/pyhecdss>) to write the PRMS time-series outputs to the HEC-DSS format. DSS files are provided for each climate scenario and model combination (total of 6) for the historic (1/1/1951 to 12/31/2005) and future (1/1/2041 to 12/31/2070) time-periods.

(This page left intentionally blank.)

6.0 References

- Abatzoglou, J.T. and Brown, T.J. 2012. A Comparison of statistical downscaling methods suited for wildfire applications. *International Journal of Climatology*, 32(5):.772-780.
- Alder, J.R., and Hostettler, S.W.. 2013. USGS National Climate Change Viewer. U.S. Geological Survey. https://www2.usgs.gov/climate_landuse/clu_rd/nccv.asp.
- Amengual, A., V. Homar, R. Romero, S. Alonso, and C. Ramis. 2012. A statistical adjustment of regional climate model outputs to local scales: Application to Platja de Palma, Spain. *Journal of Climate*, 25:939-957. (<https://digital.csic.es/bitstream/10261/88255/1/Amengual-Journal-Climate-2012-v25-n3-p939.pdf>)
- Moriasi, D.N., Arnold, J.G., Van Liew, M.W., Bingner, R.L., Harmel, R.D. and Veith, T.L. 2007. Model evaluation guidelines for systematic quantification of accuracy in watershed simulations. *Transactions of the ASABE*, 50(3): 885-900.
- Mote, P., Brekke, L., Duffy, P.B., Maurer, E.. 2011. Guidelines for Constructing Climate Scenarios. EOS, *Transactions of the American Geophysical Union*, 92(31): 257-258.
- NCDENR. 2009. Cape Fear River Basin Water Supply Plan. North Carolina Department of Natural Resources, Division of Water Resources, March 2009. Available at, https://files.nc.gov/ncdeq/Water%20Resources/Planning_Section/Basin_Planning/Cape_Fear/Cape-Fear-Water-Resources-Plan-Draft-4-30-09.pdf.
- Regan, R.S., Markstrom, S.L., Hay, L.E., Viger, R.J., Norton, P.A., Driscoll, J.M., and LaFontaine, J.H. 2018. Description of the National Hydrologic Model for use with the Precipitation-Runoff Modeling System (PRMS): U.S. Geological Survey Techniques and Methods, book 6, chap B9, 38 p. Available at, <https://doi.org/10.3133/tm6B9>.
- Rupp, D.E. 2016, An Evaluation of 20th Century Climate for the Southeastern United States as Simulated by Coupled Model Intercomparison Project Phase 5 (CMIP5) Global Climate Models: U.S. Geological Survey Open-File Report 2016–1047. <http://dx.doi.org/10.3133/ofr20161047>.
- Sanford, W.E. and Selnick, D.L. 2013. Estimation of evapotranspiration across the conterminous United States using a regression with climate and land-cover data. *JAWRA, Journal of the American Water Resources Association*, 49(1): 217-230.
- USGCRP. 2018. Impacts, Risks, and Adaptations in the United States: Fourth National Climate Assessment, Volume II [Reidmiller, D.R., C.W. Avery, D.R. Easterling, K.E. Kunkel, K.L.M. Lewis, T.K. Maycock, and B.C. Stewart (eds.)]. U.S. Global Change Research Program, Washington, DC. doi: 10.7930/NCA4.2018.

Acknowledgments

Many thanks to Parker Norton, Steven Markstrom, R. Steve Regan, Roland Viger, and Jacob LaFontaine for providing a geographic subset of the National Hydrology Model and PRMS parameter database for our region of interest. We also thank Philip Morefield of U.S. EPA Office of Research and Development for providing the Python code for the LASSO tool. We acknowledge the World Climate Research Programme's Working Group on Coupled Modeling, which is responsible for CMIP5, and we thank these modeling groups for producing and making available their model output. For CMIP5, the U.S. Department of Energy's Program for Climate Model Diagnosis and Intercomparison provides coordinating support and led development of software infrastructure in partnership with the Global Organization for Earth System Science Portals. The dataset MACAv2-METDATA was produced with funding from the Regional Approaches to Climate Change (REACCH) project and the South East Climate Science Center (SECSC).



ATTACHMENT B

Summary of Withdrawals and Discharges in Cape Fear-Neuse River Combined River Basin Model

General Note: Table values are annual averages and vary seasonally. WTP Process Water (PW) is not included in the withdrawal value when the PW discharge location is sufficiently close to the withdrawal location.

A – Values in millions of gallons per day (mgd) and include purchases from other utilities; excludes sales to other utilities with an OASIS node

B - Values in mgd and include wastewater discharges to other utilities; excludes wastewater discharges from other utilities

OASIS Node	Name of Water Utility (or Company)	PWSID(s)	Ownership	2025 Conditions		2055 Conditions	
				Withdrawals and Purchases ^A	Discharges ^B	Withdrawals and Purchases ^A	Discharges ^B
0031	Reidsville	02-79-020	Municipal	3.93	2.29	4.37	2.45
0075	Haw River	02-01-020	Municipal	0.19	0.16	0.27	0.22
0123	Greensboro	02-41-010	Municipal	35.84	35.67	46.58	46.21
0223	High Point	02-41-020	Municipal	11.22	11.99	13.18	14.08
0261	City of Randleman	02-76-015	Municipal	0.84	0.84	0.94	0.94
0301	Ramseur	02-76-020	Municipal	0.62	0.21	0.82	0.28
0321	Graham & Mebane	02-01-015 & 02-01-018	Municipal	4.18	3.19	7.10	5.42
0327	Siler City	03-19-010	Municipal	2.03	1.84	2.67	2.42
0341	Burlington	02-01-010	Municipal	12.92	11.12	16.13	13.88
0401	Pittsboro	03-19-015	Municipal	1.41	0.81	4.65	3.2
0431	OWASA	03-68-010	Authority	7.17	6.8	10.62	10.07
0471	Cary-Apex (includes RTP and Morrisville)	03-92-020 & 03-92-045	Municipal	24.52	22.39	38.24	34.91
0473	Chatham Co. North System	03-19-126	County	2.84	0.39	3.35	0.46
0476	Chatham Co. Asbury System	40-19-010	Municipal	1.04	0	2.05	0
0483	Performance Fibers / Allied Signal Demand	NA	Industrial	0.20	0.2	0.20	0.2
0491	Sanford	05-53-010	Municipal	6.31	5.51	9.15	5.62
0521	Progress Harris	NA	Industrial	20.00	0	20.00	0
0551	Harnett County	03-43-045	County	16.24	9.28	21.56	12.32
0601	Pilgrims Pride	NA	Industrial	0.97	0.06	0.97	0.06
0605	Goldston-Gulf	03-19-025	District	0.08	0.02	0.07	0.02
0654	Angier	03-43-015	Municipal	0.58	0.51	1.31	1.15
0663	Dunn	03-43-010	Municipal	3.55	2.44	3.48	2.39
0674	Carolina Trace	03-53-101	Industry	0.20	0.2	0.22	0.22
0701	Carthage	03-63-025	Municipal	0.37	0	0.55	0
0719	Spring Lake	03-26-020	Municipal	0.90	0.9	0.91	0.91
0721	Old North Utility Services, Inc.	50-26-019	Business	3.49	3.58	4.13	4.23
0733	Fayetteville	03-26-010	Municipal	26.65	26.54	55.27	55.04
0735	Hoke County	03-47-025	Municipal	0.91	0.88	1.11	1.08
0781	Dupont	NA	Industrial	11.17	11.91	11.17	11.91
0785	LCFWSA Bladen Bluff	50-09-012	Authority	4.04	0	4.04	0
0823	Cape Fear PUA-Wilmington	04-65-010	Authority	15.22	0	24.48	0

OASIS Node	Name of Water Utility (or Company)	PWSID(s)	Ownership	2025 Conditions		2055 Conditions	
				Withdrawals and Purchases ^A	Discharges ^B	Withdrawals and Purchases ^A	Discharges ^B
0825	LCFWSA Kings Bluff	50-09-013	Authority	21.69	0	40.86	0
0903	Jamestown	02-41-030	Municipal	0.57	0	0.87	0
0904	Archdale	02-76-030	Municipal	0.86	0.83	0.98	0.94
0923	Holly Springs	03-92-050	Municipal	3.68	3.58	9.50	9.25
0940	Broadway	03-53-015	Municipal	0.10	0.06	0.14	0.09
1046	Orange-Alamance	03-68-020	Non-Profit	0.62	0.06	0.70	0.07
1106	Hillsborough	03-68-015	Municipal	1.42	0.91	1.89	1.21
1162	Durham	03-32-010	Municipal	32.93	27.03	38.17	31.33
1256	SGWASA	02-39-107	Authority	1.79	1.1	1.84	1.14
1306	Raleigh	03-92-010	Municipal	59.75	52.4	92.40	81.03
1506	Wilson	04-98-010	Municipal	6.69	5.72	6.59	5.63
1646	Johnston County	03-51-070	County	17.08	8.98	41.59	21.88
1666	Smithfield	03-51-010	Municipal	1.62	1.22	1.69	1.27
1706	Fuquay-Varina	03-92-055	Municipal	3.58	3.27	8.37	7.66
1756	Benson	03-51-025	Municipal	0.86	0.3	1.03	0.36
1766	Progress Lee Steam Plant	NA	Industrial	8.91	0	8.91	0
1786	Goldsboro	04-96-010	Municipal	7.05	9.81	8.82	12.27
1806	Neuse Regional WASA	60-54-001	Authority	8.25	7.07	8.39	7.19
1906	Weyerhaeuser	NA	Industrial	14.47	14.09	14.47	14.09



ATTACHMENT C

**Fayetteville Public Works Commission Water Shortage Response Trigger
Flow Mapping**

Effective July 12, 2023, the Fayetteville PWC adopted changes to their WSRP including the addition of water shortage triggers based off the elevation at their Cape Fear River water supply intake. The CFNCRB model used for hydrological analysis in this EIS is a water accounting model and does not quantify water elevations at specific stream sites. Therefore, to include PWC's updated WSRP triggers in the CFNCRB model analysis, each elevation trigger was mapped to a flow value. No USGS data at the Cape Fear River at Fayetteville gauge exists for gauge heights as low as the proposed PWC WSRP triggers.

To estimate what flows may be observed in the Cape Fear River at Fayetteville for the PWC triggers levels, a relationship was developed based on existing USGS data and HEC-RAS river bathymetry information. Based on comparisons to existing USGS data, the HEC-RAS model overpredicted streamflow at the gauge for low stream flows, so these results could not be used directly. Instead, the shape of HEC-RAS relationship between stage and discharge was mapped onto the USGS data used to develop an equation to project flows between the lowest USGS records and a gauge height of 0 feet.

Table C.1: Fayetteville PWC WSRP Triggers as Flows

PWC Drought Stage	PWC Trigger - River Stage at Fayetteville (feet)	Projected River Flow for Trigger Height (cfs)
1	9.45	527
2	8.9	319
3	8.4	202
4	7.66	103



ATTACHMENT D

Cape Fear-Neuse River Combined River Basin Model OCL Code

_SafeYield_Constants.ocl

```
1 /* '_SafeYield_Constants.ocl'
2   This file is automatically generated by the OASIS GUI.
3   Any changes you make to this file will be overwritten by the program. */
4
5 :substitute: [SafeYield_IterNum] = 06 /* Iteration number in the safe-yield procedure */
6
```

Agric_Allocation.ocl

```
1 /* File is Agric_Allocation.ocl. */
2
3 /* This file allocates the agricultural demands by the assumed distribution of
4 demand within each county */
5
6 /* The county demand is represented by "dem__" that varies by number. These
7 numbers are established in the agricultural input dialog box, with 01 set for Alamance, 02 for
8 Bladen, and so on. */
9
10 // For counties in the the Cape Fear Basin
11
12 /* Note that for Alamance, Chatham, Cumberland, Randolph, and Moore, M&N changed the
13 distribution to reflect demand patterns since 1998 */
14
15 Set Demand_Alamance_35Pct : demand0371 { value : dem01 * 0.35 }
16 Set Demand_Alamance_30Pct : demand0361 { value : dem01 * 0.30 }
17 Set Demand_Alamance_35Pct : demand0081 { value : demand0371 }
18
19 Set Demand_Bladen_60Pct : demand0811 { value : dem02 * 0.60 }
20 Set Demand_Bladen_20Pct : demand0801 { value : dem02 * 0.20 }
21 Set Demand_Bladen_20Pct : demand0821 { value : dem02 * 0.20 }
22
23 Set Demand_Caswell_100% : demand0083 { value : dem03 * 1.0 }
24
25 Set Demand_Chatham_10Pct : demand0403 { value : dem04 * 0.10 }
26 Set Demand_Chatham_85Pct : demand0621 { value : dem04 * 0.85 }
27 Set Demand_Chatham_5Pct : demand0481 { value : dem04 * 0.05 }
28
29 Set Demand_Cumberland_50Pct : demand0741 { value : dem05 * 0.50 }
30 Set Demand_Cumberland_10Pct : demand0775 { value : dem05 * 0.10 }
31 Set Demand_Cumberland_40Pct : demand0783 { value : dem05 * 0.40 }
32
33 Set Demand_Durham_3Pct : demand0461 { value : dem06 * 0.03 }
34
35 Set Demand_Forsyth_50Pct : demand0111 { value : dem07 }
36 Set Demand_Forsyth_50Pct : demand0211 { value : demand0111 }
37
38 Set Demand_Guilford_20Pct : demand0051 { value : dem08 * 0.20 }
39 Set Demand_Guilford_15Pct : demand0331 { value : dem08 * 0.15 }
40 Set Demand_Guilford_40Pct : demand0161 { value : dem08 * 0.40 }
41 Set Demand_Guilford_13Pct : demand0043 { value : dem08 * 0.13 }
42 Set Demand_Guilford_12Pct : demand0231 { value : dem08 * 0.12 }
43
44
45 Set Demand_Harnett_15Pct : demand0691 { value : dem09 * 0.15 }
46 Set Demand_Harnett_35Pct : demand0553 { value : dem09 * 0.35 }
47 Set Demand_Harnett_50Pct : demand0681 { value : dem09 * 0.50 }
```

Agric_Allocation.ocl

```
48
49 Set Demand_Hoke_100% : demand0773 { value : dem10 * 1.0 }
50
51 Set Demand_Lee_7Pct : demand0623 { value : dem11 * 0.07 }
52 Set Demand_Lee_55Pct : demand0671 { value : dem11 * 0.55 }
53 Set Demand_Lee_38Pct : demand0511 { value : dem11 * 0.38 }
54
55 Set Demand_Montgomery_100% : demand0593 { value : dem12 * 1.0 }
56
57 Set Demand_Moore_40Pct : demand0603 { value : dem13 * 0.40 }
58 Set Demand_Moore_30Pct : demand0713 { value : dem13 * 0.30 }
59 Set Demand_Moore_30Pct : demand0595 { value : dem13 * 0.30 }
60
61 // Orange Co. - for CF as a percentage of the acreage (48%) in the basin
62 Set Demand_Orange_36Pct : demand0441 { value : dem14 * 0.36 * 0.48 }
63 Set Demand_Orange_24Pct : demand0381 { value : dem14 * 0.24 * 0.48 }
64 Set Demand_Orange_40Pct : demand0311 { value : dem14 * 0.40 * 0.48 }
65
66 Set Demand_Randolph_50Pct : demand0581 { value : dem15 * 0.50 }
67 Set Demand_Randolph_30Pct : demand0281 { value : dem15 * 0.30 }
68 Set Demand_Randolph_20Pct : demand0263 { value : dem15 * 0.20 }
69
70 Set Demand_Rockingham_40Pct : demand0021 { value : dem16 * 0.40 }
71 Set Demand_Rockingham_60Pct : demand0041 { value : dem16 * 0.60 }
72
73 // Wake Co. - for CF as a percentage of the acreage (13%) in the basin
74 Set Demand_Wake_5Pct : demand0541 { value : dem17 * 0.05 * 0.13 }
75 Set Demand_Wake_75Pct : demand0411 { value : dem17 * 0.75 * 0.13 }
76 Set Demand_Wake_20Pct : demand0531 { value : dem17 * 0.20 * 0.13 }
77
78
79
80 // For counties in the the Neuse Basin
81
82 Set Demand_Or_Pond_Ag : demand1062 { value: dem14 * 0.095 }
83 Set Demand_WFER_Ag : demand1052 { value: dem14 * 0.095 }
84 Set Demand_EnoDurha_Ag : demand1112 { value: dem14 * 0.16 + dem06 * 0.137 }
85 Set Demand_Michie_Ag : demand1142 { value: dem06 * 0.078 + dem25 * 0.31 }
86 Set Demand_LitRes_Ag : demand1202 { value: dem14 * 0.03 + dem06 * 0.097 + dem14 * 0.14 }
87 Set Demand_Falls_Ag : demand1302 { value: dem06 * 0.076 + dem20 * 0.02 + dem06 * 0.488 + dem25 * 0.01 + dem20 * 0.07
88           + dem06 * 0.094 + dem17 * 0.05 + dem19 * 0.02 + dem20 * 0.15 }
89 Set Demand_Clayt_Ag : demand1632 { value: dem22 * 0.04 + dem17 * 0.20 + dem19 * 0.01 + dem17 * 0.035 }
90 Set Demand_Middl_Ag : demand1482 { value: dem22 * 0.01 + dem17 * 0.158 }
91 Set Demand_Litpr_Ag : demand1752 { value: dem28 * 0.02 + dem22 * 0.18 + dem17 * 0.158 + dem19 * 0.03 }
92 Set Demand_Golds_Ag : demand1782 { value: dem22 * 0.10 + dem17 * 0.053 + dem22 * 0.08 + dem27 * 0.42 + dem22 * 0.39
93           + dem22 * 0.13 }
94 Set Demand_Kinst_Ag : demand1802 { value: dem23 * 0.35 + dem21 * 0.05 }
```

Agric_Allocation.ocl

```
95 Set Demand_Buckhorn_Ag : demand1502 { value: dem28 * 0.05 + dem22 * 0.04 + dem24 * 0.13 + dem17 * 0.035 + dem19 * 0.05 }
96 Set Demand_Hooke_Ag : demand1562 { value: dem27 * 0.23 + dem21 * 0.57 + dem28 * 0.70 + dem24 * 0.07 + dem22 * 0.01 }
97 Set Demand_Weyer_Ag : demand1902 { value: dem18 * 0.04 + dem23 * 0.39 + dem23 * 0.09 + dem21 * 0.39 + dem26 * 0.17
98     + dem28 * 0.04 + dem26 * 0.23 }
99
100 /* Adjust Little River Ag Demands to distribute them across the proposed Reservoir's sub-basin*/
101 Set Demand_LitR_sub_Ag : demand1738 { value: demand1752 * 52.6/232 }
102 Set Demand_Litpr_Ag : demand1752 { value: demand1752 - demand1738 }
```

Agric_Calculation.ocl

```
1 /* File is Agric_Calculation.ocl. */
2
3 /* Note the precip data is contained in the basedata file and for simplicity uses Jordan Lake for the Cape Fear
4    and Falls Lake for the Neuse. */
5
6 // The first 17 counties are for the Cape Fear Basin. The next 11 are for the Neuse. Three counties are in both basins (Wake, Durham, and Orange).
7 // For the combined model, the more recent acreages (from the Neuse model) for these counties are used.
8
9 // First compute agricultural water demand for Cape Fear counties based on Jordan Lake precip. The counties are
10 // labeled in the Edit Agricultural Data dialog box in the GUI. Note - counties in both basins (Durham, Orange, Wake) use the CF precip.
11 :For:
12 { [cty] = {01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17}
13 }
14
15 RUN_MODULE: AgricDem
16 {
17   Input: { [cty],           // County number
18           timesers(CFear/precip), // Precip for Jordan Lake in inches
19
20           pattern(IrrCoef_Tobacco), // Water Use Coefficients for Tobacco, etc.
21           pattern(IrrCoef_Turf),
22           pattern(IrrCoef_Golf),
23           pattern(IrrCoef_ContNurs),
24           pattern(IrrCoef_FieldNurs),
25           pattern(IrrCoef_Cotton),
26           pattern(IrrCoef_EarlySoy),
27           pattern(IrrCoef_LateSoy),
28           pattern(IrrCoef_Corn),
29           pattern(IrrCoef_Veg),
30           pattern(IrrCoef_PastHay),
31           pattern(IrrCoef_Peanut),
32           pattern(IrrCoef_Blueberry),
33           pattern(IrrCoef_Strawberry),
34           pattern(IrrCoef_Fruit),
35           pattern(IrrCoef_Beef),
36           pattern(IrrCoef_Dairy),
37           pattern(IrrCoef_Horse),
38           pattern(IrrCoef_Pig),
39           pattern(IrrCoef_Chicken),
40           pattern(IrrCoef_Turkey),
41           pattern(IrrCoef_OtherAnimal)
42   }
43
44   Output: { dem[cty] }
45 }
46 :Next:
47
```

Agric_Calculation.ocl

```
48 /* Then compute agricultural demand for the Neuse counties based on Falls Lake precip.
49 Note - counties in both basins (Durham, Orange, Wake) use the CF precip.*/
50 :For:
51 { [cty] = {18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28}
52 }
53
54 RUN_MODULE: AgricDem
55 {
56   Input: { [cty],           // County number
57           timesers(Neuse/precip), // Precip for Falls Lake in inches
58
59           pattern(IrrCoef_Tobacco), // Water Use Coefficients for Tobacco, etc.
60           pattern(IrrCoef_Turf),
61           pattern(IrrCoef_Golf),
62           pattern(IrrCoef_ContNurs),
63           pattern(IrrCoef_FieldNurs),
64           pattern(IrrCoef_Cotton),
65           pattern(IrrCoef_EarlySoy),
66           pattern(IrrCoef_LateSoy),
67           pattern(IrrCoef_Corn),
68           pattern(IrrCoef_Veg),
69           pattern(IrrCoef_PastHay),
70           pattern(IrrCoef_Peanut),
71           pattern(IrrCoef_Blueberry),
72           pattern(IrrCoef_Strawberry),
73           pattern(IrrCoef_Fruit),
74           pattern(IrrCoef_Beef),
75           pattern(IrrCoef_Dairy),
76           pattern(IrrCoef_Horse),
77           pattern(IrrCoef_Pig),
78           pattern(IrrCoef_Chicken),
79           pattern(IrrCoef_Turkey),
80           pattern(IrrCoef_OtherAnimal)
81   }
82
83   Output: { dem[cty] }
84 }
85 :Next:
86
87
88 /* The results are in mgd. Now convert these to acre feet for use in the
89 agric_allocation.ocl file */
90
91 // For the Cape Fear
92 Set : dem01 { value : convert_units {dem01, mgd, af } }
93 Set : dem02 { value : convert_units {dem02, mgd, af } }
94 Set : dem03 { value : convert_units {dem03, mgd, af } }
```

Agric_Calculation.ocl

```
95 Set : dem04 { value : convert_units {dem04, mgd, af } }
96 Set : dem05 { value : convert_units {dem05, mgd, af } }
97 Set : dem06 { value : convert_units {dem06, mgd, af } }
98 Set : dem07 { value : convert_units {dem07, mgd, af } }
99 Set : dem08 { value : convert_units {dem08, mgd, af } }
100 Set : dem09 { value : convert_units {dem09, mgd, af } }
101 Set : dem10 { value : convert_units {dem10, mgd, af } }
102 Set : dem11 { value : convert_units {dem11, mgd, af } }
103 Set : dem12 { value : convert_units {dem12, mgd, af } }
104 Set : dem13 { value : convert_units {dem13, mgd, af } }
105 Set : dem14 { value : convert_units {dem14, mgd, af } }
106 Set : dem15 { value : convert_units {dem15, mgd, af } }
107 Set : dem16 { value : convert_units {dem16, mgd, af } }
108 Set : dem17 { value : convert_units {dem17, mgd, af } }
109
110 // For the Neuse
111 Set : dem18 { value : convert_units {dem18, mgd, af } }
112 Set : dem19 { value : convert_units {dem19, mgd, af } }
113 Set : dem20 { value : convert_units {dem20, mgd, af } }
114 Set : dem21 { value : convert_units {dem21, mgd, af } }
115 Set : dem22 { value : convert_units {dem22, mgd, af } }
116 Set : dem23 { value : convert_units {dem23, mgd, af } }
117 Set : dem24 { value : convert_units {dem24, mgd, af } }
118 Set : dem25 { value : convert_units {dem25, mgd, af } }
119 Set : dem26 { value : convert_units {dem26, mgd, af } }
120 Set : dem27 { value : convert_units {dem27, mgd, af } }
121 Set : dem28 { value : convert_units {dem28, mgd, af } }
```

Benson_ops.ocl

```
1 /* BENSON_OPS.OCL */
2
3 /* Operational policy for Bensons's system */
4
5 // Set targets to dictate deliveries from Dunn and Johnston Cos.
6 Target Dunn_Del : dflow0662.1756
7 { condition : default
8   priority : 1
9   penalty+ : 75
10  penalty- : 75
11  Value   : 0.96 * min{_Benson_Consvn_1_Demand, _Benson_Consvn_2_Demand,
12    _Benson_Consvn_3_Demand, _Benson_Consvn_4_Demand,
13    _Benson_Consvn_5_Demand, _Benson_Consvn_6_Demand,
14    demand1756} // 96% from Dunn, the rest will be from Johnston Co. (arc 1656.1756)
15 }
16
17 Target JC_Del : dflow1656.1756
18 { condition : default
19   priority : 1
20   penalty+ : 75
21   penalty- : 75
22  Value   : 0.04 * min{_Benson_Consvn_1_Demand, _Benson_Consvn_2_Demand,
23    _Benson_Consvn_3_Demand, _Benson_Consvn_4_Demand,
24    _Benson_Consvn_5_Demand, _Benson_Consvn_6_Demand,
25    demand1756} // 4% from Johnston Co. (arc 1656.1756)
26 }
```

buckhorn_Wilson_ops.ocl

```
1 /* BUCKHORN_Wilson_OPS.OCL */
2
3 /* Minimum release policy for Wilson's Buckhorn Lake - based on storage remaining.
4 Modified by R. Palmer - minimum release needs to be made below the
5 City of Wilson withdrawal point - Wiggon's Mill Lake, not Buckhorn Dam - will add the arc downstream accordingly*/
6
7 Set : min_flow1520.1560
8 { condition : storage1500 / max_stor1500 < 0.5
9   Value    : convert_units { 1.4 , cfs , af }
10
11   condition : storage1500 / max_stor1500 < 0.7
12   Value    : convert_units { 5.3 , cfs , af }
13
14   condition : default
15   Value    : convert_units { 7.6 , cfs , af }
16 }
```

constants.ocl

```
1  /* 'constants.ocl'
2   This file is automatically generated by the OASIS GUI.
3   Any changes you make to this file will be overwritten by the program.
4   To edit the Constants table, do not edit this file. Instead, go to
5   the 'OCL' tab of the GUI and edit the 'OCL Constants' table. */
6
7  :substitute: [ClaytonTarget_Override] = 0          /* 0 = Normal Clayton target; 1 = Override target when Falls WQ < threshold */
8  :substitute: [ClaytonTarget_SafeFact] = 0          /* Pct. safety factor for Clayton minimum target */
9  :substitute:   [Demand_FV_Neuse] = 0.62           /* Fraction of Fuquay Varina Demand in the Neuse River Basin */
10 :substitute:   [Demand_Multiplier] = 1             /* Multiplication factor used to adjust all demands in the system */
11 :substitute:   [Drought_Plans_On] = 1              /* 1 = Use drought plans, 0 = do not use drought plans */
12 :substitute:   [FLakeMin_SafeFact] = 0             /* Pct. safety factor for Falls minimum releases */
13 :substitute:   [FV_Harnett_Supply] = 2             /* Supply contract from Harnett County to Fuquay Varina */
14 :substitute:   [FV_Johnston_Supply] = 0            /* Supply contract from Johnston County to Fuquay Varina */
15 :substitute:   [FV_Ral_Supply] = 0                 /* Supply contract from Raleigh to Fuquay Varina */
16 :substitute:   [FV_Sanford_Supply] = 0             /* Supply contract from Sanford to Fuquay Varina */
17 :substitute:   [Use_Demand_Multiplier] = 0         /* Flag tells whether to adjust all demands in the system with a mult. factor */
```

constants_removed.ocl

```
1 /* this file was created to contain constants removed from constants table to simplify run
2 evaluated in beginning of main.ocl so all files can reference values as needed */
3
4 //Raleigh constants
5 :SUBSTITUTE: [Total_Max_WQ_Storage] = 44022 /*Raleigh total max water quality storage, af */
6 :SUBSTITUTE: [Total_Max_WS_Storage] = 62300 /* Raleigh total max water supply storage, af*/
7 :SUBSTITUTE: [NR_DS_intake] = 0 /*Neuse River raleigh intake benton mgd*/
8 :SUBSTITUTE: [DE_Benton_WTP_Capacity] = 40 /*DE Benton WTP Capacity, mgd*/
9 // Falls Lake
10 :SUBSTITUTE: [Falls_upper_rule] = 251.5 /*Falls Lake upper rule, ft */
11 :SUBSTITUTE: [Falls_lower_rule] = 236.5 /*Falls Lake lower rule, ft*/
12 :SUBSTITUTE: [FLake_WQ_Threshold] = 20 /*Falls Lake water quality threshold, % */
13 :SUBSTITUTE: [FLake_WQ_Stor] = 42110 /*Falls Lake water quality storage, af */
14 :SUBSTITUTE: [FLake_WS_Stor] = 59595 /*Falls Lake Water Supply Storage, af */
15 // Beaverdam Lake
16 :SUBSTITUTE: [Bdam_WQ_Stor] = 1912 /*Beaverdam water quality storage, af */
17 :SUBSTITUTE: [Bdam_WS_Stor] = 2705 /* Beaverdam water supply storage, af*/
18 :SUBSTITUTE: [Bdam_WQ_WS_Stor] = 4617 /*Beaverdam total water quality and water supply storage, af */
19
20 //Jordan Lake constantss
21 :SUBSTITUTE: [Max_WQ_Storage] = 94600 /* Jordan max water quality storage, af */
22 :SUBSTITUTE: [Lillington_Target_Normal] = 600 /* cape Fear Lillington Gage Target, cfs*/
23 :SUBSTITUTE: [Max_WS_Storage] = 45800 /* Jordan max ater supply storage, af */
24 :SUBSTITUTE: [Max_WQ_WS_Storage] = 140400 /* Jordan lake max total storage, af*/
25 // allocation fractions
26 :SUBSTITUTE: [WS_CaryAp_Fraction] = 0.392 /* Available water supply storage for Cary Apex (as a fraction of the total pool) */
27 :SUBSTITUTE: [WS_Chatham_Fraction] = 0.13 /* Available water supply storage for Chatham Co. (as a fraction of the total pool) */
28 :SUBSTITUTE: [WS_Durham_Fraction] = 0.165 /* Available water supply storage for Durham (as a fraction of the total pool) */
29 :SUBSTITUTE: [WS_Holly_Fraction] = 0.02 /* Available water supply storage for Holly Springs (as a fraction of the total pool) */
30 :SUBSTITUTE: [WS_Morris_Fraction] = 0.035 /* Available water supply storage for Morrisville(as a fraction of the total pool) */
31 :SUBSTITUTE: [WS_Orange_Fraction] = 0.015 /* Available water supply storage for Orange Co. (as a fraction of the total pool) */
32 :SUBSTITUTE: [WS_Other_Fraction] = 0.088 /* Available water supply storage for unallocated (as a fraction of the total pool) */
33 :SUBSTITUTE: [WS_OWASA_Fraction] = 0.05 /* Available water supply storage for OWASA (as a fraction of the total pool) */
34 :SUBSTITUTE: [WS_RTP_Fraction] = 0.035 /* Available water supply storage for RTP (as a fraction of the total pool) */
35 :SUBSTITUTE: [WS_Pitt_Fraction] = 0.06 /* Available water supply storage for Pittsboro (as a fraction of the total pool) */
36 :SUBSTITUTE: [WS_Hillsb_Fraction] = 0.01 /* Available water supply storage for Hillsborough (as a fraction of the total pool) */
37
38 //Durham constants
39 :SUBSTITUTE: [TQ_Max_LM_Refill_Rate] = 20 /* Teer Quarry max Lake Michie refill, mgd*/
40 :SUBSTITUTE: [Max_Quarry_refill_rate] = 0 /* Maximum Raleigh quarry refill rate, mgd*/
41
42
```

Crabtree_ops.ocl

```
1 /* CRABTREE.OCL */
2
3 /* Set the Crabtree Creek inflows and net evap for the individual flood control impoundments
4  Instead of having 11 inflow and evap records in the basedata file, base all of them
5  the inflow1400/evap1400 from the main basedata.dss */
6
7
8 /* Variables for the incremental DA into each reservoir */
9 :Substitute: [1400] = 2.1
10 :Substitute: [1402] = 1.4
11 :Substitute: [1404] = 2.3
12 :Substitute: [1406] = 8.9
13 :Substitute: [1408] = 5.2
14 :Substitute: [1410] = 8.2
15 :Substitute: [1412] = 2.5
16 :Substitute: [1414] = 11.5
17 :Substitute: [1416] = 3.7
18 :Substitute: [1418] = 23.1
19 :Substitute: [1422] = 24.8
20 :Substitute: [CrabtreeTotal] = 93.7
21
22 /* Filter the total inflow (in case there are any negative provisional inflows) */
23 Set : _TempInfCrabtree { Value : timesers(1400/inflow) }
24 Set : _TotInfCrabtree { Value : max{0, _TempInfCrabtree - _InfDeficitCrabtree(-1) } }
25 Set : _InfDeficitCrabtree { Value : max{0, _InfDeficitCrabtree(-1) - _TempInfCrabtree } }
26
27 /* Set the inflows - proportion by drainage area the total inflow to Crabtree Creek */
28 Set : inflow1400 { value : _TotInfCrabtree / [CrabtreeTotal] * [1400] }
29 Set : inflow1402 { value : _TotInfCrabtree / [CrabtreeTotal] * [1402] }
30 Set : inflow1404 { value : _TotInfCrabtree / [CrabtreeTotal] * [1404] }
31 Set : inflow1406 { value : _TotInfCrabtree / [CrabtreeTotal] * [1406] }
32 Set : inflow1408 { value : _TotInfCrabtree / [CrabtreeTotal] * [1408] }
33 Set : inflow1410 { value : _TotInfCrabtree / [CrabtreeTotal] * [1410] }
34 Set : inflow1412 { value : _TotInfCrabtree / [CrabtreeTotal] * [1412] }
35 Set : inflow1414 { value : _TotInfCrabtree / [CrabtreeTotal] * [1414] }
36 Set : inflow1416 { value : _TotInfCrabtree / [CrabtreeTotal] * [1416] }
37 Set : inflow1418 { value : _TotInfCrabtree / [CrabtreeTotal] * [1418] }
38 Set : inflow1422 { value : _TotInfCrabtree / [CrabtreeTotal] * [1422] }
39
40 /* Set the evap for all nodes */
41 :For:
42 { [node] = { 1400, 1402, 1404, 1406, 1408, 1410, 1412, 1414, 1416, 1418, 1422 }
43 }
44 Set : evap[node] { value : stor_to_area { [node], storage[node] } * timesers(1400/evap) / 11 }
45
46 :Next:
47
```

Crabtree_ops.ocl

```
48 /* Set the spillway rating curves for the Crabtree Creek impoundments. Prevent releases from drawing pond below spill elevation */
49 Target 1400_release: dflow1400.1412
50 { Condition : default
51   priority : 1
52   penalty+ : 1000
53   penalty- : 1000
54   Value   : min {convert_units { Lookup{ 1400Outflow, elevation1400 }, cfs, af}, storage1400 - elev_to_stor {1400, 305} }
55 }
56
57 Target 1402_release: dflow1402.1412
58 { Condition : default
59   priority : 1
60   penalty+ : 1000
61   penalty- : 1000
62   Value   : min {convert_units { Lookup{ 1402Outflow, elevation1402 }, cfs, af}, storage1402 - elev_to_stor {1402, 326} }
63 }
64
65 Target 1404_release: dflow1404.1412
66 { Condition : default
67   priority : 1
68   penalty+ : 1000
69   penalty- : 1000
70   Value   : min {convert_units { Lookup{ 1404Outflow, elevation1404 }, cfs, af}, storage1404 - elev_to_stor {1404, 342.5} }
71 }
72
73 Target 1406_release: dflow1406.1412
74 { Condition : default
75   priority : 1
76   penalty+ : 1000
77   penalty- : 1000
78   Value   : min {convert_units { Lookup{ 1406Outflow, elevation1406 }, cfs, af}, storage1406 - elev_to_stor {1406, 306.5} }
79 }
80
81 Target 1408_release: dflow1408.1412
82 { Condition : default
83   priority : 1
84   penalty+ : 1000
85   penalty- : 1000
86   Value   : min {convert_units { Lookup{ 1408Outflow, elevation1408 }, cfs, af}, storage1408 - elev_to_stor {1408, 313} }
87 }
88
89 Target 1410_release: dflow1410.1412
90 { Condition : default
91   priority : 1
92   penalty+ : 1000
93   penalty- : 1000
94   Value   : min {convert_units { Lookup{ 1410Outflow, elevation1410 }, cfs, af}, storage1410 - elev_to_stor {1410, 306.5} }
```

Crabtree_ops.ocl

```
95 }
96
97 Target 1412_release: dflow1412.1416
98 { Condition : default
99   priority : 1
100   penalty+ : 1000
101   penalty- : 1000
102   Value    : min {convert_units { Lookup{ 1412Outflow, elevation1412 }, cfs, af}, storage1412 - elev_to_stor {1412, 276} }
103 }
104
105 Target 1414_release: dflow1414.1416
106 { Condition : default
107   priority : 1
108   penalty+ : 1000
109   penalty- : 1000
110   Value    : min {convert_units { Lookup{ 1414Outflow, elevation1414 }, cfs, af}, storage1414 - elev_to_stor {1414, 301} }
111 }
112
113 Target 1416_release: dflow1416.1424
114 { Condition : default
115   priority : 1
116   penalty+ : 1000
117   penalty- : 1000
118   Value    : min {convert_units { Lookup{ 1416Outflow, elevation1416 }, cfs, af}, storage1416 - elev_to_stor {1416, 230} }
119 }
120
121 Target 1418_release: dflow1418.1424
122 { Condition : default
123   priority : 1
124   penalty+ : 1000
125   penalty- : 1000
126   Value    : min {convert_units { Lookup{ 1418Outflow, elevation1418 }, cfs, af}, storage1418 - elev_to_stor {1418, 335} }
127 }
128
129 Target 1422_release: dflow1422.1424
130 { Condition : default
131   priority : 1
132   penalty+ : 1000
133   penalty- : 1000
134   Value    : min {convert_units { Lookup{ 1422Outflow, elevation1422 }, cfs, af}, storage1422 - elev_to_stor {1422, 252} }
135 }
```

drought_plan_durham.ocl

```
1 /* durham_drought_plan.ocl
2 Forecast-based triggers and demand reductions based on Durham's Water Shortage Response Plan */
3
4 :If: {[Drought_Plans_On] = 1} // First check if drought plan variable is on
5
6 /* Compute Durham's usable storage */
7
8 Set : _Durham_usable_stor { Value : (storage1140 - lower_rule1140) + (storage1200 - lower_rule1200) }
9
10 Set : _Max_Durham_usable_stor { Value : (upper_rule1140 - lower_rule1140) + (upper_rule1200 - lower_rule1200) }
11
12 Set : _Durham_usable_pct { Value : 100 * (_Durham_usable_stor / _Max_Durham_usable_stor) }
13
14
15 /* This section computes the projected demand, inflow, and net evap for each forecast horizon.
16 The forecast horizon # is the forecast used to help establish when level # (same number) restrictions are imposed.
17 The min flow requirement is small compared to the demand, so ignore; plus min flow is lowest when forecasts are likely to show
18 any triggering */
19
20
21 /* First Trigger Horizon */
22 Set : _Proj_1_Demand
23 { Condition : weekday{year, month, day} <= 1
24 Value : accumulate { demand1162, 0, +[Forecast_1_Horizon_Days] }
25
26 Condition : default
27 Value : _Proj_1_Demand(-1)
28 }
29
30 Set : _Proj_1_Evap
31 { condition : weekday{year, month, day} <= 1
32 value : stor_to_area { 1140 , storage1140 } * 7 * (timesers(1140/Evap_[ForcCode_1]) / 12 )
33 + stor_to_area { 1200 , storage1200 } * 7 * (timesers(1200/Evap_[ForcCode_1]) / 12 )
34
35 Condition : default
36 Value : _Proj_1_Evap(-1)
37 }
38
39 /* Since timestep is daily and forecasts in dss file are weekly, the forecast must be multiplied by 7 */
40
41 Set : _Proj_1_Inflow
42 { value : 7 * (timesers(1140/[ForcCode_1]) ) + 7 * (timesers(1200/[ForcCode_1]) )
43 }
44
45
46 /* Second Trigger Horizon */
47 Set : _Proj_2_Demand
```

drought_plan_durham.ocf

```
48 { Condition : weekday{year, month, day} <= 1
49   Value   : accumulate { demand1162, 0, +[Forecast_2_Horizon_Days] } * ( 1 - pattern(Stage_1_Dem_Red) )
50 // Note: demand reductions in each stage are cumulative!
51
52 Condition : default
53 Value   : _Proj_2_Demand(-1)
54 }
55
56
57 Set : _Proj_2_Evap
58 { condition : weekday{year, month, day} <= 1
59 value : stor_to_area { 1140 , storage1140 } * 7 * (timesers(1140/Evap_[ForcCode_2]) / 12 )
60 + stor_to_area { 1200 , storage1200 } * 7 * (timesers(1200/Evap_[ForcCode_2]) / 12 )
61
62 Condition : default
63 Value   : _Proj_2_Evap(-1)
64 }
65
66 Set : _Proj_2_Inflow
67 { value : 7 * (timesers(1140/[ForcCode_2]) ) + 7 * (timesers(1200/[ForcCode_2]) )
68 }
69
70 /* Third Trigger Horizon */
71 Set : _Proj_3_Demand
72 { Condition : weekday{year, month, day} <= 1
73   Value   : accumulate { demand1162, 0, +[Forecast_3_Horizon_Days] } * ( 1 - pattern(Stage_2_Dem_Red) )
74
75 Condition : default
76 Value   : _Proj_3_Demand(-1)
77 }
78
79
80 Set : _Proj_3_Evap
81 { condition : weekday{year, month, day} <= 1
82 value : stor_to_area { 1140 , storage1140 } * 7 * (timesers(1140/Evap_[ForcCode_3]) / 12 )
83 + stor_to_area { 1200 , storage1200 } * 7 * (timesers(1200/Evap_[ForcCode_3]) / 12 )
84
85 Condition : default
86 Value   : _Proj_3_Evap(-1)
87 }
88
89
90 Set : _Proj_3_Inflow
91 { value : 7 * (timesers(1140/[ForcCode_3]) ) + 7 * (timesers(1200/[ForcCode_3]) )
92 }
93
94
```

drought_plan_durham.ocl

```
95  /* Fourth Trigger Horizon */
96  Set : _Proj_4_Demand
97  { Condition : weekday{year, month, day} <= 1
98    Value   : accumulate { demand1162, 0, +[Forecast_4_Horizon_Days] } * ( 1 - pattern(Stage_3_Dem_Red) )
99
100    Condition : default
101    Value    : _Proj_4_Demand(-1)
102  }
103
104
105  Set : _Proj_4_Evap
106  { condition : weekday{year, month, day} <= 1
107    value : stor_to_area { 1140 , storage1140 } * 7 * (timesers(1140/Evap_[ForcCode_4]) / 12 )
108    + stor_to_area { 1200 , storage1200 } * 7 * (timesers(1200/Evap_[ForcCode_4]) / 12 )
109
110    Condition : default
111    Value    : _Proj_4_Evap(-1)
112  }
113
114
115  Set : _Proj_4_Inflow
116  { value : 7 * (timesers(1140/[ForcCode_4]) ) + 7 * (timesers(1200/[ForcCode_4]) )
117  }
118
119
120  // Use this for the refill calculation later on.
121  Set : _Proj_5_Inflow
122  { value : 7 * (timesers(1140/[ForcCode_5]) ) + 7 * (timesers(1200/[ForcCode_5]) )
123  }
124
125
126
127  /* This section computes the projected water supply storage based on the the demand, inflow, and net
128  evaporation for the forecast horizon. Note these udefs are volumetric */
129
130  Set : _Proj_1_WSPool
131  { Condition : weekday{year, month, day} <= 1
132    Value   : min{ _Durham_usable_stor(-1) + _Proj_1_Inflow -
133      _Proj_1_Evap - _Proj_1_Demand, _Max_Durham_usable_stor }
134
135    Condition : default
136    Value    : _Proj_1_WSPool(-1)
137  }
138
139  Set : _Proj_2_WSPool
140  { Condition : weekday{year, month, day} <= 1
141    Value   : min{ _Durham_usable_stor(-1) + _Proj_2_Inflow -
```

drought_plan_durham.ocl

```
142     _Proj_2_Evap - _Proj_2_Demand, _Max_Durham_usable_stor}
143
144 Condition : default
145 Value    : _Proj_2_WSPool(-1)
146 }
147
148
149 Set : _Proj_3_WSPool
150 { Condition : weekday{year, month, day} <= 1
151 Value    : min{_Durham_usable_stor(-1) + _Proj_3_Inflow -
152     _Proj_3_Evap - _Proj_3_Demand, _Max_Durham_usable_stor}
153
154 Condition : default
155 Value    : _Proj_3_WSPool(-1)
156 }
157
158
159 Set : _Proj_4_WSPool
160 { Condition : weekday{year, month, day} <= 1
161 Value    : min{_Durham_usable_stor(-1) + _Proj_4_Inflow -
162     _Proj_4_Evap - _Proj_4_Demand, _Max_Durham_usable_stor}
163
164 Condition : default
165 Value    : _Proj_4_WSPool(-1)
166 }
167
168 /* USE JUST ONE REFILL TRIGGER (PROJ_REFILL) AND ASSUME ALL RESTRICTIONS STAY ON UNTIL TRIGGER IS MET OR
169    USABLE STORAGE HITS 95%. USE INFLOW ASSOCIATED WITH TRIG 5 PARAMETERS.
170    USE FULL UNRESTRICTED DEMAND TO BE CONSERVATIVE. */
171 Set : _Proj_WSPool_Refill
172 { Condition : weekday{year, month, day} <= 1
173 Value    : min{_Durham_usable_stor(-1) + _Proj_5_Inflow - _Proj_4_Evap - _Proj_1_Demand, _Max_Durham_usable_stor}
174
175 Condition : default
176 Value    : _Proj_WSPool_Refill(-1)
177 }
178
179
180
181 /*Set : _Proj_3_WSPool_Refill
182 { Condition : weekday{year, month, day} <= 1
183 Value    : min{_Durham_usable_stor(-1) + _Proj_4_Inflow - _Proj_3_Evap - _Proj_1_Demand, _Max_Durham_usable_stor}
184
185 Condition : default
186 Value    : _Proj_3_WSPool_Refill(-1)
187 }
188
```

drought_plan_durham.ocl

```
189
190 Set : _Proj_2_WSPool_Refill
191 { Condition : weekday{year, month, day} <= 1
192   Value   : min{ _Durham_usable_stor(-1) + _Proj_4_Inflow - _Proj_3_Evap - _Proj_1_Demand, _Max_Durham_usable_stor}
193
194   Condition : default
195   Value    : _Proj_2_WSPool_Refill(-1)
196 }
197
198 Set : _Proj_1_WSPool_Refill
199 { Condition : weekday{year, month, day} <= 1
200   Value   : min{ _Durham_usable_stor(-1) + _Proj_4_Inflow - _Proj_3_Evap - _Proj_1_Demand, _Max_Durham_usable_stor}
201
202   Condition : default
203   Value    : _Proj_1_WSPool_Refill(-1)
204 }
205 */
206
207
208 /* This section evaluates whether the two triggers were on during the
209    last time step. If so, it checks to see whether the water supply pool has refilled,
210    in which case the triggers are released. If the trigger was not on in the last timestep,
211    it compares the projected storage with the threshold to determine whether it should be turned on.
212
213
214    Use 28 day waiting period between restrictions */
215
216
217
218
219 Set : _Durham_Trigger_4_On
220 {
221   Condition : _Durham_Trigger_4_On(-1) = 1
222   {
223     Condition : _Proj_WSPool_Refill >= [Trigger_5_Stor] / 100 * _Max_Durham_usable_stor or _Durham_usable_pct >= 95
224     Value    : 0
225
226     Condition : default
227     Value    : _Durham_Trigger_4_On(-1)
228   }
229
230   Condition : _Durham_Stage_3_Counter(-1) >= 28
231   { Condition : weekday{year, month, day} <= 1
232     {
233       Condition : _Proj_4_WSPool <= [Trigger_4_Stor] / 100 * _Max_Durham_usable_stor
234       Value    : 1
235     }
236   }
```

drought_plan_durham.ocl

```
236
237 Condition : default
238   Value   : _Durham_Trigger_4_On(-1)
239 }
240
241 Condition : default
242   Value   : _Durham_Trigger_4_On(-1)
243 }
244
245
246
247 Set : _Durham_Trigger_3_On
248 {
249   Condition : _Durham_Trigger_3_On(-1) = 1
250   {
251     Condition : _Proj_WSPool_Refill >= [Trigger_5_Stor] / 100 * _Max_Durham_usable_stor or _Durham_usable_pct >= 95
252     Value     : 0
253   }
254   Condition : default
255   Value     : _Durham_Trigger_3_On(-1)
256 }
257
258 Condition : _Durham_Stage_2_Counter(-1) >= 28
259 { Condition : weekday{year, month, day} <= 1
260   {
261     Condition : _Proj_3_WSPool <= [Trigger_3_Stor] / 100 * _Max_Durham_usable_stor
262     Value     : 1
263   }
264 }
265 Condition : default
266   Value   : _Durham_Trigger_3_On(-1)
267 }
268
269 Condition : default
270   Value   : _Durham_Trigger_3_On(-1)
271 }
272
273
274
275
276
277 Set : _Durham_Trigger_2_On
278 {
279   Condition : _Durham_Trigger_2_On(-1) = 1
280   {
281     Condition : _Proj_WSPool_Refill >= [Trigger_5_Stor] / 100 * _Max_Durham_usable_stor or _Durham_usable_pct >= 95
282     Value     : 0
```

drought_plan_durham.ocl

```
283
284     Condition : default
285     Value   : _Durham_Trigger_2_On(-1)
286 }
287
288 Condition : _Durham_Stage_1_Counter(-1) >= 28
289 { Condition : weekday{year, month, day} <= 1
290     {
291         Condition : _Proj_2_WSPool <= [Trigger_2_Stor] / 100 * _Max_Durham_usable_stor
292         Value   : 1
293     }
294
295 Condition : default
296     Value   : _Durham_Trigger_2_On(-1)
297 }
298
299 Condition : default
300     Value   : _Durham_Trigger_2_On(-1)
301 }
302
303
304 Set : _Durham_Trigger_1_On
305 {
306     Condition : _Durham_Trigger_1_On(-1) = 1
307     {
308         Condition : _Proj_WSPool_Refill >= [Trigger_5_Stor] / 100 * _Max_Durham_usable_stor or _Durham_usable_pct >= 95
309         Value   : 0
310
311         Condition : default
312         Value   : _Durham_Trigger_1_On(-1)
313     }
314
315     Condition : weekday{year, month, day} <= 1
316     {
317         Condition : _Proj_1_WSPool <= [Trigger_1_Stor] / 100 * _Max_Durham_usable_stor or _Durham_usable_pct < 40
318         Value   : 1
319     }
320
321     Condition : default
322     Value   : _Durham_Trigger_1_On(-1)
323 }
324
325
326 :FOR:
327 { [num] = { 1, 2, 3, 4 }
328 }
329
```

drought_plan_durham.ocf

```
330 Set : _Durham_Stage_[num]_Counter
331 {
332   Condition : _Durham_Trigger_[num]_On = 1
333   Value      : _Durham_Stage_[num]_Counter(-1) + 1
334
335
336   Condition : default
337   Value      : 0
338 }
339
340 /* When Teer Quarry is active (assumed to be the case in this 2055 run), it is assumed that if in stage 1 drought phase, there would
341    be no demand reductions. Teer Quarry supply would allow us to avoid that. */
342
343 Set : _Durham_Consvn_[num]_Demand
344 {
345   Condition : _Durham_Trigger_2_On = 1 or _Durham_Trigger_3_On = 1 or _Durham_Trigger_4_On = 1
346   Value      : demand1162 * ( 1 - pattern(Stage_[num]_Dem_Red) )
347
348   Condition : default
349   Value      : demand1162
350 }
351
352
353 Constraint Durham_Demand_Limit_Consvn_[num] :
354   { Condition : _Durham_Trigger_[num]_On = 1
355     Expression : ddelivery1162 <= _Durham_Consvn_[num]_Demand }
356
357
358 Set : _Durham_Ph_[num]_event_counter
359 { Condition : _Durham_Stage_[num]_Counter = 5 and _Durham_Stage_[num]_Counter(-1) = 4
360   Value      : _Durham_Ph_[num]_event_counter(-1) + 1
361
362   Condition : default
363   Value      : _Durham_Ph_[num]_event_counter(-1)
364 }
365
366 :NEXT:
367
368 Set : _Trig_Level_Durham
369 { condition : _Durham_Trigger_4_On = 1
370   value      : 4
371
372   condition : _Durham_Trigger_3_On = 1
373   value      : 3
374
375   condition : _Durham_Trigger_2_On = 1
376   value      : 2
```

drought_plan_durham.ocl

```
377
378 condition : _Durham_Trigger_1_On = 1
379 value      : 1
380
381 condition : default
382 value     : 0
383 }
384
385 :else:
386
387 // Otherwise, set the triggers to zero and trig level to 0. The quarry operations refer to the triggers. This will allow the trig level to be plotted to
388 // confirm plan was off.
389
390
391 :For: { [trig] = {1, 2, 3, 4}}
392
393 Set : _Durham_Trigger_[trig]_On { value : 0 }
394
395 :Next:
396
397
398 Set : _Trig_Level_Durham { value : 0 }
399
400
401 :endif:
402
```

drought_plans_cf.ocl

```
1 /* File is drought_plans_cf.ocl. Computes trigger levels and demand reductions. */
2
3 :If: {[Drought_Plans_On] = 1} // First check if drought plan variable is on
4
5 :Include: ocl\OWASA_wsrp.ocl // OWASA's forecast-based plan is in a separate OCL file
6
7 /* Burlington */
8 Set : _Burl_Max_Usable_Stor { Value: (upper_rule0070 - lower_rule0070) + (upper_rule0340 - lower_rule0340) }
9 Set : _Burl_Usable_Stor { Value : min { _Burl_Max_Usable_Stor, storage0070 - lower_rule0070 + storage0340 - lower_rule0340 } }
10 Set : _Burl_Usable_Stor_Pct { Value : 100 * _Burl_Usable_Stor / _Burl_Max_Usable_Stor }
11
12 Set : _Burl_Trigger_6_On { Value : 0 }
13
14 Set : _Burl_Trigger_5_On
15 { Condition : _Burl_Trigger_5_On(-1) = 1
16   { Condition : _Burl_Usable_Stor_Pct >= 100
17     Value : 0
18
19     Condition : default
20     Value : _Burl_Trigger_5_On(-1)
21   }
22
23   Condition : _Burl_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
24   { Condition : weekday{year, month, day} <= 1
25     { Condition : _Burl_Usable_Stor_Pct <= 15
26       Value : 1
27     }
28     Condition : default
29     Value : _Burl_Trigger_5_On(-1)
30   }
31   Condition : default
32   Value : _Burl_Trigger_5_On(-1)
33 }
34
35 Set : _Burl_Trigger_4_On
36 { Condition : _Burl_Trigger_4_On(-1) = 1
37   { Condition : _Burl_Usable_Stor_Pct >= 100
38     Value : 0
39
40     Condition : default
41     Value : _Burl_Trigger_4_On(-1)
42   }
43
44   Condition : _Burl_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
45   { Condition : weekday{year, month, day} <= 1
46     { Condition : _Burl_Usable_Stor_Pct < 30
47       Value : 1
```

drought_plans_cf.ocl

```
48     }
49     Condition : default
50     Value    : _Burl_Trigger_4_On(-1)
51 }
52 Condition : default
53 Value    : _Burl_Trigger_4_On(-1)
54 }
55
56 Set : _Burl_Trigger_3_On
57 { Condition : _Burl_Trigger_3_On(-1) = 1
58   { Condition : _Burl_Usable_Stor_Pct >= 100
59     Value    : 0
60   }
61   Condition : default
62   Value    : _Burl_Trigger_3_On(-1)
63 }
64
65 Condition : _Burl_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
66 { Condition : weekday{year, month, day} <= 1
67   { Condition : _Burl_Usable_Stor_Pct < 45
68     Value    : 1
69   }
70   Condition : default
71   Value    : _Burl_Trigger_3_On(-1)
72 }
73 Condition : default
74 Value    : _Burl_Trigger_3_On(-1)
75 }
76
77
78 Set : _Burl_Trigger_2_On
79 { Condition : _Burl_Trigger_2_On(-1) = 1
80   { Condition : _Burl_Usable_Stor_Pct >= 100
81     Value    : 0
82   }
83   Condition : default
84   Value    : _Burl_Trigger_2_On(-1)
85 }
86
87 Condition : _Burl_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
88 { Condition : weekday{year, month, day} <= 1
89   { Condition : _Burl_Usable_Stor_Pct < 60
90     Value    : 1
91   }
92   Condition : default
93   Value    : _Burl_Trigger_2_On(-1)
94 }
```

drought_plans_cf.ocl

```
95 Condition : default
96 Value : _Burl_Trigger_2_On(-1)
97 }
98
99
100 Set : _Burl_Trigger_1_On
101 { Condition : _Burl_Trigger_1_On(-1) = 1
102 { Condition : _Burl_Usable_Stor_Pct >= 100
103 Value : 0
104
105 Condition : default
106 Value : _Burl_Trigger_1_On(-1)
107 }
108
109 Condition : weekday{year, month, day} <= 1
110 { Condition : _Burl_Usable_Stor_Pct < 75
111 Value : 1
112
113 Condition : default
114 Value : _Burl_Trigger_1_On(-1)
115 }
116 Condition : default
117 Value : _Burl_Trigger_1_On(-1)
118 }
119
120 /* Grensboro */
121 Set : _Gree_Max_Usable_Stor { Value: (upper_rule0120 - lower_rule0120) + (upper_rule0140 - lower_rule0140) }
122 Set : _Gree_Usable_Stor { Value : min { _Gree_Max_Usable_Stor, (storage0120 - lower_rule0120) + (storage0140 - lower_rule0140) } }
123 Set : _Gree_Usable_Stor_Pct { Value : 100 * _Gree_Usable_Stor / _Gree_Max_Usable_Stor }
124 Set : _Gree_DSR { Value : _Gree_Usable_Stor / demand0123 }
125
126 Set : _Gree_Trigger_6_On { Value : 0 }
127
128 Set : _Gree_Trigger_5_On
129 { Condition : _Gree_Trigger_5_On(-1) = 1
130 { Condition : _Gree_Usable_Stor_Pct >= 100
131 Value : 0
132
133 Condition : default
134 Value : _Gree_Trigger_5_On(-1)
135 }
136
137 Condition : _Gree_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
138 { Condition : weekday{year, month, day} <= 1
139 { Condition : _Gree_DSR <= 75
140 Value : 1
141 }
```

drought_plans_cf.ocl

```
142     Condition : default
143     Value      : _Gree_Trigger_5_On(-1)
144 }
145 Condition : default
146 Value      : _Gree_Trigger_5_On(-1)
147 }
148
149 Set : _Gree_Trigger_4_On
150 { Condition : _Gree_Trigger_4_On(-1) = 1
151   { Condition : _Gree_Usable_Stor_Pct >= 100
152     Value      : 0
153   }
154   Condition : default
155   Value      : _Gree_Trigger_4_On(-1)
156 }
157
158 Condition : _Gree_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
159 { Condition : weekday{year, month, day} <= 1
160   { Condition : _Gree_DSR <= 100
161     Value      : 1
162   }
163   Condition : default
164   Value      : _Gree_Trigger_4_On(-1)
165 }
166 Condition : default
167 Value      : _Gree_Trigger_4_On(-1)
168 }
169
170 Set : _Gree_Trigger_3_On
171 { Condition : _Gree_Trigger_3_On(-1) = 1
172   { Condition : _Gree_Usable_Stor_Pct >= 100
173     Value      : 0
174   }
175   Condition : default
176   Value      : _Gree_Trigger_3_On(-1)
177 }
178
179 Condition : _Gree_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
180 { Condition : weekday{year, month, day} <= 1
181   { Condition : _Gree_DSR <= 125
182     Value      : 1
183   }
184   Condition : default
185   Value      : _Gree_Trigger_3_On(-1)
186 }
187 Condition : default
188 Value      : _Gree_Trigger_3_On(-1)
```

drought_plans_cf.ocl

```
189 }
190
191
192 Set : _Gree_Trigger_2_On
193 { Condition : _Gree_Trigger_2_On(-1) = 1
194   { Condition : _Gree_Usable_Stor_Pct >= 100
195     Value : 0
196
197     Condition : default
198     Value : _Gree_Trigger_2_On(-1)
199   }
200
201   Condition : _Gree_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
202   { Condition : weekday{year, month, day} <= 1
203     { Condition : _Gree_DSR <= 150
204       Value : 1
205     }
206     Condition : default
207     Value : _Gree_Trigger_2_On(-1)
208   }
209   Condition : default
210   Value : _Gree_Trigger_2_On(-1)
211 }
212
213
214 Set : _Gree_Trigger_1_On
215 { Condition : _Gree_Trigger_1_On(-1) = 1
216   { Condition : _Gree_Usable_Stor_Pct >= 100
217     Value : 0
218
219     Condition : default
220     Value : _Gree_Trigger_1_On(-1)
221   }
222
223   Condition : weekday{year, month, day} <= 1
224   { Condition : _Gree_DSR <= 200 // Note - Drought plan only references 'water levels ... do not conform to
225     //seasonal expectation' - subbed in 200 DSR so trigger would activate
226     Value : 1
227
228     Condition : default
229     Value : _Gree_Trigger_1_On(-1)
230   }
231   Condition : default
232   Value : _Gree_Trigger_1_On(-1)
233 }
234
235 /* High Point */
```

drought_plans_cf.ocl

```
236 Set : _High_Max_Usable_Stor { Value: (upper_rule0220- lower_rule0220) }
237 Set : _High_Usable_Stor { Value : min { _High_Max_Usable_Stor, storage0220 - lower_rule0220 } }
238 Set : _High_Usable_Stor_Pct { Value : 100 * _High_Usable_Stor / _High_Max_Usable_Stor }
239
240 Set : _High_Trigger_6_On { Value : 0 }
241
242 Set : _High_Trigger_5_On { Value : 0 }
243
244 Set : _High_Trigger_4_On
245 { Condition : _High_Trigger_4_On(-1) = 1
246   { Condition : _High_Usable_Stor_Pct >= 100
247     Value : 0
248
249     Condition : default
250     Value : _High_Trigger_4_On(-1)
251   }
252
253   Condition : _High_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
254   { Condition : weekday{year, month, day} <= 1
255     { Condition : _High_Usable_Stor_Pct < 40
256       Value : 1
257     }
258     Condition : default
259     Value : _High_Trigger_4_On(-1)
260   }
261   Condition : default
262   Value : _High_Trigger_4_On(-1)
263 }
264
265 Set : _High_Trigger_3_On
266 { Condition : _High_Trigger_3_On(-1) = 1
267   { Condition : _High_Usable_Stor_Pct >= 100
268     Value : 0
269
270     Condition : default
271     Value : _High_Trigger_3_On(-1)
272   }
273
274   Condition : _High_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
275   { Condition : weekday{year, month, day} <= 1
276     { Condition : _High_Usable_Stor_Pct < 50
277       Value : 1
278     }
279     Condition : default
280     Value : _High_Trigger_3_On(-1)
281   }
282   Condition : default
```

drought_plans_cf.ocl

```
283 Value : _High_Trigger_3_On(-1)
284 }
285
286
287 Set : _High_Trigger_2_On
288 { Condition : _High_Trigger_2_On(-1) = 1
289   { Condition : _High_Usable_Stor_Pct >= 100
290     Value : 0
291
292     Condition : default
293     Value : _High_Trigger_2_On(-1)
294   }
295
296   Condition : _High_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
297   { Condition : weekday{year, month, day} <= 1
298     { Condition : _High_Usable_Stor_Pct < 60
299       Value : 1
300     }
301     Condition : default
302     Value : _High_Trigger_2_On(-1)
303   }
304   Condition : default
305   Value : _High_Trigger_2_On(-1)
306 }
307
308
309 Set : _High_Trigger_1_On
310 { Condition : _High_Trigger_1_On(-1) = 1
311   { Condition : _High_Usable_Stor_Pct >= 100
312     Value : 0
313
314     Condition : default
315     Value : _High_Trigger_1_On(-1)
316   }
317
318   Condition : weekday{year, month, day} <= 1
319   { Condition : _High_Usable_Stor_Pct < 80
320     Value : 1
321
322     Condition : default
323     Value : _High_Trigger_1_On(-1)
324   }
325   Condition : default
326   Value : _High_Trigger_1_On(-1)
327 }
328
329 /* Reidsville */
```

drought_plans_cf.ocl

```
330 Set : _Reid_Max_Usable_Stor { Value : upper_rule0030 - lower_rule0030 }
331 Set : _Reid_Usable_Stor { Value : min { _Reid_Max_Usable_Stor, storage0030 - lower_rule0030 } }
332 Set : _Reid_Usable_Stor_Pct { Value : 100 * _Reid_Usable_Stor / _Reid_Max_Usable_Stor }
333 Set : _Reid_DSR { Value : _Reid_Usable_Stor / (demand0031) }
334
335 Set : _Reid_Trigger_6_On { Value : 0 }
336
337 Set : _Reid_Trigger_5_On
338 { Condition : _Reid_Trigger_5_On(-1) = 1
339   { Condition : _Reid_Usable_Stor_Pct >= 100
340     Value : 0
341
342     Condition : default
343     Value : _Reid_Trigger_5_On(-1)
344   }
345
346   Condition : _Reid_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
347   { Condition : weekday{year, month, day} <= 1
348     { Condition : _Reid_DSR <= 50
349       Value : 1
350     }
351     Condition : default
352     Value : _Reid_Trigger_5_On(-1)
353   }
354   Condition : default
355   Value : _Reid_Trigger_5_On(-1)
356 }
357
358 Set : _Reid_Trigger_4_On
359 { Condition : _Reid_Trigger_4_On(-1) = 1
360   { Condition : _Reid_Usable_Stor_Pct >= 100
361     Value : 0
362
363     Condition : default
364     Value : _Reid_Trigger_4_On(-1)
365   }
366
367   Condition : _Reid_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
368   { Condition : weekday{year, month, day} <= 1
369     { Condition : _Reid_DSR <= 75
370       Value : 1
371     }
372     Condition : default
373     Value : _Reid_Trigger_4_On(-1)
374   }
375   Condition : default
376   Value : _Reid_Trigger_4_On(-1)
```

drought_plans_cf.ocl

```
377 }
378
379 Set : _Reid_Trigger_3_On
380 { Condition : _Reid_Trigger_3_On(-1) = 1
381   { Condition : _Reid_Usable_Stor_Pct >= 100
382     Value : 0
383
384     Condition : default
385     Value : _Reid_Trigger_3_On(-1)
386   }
387
388   Condition : _Reid_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
389   { Condition : weekday{year, month, day} <= 1
390     { Condition : _Reid_DSR <= 100
391       Value : 1
392     }
393     Condition : default
394     Value : _Reid_Trigger_3_On(-1)
395   }
396   Condition : default
397   Value : _Reid_Trigger_3_On(-1)
398 }
399
400
401 Set : _Reid_Trigger_2_On
402 { Condition : _Reid_Trigger_2_On(-1) = 1
403   { Condition : _Reid_Usable_Stor_Pct >= 100
404     Value : 0
405
406     Condition : default
407     Value : _Reid_Trigger_2_On(-1)
408   }
409
410   Condition : _Reid_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
411   { Condition : weekday{year, month, day} <= 1
412     { Condition : _Reid_DSR <= 125
413       Value : 1
414     }
415     Condition : default
416     Value : _Reid_Trigger_2_On(-1)
417   }
418   Condition : default
419   Value : _Reid_Trigger_2_On(-1)
420 }
421
422
423 Set : _Reid_Trigger_1_On
```

drought_plans_cf.ocl

```
424 { Condition : _Reid_Trigger_1_On(-1) = 1
425   { Condition : _Reid_Usable_Stor_Pct >= 100
426     Value   : 0
427
428     Condition : default
429     Value    : _Reid_Trigger_1_On(-1)
430   }
431
432   Condition : weekday{year, month, day} <= 1
433   { Condition : _Reid_DSR <= 150
434     Value   : 1
435
436     Condition : default
437     Value    : _Reid_Trigger_1_On(-1)
438   }
439   Condition : default
440   Value    : _Reid_Trigger_1_On(-1)
441 }
442
443 /* Ramseur */
444 Set : _Rams_Max_Usable_Stor { Value : upper_rule0300- lower_rule0300 }
445 Set : _Rams_Usable_Stor { Value : min { _Rams_Max_Usable_Stor, storage0300- lower_rule0300 } }
446 Set : _Rams_Usable_Stor_Pct { Value : 100 * _Rams_Usable_Stor / _Rams_Max_Usable_Stor }
447
448 Set : _Rams_Trigger_6_On { Value : 0 }
449
450 Set : _Rams_Trigger_5_On
451 { Condition : _Rams_Trigger_5_On(-1) = 1
452   { Condition : _Rams_Usable_Stor_Pct >= 100
453     Value   : 0
454
455     Condition : default
456     Value    : _Rams_Trigger_5_On(-1)
457   }
458
459   Condition : _Rams_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
460   { Condition : weekday{year, month, day} <= 1
461     { Condition : _Rams_Usable_Stor_Pct <= 0
462       Value   : 1
463     }
464     Condition : default
465     Value    : _Rams_Trigger_5_On(-1)
466   }
467   Condition : default
468   Value    : _Rams_Trigger_5_On(-1)
469 }
470
```

drought_plans_cf.ocl

```
471 Set : _Rams_Trigger_4_On
472 { Condition : _Rams_Trigger_4_On(-1) = 1
473   { Condition : _Rams_Usable_Stor_Pct >= 100
474     Value : 0
475
476     Condition : default
477     Value : _Rams_Trigger_4_On(-1)
478   }
479
480   Condition : _Rams_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
481   { Condition : weekday{year, month, day} <= 1
482     { Condition : _Rams_Usable_Stor_Pct < 67
483       Value : 1
484     }
485     Condition : default
486     Value : _Rams_Trigger_4_On(-1)
487   }
488   Condition : default
489   Value : _Rams_Trigger_4_On(-1)
490 }
491
492 Set : _Rams_Trigger_3_On
493 { Condition : _Rams_Trigger_3_On(-1) = 1
494   { Condition : _Rams_Usable_Stor_Pct >= 100
495     Value : 0
496
497     Condition : default
498     Value : _Rams_Trigger_3_On(-1)
499   }
500
501   Condition : _Rams_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
502   { Condition : weekday{year, month, day} <= 1
503     { Condition : _Rams_Usable_Stor_Pct < 75
504       Value : 1
505     }
506     Condition : default
507     Value : _Rams_Trigger_3_On(-1)
508   }
509   Condition : default
510   Value : _Rams_Trigger_3_On(-1)
511 }
512
513
514 Set : _Rams_Trigger_2_On
515 { Condition : _Rams_Trigger_2_On(-1) = 1
516   { Condition : _Rams_Usable_Stor_Pct >= 100
517     Value : 0
```

drought_plans_cf.ocl

```
518
519     Condition : default
520     Value      : _Rams_Trigger_2_On(-1)
521 }
522
523 Condition : _Rams_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
524 { Condition : weekday{year, month, day} <= 1
525     { Condition : _Rams_Usable_Stor_Pct < 83
526         Value      : 1
527     }
528     Condition : default
529     Value      : _Rams_Trigger_2_On(-1)
530 }
531 Condition : default
532 Value      : _Rams_Trigger_2_On(-1)
533 }
534
535
536 Set : _Rams_Trigger_1_On
537 { Condition : _Rams_Trigger_1_On(-1) = 1
538     { Condition : _Rams_Usable_Stor_Pct >= 100
539         Value      : 0
540     }
541     Condition : default
542     Value      : _Rams_Trigger_1_On(-1)
543 }
544
545 Condition : weekday{year, month, day} <= 1
546 { Condition : _Rams_Usable_Stor_Pct < 91
547     Value      : 1
548 }
549     Condition : default
550     Value      : _Rams_Trigger_1_On(-1)
551 }
552 Condition : default
553 Value      : _Rams_Trigger_1_On(-1)
554 }
555
556 /* Graham-Mebane */
557 Set : _GramMeb_Max_Usable_Stor { Value : upper_rule0320 - lower_rule0320 }
558 Set : _GramMeb_Usable_Stor { Value : min { _GramMeb_Max_Usable_Stor, storage0320 - lower_rule0320 } }
559 Set : _GramMeb_Usable_Stor_Pct { Value : 100 * _GramMeb_Usable_Stor / _GramMeb_Max_Usable_Stor }
560 Set : _GramMeb_DSR { Value : _GramMeb_Usable_Stor / (demand0321) }
561
562 Set : _GramMeb_Trigger_6_On { Value : 0 }
563
564 Set : _GramMeb_Trigger_5_On
```

drought_plans_cf.ocl

```
565 { Condition : _GramMeb_Trigger_5_On(-1) = 1
566   { Condition : _GramMeb_Usable_Stor_Pct >= 100
567     Value   : 0
568
569     Condition : default
570     Value    : _GramMeb_Trigger_5_On(-1)
571   }
572
573 Condition : _GramMeb_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
574 { Condition : weekday{year, month, day} <= 1
575   { Condition : _GramMeb_DSR <= 30
576     Value   : 1
577   }
578   Condition : default
579   Value    : _GramMeb_Trigger_5_On(-1)
580 }
581 Condition : default
582 Value    : _GramMeb_Trigger_5_On(-1)
583 }
584
585 Set : _GramMeb_Trigger_4_On
586 { Condition : _GramMeb_Trigger_4_On(-1) = 1
587   { Condition : _GramMeb_Usable_Stor_Pct >= 100
588     Value   : 0
589
590     Condition : default
591     Value    : _GramMeb_Trigger_4_On(-1)
592   }
593
594 Condition : _GramMeb_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
595 { Condition : weekday{year, month, day} <= 1
596   { Condition : _GramMeb_DSR <= 60
597     Value   : 1
598   }
599   Condition : default
600   Value    : _GramMeb_Trigger_4_On(-1)
601 }
602 Condition : default
603 Value    : _GramMeb_Trigger_4_On(-1)
604 }
605
606 Set : _GramMeb_Trigger_3_On
607 { Condition : _GramMeb_Trigger_3_On(-1) = 1
608   { Condition : _GramMeb_Usable_Stor_Pct >= 100
609     Value   : 0
610
611     Condition : default
```

drought_plans_cf.ocl

```
612     Value   : _GramMeb_Trigger_3_On(-1)
613 }
614
615 Condition : _GramMeb_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
616 { Condition : weekday{year, month, day} <= 1
617     { Condition : _GramMeb_DSR <= 90
618         Value   : 1
619     }
620     Condition : default
621     Value     : _GramMeb_Trigger_3_On(-1)
622 }
623 Condition : default
624 Value     : _GramMeb_Trigger_3_On(-1)
625 }
626
627
628 Set : _GramMeb_Trigger_2_On
629 { Condition : _GramMeb_Trigger_2_On(-1) = 1
630     { Condition : _GramMeb_Usable_Stor_Pct >= 100
631         Value   : 0
632     }
633     Condition : default
634     Value     : _GramMeb_Trigger_2_On(-1)
635 }
636
637 Condition : _GramMeb_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
638 { Condition : weekday{year, month, day} <= 1
639     { Condition : _GramMeb_DSR <= 120
640         Value   : 1
641     }
642     Condition : default
643     Value     : _GramMeb_Trigger_2_On(-1)
644 }
645 Condition : default
646 Value     : _GramMeb_Trigger_2_On(-1)
647 }
648
649
650 Set : _GramMeb_Trigger_1_On
651 { Condition : _GramMeb_Trigger_1_On(-1) = 1
652     { Condition : _GramMeb_Usable_Stor_Pct >= 100
653         Value   : 0
654     }
655     Condition : default
656     Value     : _GramMeb_Trigger_1_On(-1)
657 }
658
```

drought_plans_cf.ocl

```
659 Condition : weekday{year, month, day} <= 1
660 { Condition : _GramMeb_DSR <= 150
661   Value : 1
662
663   Condition : default
664   Value : _GramMeb_Trigger_1_On(-1)
665 }
666 Condition : default
667 Value : _GramMeb_Trigger_1_On(-1)
668 }
669
670 /* Siler City */
671
672 Set : _Siler_Trigger_6_On { Value : 0 }
673 Set : _Siler_Trigger_5_On { Value : 0 }
674
675 Set : _Siler_Trigger_4_On
676 { Condition : _Siler_Trigger_4_On(-1) = 1
677   { Condition : _SilerCity_UsableStorPct >= 100
678     Value : 0
679
680     Condition : default
681     Value : _Siler_Trigger_4_On(-1)
682   }
683
684   Condition : _Siler_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
685   { Condition : weekday{year, month, day} <= 1
686     { Condition : _SilerCity_UsableStorPct < 10
687       Value : 1
688     }
689     Condition : default
690     Value : _Siler_Trigger_4_On(-1)
691   }
692   Condition : default
693   Value : _Siler_Trigger_4_On(-1)
694 }
695
696 Set : _Siler_Trigger_3_On
697 { Condition : _Siler_Trigger_3_On(-1) = 1
698   { Condition : _SilerCity_UsableStorPct >= 100
699     Value : 0
700
701     Condition : default
702     Value : _Siler_Trigger_3_On(-1)
703   }
704
705   Condition : _Siler_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
```

drought_plans_cf.ocl

```
706 { Condition : weekday{year, month, day} <= 1
707 { Condition : _SilerCity_UsableStorPct < 20
708 Value : 1
709 }
710 Condition : default
711 Value : _Siler_Trigger_3_On(-1)
712 }
713 Condition : default
714 Value : _Siler_Trigger_3_On(-1)
715 }
716
717
718 Set : _Siler_Trigger_2_On
719 { Condition : _Siler_Trigger_2_On(-1) = 1
720 { Condition : _SilerCity_UsableStorPct >= 100
721 Value : 0
722
723 Condition : default
724 Value : _Siler_Trigger_2_On(-1)
725 }
726
727 Condition : _Siler_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
728 { Condition : weekday{year, month, day} <= 1
729 { Condition : _SilerCity_UsableStorPct < 40
730 Value : 1
731 }
732 Condition : default
733 Value : _Siler_Trigger_2_On(-1)
734 }
735 Condition : default
736 Value : _Siler_Trigger_2_On(-1)
737 }
738
739
740 Set : _Siler_Trigger_1_On
741 { Condition : _Siler_Trigger_1_On(-1) = 1
742 { Condition : _SilerCity_UsableStorPct >= 100
743 Value : 0
744
745 Condition : default
746 Value : _Siler_Trigger_1_On(-1)
747 }
748
749 Condition : weekday{year, month, day} <= 1
750 { Condition : _SilerCity_UsableStorPct < 70
751 Value : 1
752
```

drought_plans_cf.ocl

```
753     Condition : default
754     Value      : _Siler_Trigger_1_On(-1)
755 }
756 Condition : default
757 Value      : _Siler_Trigger_1_On(-1)
758 }
759
760 /* Pittsboro - based on intake pool elevation, cannot model without more information */
761
762 /* Cary-Apex */
763 Set : _Cary_DSR
764 { Condition : abs_period <= 2
765   Value      : ([Starting_Storage_CaryAp] + [Starting_Storage_RTP] + [Starting_Storage_Morris]) / (demand0471 + demand0474 + demand0477)
766 }
767 Condition : default
768 Value      : (_Storage_CaryAp(-1) + _Storage_RTP(-1) + _Storage_Morris(-1))
769 / ( ( accumulate {demand0471, -30,-1} + accumulate{demand0474, -30, -1} + accumulate {demand0477, -30, -1} ) / 30 )
770 }
771
772 Set : _Cary_Trigger_6_On { Value : 0 }
773 Set : _Cary_Trigger_5_On { Value : 0 }
774
775 Set : _Cary_Trigger_4_On
776 { Condition : _Cary_Trigger_4_On(-1) = 1
777   { // condition needs to be met for 14 consecutive days
778     Condition : _Cary_DSR(-14) >= 60 and _Cary_DSR(-13) >= 60 and _Cary_DSR(-12) >= 60 and _Cary_DSR(-11) >= 60
779       and _Cary_DSR(-10) >= 60 and _Cary_DSR(-9) >= 60 and _Cary_DSR(-8) >= 60 and _Cary_DSR(-7) >= 60
780       and _Cary_DSR(-6) >= 60 and _Cary_DSR(-5) >= 60 and _Cary_DSR(-4) >= 60 and _Cary_DSR(-3) >= 60
781       and _Cary_DSR(-2) >= 60 and _Cary_DSR(-1) >= 60
782     Value      : 0
783   }
784   Condition : default
785   Value      : _Cary_Trigger_4_On(-1)
786 }
787
788 Condition : _Cary_Stage_3_Counter(-1) >= 1 // No waiting period required for stage 4
789 { Condition : weekday{year, month, day} <= 1
790   { Condition : _Cary_DSR <= 30
791     Value      : 1
792   }
793   Condition : default
794   Value      : _Cary_Trigger_4_On(-1)
795 }
796 Condition : default
797 Value      : _Cary_Trigger_4_On(-1)
798 }
799
```

drought_plans_cf.ocl

```
800 Set : _Cary_Trigger_3_On
801 { Condition : _Cary_Trigger_3_On(-1) = 1
802   { // condition needs to be met for 14 consecutive days
803     Condition : _Cary_DSR(-14) >= 90 and _Cary_DSR(-13) >= 90 and _Cary_DSR(-12) >= 90 and _Cary_DSR(-11) >= 90
804       and _Cary_DSR(-10) >= 90 and _Cary_DSR(-9) >= 90 and _Cary_DSR(-8) >= 90 and _Cary_DSR(-7) >= 90
805       and _Cary_DSR(-6) >= 90 and _Cary_DSR(-5) >= 90 and _Cary_DSR(-4) >= 90 and _Cary_DSR(-3) >= 90
806       and _Cary_DSR(-2) >= 90 and _Cary_DSR(-1) >= 90
807     Value : 0
808
809
810     Condition : default
811     Value : _Cary_Trigger_3_On(-1)
812   }
813
814   Condition : _Cary_Stage_2_Counter(-1) >= 1 // No waiting period required for stage 3
815   { Condition : weekday{year, month, day} <= 1
816     { Condition : _Cary_DSR <= 60
817       Value : 1
818     }
819     Condition : default
820     Value : _Cary_Trigger_3_On(-1)
821   }
822   Condition : default
823   Value : _Cary_Trigger_3_On(-1)
824 }
825
826
827 Set : _Cary_Trigger_2_On
828 { Condition : _Cary_Trigger_2_On(-1) = 1
829   { // condition needs to be met for 14 consecutive days
830     Condition : _Cary_DSR(-14) >= 120 and _Cary_DSR(-13) >= 120 and _Cary_DSR(-12) >= 120 and _Cary_DSR(-11) >= 120
831       and _Cary_DSR(-10) >= 120 and _Cary_DSR(-9) >= 120 and _Cary_DSR(-8) >= 120 and _Cary_DSR(-7) >= 120
832       and _Cary_DSR(-6) >= 120 and _Cary_DSR(-5) >= 120 and _Cary_DSR(-4) >= 120 and _Cary_DSR(-3) >= 120
833       and _Cary_DSR(-2) >= 120 and _Cary_DSR(-1) >= 120
834     Value : 0
835
836     Condition : default
837     Value : _Cary_Trigger_2_On(-1)
838   }
839
840   Condition : _Cary_Stage_1_Counter(-1) >= 28 // Require a 28 day waiting period before going into phase 2
841   { Condition : weekday{year, month, day} <= 1
842     { Condition : _Cary_DSR <= 90
843       Value : 1
844     }
845     Condition : default
846     Value : _Cary_Trigger_2_On(-1)
```

drought_plans_cf.ocl

```
847 }
848 Condition : default
849 Value : _Cary_Trigger_2_On(-1)
850 }
851
852
853 Set : _Cary_Trigger_1_On
854 { Condition : _Cary_Trigger_1_On(-1) = 1
855 { /* condition needs to be met for 14 consecutive days. WSRP refers to "Jordan Lake Water Supply allocation has been 100% full"
856 - assume that is each of the three accounts that go into the calculation of DSR.*/
857 Condition : (_Stor_Final_Pct_CaryAp(-14) >= 100 and _Stor_Final_Pct_CaryAp(-13) >= 100 and _Stor_Final_Pct_CaryAp(-12) >= 100
858 and _Stor_Final_Pct_CaryAp(-11) >= 100 and _Stor_Final_Pct_CaryAp(-10) >= 100 and _Stor_Final_Pct_CaryAp(-9) >= 100
859 and _Stor_Final_Pct_CaryAp(-8) >= 100 and _Stor_Final_Pct_CaryAp(-7) >= 100 and _Stor_Final_Pct_CaryAp(-6) >= 100
860 and _Stor_Final_Pct_CaryAp(-5) >= 100 and _Stor_Final_Pct_CaryAp(-4) >= 100 and _Stor_Final_Pct_CaryAp(-3) >= 100
861 and _Stor_Final_Pct_CaryAp(-2) >= 100 and _Stor_Final_Pct_CaryAp(-1) >= 100 )
862 and (_Stor_Final_Pct_RTP(-14) >= 100 and _Stor_Final_Pct_RTP(-13) >= 100 and _Stor_Final_Pct_RTP(-12) >= 100
863 and _Stor_Final_Pct_RTP(-11) >= 100 and _Stor_Final_Pct_RTP(-10) >= 100 and _Stor_Final_Pct_RTP(-9) >= 100
864 and _Stor_Final_Pct_RTP(-8) >= 100 and _Stor_Final_Pct_RTP(-7) >= 100 and _Stor_Final_Pct_RTP(-6) >= 100
865 and _Stor_Final_Pct_RTP(-5) >= 100 and _Stor_Final_Pct_RTP(-4) >= 100 and _Stor_Final_Pct_RTP(-3) >= 100
866 and _Stor_Final_Pct_RTP(-2) >= 100 and _Stor_Final_Pct_RTP(-1) >= 100 )
867 and (_Stor_Final_Pct_Morris(-14) >= 100 and _Stor_Final_Pct_Morris(-13) >= 100 and _Stor_Final_Pct_Morris(-12) >= 100
868 and _Stor_Final_Pct_Morris(-11) >= 100 and _Stor_Final_Pct_Morris(-10) >= 100 and _Stor_Final_Pct_Morris(-9) >= 100
869 and _Stor_Final_Pct_Morris(-8) >= 100 and _Stor_Final_Pct_Morris(-7) >= 100 and _Stor_Final_Pct_Morris(-6) >= 100
870 and _Stor_Final_Pct_Morris(-5) >= 100 and _Stor_Final_Pct_Morris(-4) >= 100 and _Stor_Final_Pct_Morris(-3) >= 100
871 and _Stor_Final_Pct_Morris(-2) >= 100 and _Stor_Final_Pct_Morris(-1) >= 100 )
872 Value : 0
873
874 Condition : default
875 Value : _Cary_Trigger_1_On(-1)
876 }
877
878 Condition : weekday{year, month, day} <= 1
879 { /* the plan calls for turning on trigger 1 if DSR <= 120 days. However, for the 2055 demand year, the demands are high enough
880 to cause the trigger to be met even if the storage account is full. So add in a condition that trigger can only turn on if
881 the DSR condition is met and storage in the Cary account is <= 80%. */
882 Condition : _Cary_DSR <= 120 and _Stor_Final_Pct_CaryAp(-1) < 80
883 Value : 1
884
885 Condition : default
886 Value : _Cary_Trigger_1_On(-1)
887 }
888 Condition : default
889 Value : _Cary_Trigger_1_On(-1)
890 }
891
892 /* Chatham North */
893 Set : _ChatNo_Usable_Stor_Pct
```

drought_plans_cf.ocl

```
894 { Condition : abs_period <= 1
895   Value   : 100
896
897   Condition : default
898   Value    : _Stor_Final_Pct_Chatham(-1)
899 }
900
901 Set : _ChatNo_Trigger_6_On {Value : 0 }
902
903 Set : _ChatNo_Trigger_5_On
904 { Condition : _ChatNo_Trigger_5_On(-1) = 1
905   { Condition : _ChatNo_Usable_Stor_Pct >= 100
906     Value    : 0
907
908     Condition : default
909     Value    : _ChatNo_Trigger_5_On(-1)
910   }
911
912   Condition : _ChatNo_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
913   { Condition : weekday{year, month, day} <= 1
914     { Condition : _ChatNo_Usable_Stor_Pct < 0
915       Value    : 1
916     }
917     Condition : default
918     Value    : _ChatNo_Trigger_5_On(-1)
919   }
920   Condition : default
921   Value    : _ChatNo_Trigger_5_On(-1)
922 }
923
924 Set : _ChatNo_Trigger_4_On
925 { Condition : _ChatNo_Trigger_4_On(-1) = 1
926   { Condition : _ChatNo_Usable_Stor_Pct >= 100
927     Value    : 0
928
929     Condition : default
930     Value    : _ChatNo_Trigger_4_On(-1)
931   }
932
933   Condition : _ChatNo_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
934   { Condition : weekday{year, month, day} <= 1
935     { Condition : _ChatNo_Usable_Stor_Pct < 30
936       Value    : 1
937     }
938     Condition : default
939     Value    : _ChatNo_Trigger_4_On(-1)
940   }
```

drought_plans_cf.ocl

```
941 Condition : default
942 Value   : _ChatNo_Trigger_4_On(-1)
943 }
944
945 Set : _ChatNo_Trigger_3_On
946 { Condition : _ChatNo_Trigger_3_On(-1) = 1
947   { Condition : _ChatNo_Usable_Stor_Pct >= 100
948     Value   : 0
949
950     Condition : default
951     Value   : _ChatNo_Trigger_3_On(-1)
952   }
953
954   Condition : _ChatNo_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
955   { Condition : weekday{year, month, day} <= 1
956     { Condition : _ChatNo_Usable_Stor_Pct < 50
957       Value   : 1
958     }
959     Condition : default
960     Value   : _ChatNo_Trigger_3_On(-1)
961   }
962   Condition : default
963   Value   : _ChatNo_Trigger_3_On(-1)
964 }
965
966
967 Set : _ChatNo_Trigger_2_On
968 { Condition : _ChatNo_Trigger_2_On(-1) = 1
969   { Condition : _ChatNo_Usable_Stor_Pct >= 100
970     Value   : 0
971
972     Condition : default
973     Value   : _ChatNo_Trigger_2_On(-1)
974   }
975
976   Condition : _ChatNo_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
977   { Condition : weekday{year, month, day} <= 1
978     { Condition : _ChatNo_Usable_Stor_Pct < 65
979       Value   : 1
980     }
981     Condition : default
982     Value   : _ChatNo_Trigger_2_On(-1)
983   }
984   Condition : default
985   Value   : _ChatNo_Trigger_2_On(-1)
986 }
987
```

drought_plans_cf.ocl

```
988
989 Set : _ChatNo_Trigger_1_On
990 { Condition : _ChatNo_Trigger_1_On(-1) = 1
991   { Condition : _ChatNo_Usable_Stor_Pct >= 100
992     Value   : 0
993   }
994   Condition : default
995   Value     : _ChatNo_Trigger_1_On(-1)
996 }
997
998 Condition : weekday{year, month, day} <= 1
999 { Condition : _ChatNo_Usable_Stor_Pct < 75
1000   Value   : 1
1001 }
1002   Condition : default
1003   Value     : _ChatNo_Trigger_1_On(-1)
1004 }
1005   Condition : default
1006   Value     : _ChatNo_Trigger_1_On(-1)
1007 }
1008
1009 /* Sanford - demand/production based - not modeled */
1010
1011 /* Harnett Co. - mostly demand based - not modeled */
1012
1013
1014 /* Dunn */
1015
1016 Set : _Dunn_Trigger_6_On
1017 { Condition : _Dunn_Trigger_5_On(-1) = 1
1018   { Condition : flow0555.0650 > convert_units { 100, cfs, af }
1019     Value   : 0
1020   }
1021   Condition : default
1022   Value     : _Dunn_Trigger_6_On(-1)
1023 }
1024
1025 Condition : _Dunn_Stage_5_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
1026 { Condition : weekday{year, month, day} <= 1
1027   { Condition : flow0555.0650 < convert_units { 100, cfs, af } and flow0555.0650(-1) < convert_units { 100, cfs, af } and
1028     flow0555.0650(-2) < convert_units { 100, cfs, af } and flow0555.0650(-3) < convert_units { 100, cfs, af } and
1029     flow0555.0650(-4) < convert_units { 100, cfs, af }
1030     Value   : 1
1031   }
1032   Condition : default
1033   Value     : _Dunn_Trigger_6_On(-1)
1034 }
```

drought_plans_cf.ocl

```
1035 Condition : default
1036 Value   : _Dunn_Trigger_6_On(-1)
1037 }
1038
1039 Set : _Dunn_Trigger_5_On
1040 { Condition : _Dunn_Trigger_5_On(-1) = 1
1041   { Condition : flow0555.0650 > convert_units { 125, cfs, af }
1042     Value   : 0
1043
1044     Condition : default
1045     Value   : _Dunn_Trigger_5_On(-1)
1046   }
1047
1048   Condition : _Dunn_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
1049   { Condition : weekday{year, month, day} <= 1
1050     { Condition : flow0555.0650 < convert_units { 125, cfs, af } and flow0555.0650(-1) < convert_units { 125, cfs, af } and
1051       flow0555.0650(-2) < convert_units { 125, cfs, af } and flow0555.0650(-3) < convert_units { 125, cfs, af } and
1052       flow0555.0650(-4) < convert_units { 125, cfs, af }
1053     Value   : 1
1054   }
1055   Condition : default
1056   Value   : _Dunn_Trigger_5_On(-1)
1057 }
1058 Condition : default
1059 Value   : _Dunn_Trigger_5_On(-1)
1060 }
1061
1062 Set : _Dunn_Trigger_4_On
1063 { Condition : _Dunn_Trigger_4_On(-1) = 1
1064   { Condition : flow0555.0650 > convert_units { 150, cfs, af }
1065     Value   : 0
1066
1067     Condition : default
1068     Value   : _Dunn_Trigger_4_On(-1)
1069   }
1070
1071   Condition : _Dunn_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
1072   { Condition : weekday{year, month, day} <= 1
1073     { Condition : flow0555.0650 < convert_units { 150, cfs, af } and flow0555.0650(-1) < convert_units { 150, cfs, af } and
1074       flow0555.0650(-2) < convert_units { 150, cfs, af } and flow0555.0650(-3) < convert_units { 150, cfs, af } and
1075       flow0555.0650(-4) < convert_units { 150, cfs, af }
1076     Value   : 1
1077   }
1078   Condition : default
1079   Value   : _Dunn_Trigger_4_On(-1)
1080 }
1081 Condition : default
```

drought_plans_cf.ocl

```
1082 Value : _Dunn_Trigger_4_On(-1)
1083 }
1084
1085 Set : _Dunn_Trigger_3_On
1086 { Condition : _Dunn_Trigger_3_On(-1) = 1
1087   { Condition : flow0555.0650 > convert_units { 175, cfs, af }
1088     Value : 0
1089
1090     Condition : default
1091     Value : _Dunn_Trigger_3_On(-1)
1092   }
1093
1094   Condition : _Dunn_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
1095   { Condition : weekday{year, month, day} <= 1
1096     { Condition : flow0555.0650 < convert_units { 175, cfs, af } and flow0555.0650(-1) < convert_units { 175, cfs, af } and
1097       flow0555.0650(-2) < convert_units { 175, cfs, af } and flow0555.0650(-3) < convert_units { 175, cfs, af } and
1098       flow0555.0650(-4) < convert_units { 175, cfs, af }
1099     Value : 1
1100   }
1101   Condition : default
1102   Value : _Dunn_Trigger_3_On(-1)
1103 }
1104 Condition : default
1105 Value : _Dunn_Trigger_3_On(-1)
1106 }
1107
1108
1109 Set : _Dunn_Trigger_2_On
1110 { Condition : _Dunn_Trigger_2_On(-1) = 1
1111   { Condition : flow0555.0650 > convert_units { 200, cfs, af }
1112     Value : 0
1113
1114     Condition : default
1115     Value : _Dunn_Trigger_2_On(-1)
1116   }
1117
1118   Condition : _Dunn_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
1119   { Condition : weekday{year, month, day} <= 1
1120     { Condition : flow0555.0650 < convert_units { 200, cfs, af } and flow0555.0650(-1) < convert_units { 200, cfs, af } and
1121       flow0555.0650(-2) < convert_units { 200, cfs, af } and flow0555.0650(-3) < convert_units { 200, cfs, af } and
1122       flow0555.0650(-4) < convert_units { 200, cfs, af }
1123     Value : 1
1124   }
1125   Condition : default
1126   Value : _Dunn_Trigger_2_On(-1)
1127 }
1128 Condition : default
```

drought_plans_cf.ocl

```
1129 Value : _Dunn_Trigger_2_On(-1)
1130 }
1131
1132
1133 Set : _Dunn_Trigger_1_On
1134 { Condition : _Dunn_Trigger_1_On(-1) = 1
1135   { Condition : flow0555.0650 > convert_units { 225, cfs, af }
1136     Value : 0
1137
1138     Condition : default
1139     Value : _Dunn_Trigger_1_On(-1)
1140   }
1141
1142   // Assume no waiting period since Dunn_Trigger 1 only drought alert
1143   Condition : weekday{year, month, day} <= 1
1144   { Condition : flow0555.0650 < convert_units { 225, cfs, af } and flow0555.0650(-1) < convert_units { 225, cfs, af } and
1145     flow0555.0650(-2) < convert_units { 225, cfs, af } and flow0555.0650(-3) < convert_units { 225, cfs, af } and
1146     flow0555.0650(-4) < convert_units { 225, cfs, af }
1147     Value : 1
1148
1149     Condition : default
1150     Value : _Dunn_Trigger_1_On(-1)
1151   }
1152   Condition : default
1153   Value : _Dunn_Trigger_1_On(-1)
1154 }
1155
1156 /* Benson - triggers follow those of Dunn - their main supplier */
1157
1158 Set : _Benson_Trigger_6_On
1159 { Condition : default
1160   Value : _Dunn_Trigger_6_On
1161 }
1162
1163 Set : _Benson_Trigger_5_On
1164 { Condition : default
1165   Value : _Dunn_Trigger_5_On
1166 }
1167
1168 Set : _Benson_Trigger_4_On
1169 { Condition : default
1170   Value : _Dunn_Trigger_4_On
1171 }
1172
1173 Set : _Benson_Trigger_3_On
1174 { Condition : default
1175   Value : _Dunn_Trigger_3_On
```

drought_plans_cf.ocl

```
1176 }
1177
1178 Set : _Benson_Trigger_2_On
1179 {   Condition : default
1180     Value    : _Dunn_Trigger_2_On
1181 }
1182
1183 Set : _Benson_Trigger_1_On
1184 {   Condition : default
1185     Value    : _Dunn_Trigger_1_On
1186 }
1187
1188
1189
1190
1191
1192 /* Carthage - Trigger based on Nicks Creek - using arc 700.710 Little River_Linden gage in model since that is where their WD is from */
1193 Set : _Carth_Trigger_6_On {Value : 0}
1194 Set : _Carth_Trigger_5_On {Value : 0}
1195
1196 Set : _Carth_Trigger_4_On
1197 {   Condition : _Carth_Trigger_4_On(-1) = 1
1198     {   Condition : flow0700.0710 > convert_units { 0.50, cfs, af }
1199         Value    : 0
1200
1201         Condition : default
1202         Value    : _Carth_Trigger_4_On(-1)
1203     }
1204
1205     Condition : _Carth_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
1206     {   Condition : weekday{year, month, day} <= 1
1207         {   Condition : flow0700.0710 < convert_units { 0.50, cfs, af }
1208             Value    : 1
1209         }
1210         Condition : default
1211         Value    : _Carth_Trigger_4_On(-1)
1212     }
1213     Condition : default
1214     Value    : _Carth_Trigger_4_On(-1)
1215 }
1216
1217 Set : _Carth_Trigger_3_On
1218 {   Condition : _Carth_Trigger_3_On(-1) = 1
1219     {   Condition : flow0700.0710 > convert_units { 1.50, cfs, af }
1220         Value    : 0
1221
1222         Condition : default
```

drought_plans_cf.ocl

```
1223     Value   : _Carth_Trigger_3_On(-1)
1224 }
1225
1226 Condition : _Carth_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
1227 { Condition : weekday{year, month, day} <= 1
1228     { Condition : flow0700.0710 < convert_units { 1.50, cfs, af } and flow0700.0710(-1) < convert_units { 1.50, cfs, af } and
1229         flow0700.0710(-2) < convert_units { 1.50, cfs, af }
1230     Value   : 1
1231 }
1232 Condition : default
1233 Value     : _Carth_Trigger_3_On(-1)
1234 }
1235 Condition : default
1236 Value     : _Carth_Trigger_3_On(-1)
1237 }
1238
1239
1240 Set : _Carth_Trigger_2_On
1241 { Condition : _Carth_Trigger_2_On(-1) = 1
1242     { Condition : flow0700.0710 > convert_units { 2.40, cfs, af }
1243     Value   : 0
1244 }
1245 Condition : default
1246 Value     : _Carth_Trigger_2_On(-1)
1247 }
1248
1249 Condition : _Carth_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
1250 { Condition : weekday{year, month, day} <= 1
1251     { Condition : flow0700.0710 < convert_units { 2.40, cfs, af } and flow0700.0710(-1) < convert_units { 2.40, cfs, af } and
1252         flow0700.0710(-2) < convert_units { 2.40, cfs, af }
1253     Value   : 1
1254 }
1255 Condition : default
1256 Value     : _Carth_Trigger_2_On(-1)
1257 }
1258 Condition : default
1259 Value     : _Carth_Trigger_2_On(-1)
1260 }
1261
1262
1263 Set : _Carth_Trigger_1_On
1264 { Condition : _Carth_Trigger_1_On(-1) = 1
1265     { Condition : flow0700.0710 > convert_units { 3, cfs, af }
1266     Value   : 0
1267 }
1268 Condition : default
1269 Value     : _Carth_Trigger_1_On(-1)
```

drought_plans_cf.ocl

```
1270 }
1271
1272 // Assume no waiting period since Carth_Trigger 1 only drought alert
1273 Condition : weekday{year, month, day} <= 1
1274 { Condition : flow0700.0710 < convert_units { 3, cfs, af } and flow0700.0710(-1) < convert_units { 3, cfs, af } and
1275     flow0700.0710(-2) < convert_units { 3, cfs, af } and flow0700.0710(-3) < convert_units { 3, cfs, af } and
1276     flow0700.0710(-4) < convert_units { 3, cfs, af } and flow0700.0710(-5) < convert_units { 3, cfs, af } and
1277     flow0700.0710(-6) < convert_units { 3, cfs, af }
1278     Value : 1
1279
1280     Condition : default
1281     Value : _Carth_Trigger_1_On(-1)
1282 }
1283 Condition : default
1284 Value : _Carth_Trigger_1_On(-1)
1285 }
1286
1287 /* Fayetteville - mostly demand based (w/ one Lillington trigger), so leaving out for now */
1288
1289
1290
1291 /* This section sets/resets the counters used to maintain the proper spacing of conservation stages */
1292
1293 :For:
1294 { [Util] = { Burl, Gree, High, Reid, Rams, GramMeb, Siler, Cary, ChatNo, Dunn, Carth, Benson }
1295 }
1296
1297 :For:
1298 { [trig] = {1, 2, 3, 4, 5, 6}
1299 }
1300
1301 Set : _[Util]_Stage_[trig]_Counter
1302 { Condition : _[Util]_Stage_[trig]_Counter(-1) > 0 and _[Util]_Trigger_[trig]_On = 0
1303     Value : 0
1304
1305     Condition : _[Util]_Trigger_[trig]_On = 1
1306     Value : _[Util]_Stage_[trig]_Counter(-1) + 1
1307
1308     Condition : default
1309     Value : _[Util]_Stage_[trig]_Counter(-1)
1310 }
1311
1312 /* Count all trigger events lasting at least 7 days */
1313
1314 Set : _[Util]_Ph_[trig]_event_counter
1315 { Condition : _[Util]_Stage_[trig]_Counter = 7 and _[Util]_Stage_[trig]_Counter(-1) = 6
1316     Value : _[Util]_Ph_[trig]_event_counter(-1) + 1
```

drought_plans_cf.ocf

```
1317
1318 Condition : default
1319 Value      : _[Util]_Ph_[trig]_event_counter(-1)
1320 }
1321
1322 :Next:
1323
1324 :Next:
1325
1326
1327 // Set conservation demand and delivery constraints for each trigger level in effect.
1328
1329 // Set demand reduction factors
1330 :SUBSTITUTE: [Dem_1_Red_Factor] = 5
1331 :SUBSTITUTE: [Dem_2_Red_Factor] = 10
1332 :SUBSTITUTE: [Dem_3_Red_Factor] = 20
1333 :SUBSTITUTE: [Dem_4_Red_Factor] = 25
1334 :SUBSTITUTE: [Dem_5_Red_Factor] = 35
1335 :SUBSTITUTE: [Dem_6_Red_Factor] = 50
1336
1337 :For:
1338 {   [trig] = {1, 2, 3, 4, 5, 6}
1339 }
1340
1341
1342
1343 // Burlington
1344 Set : _Burl2_Consvn_[trig]_Demand
1345 {   Condition : _Burl_Trigger_[trig]_On = 1
1346     Value      : Demand0341 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1347 }
1348 Condition : default
1349 Value      : Demand0341
1350 }
1351
1352 Constraint Burl2_Demand_Limit_Consvn_[trig] :
1353     {   Condition : _Burl_Trigger_[trig]_On = 1
1354         Expression : dflow0071.0341 <= _Burl2_Consvn_[trig]_Demand }
1355
1356 // Greensboro
1357 Set : _Gree2_Consvn_[trig]_Demand
1358 {   Condition : _Gree_Trigger_[trig]_On = 1
1359     Value      : Demand0123 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1360 }
1361 Condition : default
1362 Value      : Demand0123
1363 }
```

drought_plans_cf.ocf

```
1364
1365 Constraint Gree2_Demand_Limit_Consvn_[trig] :
1366     { Condition : _Gree_Trigger_[trig]_On = 1
1367       Expression : dflow0121.0123 <= _Gree2_Consvn_[trig]_Demand }
1368
1369 // High Point
1370 Set : _High_Consvn_[trig]_Demand
1371 { Condition : _High_Trigger_[trig]_On = 1
1372   Value   : Demand0223 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1373
1374   Condition : default
1375   Value     : Demand0223
1376 }
1377
1378 Constraint High_Demand_Limit_Consvn_[trig] :
1379     { Condition : _High_Trigger_[trig]_On = 1
1380       Expression : dflow0220.0221 <= _High_Consvn_[trig]_Demand }
1381
1382 // Reidsville
1383 Set : _Reid_Consvn_[trig]_Demand
1384 { Condition : _Reid_Trigger_[trig]_On = 1
1385   Value   : Demand0031 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1386
1387   Condition : default
1388   Value     : Demand0031
1389 }
1390
1391 Constraint Reid_Demand_Limit_Consvn_[trig] :
1392     { Condition : _Reid_Trigger_[trig]_On = 1
1393       Expression : dflow0029.0031 <= _Reid_Consvn_[trig]_Demand }
1394
1395 // Ramseur
1396 Set : _Rams_Consvn_[trig]_Demand
1397 { Condition : _Rams_Trigger_[trig]_On = 1
1398   Value   : Demand0301 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1399
1400   Condition : default
1401   Value     : Demand0301
1402 }
1403
1404 Constraint Rams_Demand_Limit_Consvn_[trig] :
1405     { Condition : _Rams_Trigger_[trig]_On = 1
1406       Expression : dflow0300.0301 <= _Rams_Consvn_[trig]_Demand }
1407
1408 // Graham-Mebane
1409 Set : _GramMeb_Consvn_[trig]_Demand
1410 { Condition : _GramMeb_Trigger_[trig]_On = 1
```

drought_plans_cf.ocf

```
1411 Value : Demand0321 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1412
1413 Condition : default
1414 Value : Demand0321
1415 }
1416
1417 Constraint GramMeb_Demand_Limit_Consvn_[trig] :
1418     { Condition : _GramMeb_Trigger_[trig]_On = 1
1419       Expression : dflow0319.0321 <= _GramMeb_Consvn_[trig]_Demand }
1420
1421 // Siler City
1422 Set : _Siler_Consvn_[trig]_Demand
1423 { Condition : _Siler_Trigger_[trig]_On = 1
1424   Value : Demand0327 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1425
1426   Condition : default
1427   Value : Demand0327
1428 }
1429
1430 Constraint Siler_Demand_Limit_Consvn_[trig] :
1431     { Condition : _Siler_Trigger_[trig]_On = 1
1432       Expression : dflow0325.0327 <= _Siler_Consvn_[trig]_Demand }
1433
1434 // Chatham-North
1435 Set : _ChatNo_Consvn_[trig]_Demand
1436 { Condition : _ChatNo_Trigger_[trig]_On = 1
1437   Value : Demand0473 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1438
1439   Condition : default
1440   Value : Demand0473
1441 }
1442
1443 Constraint ChatNo_Demand_Limit_Consvn_[trig] :
1444     { Condition : _ChatNo_Trigger_[trig]_On = 1
1445       Expression : dflow0470.0473 <= _ChatNo_Consvn_[trig]_Demand }
1446
1447 // Dunn
1448 Set : _Dunn_Consvn_[trig]_Demand
1449 { Condition : _Dunn_Trigger_[trig]_On = 1
1450   Value : Demand0663 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1451
1452   Condition : default
1453   Value : Demand0663
1454 }
1455
1456 Constraint Dunn_Demand_Limit_Consvn_[trig] :
1457     { Condition : _Dunn_Trigger_[trig]_On = 1
```

drought_plans_cf.ocf

```
1458      Expression : dflow0662.0663 <= _Dunn_Consvn_[trig]_Demand }
1459
1460 //Benson
1461 Set : _Benson_Consvn_[trig]_Demand
1462 { Condition : _Benson_Trigger_[trig]_On = 1
1463   Value   : Demand1756 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1464
1465   Condition : default
1466   Value   : Demand1756
1467 }
1468
1469 Constraint Benson_Demand_Limit_Consvn_[trig] :
1470   { Condition : _Benson_Trigger_[trig]_On = 1
1471     Expression : dflow0662.1756 <= _Benson_Consvn_[trig]_Demand }
1472
1473 // Carthage
1474 Set : _Carth_Consvn_[trig]_Demand
1475 { Condition : _Carth_Trigger_[trig]_On = 1
1476   Value   : Demand0701 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
1477
1478   Condition : default
1479   Value   : Demand0701
1480 }
1481
1482 Constraint Carth_Demand_Limit_Consvn_[trig] :
1483   { Condition : _Carth_Trigger_[trig]_On = 1
1484     Expression : dflow0700.0701 <= _Carth_Consvn_[trig]_Demand }
1485
1486
1487 :Next:
1488
1489 // Set Cary's Consv Demand - differs seasonally
1490
1491 Set : _Cary_Consvn_1_Demand
1492 {
1493   Condition : month > 4 and month < 11 and _Cary_Trigger_1_On = 1
1494   Value   : Demand0471 * ( 1 - 13 / 100 )
1495
1496   Condition : _Cary_Trigger_1_On = 1
1497   Value   : Demand0471 * ( 1 - 6 / 100 )
1498
1499   Condition : default
1500   Value   : Demand0471
1501 }
1502
1503 Set : _Cary_Consvn_2_Demand
1504 {
```

drought_plans_cf.ocf

```
1505 Condition : month > 4 and month < 11 and _Cary_Trigger_2_On = 1
1506 Value : Demand0471 * ( 1 - 32 / 100 )
1507
1508 Condition : _Cary_Trigger_2_On = 1
1509 Value : Demand0471 * ( 1 - 10 / 100 )
1510
1511 Condition : default
1512 Value : Demand0471
1513 }
1514
1515 Set : _Cary_Consvn_3_Demand
1516 {
1517 Condition : month > 4 and month < 11 and _Cary_Trigger_3_On = 1
1518 Value : Demand0471 * ( 1 - 38 / 100 )
1519
1520 Condition : _Cary_Trigger_3_On = 1
1521 Value : Demand0471 * ( 1 - 17 / 100 )
1522
1523 Condition : default
1524 Value : Demand0471
1525 }
1526
1527 Set : _Cary_Consvn_4_Demand
1528 {
1529 Condition : month > 4 and month < 11 and _Cary_Trigger_4_On = 1
1530 Value : Demand0471 * ( 1 - 46 / 100 )
1531
1532 Condition : _Cary_Trigger_4_On = 1
1533 Value : Demand0471 * ( 1 - 29 / 100 )
1534
1535 Condition : default
1536 Value : Demand0471
1537 }
1538
1539 :For:
1540 { [trig] = {1, 2, 3, 4}
1541 }
1542
1543 Constraint Cary_Demand_Limit_Consvn_[trig] :
1544 { Condition : _Cary_Trigger_[trig]_On = 1
1545 Expression : dflow0479.0471 <= _Cary_Consvn_[trig]_Demand }
1546
1547 :Next:
1548
1549 // Includes Morrisville & RTP
1550
1551 Set : _RTP_Consvn_1_Demand
```

drought_plans_cf.ocl

```
1552 {
1553   Condition : month > 4 and month < 11 and _Cary_Trigger_1_On = 1
1554   Value    : Demand0474 * ( 1 - 13 / 100 )
1555
1556   Condition : _Cary_Trigger_1_On = 1
1557   Value    : Demand0474 * ( 1 - 6 / 100 )
1558
1559   Condition : default
1560   Value    : Demand0474
1561 }
1562
1563 Set : _RTP_Consvn_2_Demand
1564 {
1565   Condition : month > 4 and month < 11 and _Cary_Trigger_2_On = 1
1566   Value    : Demand0474 * ( 1 - 32 / 100 )
1567
1568   Condition : _Cary_Trigger_2_On = 1
1569   Value    : Demand0474 * ( 1 - 10 / 100 )
1570
1571   Condition : default
1572   Value    : Demand0474
1573 }
1574
1575 Set : _RTP_Consvn_3_Demand
1576 {
1577   Condition : month > 4 and month < 11 and _Cary_Trigger_3_On = 1
1578   Value    : Demand0474 * ( 1 - 38 / 100 )
1579
1580   Condition : _Cary_Trigger_3_On = 1
1581   Value    : Demand0471 * ( 1 - 17 / 100 )
1582
1583   Condition : default
1584   Value    : Demand0474
1585 }
1586
1587 Set : _RTP_Consvn_4_Demand
1588 {
1589   Condition : month > 4 and month < 11 and _Cary_Trigger_4_On = 1
1590   Value    : Demand0474 * ( 1 - 46 / 100 )
1591
1592   Condition : _Cary_Trigger_4_On = 1
1593   Value    : Demand0474 * ( 1 - 29 / 100 )
1594
1595   Condition : default
1596   Value    : Demand0474
1597 }
1598
```

drought_plans_cf.ocf

```
1599 :For:
1600 { [trig] = {1, 2, 3, 4}
1601 }
1602
1603 Constraint RTP_Demand_Limit_Consvn_[trig] :
1604 { Condition : _Cary_Trigger_[trig]_On = 1
1605   Expression : dflow0479.0474 <= _RTP_Consvn_[trig]_Demand }
1606
1607 :Next:
1608
1609 Set : _Morris_Consvn_1_Demand
1610 {
1611   Condition : month > 4 and month < 11 and _Cary_Trigger_1_On = 1
1612   Value    : Demand0477 * ( 1 - 13 / 100 )
1613
1614   Condition : _Cary_Trigger_1_On = 1
1615   Value    : Demand0477 * ( 1 - 6 / 100 )
1616
1617   Condition : default
1618   Value    : Demand0471
1619 }
1620
1621 Set : _Morris_Consvn_2_Demand
1622 {
1623   Condition : month > 4 and month < 11 and _Cary_Trigger_2_On = 1
1624   Value    : Demand0477 * ( 1 - 32 / 100 )
1625
1626   Condition : _Cary_Trigger_2_On = 1
1627   Value    : Demand0477 * ( 1 - 10 / 100 )
1628
1629   Condition : default
1630   Value    : Demand0477
1631 }
1632
1633 Set : _Morris_Consvn_3_Demand
1634 {
1635   Condition : month > 4 and month < 11 and _Cary_Trigger_3_On = 1
1636   Value    : Demand0477 * ( 1 - 38 / 100 )
1637
1638   Condition : _Cary_Trigger_3_On = 1
1639   Value    : Demand0477 * ( 1 - 17 / 100 )
1640
1641   Condition : default
1642   Value    : Demand0477
1643 }
1644
1645 Set : _Morris_Consvn_4_Demand
```

drought_plans_cf.ocl

```
1646 {
1647   Condition : month > 4 and month < 11 and _Cary_Trigger_4_On = 1
1648   Value    : Demand0477 * ( 1 - 46 / 100 )
1649
1650   Condition : _Cary_Trigger_4_On = 1
1651   Value    : Demand0477 * ( 1 - 29 / 100 )
1652
1653   Condition : default
1654   Value    : Demand0477
1655 }
1656
1657 :For:
1658 { [trig] = {1, 2, 3, 4}
1659 }
1660
1661 Constraint Morris_Demand_Limit_Consvn_[trig] :
1662 { Condition : _Cary_Trigger_[trig]_On = 1
1663   Expression : dflow0479.0477 <= _Morris_Consvn_[trig]_Demand }
1664
1665 :Next:
1666
1667
1668
1669
1670 :else:
1671 // Do nothing if not using drought plans
1672 :endif:
1673
```

drought_plans_neuse.ocl

```
1 /* File is drought_plans_neuse.ocl. Computes trigger levels and demand reductions. */
2
3 :If: {[Drought_Plans_On] = 1} // First check if drought plan variable is on
4
5 //Note - Hillsborough and Orange-Alamance drought restrictions are handled in upper_eno_ops.ocl
6
7
8
9
10 // Raleigh -Turn triggers on based on monthly curves. Triggers are lifted when storage is above the trigger storage + 20% */
11 Set : _Ral_Trigger_1_On
12 {
13   Condition : _Ral_Trigger_1_On(-1) = 1
14   {
15     Condition : _Total_WS_Stor(-1) >= min { (lookup{ Ral_Trig1, month } + 20) / 100 * [Total_Max_WS_Storage], [Total_Max_WS_Storage] }
16     Value : 0
17
18     Condition : default
19     Value : _Ral_Trigger_1_On(-1)
20   }
21
22   Condition : weekday{year, month, day} <= 1
23   {
24     Condition : _Total_WS_Stor(-1) <= lookup{ Ral_Trig1, month } / 100 * [Total_Max_WS_Storage]
25     Value : 1
26   }
27
28   Condition : default
29   Value : _Ral_Trigger_1_On(-1)
30 }
31
32 Set : _Ral_Trigger_2_On
33 {
34   Condition : _Ral_Trigger_2_On(-1) = 1
35   {
36     Condition : _Total_WS_Stor(-1) >= (lookup{ Ral_Trig2, month } + 20) / 100 * [Total_Max_WS_Storage] //Total max ws storage
37     Value : 0
38
39     Condition : default
40     Value : _Ral_Trigger_2_On(-1)
41   }
42
43   Condition : _Ral_Stage_1_Counter(-1) >= 30
44   { Condition : weekday{year, month, day} <= 1
45     {
46       Condition : _Total_WS_Stor(-1) <= lookup{ Ral_Trig2, month } / 100 * [Total_Max_WS_Storage]
47       Value : 1
```

drought_plans_neuse.ocl

```
48  }
49
50  Condition : default
51    Value   : _Ral_Trigger_2_On(-1)
52  }
53
54  Condition : default
55    Value   : _Ral_Trigger_2_On(-1)
56  }
57
58  Set : _Ral_Trigger_3_On
59  {
60    Condition : _Ral_Trigger_3_On(-1) = 1
61    {
62      Condition : _Total_WS_Stor(-1) >= (lookup{ Ral_Trig3, month } + 20) / 100 * [Total_Max_WS_Storage]
63      Value     : 0
64    }
65    Condition : default
66    Value     : _Ral_Trigger_3_On(-1)
67  }
68
69  Condition : _Ral_Stage_2_Counter(-1) >= 30
70  { Condition : weekday{year, month, day} <= 1
71    {
72      Condition : _Total_WS_Stor(-1) <= lookup{ Ral_Trig3, month } / 100 * [Total_Max_WS_Storage]
73      Value     : 1
74    }
75  }
76  Condition : default
77    Value   : _Ral_Trigger_3_On(-1)
78  }
79
80  Condition : default
81    Value   : _Ral_Trigger_3_On(-1)
82  }
83
84  /* This section sets/resets the counters used to maintain the proper spacing
85     of conservation stages */
86
87  Set : _Ral_Stage_1_Counter
88  {
89    Condition : _Ral_Stage_1_Counter(-1) > 0
90    {
91      Condition : _Total_WS_Stor(-1) >= min { (lookup{ Ral_Trig1, month } + 20) / 100 * [Total_Max_WS_Storage], [Total_Max_WS_Storage] }
92      Value     : 0
93    }
94  }
```

drought_plans_neuse.ocl

```
95 Condition : _Ral_Trigger_1_On = 1
96 Value    : _Ral_Stage_1_Counter(-1) + 1
97
98
99 Condition : default
100 Value    : _Ral_Stage_1_Counter(-1)
101 }
102
103
104 Set : _Ral_Stage_2_Counter
105 {
106 Condition : _Ral_Stage_2_Counter(-1) > 0
107 {
108 Condition : _Total_WS_Stor(-1) >= (lookup{ Ral_Trig2, month } + 20) / 100 * [Total_Max_WS_Storage]
109 Value    : 0
110 }
111
112 Condition : _Ral_Trigger_2_On = 1
113 Value    : _Ral_Stage_2_Counter(-1) + 1
114
115
116 Condition : default
117 Value    : _Ral_Stage_2_Counter(-1)
118 }
119
120 Set : _Ral_Stage_3_Counter
121 {
122 Condition : _Ral_Stage_3_Counter(-1) > 0
123 {
124 Condition : _Total_WS_Stor(-1) >= (lookup{ Ral_Trig3, month } + 20) / 100 * [Total_Max_WS_Storage]
125 Value    : 0
126 }
127
128 Condition : _Ral_Trigger_3_On = 1
129 Value    : _Ral_Stage_3_Counter(-1) + 1
130
131
132 Condition : default
133 Value    : _Ral_Stage_3_Counter(-1)
134 }
135
136
137
138 /* This section determines the demand depending upon which level of conservation
139 is in place. */
140
141 Set : _Ral_Consvn_1_Demand
```

drought_plans_neuse.ocf

```
142 {
143   Condition : _Ral_Trigger_1_On = 1
144   Value    : Demand1306 * ( 1 - ( lookup { Raleigh_Stage1_Red, month } ) / 100 )
145
146   Condition : default
147   Value    : Demand1306
148 }
149
150 Set : _Ral_Consvn_2_Demand
151 {
152   Condition : _Ral_Trigger_2_On = 1
153   Value    : Demand1306 * ( 1 - ( lookup { Raleigh_Stage1_Red, month } + lookup { Raleigh_Stage2_Red, month } ) / 100 )
154
155   Condition : default
156   Value    : Demand1306
157 }
158
159 Set : _Ral_Consvn_3_Demand
160 {
161   Condition : _Ral_Trigger_3_On = 1
162   Value    : Demand1306 * ( 1 - ( lookup { Raleigh_Stage1_Red, month } + lookup { Raleigh_Stage2_Red, month }
163     + lookup { Raleigh_Stage3_Red, month } ) / 100 )
164
165   Condition : default
166   Value    : Demand1306
167 }
168
169 /* Constrain the water supply withdrawal to implement the desired conservation */
170
171 Constraint Demand_Limit_Consvn_1 :
172   { Condition : _Ral_Trigger_1_On = 1
173     Expression : ddelivery1306 <= _Ral_Consvn_1_Demand }
174
175 Constraint Demand_Limit_Consvn_2 :
176   { Condition : _Ral_Trigger_2_On = 1
177     Expression : ddelivery1306 <= _Ral_Consvn_2_Demand }
178
179 Constraint Demand_Limit_Consvn_3 :
180   { Condition : _Ral_Trigger_3_On = 1
181     Expression : ddelivery1306 <= _Ral_Consvn_3_Demand }
182
183
184 /* Turn on event counter whenever duration exceeds 4 days */
185
186 Set : _Ral_Ph_1_event_counter
187 { Condition : _Ral_Stage_1_Counter = 5 and _Ral_Stage_1_Counter(-1) = 4
188   Value : _Ral_Ph_1_event_counter(-1) + 1
```

drought_plans_neuse.ocl

```
189
190 Condition : default
191 Value      : _Ral_Ph_1_event_counter(-1)
192 }
193
194 Set : _Ral_Ph_2_event_counter
195 { Condition : _Ral_Stage_2_Counter = 5 and _Ral_Stage_2_Counter(-1) = 4
196   Value      : _Ral_Ph_2_event_counter(-1) + 1
197 }
198 Condition : default
199 Value      : _Ral_Ph_2_event_counter(-1)
200 }
201
202 Set : _Ral_Ph_3_event_counter
203 { Condition : _Ral_Stage_3_Counter = 5 and _Ral_Stage_3_Counter(-1) = 4
204   Value      : _Ral_Ph_3_event_counter(-1) + 1
205 }
206 Condition : default
207 Value      : _Ral_Ph_3_event_counter(-1)
208 }
209
210 // SGWASA
211
212 Set : _SGWASA_Trigger_5_On
213 { Condition : _SGWASA_Trigger_5_On(-1) = 1
214   { Condition : elevation1250 >= 356
215     Value      : 0
216   }
217   Condition : default
218   Value      : _SGWASA_Trigger_5_On(-1)
219 }
220
221 Condition : _SGWASA_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
222 { Condition : weekday{year, month, day} <= 1
223   { Condition : elevation1250 <= 320
224     Value      : 1
225   }
226   Condition : default
227   Value      : _SGWASA_Trigger_5_On(-1)
228 }
229 Condition : default
230 Value      : _SGWASA_Trigger_5_On(-1)
231 }
232
233 Set : _SGWASA_Trigger_4_On
234 { Condition : _SGWASA_Trigger_4_On(-1) = 1
235   { Condition : elevation1250 >= 356
```

drought_plans_neuse.ocl

```
236     Value    : 0
237
238     Condition : default
239     Value     : _SGWASA_Trigger_4_On(-1)
240 }
241
242 Condition : _SGWASA_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
243 { Condition : weekday{year, month, day} <= 1
244   { Condition : elevation1250 < 340.5
245     Value     : 1
246   }
247   Condition : default
248   Value     : _SGWASA_Trigger_4_On(-1)
249 }
250 Condition : default
251 Value     : _SGWASA_Trigger_4_On(-1)
252 }
253
254 Set : _SGWASA_Trigger_3_On
255 { Condition : _SGWASA_Trigger_3_On(-1) = 1
256   { Condition : elevation1250 >= 356
257     Value     : 0
258   }
259   Condition : default
260   Value     : _SGWASA_Trigger_3_On(-1)
261 }
262
263 Condition : _SGWASA_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
264 { Condition : weekday{year, month, day} <= 1
265   { Condition : elevation1250 < 343.08
266     Value     : 1
267   }
268   Condition : default
269   Value     : _SGWASA_Trigger_3_On(-1)
270 }
271 Condition : default
272 Value     : _SGWASA_Trigger_3_On(-1)
273 }
274
275
276 Set : _SGWASA_Trigger_2_On
277 { Condition : _SGWASA_Trigger_2_On(-1) = 1
278   { Condition : elevation1250 >= 356
279     Value     : 0
280   }
281   Condition : default
282   Value     : _SGWASA_Trigger_2_On(-1)
```

drought_plans_neuse.ocl

```
283 }
284
285 Condition : _SGWASA_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
286 { Condition : weekday{year, month, day} <= 1
287   { Condition : elevation1250 < 345.25
288     Value : 1
289   }
290   Condition : default
291   Value : _SGWASA_Trigger_2_On(-1)
292 }
293 Condition : default
294 Value : _SGWASA_Trigger_2_On(-1)
295 }
296
297
298 Set : _SGWASA_Trigger_1_On
299 { Condition : _SGWASA_Trigger_1_On(-1) = 1
300   { Condition : elevation1250 >= 356
301     Value : 0
302   }
303   Condition : default
304   Value : _SGWASA_Trigger_1_On(-1)
305 }
306
307 Condition : weekday{year, month, day} <= 1
308 { Condition : elevation1250 < 349.67
309   Value : 1
310 }
311 Condition : default
312 Value : _SGWASA_Trigger_1_On(-1)
313 }
314 Condition : default
315 Value : _SGWASA_Trigger_1_On(-1)
316 }
317
318 // Wilson
319
320 Set : _Wilson_Trigger_5_On
321 { Condition : _Wilson_Trigger_5_On(-1) = 1
322   { Condition : elevation1500 >= 148
323     Value : 0
324   }
325   Condition : default
326   Value : _Wilson_Trigger_5_On(-1)
327 }
328
329 Condition : _Wilson_Stage_4_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 5
```

drought_plans_neuse.ocl

```
330 { Condition : weekday{year, month, day} <= 1
331 { Condition : elevation1500<= 135
332 Value : 1
333 }
334 Condition : default
335 Value : _Wilson_Trigger_5_On(-1)
336 }
337 Condition : default
338 Value : _Wilson_Trigger_5_On(-1)
339 }
340
341 Set : _Wilson_Trigger_4_On
342 { Condition : _Wilson_Trigger_4_On(-1) = 1
343 { Condition : elevation1500 >= 148
344 Value : 0
345
346 Condition : default
347 Value : _Wilson_Trigger_4_On(-1)
348 }
349
350 Condition : _Wilson_Stage_3_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 4
351 { Condition : weekday{year, month, day} <= 1
352 { Condition : elevation1500< 138
353 Value : 1
354 }
355 Condition : default
356 Value : _Wilson_Trigger_4_On(-1)
357 }
358 Condition : default
359 Value : _Wilson_Trigger_4_On(-1)
360 }
361
362 Set : _Wilson_Trigger_3_On
363 { Condition : _Wilson_Trigger_3_On(-1) = 1
364 { Condition : elevation1500 >= 148
365 Value : 0
366
367 Condition : default
368 Value : _Wilson_Trigger_3_On(-1)
369 }
370
371 Condition : _Wilson_Stage_2_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 3
372 { Condition : weekday{year, month, day} <= 1
373 { Condition : elevation1500< 140
374 Value : 1
375 }
376 Condition : default
```

drought_plans_neuse.ocl

```
377     Value   : _Wilson_Trigger_3_On(-1)
378 }
379 Condition : default
380 Value     : _Wilson_Trigger_3_On(-1)
381 }
382
383
384 Set : _Wilson_Trigger_2_On
385 { Condition : _Wilson_Trigger_2_On(-1) = 1
386   { Condition : elevation1500 >= 148
387     Value     : 0
388
389     Condition : default
390     Value     : _Wilson_Trigger_2_On(-1)
391   }
392
393   Condition : _Wilson_Stage_1_Counter(-1) >= 14 // Require a 14 day waiting period before going into phase 2
394   { Condition : weekday{year, month, day} <= 1
395     { Condition : elevation1500 < 142
396       Value     : 1
397     }
398     Condition : default
399     Value     : _Wilson_Trigger_2_On(-1)
400   }
401   Condition : default
402   Value     : _Wilson_Trigger_2_On(-1)
403 }
404
405
406 Set : _Wilson_Trigger_1_On
407 { Condition : _Wilson_Trigger_1_On(-1) = 1
408   { Condition : elevation1500 >= 148
409     Value     : 0
410
411     Condition : default
412     Value     : _Wilson_Trigger_1_On(-1)
413   }
414
415   Condition : weekday{year, month, day} <= 1
416   { Condition : elevation1500 < 144
417     Value     : 1
418
419     Condition : default
420     Value     : _Wilson_Trigger_1_On(-1)
421   }
422   Condition : default
423   Value     : _Wilson_Trigger_1_On(-1)
```

drought_plans_neuse.ocl

```
424 }
425
426 /* This section sets/resets the counters used to maintain the proper spacing of conservation stages */
427
428 :For:
429 { [Util] = { SGWASA, Wilson }
430 }
431
432 :For:
433 { [trig] = {1, 2, 3, 4, 5}
434 }
435
436 Set : _[Util]_Stage_[trig]_Counter
437 { Condition : _[Util]_Stage_[trig]_Counter(-1) > 0 and _[Util]_Trigger_[trig]_On = 0
438   Value : 0
439
440   Condition : _[Util]_Trigger_[trig]_On = 1
441   Value : _[Util]_Stage_[trig]_Counter(-1) + 1
442
443   Condition : default
444   Value : _[Util]_Stage_[trig]_Counter(-1)
445 }
446
447 /* Count all trigger events lasting at least 7 days */
448
449 Set : _[Util]_Ph_[trig]_event_counter
450 { Condition : _[Util]_Stage_[trig]_Counter = 7 and _[Util]_Stage_[trig]_Counter(-1) = 6
451   Value : _[Util]_Ph_[trig]_event_counter(-1) + 1
452
453   Condition : default
454   Value : _[Util]_Ph_[trig]_event_counter(-1)
455 }
456
457 :Next:
458
459 :Next:
460
461
462 // Set conservation demand and delivery constraints for each trigger level in effect.
463
464 // Set demand reduction factors
465 :SUBSTITUTE: [Dem_1_Red_Factor] = 5
466 :SUBSTITUTE: [Dem_2_Red_Factor] = 10
467 :SUBSTITUTE: [Dem_3_Red_Factor] = 20
468 :SUBSTITUTE: [Dem_4_Red_Factor] = 25
469 :SUBSTITUTE: [Dem_5_Red_Factor] = 35
470 :SUBSTITUTE: [Dem_6_Red_Factor] = 50
```

drought_plans_neuse.ocf

```
471
472 :For:
473 { [trig] = {1, 2, 3, 4, 5}
474 }
475
476
477
478 // SGWASA
479 Set : _SGWASA_Consvn_[trig]_Demand
480 { Condition : _SGWASA_Trigger_[trig]_On = 1
481   Value   : Demand1256 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
482
483   Condition : default
484   Value   : Demand1256
485 }
486
487 Constraint SGWASA_Demand_Limit_Consvn_[trig] :
488   { Condition : _SGWASA_Trigger_[trig]_On = 1
489     Expression : dflow1250.1256 <= _SGWASA_Consvn_[trig]_Demand }
490
491 //Wilson
492 Set : _Wilson_Consvn_[trig]_Demand
493 { Condition : _Wilson_Trigger_[trig]_On = 1
494   Value   : Demand1506 * ( 1 - [Dem_[trig]_Red_Factor] / 100 )
495
496   Condition : default
497   Value   : Demand1506
498 }
499
500 Constraint Wilson_Demand_Limit_Consvn_[trig] :
501   { Condition : _Wilson_Trigger_[trig]_On = 1
502     Expression : dflow1520.1505 <= _Wilson_Consvn_[trig]_Demand }
503
504 :Next:
505
506 :else:
507 // Do nothing if not using drought plans
508 :endif:
```

drought_protocol_Jordan.ocl

```
1 // Drought protocol
2
3 :SUBSTITUTE: [WQ_Pct_Remaining_Stage_1] = 80
4 :SUBSTITUTE: [WQ_Pct_Remaining_Stage_2] = 60
5 :SUBSTITUTE: [WQ_Pct_Remaining_Stage_3] = 40
6 :SUBSTITUTE: [WQ_Pct_Remaining_Stage_4] = 20
7 :SUBSTITUTE: [Jordan_Minimum_Release_Normal] = 40
8 :SUBSTITUTE: [Jordan_Minimum_Release_Stage_1] = 40
9 :SUBSTITUTE: [Jordan_Minimum_Release_Stage_2] = 40
10 :SUBSTITUTE: [Jordan_Minimum_Release_Stage_3] = 200
11 :SUBSTITUTE: [Jordan_Minimum_Release_Stage_4] = 100
12
13 :SUBSTITUTE: [Level_Change_Time_Interval] = 7
14
15
16
17 // Determine average inflow to WQ account over the last 14 days
18 Set : _Avg_JLake_Inflow
19 { condition : abs_period = 1
20 value : inflow0470
21
22 condition : abs_period <= 14
23 value : _JLake_WQ_Inf(-1)
24
25 condition : default
26 value : accumulate{ _JLake_WQ_Inf(-1) , -14, -1 } / 14
27 }
28
29
30 /* Determine which zone of the WQ pool the lake is in. In the udef list, initialize the WQ storage to the starting storage as defined
31 in the constants table.*/
32 Set : _WQZone
33 { condition : _WQ_Storage(-1) / [Max_WQ_Storage] * 100 <= [WQ_Pct_Remaining_Stage_4] /* WQ Zone 4 */
34 value : 4
35
36 condition : _WQ_Storage(-1) / [Max_WQ_Storage] * 100 <= [WQ_Pct_Remaining_Stage_3] /* WQ Zone 3 */
37 value : 3
38
39 condition : _WQ_Storage(-1) / [Max_WQ_Storage] * 100 <= [WQ_Pct_Remaining_Stage_2] /* WQ Zone 2 */
40 value : 2
41
42 condition : _WQ_Storage(-1) / [Max_WQ_Storage] * 100 <= [WQ_Pct_Remaining_Stage_1] /* WQ Zone 1 */
43 value : 1
44
45 condition : default /* WQ Zone 0 (Normal Operations) [right now, 80% and above) */
46 value : 0
47 }
```

drought_protocol_Jordan.ocl

```
48
49 /* This is to set the triggers. In all cases, the triggers and associated level counters are reset to zero when the elevation reaches 216 feet.
50
51 For the first trigger, activate it when the water quality zone reaches 1.
52 The triggers for other levels activate whenever the pond hits that water quality zone (or lower) and a specified number of days in the prior level
53 has elapsed. The specified number of days (specified in the OCL constants) is the minimum interval between levels. In other words, the trigger will
54 stay in place for at least a specified number of days (even if the zone drops below that level) at which time the next trigger goes on.
55
56 Each level # is associated with the water quality zone.
57
58 Note that on refill, no skipping of levels is allowed. The WQ Zone must improve two levels before turning off the next level trigger. */
59
60 Set : _Trigger_1_On
61 { // For first day of simulation, set to the initial value in the udef list as defined in the constants table. User may wish to simulate conditions
62 // starting with a certain trigger condition. Setting the WQ zone would not be adequate since there is generally a waiting period between triggers.
63 // The trigger condition is important since it sets the minimum release from Jordan and target flow at Lillington.
64 condition : abs_period = 1
65 value : _Trigger_1_On(-1)
66
67 // Turning off trigger
68 condition : _Count_Trigger_1(-1) > 0 and elevation0470 < 216
69 { condition : _Trigger_2_On(-1) = 1 // during drawdown
70 value : 0
71
72 condition : default // during refill, trigger will stay on as long as pond has not refilled to 216 feet
73 value : _Trigger_1_On(-1)
74 }
75
76 // Turning on trigger
77
78 // The first condition is during drawdown. WQ zone could drop to zones 2 through 4, but those triggers cannot go on until passing through the
79 // first trigger. Once we've gotten to the second and higher triggers, the 1st trigger will turn off, as there is no waiting period.
80 condition : _WQZone >= 1 and elevation0470 < 216 and _Trigger_2_On(-1) = 0 and _Trigger_3_On(-1) = 0 and _Trigger_4_On(-1) = 0
81 Value : 1
82
83 // for turning on trigger during refill. It cannot turn on again if pond has refilled to 216 feet.
84 condition : _Trigger_2_On(-1) = 1 and _WQZone = 0 and elevation0470 < 216
85 Value : 1
86
87 // Otherwise, trigger is off
88 Condition : default
89 Value : 0
90 }
91
92 // Logic is similar for the other triggers.
93 Set : _Trigger_2_On
94 { condition : abs_period = 1
```

drought_protocol_Jordan.ocl

```
95 value    : _Trigger_2_On(-1)
96
97 // Turning off trigger
98 condition : _Count_Trigger_2(-1) > 0 and elevation0470 < 216
99 { condition : _Trigger_3_On(-1) = 1 // during drawdown
100 value    : 0
101
102 condition : _WQZone <= 0 // during refill.
103 value    : 0
104
105 condition : default
106 value    : _Trigger_2_On(-1)
107 }
108
109 // Turning on trigger
110
111 // The first condition is during drawdown
112 condition : _Count_Trigger_1(-1) >= [Level_Change_Time_Interval] and _WQZone >= 2 and elevation0470 < 216
113 Value    : 1
114
115 // The second condition is during refill. It cannot turn on again unless WQ zone is two zones higher than yesterday.
116 condition : _Trigger_3_On(-1) = 1 and _WQZone <= 1 and elevation0470 < 216
117 value    : 1
118
119 // Otherwise, trigger is off
120 Condition : default
121 Value    : 0
122 }
123
124
125 Set : _Trigger_3_On
126 { condition : abs_period = 1
127 value    : _Trigger_3_On(-1)
128
129 // Turning off trigger
130 condition : _Count_Trigger_3(-1) > 0 and elevation0470 < 216
131 { condition : _Trigger_4_On(-1) > 0 // during drawdown
132 value    : 0
133
134 condition : _WQZone <= 1 // during refill
135 value    : 0
136
137 condition : default
138 value    : _Trigger_3_On(-1)
139 }
140
141 // Turning on trigger
```

drought_protocol_Jordan.ocl

```
142
143 // The first condition is during drawdown
144 condition : _Count_Trigger_2(-1) >= [Level_Change_Time_Interval] and _WQZone >= 3 and elevation0470 < 216
145   Value   : 1
146
147 // The second condition is during refill.
148 condition : _Trigger_4_On(-1) = 1 and _WQZone <= 2 and elevation0470 < 216
149 value    : 1
150
151 // Otherwise, trigger is off
152 Condition : default
153 Value    : 0
154 }
155
156 Set : _Trigger_4_On
157 { condition : abs_period = 1
158 value    : _Trigger_4_On(-1)
159
160 // Turning off trigger
161 condition : _Count_Trigger_4(-1) > 0 and elevation0470 < 216
162 { condition : _WQZone <= 2 // during refill.
163 value    : 0
164
165 condition : default
166 value    : _Trigger_4_On(-1)
167 }
168
169 // Turning on trigger
170
171 // During drawdown
172 condition : _Count_Trigger_3(-1) >= [Level_Change_Time_Interval] and _WQZone >= 4 and elevation0470 < 216
173 Value    : 1
174
175 // Otherwise, trigger is off
176 Condition : default
177 Value    : 0
178 }
179
180
181
182
183 /* The following lines set the drought stage according to which triggers are on and for how long.*/
184 Set : _Drought_Stage
185 { condition : _Trigger_4_On = 1
186 value    : 4
187
188 condition : _Trigger_3_On = 1
```

drought_protocol_Jordan.ocl

```
189  value  : 3
190
191  condition : _Trigger_2_On = 1
192  value  : 2
193
194  condition : _Trigger_1_On = 1
195  value  : 1
196
197  condition : _Trigger_1_On(-1) = 1 or _Trigger_2_On(-1) = 1 or _Trigger_3_On(-1) = 1 or _Trigger_4_On(-1) = 1
198  value  : _WQZone
199
200  condition : default
201  value  : 0
202 }
203
204
205 // This is for determining whether the lake is drawing down based on changing WQ zones (rather than just day to day change in WQ storage
206 // while in that zone). Turn the index off only if the WQ zone increases during refill.
207 Set : _Level_Drawdown
208 { condition : _Level_Drawdown(-1) = 1
209     { condition : _Drought_Stage < _Drought_Stage(-1)
210         value  : 0
211     }
212     condition : default
213     value  : _Level_Drawdown(-1)
214 }
215
216 condition : _Drought_Stage > _Drought_Stage(-1)
217 value  : 1
218
219 condition : default
220 value  : 0
221 }
222
223
224 // These are the counters associated with each trigger
225
226 // Do FOR:NEXT loop since the counters are the same for all Jordan Lake trigger levels. Here, DWR has chosen
227 // to end a trigger level when the next has been reached rather than keeping it on for the entire drought.
228
229 :FOR:
230 { [Level] = { 1, 2, 3, 4 } }
231
232 // Number of days in which counter is on and the number of days in each drought stage
233 Set : _Count_Trigger_[Level]
234 {
235     Condition : _Count_Trigger_[Level](-1) >= 1
```

drought_protocol_Jordan.ocf

```
236 {
237     Condition : _Trigger_[Level]_On = 0
238     Value    : 0
239
240     Condition : default
241     Value    : _Count_Trigger_[Level](-1) + 1
242 }
243
244 Condition : _Trigger_[Level]_On = 1
245 Value    : 1
246
247 Condition : default
248 Value    : 0
249 }
250
251 // DWR included this counter for determining total # of days at each level over the simulation period. Here the
252 // trigger stays on and is counted even if another trigger has been reached.
253 Set : _Total_Count_Trigger_[Level]
254 { Condition : _Count_Trigger_[Level] > 0
255     Value    : _Total_Count_Trigger_[Level](-1) + 1
256
257     Condition : default
258     Value    : 0
259 }
260
261
262 // Establish a day counter which resets after _ days have elapsed as defined by the user for the [Level Change Time Interval].
263 // This will be used to determine adjustments to the Lillington target after the day counter reaches the time interval
264 Set : _CumDayWithinInt_[Level]
265 { condition : _CumDayWithinInt_[Level](-1) = [Level_Change_Time_Interval]
266 { condition : _Trigger_[Level]_On = 1
267     value    : 1
268
269 condition : default
270 value    : 0
271 }
272
273 condition : _Trigger_[Level]_On = 1
274 value    : _CumDayWithinInt_[Level](-1) + 1
275
276 condition : default
277 value    : 0
278 }
279
280
281 :NEXT:
282
```

drought_protocol_Jordan.ocl

```
283 /* These are counters to track the number of times (events) in the record each trigger level would have activated. This is not the same as tracking
284 as how often a zone is reached due to the criteria for switching levels (which include a waiting period). Events are arbitrarily selected to last
285 at least 5 days. In other words, the phase 1 counter will solve to 2 if in 2 drought years, trigger 1 is activated twice, each time lasting at least 5 days.
286 If the trigger is reactivated during refill, and if it lasts for 5 days, the phase event will be counted here. To get a better representation of the actual
287 number of drought events, not the drawdown and refill events, may need to adjust this code. */
288
289 :FOR:
290 { [Level] = { 1, 2, 3, 4 } }
291
292 Set : _Ph_[Level]_event_count
293 { Condition : _Count_Trigger_[level] = 5 and _Count_Trigger_[level](-1) = 4
294   Value : _Ph_[Level]_event_count(-1) + 1
295
296   Condition : default
297   Value : _Ph_[Level]_event_count(-1)
298 }
299
300 :NEXT:
301
302
303 /* The following lines determine the Lillington target according to the drought level and the number of days at that drought level.
304 The target at Lillington steps down (on drawdown) or up (on refill) by a specified amount every specified number of
305 days (Level_Change_Time_Interval).*/
306 :substitute: [Lillington_Increment_Stage_1] = 50 /* In cfs */
307 :substitute: [Lillington_Increment_Stage_2] = 50 /* In cfs */
308 :substitute: [Lillington_Increment_Stage_3] = 0 /* In cfs */
309 :substitute: [Lillington_Increment_Stage_4] = 0 /* In cfs */
310 :substitute: [Lillington_Lower_Target_Stage_1] = 450 /* In cfs */
311 :substitute: [Lillington_Lower_Target_Stage_2] = 300 /* In cfs */
312 :substitute: [Lillington_Lower_Target_Stage_3] = 0 /* In cfs */
313 :substitute: [Lillington_Lower_Target_Stage_4] = 0 /* In cfs */
314 :substitute: [Lillington_Upper_Target_Stage_1] = 600 /* In cfs */
315 :substitute: [Lillington_Upper_Target_Stage_2] = 450 /* In cfs */
316 :substitute: [Lillington_Upper_Target_Stage_3] = 0 /* In cfs */
317 :substitute: [Lillington_Upper_Target_Stage_4] = 0 /* In cfs */
318
319
320 :FOR:
321 { [Level] = { 1, 2, 3, 4 } }
322
323 Set : _Lill_Target_[Level]
324 { /* for moving into more restrictive drought phases (based on trigger conditions) during drawdown. On the first day of entering
325 the more restrictive trigger, set the target to the upper end of the target range associated with that trigger. Do not do
326 this if in the previous phase (as expressed by yesterday's Lillington target value, or min_flow0550.0555(-1)), the target
327 was at the lower end of the lower phase. In this case, drop down by the user-defined increment right away. */
328   condition : _Drought_Stage > _Drought_Stage(-1)
329   { condition : min_flow0550.0555(-1) = convert_units {[Lillington_Upper_Target_Stage_[Level]], cfs, af}
```

drought_protocol_Jordan.ocl

```
330     value    : convert_units {[Lillington_Upper_Target_Stage_[Level]] - [Lillington_Increment_Stage_[Level]], cfs, af}
331
332     condition : default
333     value     : convert_units {[Lillington_Upper_Target_Stage_[Level]], cfs, af}
334 }
335
336 /* For moving into less restrictive drought phases during refill. Only apply the lower end of the target range to be conservative.
337 For example, if the range is 450 to 600 cfs, keep the target at 450 cfs throughout that period (even if longer than 7 days). */
338 condition : _Drought_Stage < _Drought_Stage(-1)
339     value    : convert_units {[Lillington_Lower_Target_Stage_[Level]], cfs, af}
340
341 // if drawdown is continuing, but the drought phase has not changed
342     condition : _Level_Drawdown = 1
343 { // reduce target by user-defined increments, but only when the user-defined time interval has been reached. The lowest value it
344 // can reach is the lower range of the target. The target will be reduced even if WQ storage is increasing while in this drought
345 // level, again to be conservative.
346 condition : _CumDayWithinInt_[Level] = [Level_Change_Time_Interval]
347     value    : max { convert_units {[Lillington_Lower_Target_Stage_[Level]], cfs, af},
348         _Lill_Target_[Level](-1) - convert_units { [Lillington_Increment_Stage_[Level]], cfs, af} }
349
350 condition : default
351     value    : _Lill_Target_[Level](-1)
352 }
353
354 // if refill is occurring, but the drought phase has not changed. Set to the lower end of the target range throughout that particular drought phase.
355 condition : _Level_Drawdown = 0
356     value    : _Lill_Target_[Level](-1)
357
358 // default condition is to set the target to its upper level
359 condition : default
360     value    : convert_units {[Lillington_Upper_Target_Stage_[Level]], cfs, af}
361 }
362
363 :NEXT:
364
365 // Now set the min flow at Lillington based on the computed target
366 Set : min_flow0550.0555
367 { condition : _Trigger_4_On = 1
368     value    : _Lill_Target_4
369
370 condition : _Trigger_3_On = 1
371     value    : _Lill_Target_3
372
373 condition : _Trigger_2_On = 1
374     value    : _Lill_Target_2
375
376 condition : _Trigger_1_On = 1
```

drought_protocol_Jordan.ocl

```
377 value : _Lill_Target_1
378
379 condition : _Trigger_1_On(-1) = 1 or _Trigger_2_On(-1) = 1 or _Trigger_3_On(-1) = 1 or _Trigger_4_On(-1) = 1
380 value : min_flow0550.0555(-1)
381
382 condition : default // which will apply if the lake refills
383 value : convert_units {[Lillington_Target_Normal], cfs, af}
384 }
385
386 // Adjust the min release from Jordan depending on drought trigger condition.
387
388 Set : min_flow0470.0480
389 { /* For trigger 3 and 4 conditions, reduce the minimum release if there is enough local inflow to provide a minimum
390 of 300 cfs at Lillington.The net withdrawal in this reach (between Deep River Moncure gage, Jordan Lake, and
391 Lillington gage) can be approximated using the largest withdrawals (Sanford and Harnett County) and WW returns
392 (Western Wake) using yesterday's flows. Factor this in to meet the 300 cfs minimum; Releases will be higher to
393 meet local net withdrawals down to Lillington due to weighting. Never release less than 40 cfs. */
394 condition : _Trigger_4_On = 1
395 value : max { convert_units{40, cfs, af},
396 min {convert_units{ [Jordan_Minimum_Release_Stage_4], cfs, af}, convert_units {300, cfs, af}
397 + flow0550.0549 + flow0490.0489 - flow0930.0510
398 - (inflow0550 + inflow0490 + flow0527.0510 + flow0640.0480 ) } }
399
400 condition : _Trigger_3_On = 1
401 value : max { convert_units{40, cfs, af},
402 min {convert_units{ [Jordan_Minimum_Release_Stage_3], cfs, af}, convert_units {300, cfs, af}
403 + flow0550.0549 + flow0490.0489 - flow0930.0510
404 - (inflow0550 + inflow0490 + flow0527.0510 + flow0640.0480 ) } }
405
406 condition : _Trigger_2_On = 1
407 value : convert_units{ [Jordan_Minimum_Release_Stage_2], cfs, af}
408
409 condition : _Trigger_1_On = 1
410 value : convert_units{ [Jordan_Minimum_Release_Stage_1], cfs, af}
411
412 condition : _Trigger_1_On(-1) = 1 or _Trigger_2_On(-1) = 1 or _Trigger_3_On(-1) = 1 or _Trigger_4_On(-1) = 1
413 value : min_flow0470.0480(-1)
414
415 condition : default
416 value : convert_units{ [Jordan_Minimum_Release_Normal], cfs, af}
417 }
418
419
```

Durham_ops.ocl

```
1 /* DURHAM_OPS.OCL */
2
3 /* Operational policy for Durham's system */
4
5 Set: _Durham_Tot_Use_Stor { value: max_stor1140 + max_stor1200 - (lower_rule1140 + lower_rule1200)}
6 Set: _Durham_Stor { value: storage1140 + storage1200}
7 Set: _Durham_Use_Stor { value: _Durham_Stor - (lower_rule1140 + lower_rule1200)}
8 Set: _Durham_Pct_Use_Stor { value: 100 * _Durham_Use_Stor / _Durham_Tot_Use_Stor }
9 Set: _Durham_TQ_Pct_Use_Stor { value: ( storage1120 - lower_rule1120 ) / (max_stor1120 - lower_rule1120 ) * 100 }
10
11
12 /* Sets the Little River Reservoir (Durham) minimum release - based on usable storage (per SEPA/NEPA [EIS] process) and time of year.
13 Lake Michie min release also is tied to usable storage. Note reference is to dead_stor since that defines the bottom of the usable
14 storage and will change with sedimentation associated with demand year. It is not tied to lower rule since the lower rule embeds
15 a reserve in the calculation and would artificially reduce the usable storage for making the min release. */
16
17 Set LittleRiverRelease : min_flow1200.1205
18 { condition : ( storage1200 - dead_stor1200 ) / (max_stor1200 - dead_stor1200) < 0.7
19   value   : convert_units {0.64,cfs,af}
20
21   condition : month > 5 and month < 12
22   value   : convert_units {2.0,cfs,af}
23
24   condition : default
25   value   : convert_units {6.0,cfs,af}
26 }
27
28
29 // For this 2055 year scenario, no planned use of the Eno to refill Teer Quarry, so shut off. Quarry would be refilled from Lake Michie.
30
31 Set Teer_Quarry_Eno_River_Refill : max_flow1115.1120 { value : 0 }
32
33 Set: _Durham_estim_spill // Used to determine Lake Michie min release and refill of Teer Quarry
34 {
35   condition : default
36   value   : max { 0,
37     (storage1140 + inflow1140 - evap1140 - demand1142)
38     + (storage1200 + inflow1200 - evap1200 - min_flow1200.1205 - demand1202)
39     - demand1162 - (max_stor1140 + max_stor1200),
40     (storage1140 + inflow1140 - evap1140 - demand1142 - demand1162 - max_stor1140) }
41   // This last term anticipates when LM will spill unavoidably when LRR is not yet near full
42 }
43
44 // For refill of quarry from Michie, contain same transfer provisions on the deadband and the Falls upper rule 1-inch allowance.
45 Set Teer_Quarry_Lake_Michie_Refill : max_flow1140.1120
46 {
47   condition : convert_units{_Durham_estim_spill, af, cfs} >= 11.75
```

Durham_ops.ocl

```
48   and (storage1120 + 10) < max_stor1120
49   and elevation1300 >= ( [Falls_upper_rule] - 0.083 )
50   value    : convert_units{ [TQ_Max_LM_Refill_Rate] , mgd , af }
51
52   condition : default
53   value     : 0
54
55 }
56
57 // Assume no supply from Little River to the quarry
58 Constraint : {dFlow1200.1120 = 0 }
59
60
61 Set TeerQuarrySupply: max_flow1120.1151
62 {
63   condition : (_Durham_Trigger_2_On(-1) = 1 or _Durham_Trigger_3_On(-1) = 1 or _Durham_Trigger_4_On(-1) = 1)
64   and storage1120 > lower_rule1120
65   and _Durham_TQ_Pct_Use_Stor > _Durham_Pct_Use_Stor //After reaching Stage 2
66   value     : convert_units {20, mgd, af}
67
68   condition : _Durham_Trigger_1_On(-1) = 1 and storage1120 > lower_rule1120
69   and _Durham_TQ_Pct_Use_Stor > _Durham_Pct_Use_Stor
70   and (Month >10 or Month <4)
71   value     : convert_units {5, mgd, af}
72
73   condition : _Durham_Trigger_1_On(-1) = 1 and storage1120 > lower_rule1120
74   and _Durham_TQ_Pct_Use_Stor > _Durham_Pct_Use_Stor
75   and (Month >3 or Month <11)
76   value     : convert_units {10, mgd, af}
77
78   condition : default
79   value     : 0
80 }
81
82
83 // Set the new minimum release for Lake Michie.
84 Set LakeMichie_min_release : min_flow1140.1205
85 { // One of the conditions for pumping from Michie to the quarry is a minimum flowby of 11.75 cfs below the dam.
86   condition : convert_units{_Durham_estim_spill, af, cfs} > 11.75
87   and (storage1120 + 10) < max_stor1120 and elevation1300 >= ([Falls_upper_rule] - 0.083)
88   value     : convert_units {11.75 ,cfs,af}
89
90 // when below 40% storage (assume usable storage)
91   condition : (storage1140 - dead_stor1140) / ( upper_rule1140 - dead_stor1140) <= 0.4
92   value     : convert_units {0.61,cfs,af}
93
94 // 40% - 70% storage release tier
```

Durham_ops.ocl

```
95 condition : (storage1140 - dead_stor1140) / ( upper_rule1140 - dead_stor1140) <= 0.7
96 value    : convert_units {1.2,cfs,af}
97
98 condition : default
99 value    : convert_units {1.75,cfs,af}
100 }
101
102
103 // Assume baseloading from the WIP of 16.5 mgd assuming sufficient storage in Durham and OWASA Jordan Lake accounts.
104 Target Jordan_Lake_usage : dFlow0468.1151
105 { condition : default
106   priority : 1
107   penalty+ : 500
108   penalty- : 500
109   Value    : min { demand1162, convert_units {16.5, mgd, af}, _Storage_Durham(-1) + _Storage_OWASA(-1)}
110 }
111
112
113
114 /* Turn off interconnects from Durham for base case - transfers can be simulated
115    with an operating policy in alternative scenarios */
116 Constraint : {dFlow0479.1151 = 0} //After WIP WTP is on-line, Durham would only buy water from Cary in an emergency
117 /*Constraint : {dFlow1151.0431 = 0} Durham-OWASA Interconnect */
118 Constraint : {dFlow1151.0471 = 0} /* Durham-Cary Interconnect */
119 Constraint : {dFlow1151.1106 = 0} /* Durham-Hillsborough Interconnect */
120 Constraint : {dFlow1151.1305 = 0} /* Durham-Raleigh Interconnect */
121
122
123 /* RESERVOIR BALANCING -- Durham
124    With a very low penalty in Priority 1, balance the water (usable stor pct) between the
125    reservoirs. This will draw Michie and Little River Res. down proportionally.
126    This can be replaced with a more comprehensive operating policy from Durham
127    in alternative scenarios */
128
129 Constraint Balance1200 : { d_StorRatio > ( Dstorage1200 - lower_rule1200 ) / (upper_rule1200 - lower_rule1200 ) }
130
131 Constraint Balance1140 : { d_StorRatio > ( Dstorage1140 - lower_rule1140 ) / (upper_rule1140 - lower_rule1140 ) }
132
133 Minimax : d_StorRatio
134 { priority : 1
135   penalty : 2
136   tolerance : .02
137 }
138
139
```

falls_bdam_ops.ocl

```
1 /* FALLS_BDAM_OPS.OCL */
2 /* Operational policies for Falls and Beaverdam */
3
4 //Set the Seasonal increase in Falls Lake Normal Pool
5
6 set Falls_Lake_upper_rule : upper_rule1300
7 {
8   Condition : default
9   value    : elev_to_stor{1300,[Falls_upper_rule]}
10 }
11
12 set Falls_Lake_lower_rule : lower_rule1300
13 { Condition : Default
14   value    : elev_to_stor{1300,[Falls_lower_rule]}
15 }
16
17 set Beaver_Dam_upper_rule : upper_rule1230
18 {
19   Condition : default
20   value    : elev_to_stor{1230,[Falls_upper_rule]}
21 }
22
23 set Beaver_Dam_lower_rule : lower_rule1230
24 {
25   Condition : default
26   value    : elev_to_stor{1230,[Falls_lower_rule]}
27 }
28
29 /* Sets the Falls minimum release - seasonal pattern (100/60 cfs) with user-defined safety factor (only when using service gates)
30 The safety factor can be set in the ocl constants table. */
31 Set FallsRelease : min_flow1300.1304
32 { condition : month > 3 and month < 11
33   value    : convert_units { 100, cfs, af } * ( 1 + [FLakeMin_SafeFact] / 100 )
34 }
35 condition : default
36 /* Winter min. release based on amount from Piggyback gates, which is approx. 60 cfs depending on stage. */
37 value    : convert_units { lookup { PiggybackGate, elevation1300 }, cfs, af }
38 }
39
40 /* Sets the Clayton minimum flow target - seasonal pattern (254/184 cfs) with user-defined safety factor
41 Also can be overridden if user chooses, when WQ storage drops below 20%; this can be truned on in the ocl constants table. */
42 Set Clayt_Target: min_flow1630.1640
43 { condition : [ClaytonTarget_Override] = 1 and ( _Total_WQ_Pct(-1) < [FLake_WQ_Threshold] or elevation1300 <= 245 )
44   value    : 0
45 }
46 condition : month > 3 and month < 11
47 value    : convert_units { 254, cfs, af } * ( 1 + [ClaytonTarget_SafeFact] / 100 )
```

falls_bdam_ops.ocl

```
48
49 condition : default
50 value : convert_units { 184, cfs, af } * ( 1 + [ClaytonTarget_SafeFact] / 100 )
51 }
52
53 /* Beaverdam elevation = projected Falls elevation if at or above 249 ft. */
54 Target Bdam_elevation : dstorage1230
55 { condition : elevation1300 >= 249.0
56 priority : 1
57 penalty+ : 10000
58 penalty- : 10000
59 Value : elev_to_stor { 1230, elevation1300 }
60 }
61
62 /*Beaverdam drought release policy*/
63
64 Target Beaverdam_release : dflow1230.1300
65
66 { /* If Falls is between 237 and 240, and Beaverdam is above [Falls_lower_rule], draw down Beaverdam maximum of 1-ft (down to a minimum
67 of [Falls_lower_rule]); next drawdown can occur after 5 days */
68 condition : elevation1230(-5) - elevation1230 < 5 and elevation1300 < 240
69 and elevation1230 > elevation1300 and elevation1230 > [Falls_lower_rule]
70 priority : 1
71 penalty+ : 1000
72 penalty- : 1000
73 Value : min { elev_to_stor { 1230, elevation1230 } - elev_to_stor { 1230, elevation1230 - 1 },
74 elev_to_stor { 1230, elevation1230 } - elev_to_stor { 1230, [Falls_lower_rule] } }
75
76 /* If Falls is below 249 ft, make sure Beaverdam is not above 249 ft */
77 condition : elevation1230 > 249 and elevation1300 < 249
78 priority : 1
79 penalty+ : 1000
80 penalty- : 1000
81 Value : elev_to_stor { 1230, elevation1230 } - elev_to_stor { 1230, 249 }
82
83 /* To ensure accurate accounting of water supply and quality pools, when stressed, release some contents from Beaverdam if either
84 yesterday's water supply or water quality account for Falls was less than 5% full; do not draw down more than 1 ft per day
85 THIS IS NOT PART OF TERRY'S SPREADSHEET (sn) */
86 condition : _FLake_WS_Pct(-1) < 5 or _FLake_WQ_Pct(-1) < 5 and elevation1230 > elevation1300 + 0.9
87 and elevation1230(-5) - elevation1230 < 5
88 priority : 1
89 penalty+ : 1000
90 penalty- : 1000
91 Value : max { 0, min { elev_to_stor { 1230, elevation1230 } - elev_to_stor { 1230, elevation1230 - 1 },
92 ( _Bdam_WS_Stor(-1) + _Bdam_WQ_Stor(-1) + inflow1230 - evap1230 ) } }
93
94 condition : default
```

falls_bdam_ops.ocl

```
95  priority : 1
96  penalty+ : 1000
97  penalty- : 1000
98  Value    : 0
99  }
100
101
102  /* Constrain the delivery for Raleigh from Falls based on amount in the total (Falls+Bdam) water supply storage account.
103     Demand will not be fulfilled if the account has gone empty and there is not enough inflow to the water supply account (for the previous day).
104     Similarly, constrain the water quality release from Falls (arc 1300.1310) based on amount in the water quality storage account.
105
106     Since we refer to yesterday's storage estimates, for the first day of the run, constrain deliveries and releases to the initialized volumes for
107     each account (for simplicity, ignore inflows) so that deliveries and releases are made. */
108
109
110  Constraint Deliv_Lim_Raleigh :
111  { condition : abs_period = 1
112    expression : dflow1300.1305 <= [FLake_WS_Stor] + [Bdam_WS_Stor]
113  }
114
115  Constraint Deliv_Lim_Raleigh :
116  { condition : abs_period > 1
117    expression : dflow1300.1305 <= _Total_WS_Stor(-1)
118  }
119
120  Constraint Release_Limit_Falls :
121  { condition : abs_period = 1
122    expression : dflow1300.1304 <= [FLake_WQ_Stor] + [Bdam_WQ_Stor]
123  }
124
125  Constraint Release_Limit_Falls :
126  { condition : abs_period > 1
127    expression : dflow1300.1304 <= _Total_WQ_Stor(-1)
128  }
```

Falls_Bdam_WQ_WS_Accounts.ocl

```
1 /* Falls_Bdam_WQ_WS_Accounts.ocl */
2
3
4 /* Beaverdam Accounting */
5
6 Set : _Bdam_Inf { value : inflow1230 - evap1230(0) } /* Base it on net inflow for Beaverdam.
7           Evap (0) since this file is included after the solve statement and we want today's evap, not tomorrow's */
8
9 Set : _Bdam_Inf_WS { value : _Pct_Max_WS_Storage / 100 * _Bdam_Inf }
10
11 Set : _Bdam_WS_Rel /* Calculate the WS outflow to Falls from Beaverdam. Assume that the WS amount is simply based on
12 the percent of water supply to total account storage in Beaverdam */
13 { condition : elevation1230 < 249 /* WS Outflow only if Beaverdam is less than 249ft (spillage is accounted for in Falls) */
14 value : flow1230.1300 * _Pct_Max_WS_Storage / 100
15
16 condition : default
17 value : 0
18 }
19
20 Set : _Bdam_WS_Stor_Init /* Calculate the initial Beaverdam WS storage (before computing spill to WQ and back*/
21 { condition : elevation1230 >= 249 or _Bdam_WS_Stor(-1) + _Bdam_Inf_WS - _Bdam_WS_Rel >= _Bdam_Max_WS_Storage
22 value : _Bdam_Max_WS_Storage
23
24 /* Prevent the water supply account from going negative */
25 condition : default
26 value : max { 0, _Bdam_WS_Stor(-1) + _Bdam_Inf_WS - _Bdam_WS_Rel }
27 }
28
29 Set : _Bdam_WStoWQ_Spill /* Calculate the spillover from WS to WQ*/
30 { condition : _Bdam_WS_Stor(-1) + _Bdam_Inf_WS - _Bdam_WS_Rel > _Bdam_Max_WS_Storage /* Spillover only if projected WS storage
31 is more than 100% */
32 value : _Bdam_WS_Stor(-1) + _Bdam_Inf_WS - _Bdam_WS_Rel - _Bdam_Max_WS_Storage
33
34 condition : default
35 value : 0
36 }
37
38 Set : _Bdam_Inf_WQ { value : _Pct_Max_WQ_Storage / 100 * _Bdam_Inf }
39
40 Set : _Bdam_WQ_Rel /* Calculate the WQ outflow to Falls from Beaverdam */
41 { condition : elevation1230 < 249 /* WQ Outflow only if Beaverdam is less than 249ft (spillage is accounted for in Falls) */
42 value : flow1230.1300 * _Pct_Max_WQ_Storage / 100
43
44 condition : default
45 value : 0
46 }
47
```

Falls_Bdam_WQ_WS_Accounts.ocl

```
48 Set : _Bdam_WQ_Stor /* Calculate the Beaverdam WQ storage */
49 {   condition : elevation1230 >= 249 or _Bdam_WQ_Stor(-1) +
50   ( _Bdam_WStoWQ_Spill + _Bdam_Inf_WQ - _Bdam_WQ_Rel ) >= _Bdam_Max_WQ_Storage
51   value      : _Bdam_Max_WQ_Storage
52
53 /*   Prevent the water quality account from going negative */
54   condition : default
55   value      : max { 0, _Bdam_WQ_Stor(-1) + ( _Bdam_WStoWQ_Spill + _Bdam_Inf_WQ - _Bdam_WQ_Rel ) }
56 }
57
58 Set : _Bdam_WQtoWS_Spill /* Calculate the spillover from WQ to WS */
59 {   condition : _Bdam_WQ_Stor(-1) +
60   ( _Bdam_WStoWQ_Spill + _Bdam_Inf_WQ - _Bdam_WQ_Rel ) > _Bdam_Max_WQ_Storage /* Spillover only if
61   projected WS storage more than 100% */
62   value      : _Bdam_WQ_Stor(-1) + ( _Bdam_WStoWQ_Spill + _Bdam_Inf_WQ - _Bdam_WQ_Rel ) - _Bdam_Max_WQ_Storage
63
64   condition : default
65   value      : 0
66 }
67
68 Set : _Bdam_WS_Stor /* Calculate the final Beaverdam WS storage (after computing spillage) */
69 {   condition : _Bdam_WS_Stor_Init + _Bdam_WQtoWS_Spill >= _Bdam_Max_WS_Storage /* Set at 100% if at or above full */
70   value      : _Bdam_Max_WS_Storage
71
72   condition : default
73   value      : _Bdam_WS_Stor_Init + _Bdam_WQtoWS_Spill
74 }
75
76
77 /* Falls Accounting */
78
79 /* Falls Lake inflow is Falls gain + upstream flows into Falls*/
80 Set : _FLake_Inf
81 { /* When Beaverdam is full, inflow to Falls account from Beaverdam will simply be the Beaverdam surplus above 249 (= net inflow).
82   Note for the general accounting (i.e, not the WS/WQ accounting), storage will accumulate in Beaverdam (and Falls) until the
83   upper rule of [Falls_upper_rule] is reached. The point of this is to mirror what historic elevations have been */
84   condition : elevation1230 >= 249 and elevation1230(0) >= 249 // second statement added by Reed
85   value      : inflow1300 + flow1163.1300 + flow1205.1300 + flow1250.1300 + flow1256.1300 +
86   flow1270.1300 + flow1705.1300 - delivery1302 - evap1300(0) + _Bdam_Inf
87
88 // the next two statements added by Reed to improve performance of reservoir balancing
89   condition : elevation1230 >= 249 and elevation1230(0) < 249 and elevation1300 < 249
90   value      : inflow1300 + flow1163.1300 + flow1205.1300 + flow1250.1300 + flow1256.1300 +
91   flow1270.1300 + flow1705.1300 - delivery1302 - evap1300(0) + _Bdam_Inf - (storage1230 - storage1230(0))
92
93   condition : elevation1230 >= 249 and elevation1230(0) < 249 and elevation1300 >= 249
94   value      : inflow1300 + flow1163.1300 + flow1205.1300 + flow1250.1300 + flow1256.1300 +
```

Falls_Bdam_WQ_WS_Accounts.ocl

```
95  flow1270.1300 + flow1705.1300 - delivery1302 - evap1300(0) + _Bdam_Inf - (elev_to_stor{1230,249} - storage1230(0))
96
97  /* Otherwise, inflow to Falls account from Beaverdam is simply the Beaverdam release defined in the main.ocl
98  (associated with drought operations). This will be today's release since
99  this accounting file is included after the solve statement in the main.ocl file */
100 condition : default
101 value : inflow1300 + flow1163.1300 + flow1205.1300 + flow1250.1300 + flow1256.1300 +
102 flow1270.1300 + flow1705.1300 - delivery1302 - evap1300(0) + flow1230.1300
103 }
104
105 Set : _FLake_Inf_WS { value : _Pct_Max_WS_Storage / 100 * _FLake_Inf } /* Calculate WS portion of Falls inflow */
106
107 /* The water supply release from Falls = the delivery to Raleigh. The delivery is constrained in the main.ocl file
108 to the amount in the water supply storage pool plus the inflow to that account. This way, the delivery will not
109 be made if the account has emptied */
110 Set : _Flake_WS_Rel { value : flow1300.1305 }
111
112 Set : _FLake_WS_Stor_Init /* Calculate the initial Falls WS storage (before computing spill to WQ and back) */
113 { condition : elevation1300 >= [Falls_upper_rule] or _FLake_WS_Stor(-1)
114 + ( _FLake_Inf_WS - _Flake_WS_Rel ) >= _FLake_Max_WS_Storage /* Set at 100% if at or above full */
115 value : _FLake_Max_WS_Storage
116
117 /* Sets the water supply storage floor as zero minus the storage in Beaverdam */
118 condition : default
119 value : max { 0 - _Bdam_WS_Stor, _FLake_WS_Stor(-1) + ( _FLake_Inf_WS - _Flake_WS_Rel ) }
120 }
121
122 Set : _FLake_WStoWQ_Spill /* Calculate the spillover from WS to WQ */
123 { condition : _FLake_WS_Stor(-1) + ( _FLake_Inf_WS - _Flake_WS_Rel ) > _FLake_Max_WS_Storage /* Spillover only if
124 projected WS storage is
125 more than 100% */
126 value : _FLake_WS_Stor(-1) + ( _FLake_Inf_WS - _Flake_WS_Rel ) - _FLake_Max_WS_Storage
127
128 condition : default
129 value : 0
130 }
131
132 Set : _FLake_Inf_WQ { value : _Pct_Max_WQ_Storage / 100 * _FLake_Inf } /* Calculate WQ portion of Falls inflow */
133
134 /* The water quality release from Falls = outflow from Falls. The release is constrained in the main.ocl file to the amount in the water
135 quality storage pool plus the inflow to that account. This way, the release will not be made if the account has emptied. Note the outflow may
136 include releasing surplus water above the rule curve, which technically would be more than the water quality release. But since the account
137 is reset to full above the rule curve, it makes no difference. However, to make it more realistic, set the WQ release to the minimum flow from Falls
138 (for simplicity) when the elevation is at [Falls_upper_rule] or above. */
139 Set : _Flake_WQ_Rel
140 { condition : elevation1300 >= [Falls_upper_rule]
141 value : min_flow1300.1304
```

Falls_Bdam_WQ_WS_Accounts.ocl

```
142
143 condition : default
144 value      : flow1300.1304
145 }
146
147 Set : _FLake_WQ_Stor /* Calculate the Falls WQ storage */
148 {   condition : elevation1300 >= [Falls_upper_rule] and elevation1230 < [Falls_upper_rule]
149     value      : _FLake_Max_WQ_Storage - ( max { 0, elev_to_stor{ 1230, [Falls_upper_rule] } - storage1230 } ) * _Pct_Max_WQ_Storage/100
150
151     condition : elevation1300 >= [Falls_upper_rule] or _FLake_WQ_Stor(-1)
152     + ( _FLake_WStoWQ_Spill + _FLake_Inf_WQ - _Flake_WQ_Rel ) >= _FLake_Max_WQ_Storage
153     value      : _FLake_Max_WQ_Storage
154
155 /* Fix WS WQ accounting error on first day of drought. */
156 condition : elevation1300(0) >= [Falls_upper_rule] and elevation1300 < [Falls_upper_rule]
157 value      : _FLake_Max_WQ_Storage - ( elev_to_stor{ 1300, [Falls_upper_rule] } - storage1300 ) * _Pct_Max_WQ_Storage/100
158
159 /* Sets the water supply storage floor as zero minus the storage in Beaverdam */
160 condition : default
161 value      : max { 0 - _Bdam_WQ_Stor, _FLake_WQ_Stor(-1)
162     + ( _FLake_WStoWQ_Spill + _FLake_Inf_WQ - _Flake_WQ_Rel ) } /* Appears to be counted twice in
163     terry's spreadsheet, but we are not here.*/
164 }
165
166 Set : _FLake_WQtoWS_Spill /* Calculate the spillover from WQ to WS */
167 {   condition : _FLake_WQ_Stor(-1)
168     + ( _FLake_WStoWQ_Spill + _FLake_Inf_WQ - _Flake_WQ_Rel ) > _FLake_Max_WQ_Storage /* Spillover only if
169     projected WS storage
170     more than 100% */
171     value      : _FLake_WQ_Stor(-1) + ( _FLake_WStoWQ_Spill + _FLake_Inf_WQ - _Flake_WQ_Rel ) - _FLake_Max_WQ_Storage
172
173     condition : default
174     value      : 0
175 }
176
177 Set : _FLake_WS_Stor /* Calculate the final Falls WS storage (after computing spillage) */
178 {   condition : elevation1300 >= [Falls_upper_rule] and elevation1230 < [Falls_upper_rule] // modified by R.Palmer
179     value      : _FLake_Max_WS_Storage - ( max { 0, elev_to_stor{ 1230, [Falls_upper_rule] } - storage1230 } ) * _Pct_Max_WS_Storage/100
180
181     // Following two conditions added by R. Palmer to improve accurate accounting under cross-over conditions
182     condition : _FLake_WS_Stor_Init + _FLake_WQtoWS_Spill >= _FLake_Max_WS_Storage /* Set to 100% if more than full */
183     value      : _FLake_Max_WS_Storage
184
185 /* Fix WS WQ accounting error on first day of drought. */
186 condition : elevation1300(0) >= [Falls_upper_rule] and elevation1300 < [Falls_upper_rule]
187 value      : _FLake_Max_WS_Storage - ( elev_to_stor{ 1300, [Falls_upper_rule] } - storage1300 ) * _Pct_Max_WS_Storage/100
188
```

Falls_Bdam_WQ_WS_Accounts.ocl

```
189
190 condition : default
191     value    : _FLake_WS_Stor_Init + _FLake_WQtoWS_Spill
192 }
193
194 Set : _Total_WS_Stor { value : _FLake_WS_Stor + _Bdam_WS_Stor } /* Sum the total WS storage for Falls + Beaverdam */
195
196
197 Set : _Total_WQ_Stor { value : _FLake_WQ_Stor + _Bdam_WQ_Stor } /* Sum the total WQ storage for Falls + Beaverdam */
198
199
200 /* Calculate the percent of full for the WS and WQ accounts */
201
202 Set : _Bdam_WS_Pct { value : 100 * _Bdam_WS_Stor / _Bdam_Max_WS_Storage }
203 Set : _Bdam_WQ_Pct { value : 100 * _Bdam_WQ_Stor / _Bdam_Max_WQ_Storage }
204 Set : _FLake_WS_Pct { value : 100 * _FLake_WS_Stor / _FLake_Max_WS_Storage }
205 Set : _FLake_WQ_Pct { value : 100 * _FLake_WQ_Stor / _FLake_Max_WQ_Storage }
206 Set : _Total_WS_Pct { value : 100 * _Total_WS_Stor / [_Total_Max_WS_Storage]}
207 Set : _Total_WQ_Pct { value : 100 * _Total_WQ_Stor / [_Total_Max_WQ_Storage] }
```

Falls_flood_ops.ocl

```
1 /* FALLS_FLOOD_OPS.OCL */
2
3 /* Flood release policy for Falls Lake */
4
5 /* Calculate estimated local inflow to Clayton, which is used in determining Falls flood releases */
6 Set : _ClaytLocal
7 {
8     Value : inflow1290 + inflow1445 + inflow1450 + inflow1630 +
9     /* To increase accuracy, estimate Crabtree outflows by using starting elevation and spillway curve */
10     min {convert_units { Lookup{ 1416Outflow, elevation1416 }, cfs, af}, storage1416 - elev_to_stor {1416, 230} } +
11     min {convert_units { Lookup{ 1418Outflow, elevation1418 }, cfs, af}, storage1418 - elev_to_stor {1418, 335} } +
12     min {convert_units { Lookup{ 1422Outflow, elevation1422 }, cfs, af}, storage1422 - elev_to_stor {1422, 252} }
13 }
14
15
16
17 /* Falls flood operations per recommendations in Terry Brown's email 02/26/2009 */
18 Target Falls_release : dflow1300.1304
19 { /* Release only the minimum release if elevation is less than 255 and est. Clayton inflows >= 7000 cfs */
20     condition : elevation1300 >= [Falls_upper_rule] and elevation1300 <= 255 and _ClaytLocal >= convert_units { 7000, cfs, af}
21     priority : 1
22     penalty+ : 50
23     penalty- : 50
24     Value : min_flow1300.1304
25
26     /* If elev. < 255 and est. Clayton inflow < 7000 cfs, release the lesser of 4000 cfs or (7000 - the Clayt inflow).
27     Also added provision to only drop Falls to the guide curve, but not less than the minimum release */
28     condition : elevation1300 >= [Falls_upper_rule] and elevation1300 <= 255 and _ClaytLocal < convert_units { 7000, cfs, af}
29     priority : 1
30     penalty+ : 50
31     penalty- : 0 // Set to 0 for underage to improve release performance - RP
32     Value : max { min_flow1300.1304, min { convert_units { 4000, cfs, af }, convert_units { 7000, cfs, af }
33     - _ClaytLocal, storage1300 - elev_to_stor { 1300, [Falls_upper_rule] } } }
34
35     /* Release only the minimum release if elevation is less than 255 - 258 and est. Clayton inflows >= 7000 cfs */
36     condition : elevation1300 > 255 and elevation1300 <= 258 and _ClaytLocal >= convert_units { 7000, cfs, af}
37     priority : 1
38     penalty+ : 50
39     penalty- : 50
40     Value : min_flow1300.1304
41
42     /* If elev. is 255 - 258 and est. Clayton inflow < 7000 cfs, release 7000 - the Clayt inflow. */
43     condition : elevation1300 > 255 and elevation1300 <= 258 and _ClaytLocal < convert_units { 7000, cfs, af}
44     priority : 1
45     penalty+ : 50
46     penalty- : 50
47     Value : convert_units { 7000, cfs, af } - _ClaytLocal
```

Falls_flood_ops.ocl

```
48
49 /* Release only the minimum release if elevation is 258 - 264.8 and est. Clayton inflows >= 8000 cfs */
50 condition : elevation1300 > 258 and elevation1300 <= 264.8 and _ClaytLocal >= convert_units { 8000, cfs, af}
51 priority : 1
52 penalty+ : 50
53 penalty- : 50
54 Value : min_flow1300.1304
55
56 /* If elev. is 258 - 264.8 and est. Clayton inflow < 8000 cfs, release 8000 - the Clayt inflow. */
57 condition : elevation1300 > 258 and elevation1300 <= 264.8 and _ClaytLocal < convert_units { 8000, cfs, af}
58 priority : 1
59 penalty+ : 50
60 penalty- : 50
61 Value : convert_units { 8000, cfs, af } - _ClaytLocal
62
63 /* If elev. is 264.8 - 268 and est. Clayton inflow >= 8000 cfs, release only the computed spillway amount */
64 condition : elevation1300 > 264.8 and elevation1300 <= 268 and _ClaytLocal >= convert_units { 8000, cfs, af}
65 priority : 1
66 penalty+ : 50
67 penalty- : 50
68 Value : convert_units { lookup { FallsSpillway, elevation1300 }, cfs, af }
69
70 /* If elev. is 264.8 - 268 and est. Clayton inflow < 8000 cfs, release [(8000 cfs + the computed spillway amount) - the Clayt inflow]. */
71 condition : elevation1300 > 264.8 and elevation1300 <= 268 and _ClaytLocal < convert_units { 8000, cfs, af}
72 priority : 1
73 penalty+ : 50
74 penalty- : 50
75 Value : convert_units { 8000 + lookup { FallsSpillway, elevation1300 }, cfs, af } - _ClaytLocal
76
77 /* If elev. is > 268, release the full amounts possible from the service gates and the spillway. */
78 condition : elevation1300 > 268
79 priority : 1
80 penalty+ : 50
81 penalty- : 50
82 Value : convert_units { lookup { FallsSvcGate, elevation1300 } + lookup { FallsSpillway, elevation1300 }, cfs, af }
83 }
84
85 /* Set targets based on flood stages at downstream gages; note that the above release policy takes priority over these targets */
86
87 /* Clayton flood control target */
88 Target Clayton_max : dflow1630.1640
89 { condition : default
90 priority : 1
91 penalty+ : 10
92 penalty- : 0
93 Value : convert_units{ 5332, cfs, af }
94 }
```

Falls_flood_ops.ocl

```
95
96 /* Goldsboro flood control target */
97 Target Goldsboro_max : dflow1780.1790
98 { condition : default
99   priority : 1
100   penalty+ : 10
101   penalty- : 0
102   Value    : convert_units{ 6003, cfs, af }
103 }
104
105 /* Kinston flood control target */
106 Target Kinston_max : dflow1800.1850
107 { condition : default
108   priority : 1
109   penalty+ : 10
110   penalty- : 0
111   Value    : convert_units{ 7168, cfs, af }
112 }
```

Fayetteville_ops.ocl

```
1 /* Fayetteville_ops.ocl */
2 /* Operational policies for Fayetteville */
3
4
5 // Switch to river intake only when Glenville < 212.2 ft
6 Target Glenville_WD : dflow0760.0731
7 { condition : storage0760 < lower_rule0760
8   priority : 1
9   penalty+ : 50
10  penalty- : 50
11  Value   : 0
12
13 // Otherwise WD 4.5 mgd (per conversation with Chris Smith at Fayetteville). 4.5 mgd is also set as the max flow pattern
14 condition : default
15 priority : 1
16 penalty+ : 50
17 penalty- : 50
18 Value   : convert_units { 4.5, mgd, af }
19 }
20
```

filter_inflows.ocl

```
1 /* FILTER_INFLOWS.OCL */
2
3 /* Sets the inflows for nodes that need to be filtered. The finalized inflows (through Sept 2011)
4 were already filtered; however, the provisional inflows from the update record routine can be
5 negative due to time of travel or imperfect impairment estimations, and therefore are filtered
6 here to prevent model infeasibility or unrealistic reservoir releases and/or demand shortages.
7 All Neuse inflows are filtered except Falls/Bdam, which can have negatives due to the use of
8 back-calculated inflows; and Michie/LRR in Durham, which are based on already unimpaired gages
9 that will not be negative. The inflows to the Crabtree Creek system are set and filtered
10 separately in Crabtree.ocl. Negative back-calculated inflows for Falls/Bdam are not physically
11 possible since we've adjusted for net evap and net withdrawals; however, reservoir storage can
12 handle these negatives. The negatives are not used in developing regressions to fill in other
13 gages, so we do not need to adjust the negatives.
14 */
15
16 // The Cape Fear inflow nodes could be expanded
17 :For:
18 { [node] = { 0020, 0040, 0070, 0090, 0300, 0310, 0324, 0325, 0590, 0760, 0140, 0145, 0170, 0210, 0220, 0260,
19 0270, 0280, 0340, 0380, 0400, 0430, 0450, 0470, 0490, 0520, 0527, 0550, 0700, 1010, 1050, 1060,
20 1080, 1100, 1110, 1115, 1250, 1270, 1290, 1420, 1440, 1445, 1450, 1500, 1560, 1630, 1740 }
21 }
22 Set : _TempInf[node] { Value : timesers([node]/inflow) }
23 Set : inflow[node] { Value : max{0, _TempInf[node] - _InfDeficit[node](-1) } }
24 Set : _InfDeficit[node] { Value : max{0, _InfDeficit[node](-1) - _TempInf[node] } }
25
26 :Next:
27
28 // In addition to filtering, this also sets inflows to points of interest
29 // that are not contained in the basedata file, and adjusts existing inflows accordingly
30
31 // New inflows for CF
32
33 // Greensboro Haw intake
34 Set : _TempInf0044 { Value : timesers(0090/inflow)*(14/174.6) }
35 Set : inflow0044 { Value : max{0, _TempInf0044 - _InfDeficit0044(-1) } }
36 Set : _InfDeficit0044 { Value : max{0, _InfDeficit0044(-1) - _TempInf0044 } }
37
38 // Adj Haw gage
39 Set : _TempInf0090 { Value : timesers(0090/inflow)*(160.6/174.6) }
40 Set : inflow0090 { Value : max{0, _TempInf0090 - _InfDeficit0090(-1) } }
41 Set : _InfDeficit0090 { Value : max{0, _InfDeficit0090(-1) - _TempInf0090 } }
42
43 // Since the timeseries for Oakrdige includes the gain to Brandt, need to separate out that gain
44 Set : _Gibso_Gain { value : 110.4 *timesers(0140/inflow) / 35 }
45
46 // Lake Higgins - 11 sq mi of the gain from Oakridge to Brandt
47 Set : _TempInf0112 { Value : (11 / 49.4) * _Gibso_Gain * 49.4 / 110.4 } // Higgins is
```

filter_inflows.ocl

```
48 Set : inflow0112 { Value : max{0, _TempInf0112 - _InfDeficit0112(-1) } }
49 Set : _InfDeficit0112 { Value : max{0, _InfDeficit0112(-1) - _TempInf0112 } }
50
51 // Brandt Reservoir - the remaining 38.4 sq mi of the gain from Oakridge to Brandt
52 Set : _TempInf0120 { Value : (38.4 / 49.4) * _Gibso_Gain * 49.4 / 110.4 }
53 Set : inflow0120 { Value : max{0, _TempInf0120 - _InfDeficit0120(-1) } }
54 Set : _InfDeficit0120 { Value : max{0, _InfDeficit0120(-1) - _TempInf0120 } }
55
56 // Adj Oakridge Inflow - now just the Oakridge gage portion of the 110 inflow timeseries
57 Set : _TempInf0110 { Value : timesers(0110/inflow) - inflow0112 - inflow0120 }
58 Set : inflow0110 { Value : max{0, _TempInf0110 - _InfDeficit0110(-1) } }
59 Set : _InfDeficit0110 { Value : max{0, _InfDeficit0110(-1) - _TempInf0110 } }
60
61 // Rocky River Discharge
62 Set : _TempInf0328 { Value : (timesers(0324/inflow)+timesers(0325/inflow))*(22.8/55) }
63 Set : inflow0328 { Value : max{0, _TempInf0328 - _InfDeficit0328(-1) } }
64 Set : _InfDeficit0328 { Value : max{0, _InfDeficit0328(-1) - _TempInf0328 } }
65
66 // Ramseur Discharge
67 Set : _TempInf0570 { Value : timesers(0300/inflow)*(6/355) }
68 Set : inflow0570 { Value : max{0, _TempInf0570 - _InfDeficit0570(-1) } }
69 Set : _InfDeficit0570 { Value : max{0, _InfDeficit0570(-1) - _TempInf0570 } }
70
71 // Adj 590 for Robbins intake
72 Set : _TempInf0590 { Value : timesers(0590/inflow)*(268/400) }
73 Set : inflow0590 { Value : max{0, _TempInf0590 - _InfDeficit0590(-1) } }
74 Set : _InfDeficit0590 { Value : max{0, _InfDeficit0590(-1) - _TempInf0590 } }
75
76 // Robbins intake
77 Set : _TempInf0580 { Value : timesers(0590/inflow)*(132/400) }
78 Set : inflow0580 { Value : max{0, _TempInf0580 - _InfDeficit0580(-1) } }
79 Set : _InfDeficit0580 { Value : max{0, _InfDeficit0580(-1) - _TempInf0580 } }
80
81 // Pilgrims Pride intake
82 Set : _TempInf0600 { Value : timesers(0640/inflow)*(371/630) }
83 Set : inflow0600 { Value : max{0, _TempInf0600 - _InfDeficit0600(-1) } }
84 Set : _InfDeficit0600 { Value : max{0, _InfDeficit0600(-1) - _TempInf0600 } }
85
86 // Node 610
87 Set : _TempInf0610 { Value : timesers(0640/inflow)*(40/630) }
88 Set : inflow0610 { Value : max{0, _TempInf0610 - _InfDeficit0610(-1) } }
89 Set : _InfDeficit0610 { Value : max{0, _InfDeficit0610(-1) - _TempInf0610 } }
90
91 // Adj Deep Moncure Gage
92 Set : _TempInf0640 { Value : timesers(0640/inflow)*(219/630) - inflow0328 - inflow0570 }
93 Set : inflow0640 { Value : max{0, _TempInf0640 - _InfDeficit0640(-1) } }
94 Set : _InfDeficit0640 { Value : max{0, _InfDeficit0640(-1) - _TempInf0640 } }
```

filter_inflows.ocl

```
95
96 // Node 660
97 Set : _TempInf0660 { Value : timesers(0780/inflow)*(286/919.6) }
98 Set : inflow0660 { Value : max{0, _TempInf0660 - _InfDeficit0660(-1) } }
99 Set : _InfDeficit0660 { Value : max{0, _InfDeficit0660(-1) - _TempInf0660 } }
100
101 // Node 680
102 Set : _TempInf0680 { Value : timesers(0780/inflow)*(20/919.6) }
103 Set : inflow0680 { Value : max{0, _TempInf0680 - _InfDeficit0680(-1) } }
104 Set : _InfDeficit0680 { Value : max{0, _InfDeficit0680(-1) - _TempInf0680 } }
105
106 // Node 700 - Carthage WS WD upstream on Little River.
107 // Note that 700/inflow timeseries is the full Little R. Linden gage flow
108 Set : _TempInf0700 { Value : timesers(0700/inflow)*(200/459) }
109 Set : inflow0700 { Value : max{0, _TempInf0700 - _InfDeficit0700(-1) } }
110 Set : _InfDeficit0700 { Value : max{0, _InfDeficit0700(-1) - _TempInf0700 } }
111
112 // Node 720 - Set as the remainder of the Little River Linden Gage flow
113 Set : _TempInf0720 { Value : timesers(0700/inflow)*(259/459) }
114 Set : inflow0720 { Value : max{0, _TempInf0720 - _InfDeficit0720(-1) } }
115 Set : _InfDeficit0720 { Value : max{0, _InfDeficit0720(-1) - _TempInf0720 } }
116
117 // Fayetteville PWC Intake
118 Set : _TempInf0730 { Value : timesers(0780/inflow)*(131/919.6) }
119 Set : inflow0730 { Value : max{0, _TempInf0730 - _InfDeficit0730(-1) } }
120 Set : _InfDeficit0730 { Value : max{0, _InfDeficit0730(-1) - _TempInf0730 } }
121
122 // Monsanto WS Intake
123 Set : _TempInf0770 { Value : timesers(0780/inflow)*(420.6/919.6) }
124 Set : inflow0770 { Value : max{0, _TempInf0770 - _InfDeficit0770(-1) } }
125 Set : _InfDeficit0770 { Value : max{0, _InfDeficit0770(-1) - _TempInf0770 } }
126
127 // Adj CF Tarheel Gage
128 Set : _TempInf0780 { Value : timesers(0780/inflow)*(62/919.6) }
129 Set : inflow0780 { Value : max{0, _TempInf0780 - _InfDeficit0780(-1) } }
130 Set : _InfDeficit0780 { Value : max{0, _InfDeficit0780(-1) - _TempInf0780 } }
131
132 // L&D #2 / Elizabethtown WWTP
133 Set : _TempInf0790 { Value : timesers(0820/inflow)*(168/403) }
134 Set : inflow0790 { Value : max{0, _TempInf0790 - _InfDeficit0790(-1) } }
135 Set : _InfDeficit0790 { Value : max{0, _InfDeficit0790(-1) - _TempInf0790 } }
136
137 // Adj of CF Kelly Gage
138 Set : _TempInf0820 { Value : timesers(0820/inflow)*(235/403) }
139 Set : inflow0820 { Value : max{0, _TempInf0820 - _InfDeficit0820(-1) } }
140 Set : _InfDeficit0820 { Value : max{0, _InfDeficit0820(-1) - _TempInf0820 } }
141
```

filter_inflows.ocl

```
142
143 // New inflows for Neuse
144
145 // 205 - Little R @ Eno R
146 Set : _TempInf1205 { Value : timesers(1115/inflow)*(105/75) }
147 Set : inflow1205 { Value : max{0, _TempInf1205 - _InfDeficit1205(-1) } }
148 Set : _InfDeficit1205 { Value : max{0, _InfDeficit1205(-1) - _TempInf1205 } }
149
150 // Adj Falls inflow (not filtered)
151 Set : inflow1300 { Value : timesers(1300/inflow) - inflow1205 }
152
153 // Apex WW Discharge
154 Set : _TempInf1405 { Value : timesers(1480/inflow)*(0.9/83.5) }
155 Set : inflow1405 { Value : max{0, _TempInf1405 - _InfDeficit1405(-1) } }
156 Set : _InfDeficit1405 { Value : max{0, _InfDeficit1405(-1) - _TempInf1405 } }
157
158 // Fuquay-Varina WW Discharge
159 Set : _TempInf1409 { Value : timesers(1480/inflow)*(7.6/83.5) }
160 Set : inflow1409 { Value : max{0, _TempInf1409 - _InfDeficit1409(-1) } }
161 Set : _InfDeficit1409 { Value : max{0, _InfDeficit1409(-1) - _TempInf1409 } }
162
163 // Cary SWRF Discharge
164 Set : _TempInf1471 { Value : timesers(1480/inflow)*(21.5/83.5) }
165 Set : inflow1471 { Value : max{0, _TempInf1471 - _InfDeficit1471(-1) } }
166 Set : _InfDeficit1471 { Value : max{0, _InfDeficit1471(-1) - _TempInf1471 } }
167
168 // Adj Middle Ck Gage
169 Set : _TempInf1480 { Value : timesers(1480/inflow)*(53.5/83.5) }
170 Set : inflow1480 { Value : max{0, _TempInf1480 - _InfDeficit1480(-1) } }
171 Set : _InfDeficit1480 { Value : max{0, _InfDeficit1480(-1) - _TempInf1480 } }
172
173 // Wiggons Mill Lake
174 Set : _TempInf1520 { Value : timesers(1560/inflow)*(77/575) }
175 Set : inflow1520 { Value : max{0, _TempInf1520 - _InfDeficit1520(-1) } }
176 Set : _InfDeficit1520 { Value : max{0, _InfDeficit1520(-1) - _TempInf1520 } }
177
178 // Adj Contentnea Hookerton Gage
179 Set : _TempInf1560 { Value : timesers(1560/inflow)*(498/575) }
180 Set : inflow1560 { Value : max{0, _TempInf1560 - _InfDeficit1560(-1) } }
181 Set : _InfDeficit1560 { Value : max{0, _InfDeficit1560(-1) - _TempInf1560 } }
182
183 // Smith Confluence -
184 Set : _TempInf1320 { Value : timesers(1630/inflow)*(20/271) }
185 Set : inflow1320 { Value : max{0, _TempInf1320 - _InfDeficit1320(-1) } }
186 Set : _InfDeficit1320 { Value : max{0, _InfDeficit1320(-1) - _TempInf1320 } }
187
188 // Crabtree Ck Confluence
```

filter_inflows.ocl

```
189 Set : _TempInf1600 { Value : timesers(1630/inflow)*(90/271) }
190 Set : inflow1600 { Value : max{0, _TempInf1600 - _InfDeficit1600(-1) } }
191 Set : _InfDeficit1600 { Value : max{0, _InfDeficit1600(-1) - _TempInf1600 } }
192
193 // Walnut Ck Confluence -
194 Set : _TempInf1620 { Value : timesers(1630/inflow)*(41/271) }
195 Set : inflow1620 { Value : max{0, _TempInf1620 - _InfDeficit1620(-1) } }
196 Set : _InfDeficit1620 { Value : max{0, _InfDeficit1620(-1) - _TempInf1620 } }
197
198 // NRWTP - Natural inflow between Walnut Creek and Neuse River WWTP - node added in 2014
199 Set : _TempInf1625 { Value : timesers(1630/inflow)*(62/271) }
200 Set : inflow1625 { Value : max{0, _TempInf1625 - _InfDeficit1625(-1) } }
201 Set : _InfDeficit1625 { Value : max{0, _InfDeficit1625(-1) - _TempInf1625 } }
202
203 // Adj Neuse Clayton Gage (increased to 58 sq. miles from 11 sq. mi. based on drainage between NRWTP and Clayton Gage)
204 Set : _TempInf1630 { Value : timesers(1630/inflow)*(58/271) }
205 Set : inflow1630 { Value : max{0, _TempInf1630 - _InfDeficit1630(-1) } }
206 Set : _InfDeficit1630 { Value : max{0, _InfDeficit1630(-1) - _TempInf1630 } }
207
208 // Kenly WW
209 Set : _TempInf1747 { Value : timesers(1750/inflow)*(165.2/181.2) }
210 Set : inflow1747 { Value : max{0, _TempInf1747 - _InfDeficit1747(-1) } }
211 Set : _InfDeficit1747 { Value : max{0, _InfDeficit1747(-1) - _TempInf1747 } }
212
213 // Adj Little R Princeton Gage
214 Set : _TempInf1750 { Value : timesers(1750/inflow)*(16/181.2) }
215 Set : inflow1750 { Value : max{0, _TempInf1750 - _InfDeficit1750(-1) } }
216 Set : _InfDeficit1750 { Value : max{0, _InfDeficit1750(-1) - _TempInf1750 } }
217
218 // Johnston County Intake
219 Set : _TempInf1650 { Value : timesers(1780/inflow)*(30/867.2) }
220 Set : inflow1650 { Value : max{0, _TempInf1650 - _InfDeficit1650(-1) } }
221 Set : _InfDeficit1650 { Value : max{0, _InfDeficit1650(-1) - _TempInf1650 } }
222
223 // Neuse Smithfield
224 Set : _TempInf1660 { Value : timesers(1780/inflow)*(26/867.2) }
225 Set : inflow1660 { Value : max{0, _TempInf1660 - _InfDeficit1660(-1) } }
226 Set : _InfDeficit1660 { Value : max{0, _InfDeficit1660(-1) - _TempInf1660 } }
227
228 // Swift Ck Confluence - changed from 4 to 144.2 based on total DA at Swift/Middle/Neuse confluence of 1500.0
229 // sq. mi (per USGS streamstats) - 1206 @ Smithfield - 83.5 @ Middle Creek - 66.3 @ L. Benson = 144.2
230 Set : _TempInf1700 { Value : timesers(1780/inflow)*(144.2/867.2) }
231 Set : inflow1700 { Value : max{0, _TempInf1700 - _InfDeficit1700(-1) } }
232 Set : _InfDeficit1700 { Value : max{0, _InfDeficit1700(-1) - _TempInf1700 } }
233
234 // Richardson Bridge Rd crossing of Neuse - potential JC Intake #2 site. Total DA is 1677 sq mi. per CH2M Hill 2013 SY Addendum
235 Set : _TempInf1730 { Value : timesers(1780/inflow)*(177/867.2) }
```

filter_inflows.ocl

```
236 Set : inflow1730 { Value : max{0, _TempInf1730 - _InfDeficit1730(-1) } }
237 Set : _InfDeficit1730 { Value : max{0, _InfDeficit1730(-1) - _TempInf1730 } }
238
239 // Alternative site for Johnston County lower Neuse Intake below the confluence with Mill Creek - total DA is 1889 sq. mi
240 // per CH2M Hill 2013 SY Addendum
241 Set : _TempInf1735 { Value : timesers(1780/inflow)*(212/867.2) }
242 Set : inflow1735 { Value : max{0, _TempInf1735 - _InfDeficit1735(-1) } }
243 Set : _InfDeficit1735 { Value : max{0, _InfDeficit1735(-1) - _TempInf1735 } }
244
245 // Princeton WWTP
246 Set : _TempInf1755 { Value : timesers(1780/inflow)*(32/867.2) }
247 Set : inflow1755 { Value : max{0, _TempInf1755 - _InfDeficit1755(-1) } }
248 Set : _InfDeficit1755 { Value : max{0, _InfDeficit1755(-1) - _TempInf1755 } }
249
250 // Progress Energy Intake - reduced to 161 based on multiple adjustments above Swift Ck confluence adjustment above
251 Set : _TempInf1760 { Value : timesers(1780/inflow)*(161/867.2) }
252 Set : inflow1760 { Value : max{0, _TempInf1760 - _InfDeficit1760(-1) } }
253 Set : _InfDeficit1760 { Value : max{0, _InfDeficit1760(-1) - _TempInf1760 } }
254
255 // Little R Confluence
256 Set : _TempInf1775 { Value : timesers(1780/inflow)*(62/867.2) }
257 Set : inflow1775 { Value : max{0, _TempInf1775 - _InfDeficit1775(-1) } }
258 Set : _InfDeficit1775 { Value : max{0, _InfDeficit1775(-1) - _TempInf1775 } }
259
260 // Adj Neuse Goldsboro Gage
261 Set : _TempInf1780 { Value : timesers(1780/inflow)*(23/867.2) }
262 Set : inflow1780 { Value : max{0, _TempInf1780 - _InfDeficit1780(-1) } }
263 Set : _InfDeficit1780 { Value : max{0, _InfDeficit1780(-1) - _TempInf1780 } }
264
265 // NRWASA Intake
266 Set : _TempInf1795 { Value : timesers(1800/inflow)*(211/293) }
267 Set : inflow1795 { Value : max{0, _TempInf1795 - _InfDeficit1795(-1) } }
268 Set : _InfDeficit1795 { Value : max{0, _InfDeficit1795(-1) - _TempInf1795 } }
269
270 // Adj Neuse Kinston Gage
271 Set : _TempInf1800 { Value : timesers(1800/inflow)*(82/293) }
272 Set : inflow1800 { Value : max{0, _TempInf1800 - _InfDeficit1800(-1) } }
273 Set : _InfDeficit1800 { Value : max{0, _InfDeficit1800(-1) - _TempInf1800 } }
274
275 // Little Contentnea Confluence
276 Set : _TempInf1570 { Value : timesers(1900/inflow)*(62/625) }
277 Set : inflow1570 { Value : max{0, _TempInf1570 - _InfDeficit1570(-1) } }
278 Set : _InfDeficit1570 { Value : max{0, _InfDeficit1570(-1) - _TempInf1570 } }
279
280 // Contentnea Confluence
281 Set : _TempInf1850 { Value : timesers(1900/inflow)*(208/625) }
282 Set : inflow1850 { Value : max{0, _TempInf1850 - _InfDeficit1850(-1) } }
```

filter_inflows.ocl

```
283 Set : _InfDeficit1850 { Value : max{0, _InfDeficit1850(-1) - _TempInf1850 } }
284
285 // Adj Weyerhauser Gain
286 Set : _TempInf1900 { Value : timesers(1900/inflow)*(355/625) }
287 Set : inflow1900 { Value : max{0, _TempInf1900 - _InfDeficit1900(-1) } }
288 Set : _InfDeficit1900 { Value : max{0, _InfDeficit1900(-1) - _TempInf1900 } }
289
290 // New Bern
291 Set : _TempInf1999 { Value : timesers(1900/inflow)*(10/625) }
292 Set : inflow1999 { Value : max{0, _TempInf1999 - _InfDeficit1999(-1) } }
293 Set : _InfDeficit1999 { Value : max{0, _InfDeficit1999(-1) - _TempInf1999 } }
```

Forecast_Horizon_Days.ocl

```
1 /* This file converts the forecast horizon in weeks to days (less one, for the accumulate function)
2    for use in the projections in the user_def_ops.ocl file */
3
4
5
6 /* Start with the forecast horizon 1 */
7 :if: {[Forecast_1_Horizon] = 24 }
8   :Substitute: [Forecast_1_Horizon_Days] = 167
9 :endif:
10
11 :if: {[Forecast_1_Horizon] = 23 }
12   :Substitute: [Forecast_1_Horizon_Days] = 160
13 :endif:
14
15 :if: {[Forecast_1_Horizon] = 22 }
16   :Substitute: [Forecast_1_Horizon_Days] = 153
17 :endif:
18
19 :if: {[Forecast_1_Horizon] = 21 }
20   :Substitute: [Forecast_1_Horizon_Days] = 146
21 :endif:
22
23 :if: {[Forecast_1_Horizon] = 20 }
24   :Substitute: [Forecast_1_Horizon_Days] = 139
25 :endif:
26
27 :if: {[Forecast_1_Horizon] = 19 }
28   :Substitute: [Forecast_1_Horizon_Days] = 132
29 :endif:
30
31 :if: {[Forecast_1_Horizon] = 18 }
32   :Substitute: [Forecast_1_Horizon_Days] = 125
33 :endif:
34
35 :if: {[Forecast_1_Horizon] = 17 }
36   :Substitute: [Forecast_1_Horizon_Days] = 118
37 :endif:
38
39 :if: {[Forecast_1_Horizon] = 16 }
40   :Substitute: [Forecast_1_Horizon_Days] = 111
41 :endif:
42
43 :if: {[Forecast_1_Horizon] = 15 }
44   :Substitute: [Forecast_1_Horizon_Days] = 104
45 :endif:
46
47 :if: {[Forecast_1_Horizon] = 14 }
```

Forecast_Horizon_Days.ocl

```
48 :Substitute: [Forecast_1_Horizon_Days] = 97
49 :endif:
50
51 :if: {[Forecast_1_Horizon] = 13 }
52 :Substitute: [Forecast_1_Horizon_Days] = 90
53 :endif:
54
55 :if: {[Forecast_1_Horizon] = 12 }
56 :Substitute: [Forecast_1_Horizon_Days] = 83
57 :endif:
58
59 :if: {[Forecast_1_Horizon] = 11 }
60 :Substitute: [Forecast_1_Horizon_Days] = 76
61 :endif:
62
63 :if: {[Forecast_1_Horizon] = 10 }
64 :Substitute: [Forecast_1_Horizon_Days] = 69
65 :endif:
66
67 :if: {[Forecast_1_Horizon] = 9 }
68 :Substitute: [Forecast_1_Horizon_Days] = 62
69 :endif:
70
71 :if: {[Forecast_1_Horizon] = 8 }
72 :Substitute: [Forecast_1_Horizon_Days] = 55
73 :endif:
74
75 :if: {[Forecast_1_Horizon] = 7 }
76 :Substitute: [Forecast_1_Horizon_Days] = 48
77 :endif:
78
79 :if: {[Forecast_1_Horizon] = 6 }
80 :Substitute: [Forecast_1_Horizon_Days] = 41
81 :endif:
82
83 :if: {[Forecast_1_Horizon] = 5 }
84 :Substitute: [Forecast_1_Horizon_Days] = 34
85 :endif:
86
87 :if: {[Forecast_1_Horizon] = 4 }
88 :Substitute: [Forecast_1_Horizon_Days] = 27
89 :endif:
90
91 :if: {[Forecast_1_Horizon] = 3 }
92 :Substitute: [Forecast_1_Horizon_Days] = 20
93 :endif:
94
```

Forecast_Horizon_Days.ocl

```
95 :if: {[Forecast_1_Horizon] = 2 }
96   :Substitute: [Forecast_1_Horizon_Days] = 13
97 :endif:
98
99 :if: {[Forecast_1_Horizon] = 1 }
100   :Substitute: [Forecast_1_Horizon_Days] = 6
101 :endif:
102
103
104 /* Repeat for forecast horizon 2 */
105
106 :if: {[Forecast_2_Horizon] = 24 }
107   :Substitute: [Forecast_2_Horizon_Days] = 167
108 :endif:
109
110 :if: {[Forecast_2_Horizon] = 23 }
111   :Substitute: [Forecast_2_Horizon_Days] = 160
112 :endif:
113
114 :if: {[Forecast_2_Horizon] = 22 }
115   :Substitute: [Forecast_2_Horizon_Days] = 153
116 :endif:
117
118 :if: {[Forecast_2_Horizon] = 21 }
119   :Substitute: [Forecast_2_Horizon_Days] = 146
120 :endif:
121
122 :if: {[Forecast_2_Horizon] = 20 }
123   :Substitute: [Forecast_2_Horizon_Days] = 139
124 :endif:
125
126 :if: {[Forecast_2_Horizon] = 19 }
127   :Substitute: [Forecast_2_Horizon_Days] = 132
128 :endif:
129
130 :if: {[Forecast_2_Horizon] = 18 }
131   :Substitute: [Forecast_2_Horizon_Days] = 125
132 :endif:
133
134 :if: {[Forecast_2_Horizon] = 17 }
135   :Substitute: [Forecast_2_Horizon_Days] = 118
136 :endif:
137
138 :if: {[Forecast_2_Horizon] = 16 }
139   :Substitute: [Forecast_2_Horizon_Days] = 111
140 :endif:
141
```

Forecast_Horizon_Days.ocf

```
142 :if: {[Forecast_2_Horizon] = 15 }
143   :Substitute: [Forecast_2_Horizon_Days] = 104
144 :endif:
145
146 :if: {[Forecast_2_Horizon] = 14 }
147   :Substitute: [Forecast_2_Horizon_Days] = 97
148 :endif:
149
150 :if: {[Forecast_2_Horizon] = 13 }
151   :Substitute: [Forecast_2_Horizon_Days] = 90
152 :endif:
153
154 :if: {[Forecast_2_Horizon] = 12 }
155   :Substitute: [Forecast_2_Horizon_Days] = 83
156 :endif:
157
158 :if: {[Forecast_2_Horizon] = 11 }
159   :Substitute: [Forecast_2_Horizon_Days] = 76
160 :endif:
161
162 :if: {[Forecast_2_Horizon] = 10 }
163   :Substitute: [Forecast_2_Horizon_Days] = 69
164 :endif:
165
166 :if: {[Forecast_2_Horizon] = 9 }
167   :Substitute: [Forecast_2_Horizon_Days] = 62
168 :endif:
169
170 :if: {[Forecast_2_Horizon] = 8 }
171   :Substitute: [Forecast_2_Horizon_Days] = 55
172 :endif:
173
174 :if: {[Forecast_2_Horizon] = 7 }
175   :Substitute: [Forecast_2_Horizon_Days] = 48
176 :endif:
177
178 :if: {[Forecast_2_Horizon] = 6 }
179   :Substitute: [Forecast_2_Horizon_Days] = 41
180 :endif:
181
182 :if: {[Forecast_2_Horizon] = 5 }
183   :Substitute: [Forecast_2_Horizon_Days] = 34
184 :endif:
185
186 :if: {[Forecast_2_Horizon] = 4 }
187   :Substitute: [Forecast_2_Horizon_Days] = 27
188 :endif:
```

Forecast_Horizon_Days.ocl

```
189
190 :if: {[Forecast_2_Horizon] = 3 }
191   :Substitute: [Forecast_2_Horizon_Days] = 20
192 :endif:
193
194 :if: {[Forecast_2_Horizon] = 2 }
195   :Substitute: [Forecast_2_Horizon_Days] = 13
196 :endif:
197
198 :if: {[Forecast_2_Horizon] = 1 }
199   :Substitute: [Forecast_2_Horizon_Days] = 6
200 :endif:
201
202
203 /* Repeat for forecast horizon 3 */
204
205 :if: {[Forecast_3_Horizon] = 24 }
206   :Substitute: [Forecast_3_Horizon_Days] = 167
207 :endif:
208
209 :if: {[Forecast_3_Horizon] = 23 }
210   :Substitute: [Forecast_3_Horizon_Days] = 160
211 :endif:
212
213 :if: {[Forecast_3_Horizon] = 22 }
214   :Substitute: [Forecast_3_Horizon_Days] = 153
215 :endif:
216
217 :if: {[Forecast_3_Horizon] = 21 }
218   :Substitute: [Forecast_3_Horizon_Days] = 146
219 :endif:
220
221 :if: {[Forecast_3_Horizon] = 20 }
222   :Substitute: [Forecast_3_Horizon_Days] = 139
223 :endif:
224
225 :if: {[Forecast_3_Horizon] = 19 }
226   :Substitute: [Forecast_3_Horizon_Days] = 132
227 :endif:
228
229 :if: {[Forecast_3_Horizon] = 18 }
230   :Substitute: [Forecast_3_Horizon_Days] = 125
231 :endif:
232
233 :if: {[Forecast_3_Horizon] = 17 }
234   :Substitute: [Forecast_3_Horizon_Days] = 118
235 :endif:
```

Forecast_Horizon_Days.ocl

```
236
237 :if: {[Forecast_3_Horizon] = 16 }
238   :Substitute: [Forecast_3_Horizon_Days] = 111
239 :endif:
240
241 :if: {[Forecast_3_Horizon] = 15 }
242   :Substitute: [Forecast_3_Horizon_Days] = 104
243 :endif:
244
245 :if: {[Forecast_3_Horizon] = 14 }
246   :Substitute: [Forecast_3_Horizon_Days] = 97
247 :endif:
248
249 :if: {[Forecast_3_Horizon] = 13 }
250   :Substitute: [Forecast_3_Horizon_Days] = 90
251 :endif:
252
253 :if: {[Forecast_3_Horizon] = 12 }
254   :Substitute: [Forecast_3_Horizon_Days] = 83
255 :endif:
256
257 :if: {[Forecast_3_Horizon] = 11 }
258   :Substitute: [Forecast_3_Horizon_Days] = 76
259 :endif:
260
261 :if: {[Forecast_3_Horizon] = 10 }
262   :Substitute: [Forecast_3_Horizon_Days] = 69
263 :endif:
264
265 :if: {[Forecast_3_Horizon] = 9 }
266   :Substitute: [Forecast_3_Horizon_Days] = 62
267 :endif:
268
269 :if: {[Forecast_3_Horizon] = 8 }
270   :Substitute: [Forecast_3_Horizon_Days] = 55
271 :endif:
272
273 :if: {[Forecast_3_Horizon] = 7 }
274   :Substitute: [Forecast_3_Horizon_Days] = 48
275 :endif:
276
277 :if: {[Forecast_3_Horizon] = 6 }
278   :Substitute: [Forecast_3_Horizon_Days] = 41
279 :endif:
280
281 :if: {[Forecast_3_Horizon] = 5 }
282   :Substitute: [Forecast_3_Horizon_Days] = 34
```

Forecast_Horizon_Days.ocl

```
283 :endif:
284
285 :if: {[Forecast_3_Horizon] = 4 }
286   :Substitute: [Forecast_3_Horizon_Days] = 27
287 :endif:
288
289 :if: {[Forecast_3_Horizon] = 3 }
290   :Substitute: [Forecast_3_Horizon_Days] = 20
291 :endif:
292
293 :if: {[Forecast_3_Horizon] = 2 }
294   :Substitute: [Forecast_3_Horizon_Days] = 13
295 :endif:
296
297 :if: {[Forecast_3_Horizon] = 1 }
298   :Substitute: [Forecast_3_Horizon_Days] = 6
299 :endif:
300
301
302 /* Repeat for forecast horizon 4 */
303
304 :if: {[Forecast_4_Horizon] = 24 }
305   :Substitute: [Forecast_4_Horizon_Days] = 167
306 :endif:
307
308 :if: {[Forecast_4_Horizon] = 23 }
309   :Substitute: [Forecast_4_Horizon_Days] = 160
310 :endif:
311
312 :if: {[Forecast_4_Horizon] = 22 }
313   :Substitute: [Forecast_4_Horizon_Days] = 153
314 :endif:
315
316 :if: {[Forecast_4_Horizon] = 21 }
317   :Substitute: [Forecast_4_Horizon_Days] = 146
318 :endif:
319
320 :if: {[Forecast_4_Horizon] = 20 }
321   :Substitute: [Forecast_4_Horizon_Days] = 139
322 :endif:
323
324 :if: {[Forecast_4_Horizon] = 19 }
325   :Substitute: [Forecast_4_Horizon_Days] = 132
326 :endif:
327
328 :if: {[Forecast_4_Horizon] = 18 }
329   :Substitute: [Forecast_4_Horizon_Days] = 125
```

Forecast_Horizon_Days.ocl

```
330 :endif:
331
332 :if: {[Forecast_4_Horizon] = 17 }
333   :Substitute: [Forecast_4_Horizon_Days] = 118
334 :endif:
335
336 :if: {[Forecast_4_Horizon] = 16 }
337   :Substitute: [Forecast_4_Horizon_Days] = 111
338 :endif:
339
340 :if: {[Forecast_4_Horizon] = 15 }
341   :Substitute: [Forecast_4_Horizon_Days] = 104
342 :endif:
343
344 :if: {[Forecast_4_Horizon] = 14 }
345   :Substitute: [Forecast_4_Horizon_Days] = 97
346 :endif:
347
348 :if: {[Forecast_4_Horizon] = 13 }
349   :Substitute: [Forecast_4_Horizon_Days] = 90
350 :endif:
351
352 :if: {[Forecast_4_Horizon] = 12 }
353   :Substitute: [Forecast_4_Horizon_Days] = 83
354 :endif:
355
356 :if: {[Forecast_4_Horizon] = 11 }
357   :Substitute: [Forecast_4_Horizon_Days] = 76
358 :endif:
359
360 :if: {[Forecast_4_Horizon] = 10 }
361   :Substitute: [Forecast_4_Horizon_Days] = 69
362 :endif:
363
364 :if: {[Forecast_4_Horizon] = 9 }
365   :Substitute: [Forecast_4_Horizon_Days] = 62
366 :endif:
367
368 :if: {[Forecast_4_Horizon] = 8 }
369   :Substitute: [Forecast_4_Horizon_Days] = 55
370 :endif:
371
372 :if: {[Forecast_4_Horizon] = 7 }
373   :Substitute: [Forecast_4_Horizon_Days] = 48
374 :endif:
375
376 :if: {[Forecast_4_Horizon] = 6 }
```

Forecast_Horizon_Days.ocl

```
377 :Substitute: [Forecast_4_Horizon_Days] = 41
378 :endif:
379
380 :if: {[Forecast_4_Horizon] = 5 }
381 :Substitute: [Forecast_4_Horizon_Days] = 34
382 :endif:
383
384 :if: {[Forecast_4_Horizon] = 4 }
385 :Substitute: [Forecast_4_Horizon_Days] = 27
386 :endif:
387
388 :if: {[Forecast_4_Horizon] = 3 }
389 :Substitute: [Forecast_4_Horizon_Days] = 20
390 :endif:
391
392 :if: {[Forecast_4_Horizon] = 2 }
393 :Substitute: [Forecast_4_Horizon_Days] = 13
394 :endif:
395
396 :if: {[Forecast_4_Horizon] = 1 }
397 :Substitute: [Forecast_4_Horizon_Days] = 6
398 :endif:
399
400
401 /* Repeat for forecast horizon 5 */
402
403 :if: {[Forecast_5_Horizon] = 24 }
404 :Substitute: [Forecast_5_Horizon_Days] = 167
405 :endif:
406
407 :if: {[Forecast_5_Horizon] = 23 }
408 :Substitute: [Forecast_5_Horizon_Days] = 160
409 :endif:
410
411 :if: {[Forecast_5_Horizon] = 22 }
412 :Substitute: [Forecast_5_Horizon_Days] = 153
413 :endif:
414
415 :if: {[Forecast_5_Horizon] = 21 }
416 :Substitute: [Forecast_5_Horizon_Days] = 146
417 :endif:
418
419 :if: {[Forecast_5_Horizon] = 20 }
420 :Substitute: [Forecast_5_Horizon_Days] = 139
421 :endif:
422
423 :if: {[Forecast_5_Horizon] = 19 }
```

Forecast_Horizon_Days.ocl

```
424 :Substitute: [Forecast_5_Horizon_Days] = 132
425 :endif:
426
427 :if: {[Forecast_5_Horizon] = 18 }
428 :Substitute: [Forecast_5_Horizon_Days] = 125
429 :endif:
430
431 :if: {[Forecast_5_Horizon] = 17 }
432 :Substitute: [Forecast_5_Horizon_Days] = 118
433 :endif:
434
435 :if: {[Forecast_5_Horizon] = 16 }
436 :Substitute: [Forecast_5_Horizon_Days] = 111
437 :endif:
438
439 :if: {[Forecast_5_Horizon] = 15 }
440 :Substitute: [Forecast_5_Horizon_Days] = 104
441 :endif:
442
443 :if: {[Forecast_5_Horizon] = 14 }
444 :Substitute: [Forecast_5_Horizon_Days] = 97
445 :endif:
446
447 :if: {[Forecast_5_Horizon] = 13 }
448 :Substitute: [Forecast_5_Horizon_Days] = 90
449 :endif:
450
451 :if: {[Forecast_5_Horizon] = 12 }
452 :Substitute: [Forecast_5_Horizon_Days] = 83
453 :endif:
454
455 :if: {[Forecast_5_Horizon] = 11 }
456 :Substitute: [Forecast_5_Horizon_Days] = 76
457 :endif:
458
459 :if: {[Forecast_5_Horizon] = 10 }
460 :Substitute: [Forecast_5_Horizon_Days] = 69
461 :endif:
462
463 :if: {[Forecast_5_Horizon] = 9 }
464 :Substitute: [Forecast_5_Horizon_Days] = 62
465 :endif:
466
467 :if: {[Forecast_5_Horizon] = 8 }
468 :Substitute: [Forecast_5_Horizon_Days] = 55
469 :endif:
470
```

Forecast_Horizon_Days.ocl

```
471 :if: {[Forecast_5_Horizon] = 7 }
472   :Substitute: [Forecast_5_Horizon_Days] = 48
473 :endif:
474
475 :if: {[Forecast_5_Horizon] = 6 }
476   :Substitute: [Forecast_5_Horizon_Days] = 41
477 :endif:
478
479 :if: {[Forecast_5_Horizon] = 5 }
480   :Substitute: [Forecast_5_Horizon_Days] = 34
481 :endif:
482
483 :if: {[Forecast_5_Horizon] = 4 }
484   :Substitute: [Forecast_5_Horizon_Days] = 27
485 :endif:
486
487 :if: {[Forecast_5_Horizon] = 3 }
488   :Substitute: [Forecast_5_Horizon_Days] = 20
489 :endif:
490
491 :if: {[Forecast_5_Horizon] = 2 }
492   :Substitute: [Forecast_5_Horizon_Days] = 13
493 :endif:
494
495 :if: {[Forecast_5_Horizon] = 1 }
496   :Substitute: [Forecast_5_Horizon_Days] = 6
497 :endif:
498
499
500
501
502
503 /* Repeat for forecast horizon 6 */
504
505 :if: {[Forecast_6_Horizon] = 24 }
506   :Substitute: [Forecast_6_Horizon_Days] = 167
507 :endif:
508
509 :if: {[Forecast_6_Horizon] = 23 }
510   :Substitute: [Forecast_6_Horizon_Days] = 160
511 :endif:
512
513 :if: {[Forecast_6_Horizon] = 22 }
514   :Substitute: [Forecast_6_Horizon_Days] = 153
515 :endif:
516
517 :if: {[Forecast_6_Horizon] = 21 }
```

Forecast_Horizon_Days.ocf

```
518 :Substitute: [Forecast_6_Horizon_Days] = 146
519 :endif:
520
521 :if: {[Forecast_6_Horizon] = 20 }
522 :Substitute: [Forecast_6_Horizon_Days] = 139
523 :endif:
524
525 :if: {[Forecast_6_Horizon] = 19 }
526 :Substitute: [Forecast_6_Horizon_Days] = 132
527 :endif:
528
529 :if: {[Forecast_6_Horizon] = 18 }
530 :Substitute: [Forecast_6_Horizon_Days] = 125
531 :endif:
532
533 :if: {[Forecast_6_Horizon] = 17 }
534 :Substitute: [Forecast_6_Horizon_Days] = 118
535 :endif:
536
537 :if: {[Forecast_6_Horizon] = 16 }
538 :Substitute: [Forecast_6_Horizon_Days] = 111
539 :endif:
540
541 :if: {[Forecast_6_Horizon] = 15 }
542 :Substitute: [Forecast_6_Horizon_Days] = 104
543 :endif:
544
545 :if: {[Forecast_6_Horizon] = 14 }
546 :Substitute: [Forecast_6_Horizon_Days] = 97
547 :endif:
548
549 :if: {[Forecast_6_Horizon] = 13 }
550 :Substitute: [Forecast_6_Horizon_Days] = 90
551 :endif:
552
553 :if: {[Forecast_6_Horizon] = 12 }
554 :Substitute: [Forecast_6_Horizon_Days] = 83
555 :endif:
556
557 :if: {[Forecast_6_Horizon] = 11 }
558 :Substitute: [Forecast_6_Horizon_Days] = 76
559 :endif:
560
561 :if: {[Forecast_6_Horizon] = 10 }
562 :Substitute: [Forecast_6_Horizon_Days] = 69
563 :endif:
564
```

Forecast_Horizon_Days.ocl

```
565 :if: {[Forecast_6_Horizon] = 9 }
566   :Substitute: [Forecast_6_Horizon_Days] = 62
567 :endif:
568
569 :if: {[Forecast_6_Horizon] = 8}
570   :Substitute: [Forecast_6_Horizon_Days] = 55
571 :endif:
572
573 :if: {[Forecast_6_Horizon] = 7 }
574   :Substitute: [Forecast_6_Horizon_Days] = 48
575 :endif:
576
577 :if: {[Forecast_6_Horizon] = 6 }
578   :Substitute: [Forecast_6_Horizon_Days] = 41
579 :endif:
580
581 :if: {[Forecast_6_Horizon] = 5 }
582   :Substitute: [Forecast_6_Horizon_Days] = 34
583 :endif:
584
585 :if: {[Forecast_6_Horizon] = 4 }
586   :Substitute: [Forecast_6_Horizon_Days] = 27
587 :endif:
588
589 :if: {[Forecast_6_Horizon] = 3 }
590   :Substitute: [Forecast_6_Horizon_Days] = 20
591 :endif:
592
593 :if: {[Forecast_6_Horizon] = 2 }
594   :Substitute: [Forecast_6_Horizon_Days] = 13
595 :endif:
596
597 :if: {[Forecast_6_Horizon] = 1 }
598   :Substitute: [Forecast_6_Horizon_Days] = 6
599 :endif:
600
601
602
603
604 /* Repeat for forecast horizon 7 */
605
606 :if: {[Forecast_7_Horizon] = 24 }
607   :Substitute: [Forecast_7_Horizon_Days] = 167
608 :endif:
609
610 :if: {[Forecast_7_Horizon] = 23 }
611   :Substitute: [Forecast_7_Horizon_Days] = 160
```

Forecast_Horizon_Days.ocl

```
612 :endif:
613
614 :if: {[Forecast_7_Horizon] = 22 }
615   :Substitute: [Forecast_7_Horizon_Days] = 153
616 :endif:
617
618 :if: {[Forecast_7_Horizon] = 21 }
619   :Substitute: [Forecast_7_Horizon_Days] = 146
620 :endif:
621
622 :if: {[Forecast_7_Horizon] = 20 }
623   :Substitute: [Forecast_7_Horizon_Days] = 139
624 :endif:
625
626 :if: {[Forecast_7_Horizon] = 19 }
627   :Substitute: [Forecast_7_Horizon_Days] = 132
628 :endif:
629
630 :if: {[Forecast_7_Horizon] = 18 }
631   :Substitute: [Forecast_7_Horizon_Days] = 125
632 :endif:
633
634 :if: {[Forecast_7_Horizon] = 17 }
635   :Substitute: [Forecast_7_Horizon_Days] = 118
636 :endif:
637
638 :if: {[Forecast_7_Horizon] = 16 }
639   :Substitute: [Forecast_7_Horizon_Days] = 111
640 :endif:
641
642 :if: {[Forecast_7_Horizon] = 15 }
643   :Substitute: [Forecast_7_Horizon_Days] = 104
644 :endif:
645
646 :if: {[Forecast_7_Horizon] = 14 }
647   :Substitute: [Forecast_7_Horizon_Days] = 97
648 :endif:
649
650 :if: {[Forecast_7_Horizon] = 13 }
651   :Substitute: [Forecast_7_Horizon_Days] = 90
652 :endif:
653
654 :if: {[Forecast_7_Horizon] = 12 }
655   :Substitute: [Forecast_7_Horizon_Days] = 83
656 :endif:
657
658 :if: {[Forecast_7_Horizon] = 11 }
```

Forecast_Horizon_Days.ocf

```
659 :Substitute: [Forecast_7_Horizon_Days] = 76
660 :endif:
661
662 :if: {[Forecast_7_Horizon] = 10 }
663 :Substitute: [Forecast_7_Horizon_Days] = 69
664 :endif:
665
666 :if: {[Forecast_7_Horizon] = 9 }
667 :Substitute: [Forecast_7_Horizon_Days] = 62
668 :endif:
669
670 :if: {[Forecast_7_Horizon] = 8 }
671 :Substitute: [Forecast_7_Horizon_Days] = 55
672 :endif:
673
674 :if: {[Forecast_7_Horizon] = 7 }
675 :Substitute: [Forecast_7_Horizon_Days] = 48
676 :endif:
677
678 :if: {[Forecast_7_Horizon] = 6 }
679 :Substitute: [Forecast_7_Horizon_Days] = 41
680 :endif:
681
682 :if: {[Forecast_7_Horizon] = 5 }
683 :Substitute: [Forecast_7_Horizon_Days] = 34
684 :endif:
685
686 :if: {[Forecast_7_Horizon] = 4 }
687 :Substitute: [Forecast_7_Horizon_Days] = 27
688 :endif:
689
690 :if: {[Forecast_7_Horizon] = 3 }
691 :Substitute: [Forecast_7_Horizon_Days] = 20
692 :endif:
693
694 :if: {[Forecast_7_Horizon] = 2 }
695 :Substitute: [Forecast_7_Horizon_Days] = 13
696 :endif:
697
698 :if: {[Forecast_7_Horizon] = 1 }
699 :Substitute: [Forecast_7_Horizon_Days] = 6
700 :endif:
```

Forecast-Trigger_Parms.ocf

```
1 // This file is automatically generated by the OASIS GUI
2 // Any changes you make in this file may be automatically overwritten
3
4 // This file contains parameter values that define the forecasting-and-trigger scenario
5
6 :SUBSTITUTE: [UseForecast] = 1
7 :SUBSTITUTE: [ForecastData] = cond
8
9
10 // The values below vary by trigger level
11
12 :SUBSTITUTE: [ForcCode_1] = R30W12
13 :SUBSTITUTE: [ForcCode_2] = R20W10
14 :SUBSTITUTE: [ForcCode_3] = R10W08
15 :SUBSTITUTE: [ForcCode_4] = R05W04
16 :SUBSTITUTE: [ForcCode_5] = R05W10
17
18 :SUBSTITUTE: [Risk_1_Factor_0] = 30
19 :SUBSTITUTE: [Risk_2_Factor_0] = 20
20 :SUBSTITUTE: [Risk_3_Factor_0] = 10
21 :SUBSTITUTE: [Risk_4_Factor_0] = 05
22 :SUBSTITUTE: [Risk_5_Factor_0] = 05
23
24 :SUBSTITUTE: [Forecast_1_Horizon_0] = 12
25 :SUBSTITUTE: [Forecast_2_Horizon_0] = 10
26 :SUBSTITUTE: [Forecast_3_Horizon_0] = 08
27 :SUBSTITUTE: [Forecast_4_Horizon_0] = 04
28 :SUBSTITUTE: [Forecast_5_Horizon_0] = 10
29
30 :SUBSTITUTE: [Risk_1_Factor] = 30
31 :SUBSTITUTE: [Risk_2_Factor] = 20
32 :SUBSTITUTE: [Risk_3_Factor] = 10
33 :SUBSTITUTE: [Risk_4_Factor] = 5
34 :SUBSTITUTE: [Risk_5_Factor] = 5
35
36 :SUBSTITUTE: [Forecast_1_Horizon] = 12
37 :SUBSTITUTE: [Forecast_2_Horizon] = 10
38 :SUBSTITUTE: [Forecast_3_Horizon] = 8
39 :SUBSTITUTE: [Forecast_4_Horizon] = 4
40 :SUBSTITUTE: [Forecast_5_Horizon] = 10
41
42 :SUBSTITUTE: [Trigger_1_Stor] = 45
43 :SUBSTITUTE: [Trigger_2_Stor] = 35
44 :SUBSTITUTE: [Trigger_3_Stor] = 25
45 :SUBSTITUTE: [Trigger_4_Stor] = 15
46 :SUBSTITUTE: [Trigger_5_Stor] = 90
47
```

Forecast-Trigger_Parms.ocf

48 :SUBSTITUTE: [Dem_1_Red_Factor] = 0
49 :SUBSTITUTE: [Dem_2_Red_Factor] = 0
50 :SUBSTITUTE: [Dem_3_Red_Factor] = 0
51 :SUBSTITUTE: [Dem_4_Red_Factor] = 0
52 :SUBSTITUTE: [Dem_5_Red_Factor] = 0
53
54 :SUBSTITUTE: [MinFlow_1_Red_Factor] = 0
55 :SUBSTITUTE: [MinFlow_2_Red_Factor] = 0
56 :SUBSTITUTE: [MinFlow_3_Red_Factor] = 0
57 :SUBSTITUTE: [MinFlow_4_Red_Factor] = 0
58 :SUBSTITUTE: [MinFlow_5_Red_Factor] = 0
59

FtBragg_ops.ocl

```
1 /*FTBRAGG_OPS.OCL */
2
3 /* Operational policy for Ft. Bragg */
4
5 // Set targets to dictate WDs between
6 Constraint : {dFlow0662.0721 = 0} // none from Dunn
7
8
9 // Set the fraction coming from Harnett w/ a substitute
10
11 :Substitute: [FtBraggWS_Harnett] = 0.5
12
13 Target Harnett_WD : dflow0549.0721
14 { condition : default
15     priority : 1
16     penalty+ : 90
17     penalty- : 90
18     Value    : [FtBraggWS_Harnett] * demand0721 // The rest will be from Fayetteville
19 }
```

Fuquay_ops.ocl

```
1 /* FUQUAY_OPS.OCL */
2
3 /* Operational policy for Fuquay-Varina's system. Set as maximum flows to limit deliveries to supply contracts, with OASIS reducing deliveries
4 if needed so that the nominal F-V demand is not exceeded. Weighting on delivery arcs reflects priority of delivery using supply contracts with
5 local entities. First, for the Neuse portion of the F-V demand (= demand 1706 x [Demand_FV_Neuse], meet first from Raleigh, then Johnston
6 County, so no IBT since they are both in the Neuse. Assume any additional supply needed to meet the Neuse portion of demand would be part
7 of the alternative that is being evaluated assuming it is in the Neuse (thus minimizing the IBT).
8
9 Any unmet portion of this demand then comes from Sanford, then Harnett County. IBT would be from Cape Fear (since Sanford and HC are in the
10 Cape Fear) to the Neuse to meet the Neuse portion of the demand. Should that not be enough, if the alternative supply is in the Cape Fear, this
11 is assumed to provide the remaining amount to meet the Neuse portion of the demand.
12
13 For the remaining portion of the F-V demand, in the Cape Fear, first meet from Sanford, then Harnett County, then Johnston County, ensuring the
14 contracts are maxed out. [Although for alternative supplies that rely on new WTP for F-V, F-V would probably prioritize the alternative supply
15 since it would be cheaper]. This approach provides consistency across all alternatives.
16
17 IBT would be from Neuse to Cape Fear (since Johnston County is in the Neuse) to meet the Cape Fear portion of the demand. Raleigh supply since
18 it is relatively small would only be used on the Neuse portion of the F-V demand. Assume any additional supply needed to meet the Cape Fear
19 portion of the demand would be part of the alternative that is being evaluated. */
20
21 // First pull from Raleigh to meet the Neuse portion of the F-V demand.
22 Set FV_Ral_Max : max_flow1305.1706 { value : min { demand1706 * [Demand_FV_Neuse], convert_units{[FV_Ral_Supply], mgd, af} } }
23
24 // Pull from JC for the remaining Neuse portion of this demand.
25 Set FV_Johnston_Prelim : _Prelim_Max_JC_Neuse
26 { value : min { demand1706 * [Demand_FV_Neuse] - max_flow1305.1706, convert_units{[FV_Johnston_Supply], mgd, af} } }
27
28 // ***
29 // Pull from the alternative being evaluated (if in the Neuse) for the remaining Neuse portion of this demand. Set to 0 if not evaluating an alternative,
30 // or evaluating an alternative that pulls only from the Cape Fear.
31 Set FV_Alt_Prelim : _Prelim_Max_Alt_Neuse
32 { value : 0 } // demand1706 * [Demand_FV_Neuse] - max_flow1305.1706 - _Prelim_Max_JC_Neuse }
33
34 // Pull from Sanford for the remaining Neuse portion of this demand.
35 Set FV_Sanford_Prelim : _Prelim_Max_Sanford_Neuse
36 { value : min { demand1706 * [Demand_FV_Neuse] - max_flow1305.1706 - _Prelim_Max_JC_Neuse
37   - _Prelim_Max_Alt_Neuse, convert_units{[FV_Sanford_Supply], mgd, af} } }
38
39 // Pull from Harnett County for the remaining Neuse portion of this demand.
40 Set FV_HC_Prelim : _Prelim_Max_HC_Neuse
41 { value : min { demand1706 * [Demand_FV_Neuse] - max_flow1305.1706 - _Prelim_Max_JC_Neuse
42   - _Prelim_Max_Alt_Neuse - _Prelim_Max_Sanford_Neuse, convert_units{[FV_Harnett_Supply], mgd, af} } }
43
44 // ***
45 // Pull from the alternative being evaluated (if in the Cape Fear) for the remaining Neuse portion of this demand. Set to 0 if not evaluating an
46 // alternative, or if the alternative pulls only from the Neuse.
47 Set FV_Alt_Prelim : _Prelim_Max_Alt_CF_to_Neuse
```

Fuquay_ops.ocl

```
48 { value : 0 }
49 // demand1706 * [Demand_FV_Neuse] - max_flow1305.1706 - _Prelim_Max_JC_Neuse - _Prelim_Max_Sanford_Neuse - _Prelim_Max_HC_Neuse }
50
51 // Set the IBTs based on this. For the Cape Fear to Neuse, it would be Sanford and HC and alternative supply (if any) deliveries to the Neuse portion
52 // of the F-V demand since they are in the Cape Fear.
53 Set : _IBT_CF_to_Neuse { value : _Prelim_Max_Sanford_Neuse + _Prelim_Max_HC_Neuse + _Prelim_Max_Alt_CF_to_Neuse }
54
55 // The above assumes the Neuse portion of the demand is fully met (check output to confirm this). Reset production for Sanford, HC, and JC
56 // based on the total system demand less the contributions above toward the Neuse portion of the demand.
57
58 // Now for the Cape Fear portion of the demand. To be met first from Sanford, then Harnett County (so no IBT), then Johnston County (so an IBT),
59 // then the alternative being evaluated (Whether in the Neuse or Cape Fear).
60 Set FV_Sanford_Max : max_flow0489.1706
61 { value : min { demand1706 - max_flow1305.1706 - _Prelim_Max_JC_Neuse - _Prelim_Max_Alt_Neuse
62   - _IBT_CF_to_Neuse, convert_units{[FV_Sanford_Supply], mgd, af } } }
63 Set FV_Harnett_Max : max_flow0549.1706
64 { value : min { demand1706 - max_flow1305.1706 - _Prelim_Max_JC_Neuse - _Prelim_Max_Alt_Neuse
65   - _IBT_CF_to_Neuse - max_flow0489.1706, convert_units{[FV_Harnett_Supply], mgd, af } } }
66
67 // Reset Johnston County delivery depending on whether there is still a demand deficit for F-V Cape Fear portion to be met. Do not include
68 // the alternative supply that comes only from the Cape Fear since that comes later..
69 Set Johnston_County_Final : max_flow1656.1706
70 { value : min {demand1706 - max_flow1305.1706 - _Prelim_Max_Alt_Neuse - max_flow0489.1706 - max_flow0549.1706,
71   convert_units{[FV_Johnston_Supply], mgd, af } } }
72
73 // ***
74 // Set alternative to 0 if not being evaluated. Otherwise, it is the amount to meet the remaining system demand.
75 Set : _Final_Max_Flow_Alt { value : 0 } // demand1706 - max_flow1305.1706 - max_flow0489.1706 - max_flow0549.1706 - max_flow1656.1706 }
76
77 // Comment out if not evaluating an alternative. Otherwise, the max flow is on the alternative supply arc.
78 // Set : max_flow0490.1706 { value : _Final_Max_Flow_Alt }
79
80
81 // Set the IBT from the Neuse to the Cape Fear to meet the Cape Fear portion of F-V demand. Again, assume Raleigh supply is only
82 // enough to help meet the Neuse portion of demand.
83 Set : _IBT_Neuse_to_CF
84 /* This will be zero if either Sanford or HC supplies water to the Neuse portion of the demand (since the alternative supply if from the Neuse
85   would be used first). If Raleigh and JC supply were high enough to meet the Neuse portion of the demand, this condition may not be met,
86   but this scenario would not occur based on expected contract amounts. */
87 { condition : _Prelim_Max_Sanford_Neuse > 0 or _Prelim_Max_HC_Neuse > 0
88   value : 0
89
90 /* This will be the amount from JC in excess of what it supplies to the Neuse portion of the demand, plus the amount of the
91   alternative supply in excess of what is supplied to the Neuse portion of the demand. */
92   condition : default
93   value : ( max_flow1656.1706 - _Prelim_Max_JC_Neuse ) + ( _Final_Max_Flow_Alt - _Prelim_Max_Alt_Neuse )
94 }
```

Gravity_Refill.ocl

```
1 /* This file contains the commands for estimating one day's spill from a reservoir.
2 The file is included once for each reservoir where detailed spill estimates are
3 required. A set of substitutes must be properly set before the :include:
4 statement of this file. The substitutes are:
5
6 //updated from Spill_Curve.ocl
7
8 [sp_us_node] = The reservoir node to which the spillway flows //1120
9 [sp_spill_node] = The junction node at which we compute spill //1115
10 [sp_ds_node] = The downstream node that represents gatehouse flow from the reservoir, or 'NONE'
11 [sp_spill_node2] = The node to which the second spillway flows, or 'NONE'.
12             If there are two spillways, then this must be the lower of the two.
13 [sp_lookup2] = The name of the OCL lookup function for the second spillway, or 'NONE'
14
15
16 The calculations are performed at a small time step for better accuracy. The
17 small time step is now 1 hour, but the file is easily modified for another
18 small-time-step size. The assumed 'total inflow' and 'total outflow' for the
19 reservoir node are assumed steady over the day. Within each small time step,
20 the spillway flow is assumed steady based on the WSE at the beginning of the
21 small time step.
22 */
23
24
25 // The number of steps must correspond with the number of iterations
26 // in the :FOR: loop below
27
28 :substitute: [sp_num_steps] = 24
29
30 // Repeat the calculations once for every small time step for calculating
31 // spillway flow. The number of iterations in the :FOR: loop must match
32 // [sp_num_steps] above. The first [sp_step_num] must be 01, and the last
33 // must be the same as [sp_num_steps].
34
35 :FOR:
36 { [sp_step_num] =
37   { 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14,15, 16, 17, 18, 19, 20, 21, 22, 23, 24 }
38 }
39
40 :if: { [sp_step_num]=01 }
41     // In the first small time step, use zero spillway flow for the day
42     :substitute: [i_sp_flow] = 0
43 :else:
44     // In the subsequent small time step, accumulate spillway flow in this variable
45     :substitute: [i_sp_flow] = sp_flow
46 :endif:
47
```

Gravity_Refill.ocl

```
48 // Compute storage in Teer that results from flow (from Eno) of the current small time step
49 SET sp_stor_[sp_us_node].[sp_spill_node]_[sp_step_num]: sp_stor
50 {
51     value: storage[sp_us_node]+ [i_sp_flow]
52
53 }
54
55 //Calculates head differential between Eno River and Teer Quarry to determine flow through pumping station,
56 //calc doesn't consider quarry elevation below 254
57
58
59 Set : Head_Differential_Teer_Hourly
60 {
61     condition 1 : stor_to_elev{[sp_us_node],sp_stor} >= 254
62     value      : Eno_River_Stage-stor_to_elev{[sp_us_node],sp_stor}
63
64     condition 2 : default
65     value       : Eno_River_Stage - 254
66 }
67
68
69
70 SET : Max_Gravity_Refill_Eno_Hourly
71 {
72     value : min{Lookup{48inConduit, Head_Differential_Teer_Hourly}, Max_Weir_Flow} //will be in cfs
73
74 }
75
76 // Compute Flow from Eno that results from the storage level at the beginning
77 // of the current small time step.
78 SET sp_flow_[sp_us_node].[sp_spill_node]_[sp_step_num]: sp_flow
79 {
80     value: [i_sp_flow]
81         + convert_units { Max_Gravity_Refill_Eno_Hourly , cfs , af }
82         / [sp_num_steps]
83
84 }
85
86
87
88 :NEXT:
89
90
91 // Apply the spill to the model using the min_flow variable. The weights in
92 // the weights table apply a very large penalty to exceeding this min flow.
93 // A negative weight on the D zone of the reservoir forces the water out
94 // of the reservoir.
```

Gravity_Refill.ocl

```
95
96 SET: Max_Gravity_Refill_Eno_Hourly_1
97 {
98     value: sp_flow
99 }
100
101
102
```

Greensboro_ops.ocl

```
1 /*GREENSBORO_OPS.OCL */
2
3 /* Operational policy for Greensboro's system */
4
5 /* Set interconnects unused in basecase to zero */
6 Constraint : {dFlow0044.0140 = 0 } // Emer Intake
7
8 //Constraint : {dFlow0271.0121 = 0 } // PTR A - currently in use, not 0
9 //Constraint : {dFlow0122.0224 = 0 } // High Pt WW
10 //Constraint : {dFlow0121.0903 = 0 } // Jamestown
11
12
13
14 // Current Townsend Min. Release
15 //Set TownsendRelease : min_flow0140.0145 { value : convert_units { 3.0, cfs, af } }
16
17 // Future scenario Townsend minimum release - based on stage
18 Set TownsendRelease : min_flow0140.0145
19 { condition : elevation0140 < 709.7
20   value    : convert_units { 2.0, cfs, af }
21
22   condition : elevation0140 < 714.5
23   value    : convert_units { 3.5, cfs, af }
24
25   condition : default
26   value    : convert_units { 7.0, cfs, af }
27 }
28
29 // Set the transfer (1 MGD constant) from Reidsville
30 Target Reids_GB_Transfer : dflow0029.0121
31 { condition : default
32   priority : 1
33   penalty+ : 10000
34   penalty- : 275
35   Value    : convert_units { 5, mgd, af } // new contract value
36 }
37
38 // Set the transfer (2 MGD constant) from Burlington
39 Target Burl_GB_Transfer : dflow0071.0121
40 { condition : default
41   priority : 1
42   penalty+ : 10000
43   penalty- : 275
44   Value    : convert_units { 5, mgd, af } //new contract value
45 }
46
47 //Set the transfer from PTR A
```

Greensboro_ops.ocl

```
48 Target PTRA_GB_Transfer: dflow0271.0121
49 { condition : default
50 priority : 1
51 penalty+ : 100
52 penalty- : 1000
53 Value : convert_units{15.31, mgd,af} // must purchase 53.1% of increase in allocation
54 }
55
56 Set PTRA_GB_Max: max_flow0271.0121
57 { condition: default
58 Value: convert_units{24.03,mgd,af} // max contract in 2055
59 }
60
61 // Set targets to dictate WDs between reservoirs
62 Target Townsend_WD : dflow0140.0121
63 { condition : default
64 priority : 1
65 penalty+ : 100
66 penalty- : 100
67 Value : 0.67 * (demand0123 - flow0071.0121 - flow0029.0121 - flow0271.0121) // 67% (previously 50%, changed by KES based off of
68 // LWSP) (less the Burlington/Reidsville/PTRA
69 // transfers) from Townsend, the rest will be from Brandt
70 }
```

Harris_ops.ocl

```
1 /* Harris_Ops.ocl */
2 /* Operational policies for Harris Lake */
3
4 // Spill rating curve for Harris.
5
6 // The D zone weight is -25, so if in the spill zone, the computed spill will occur because 25 points will otherwise be lost.
7 // However, spill will not exceed the computed amount because 100 points will be lost, or a net loss of 100 -25, or 75 points.
8 // We don't want spill to occur above the computed amount in order to meet shortages downstream on the main stem. Also, we don't
9 // want the spill to be curtailed for a Fayetteville max flow downstream of 20,000 cfs, which is the Corps operating target. Jordan
10 // will curtail releases (but not below the minimum release), but Harris will not, so the D zone penalty is higher than the weight
11 // at Fayetteville.
12
13 // If reservoir elevation is below the spill zone starting at 220 feet, only the min release (if any is set) will be met since that arc gets a weight
14 // of gets a weight of 10. The spill arc gets a weight of -10. Note releases will not exceed the minimum when below the spill zone since
15 // a weight of -100 is placed on the B zone of the arc. Normally this is not needed but with the interplay with Jordan Lake, the weights in the
16 // reservoir zones are such that we need additional confirmation that Harris won't release more than the minimum in this arc.
17
18 // Set a udef for the projected end of day elevation will be used to determine spill from the rating curve.
19 Set : _Proj_Harris_Storage { value : min {max_stor0520, storage0520 + inflow0520 - ( timesers(0520/evap)
20     / 12 * stor_to_area{0520,storage0520} )
21     - delivery0531 - delivery0521 - flow0521.0520 - flow0520.0528 - flow0520.0525 } }
22 Set : _Proj_Harris_Elev { value : stor_to_elev {0520, _Proj_Harris_Storage} }
23
24
25 Target Harris_spill: dflow0520.0526
26 { Condition : default
27     priority : 1
28     penalty+ : 100
29     penalty- : 0
30     Value : convert_units { Lookup{ Harris_Spill, _Proj_Harris_Elev }, cfs, af}
31 }
32
```

HawR_Or_Almnc.ocf

```
1 /* Northeast Har River Basin Ops */
2 // Orange- Alamance
3 // Haw River 02-01-020
4 // Graham-Mebane - to be used later
5
6
7 // Set the transfer from Haw River to Orange-Alamance
8
9 Set : inflow1041 { Value : convert_units { 0.05, mgd, af } } // Looking at sum of well usage from LWSP and days of use
10
11 Target Burl_HR_OA : dflow0074.1046
12 { condition : default
13   priority : 1
14   penalty+ : 500
15   penalty- : 20
16   Value : min {convert_units { 0.8, mgd, af }, demand1046 - _Max_OrAl_WD } // contract value is 0.8 mgd max
17 }
18
19
```

Johnston_ops.ocl

```
1 /* Johnston_OPS.OCL */
2
3 /* Operational policy for Johnston County's facilities */
4
5 :substitute: [Tim_Broome_Permit] = 17 //mgd, DWR permitted withdrawal includes return (assumed 10% in the WW_returns.ocl file) -- sn comment
6
7 // Existing intake
8 Set: max_flow1650.1654 { value : Convert_Units {[Tim_Broome_Permit], mgd, af } }
9
10
11 //Purchases //Setting these first to be used in flow by calcs for lower intake -KS
12
13 Set: max_flow1660.1656 //Smithfield sales
14 { condition : default
15 value : convert_units{3.0, mgd, af}
16 }
17
18 Set: max_flow1505.1656 //Wilson sales, set at less than 2 mgd IBT trigger amount
19 { condition : default
20 value : convert_units{1.99, mgd, af}
21 }
22
23 Set: max_flow0549.1656 //Harnett sales, set at less than 2 mgd IBT-trigger amount
24 { condition : default
25 value : convert_units{1.99, mgd, af}
26 }
27
28
29
30
31
32
33 // This is for intake 2 operations with the quarries. Use simplified estimate of flow upstream of intake 2 using yesterday's flow + local inflow.
34 // Set to min flow for day 1 x d.a. adjustment to get a reasonable estimate for day 1.
35
36 Set: Exp_RBrdgeRd_Upstream
37 { condition : abs_period = 1
38 value : min_flow1630.1640 * 1677 / 1150
39
40 condition : default
41 value : flow1700.1730 + inflow1730
42 }
43
44
45 /* This assumes JC Intake#2 on Neuse is at Richardson Bridge Rd, not below the confluence with Mill Creek (node 1735).
46 WD amounts per the revised guidance from Reed (no longer using the 2009 EA/FONSI).
47
```

Johnston_ops.ocl

```
48 So pumped flows are as follows: none below 198 cfs (as estimated upstream). Up to 29.2 mgd (20% of the updated 7Q10)
49 for flows below 903 cfs (which is the median annual flow). with pumping limited to ensure flow does not drop below 198 cfs.
50 Above 903 cfs, pump 20% of the estimated flow (or the amount above 903 cfs, whichever is less) or the maximum amount set
51 for the alternative (in lookup table). There may be a quick bump in pumping from 29.2 to the maximum pumping level above
52 903 cfs depending on what the maximum pumping level is used. Here it is 30 mgd. */
53
54 Set: max_flow1730.1652
55 { condition : convert_units{Exp_RBrdgeRd_Upstream, af, cfs} > 903
56 value : min {
57     max { convert_units {lookup {JohnstonCFlow, 903}, mgd, af},
58     min {0.2 * Exp_RBrdgeRd_Upstream, Exp_RBrdgeRd_Upstream - convert_units {903, cfs, af} } } ,
59     convert_Units {lookup {JohnstonCFlow, convert_units{Exp_RBrdgeRd_Upstream, af, cfs}}, mgd, af}
60 }
61
62 condition : default
63 value : min {convert_Units {lookup {JohnstonCFlow, convert_units{Exp_RBrdgeRd_Upstream, af, cfs}}, mgd, af},
64     max {Exp_RBrdgeRd_Upstream - convert_units {198, cfs, af}, 0} }
65 }
66
67 /* Assume abandoned quarry is being used. Water is assumed here to go directly to the demand, even though it would go technically
68 through the WTP node of 1652. Can do this here since it is assumed there would be no WTP process loss with the new plant.
69 Water only pumped to quarry if below full (could do with weighting of course). Put a negative weight on delivery arc to
70 prioritize water from intake node/WTP. */
71 Set : max_flow1653.1648
72 { condition : storage1648 < max_stor1648
73 value : 1000 // Set high limit as not to be constraining
74
75 condition : default
76 value : 0
77 }
78
79 // Do not consider any use of the active quarry, so set supply to the quarry to 0.
80 Set : max_flow1653.1647 { value : 0 }
```

Jordan_ops.ocl

```
1 /* Jordan_Ops.ocl */
2 /* Operational policies for Jordan Lake */
3
4 // Limit the increase in flood releases from previous day (per Terry Brown's suggestion) when Jordan is above normal pool
5 Target JordanFloodRelease : dflow0470.0480
6 { // Above 240 ft just release uncontrolled spill
7   condition : elevation0470 >= 240
8   priority : 1
9   penalty+ : 10
10  penalty- : 0
11  Value : convert_units { lookup { JordanSpillway, elevation0470 }, cfs, af }
12
13 // When Jordan is on the way back down (defined by decreasing inflows) limit the decrease in releases for a 'soft landing',
14 // making sure not to drop it below the normal pool.
15 condition : elevation0470 >= 216 and inflow0470 < inflow0470(-1) and inflow0470(-1) < inflow0470(-2) and inflow0470(-2) < inflow0470(-3)
16 priority : 1
17 penalty+ : 10
18 penalty- : 0
19 Value : min { flow0470.0480(-1) - convert_units { 4000, cfs, af }, storage0470 - elev_to_stor { 0470, 216 } }
20
21 // Above 220 ft release no more than the previous days' release + 5500 cfs
22 condition : elevation0470 >= 220
23 priority : 1
24 penalty+ : 10
25 penalty- : 0
26 Value : flow0470.0480(-1) + convert_units { 5500, cfs, af }
27
28 // Above 216 ft release no more than the previous days' release + 4000 cfs, making sure not to drop it below the normal pool.
29 condition : elevation0470 >= 216
30 priority : 1
31 penalty+ : 10
32 penalty- : 0
33 Value : min { flow0470.0480(-1) + convert_units { 4000, cfs, af }, storage0470 - elev_to_stor { 0470, 216 } }
34 }
35
36 // Set a flood target of 18,000 cfs at Lillington
37 Target LillingtonMaxFlow : dflow0550.0555
38 { condition : default
39   priority : 1
40   penalty+ : 12
41   penalty- : 0
42   Value : convert_units { 18000, cfs, af }
43 }
44
45 // Set a flood control target at Fayetteville of 20,000 cfs, meaning Jordan will store water to minimize chance of having flow downstream
46 // exceed this target. Local inflows between Jordan and Fayetteville could cause flows to exceed this target. However, Jordan will not curtail
47 // the minimum release, nor the release to meet local demands. So the penalty for going above the 20000 cfs flow is less than the minimum release
```

Jordan_ops.ocl

```
48 // weight from Jordan (but is more than the D zone weight for Jordan).
49 Target FayettevilleMaxFlow : dflow0740.0749
50 { condition : default
51   priority : 1
52   penalty+ : 12
53   penalty- : 0
54   Value    : convert_units {20000, cfs, af }
55 }
56
57
58 /* The Jordan water quality and supply accounting file is evaluated after the solve statement, mainly to establish the water quality
59 release based on computation of the decision variable for outflow from Jordan. This determination is made based on weights and min
60 flow targets from Jordan and at Lillington (and points in between). The min flow from Jordan depends on the drought protocol.
61 When the Lillington target applies, the model will release enough water to exactly meet the target after accounting for today's
62 inflows (namely on the Deep River) and demands between Jordan and Lillington (the intent of which is to mimic how the Corps would
63 operate). Extra water will not be released above the target based on how the weighting is done.
64
65 Set delivery for the water supply users based on amount in the their accounts. Demand will not be fulfilled if the account has gone
66 empty and there is not enough inflow to the water supply account (for simplicity, use yesterday's inflow as factored into yesterday's
67 storage).The water supply account is not allowed to go negative (see the Jordan_WQ_WS_Accounts.ocl file). Similarly, set the water
68 quality release from Jordan (arc 470.480) based on amount in the water quality storage account, again forbidding the account to go negative.
69
70 Since we refer to yesterday's storage estimates, for the first day of the run, constrain deliveries and releases to the initialized
71 volumes for each account so that deliveries and releases are made */
72
73
74 // Water supply releases
75 Constraint Deliv_Lim_CaryAp :
76 { condition : abs_period = 1
77   expression : ddelivery0471 <= [WS_CaryAp_Fraction] * [Max_WS_Storage]
78 }
79
80 Constraint Deliv_Lim_CaryAp :
81 { condition : abs_period > 1
82   expression : ddelivery0471 <= _Stor_Final_CaryAp(-1)
83 }
84
85 Constraint Deliv_Lim_Chatham :
86 { condition : abs_period = 1
87   expression : ddelivery0473 <= [WS_Chatham_Fraction] * [Max_WS_Storage]
88 }
89
90 Constraint Deliv_Lim_Chatham :
91 { condition : abs_period > 1
92   expression : ddelivery0473 <= _Stor_Final_Chatham(-1)
93 }
94
```

Jordan_ops.ocl

```
95 Constraint Deliv_Lim_Pittsboro :
96 { condition : abs_period = 1
97   expression : dflow0468.0401 <= [WS_Pitt_Fraction] * [Max_WS_Storage]
98 }
99
100 Constraint Deliv_Lim_Pittsboro :
101 { condition : abs_period > 1
102   expression : dflow0468.0401 <= _Stor_Final_Pitt(-1) // + 0.7 * _Stor_Final_Chatham(-1) // RNP SWAG that Chatham and
103               // Pittsboro work something out
104               // on their JL allocations
105 }
106
107 Constraint Deliv_Lim_RTP :
108 { condition : abs_period = 1
109   expression : ddelivery0474 <= [WS_RTP_Fraction] * [Max_WS_Storage]
110 }
111
112 Constraint Deliv_Lim_RTP :
113 { condition : abs_period > 1
114   expression : ddelivery0474 <= _Stor_Final_RTP(-1)
115 }
116
117 Constraint Deliv_Lim_Other :
118 { condition : abs_period = 1
119   expression : ddelivery0475 <= [WS_Other_Fraction] * [Max_WS_Storage]
120 }
121
122 Constraint Deliv_Lim_Other :
123 { condition : abs_period > 1
124   expression : ddelivery0475 <= _Stor_Final_Other(-1)
125 }
126
127 Constraint Deliv_Lim_Durham&OWASA :
128 { condition : abs_period = 1
129   expression : dflow0468.1151 <= [WS_Durham_Fraction] * [Max_WS_Storage] + [WS_OWASA_Fraction] * [Max_WS_Storage]
130 }
131
132 Constraint Deliv_Lim_Durham&OWASA :
133 { condition : abs_period > 1
134   expression : dflow0468.1151 <= _Stor_Final_Durham(-1) + _Stor_Final_OWASA(-1)
135 }
136
137 Constraint Deliv_Lim_Durham&OWASA_alt :
138 { condition : abs_period = 1
139   expression : dflow0479.1151 <= [WS_Durham_Fraction] * [Max_WS_Storage] + [WS_OWASA_Fraction] * [Max_WS_Storage]
140 }
141
```

Jordan_ops.ocl

```
142 Constraint Deliv_Lim_Durham&OWASA_alt :
143 { condition : abs_period > 1
144   expression : dflow0479.1151 <= _Stor_Final_Durham(-1) + _Stor_Final_OWASA(-1)
145 }
146
147 Constraint Deliv_Lim_Morris :
148 { condition : abs_period = 1
149   expression : ddelivery0477 <= [WS_Morris_Fraction] * [Max_WS_Storage]
150 }
151
152 Constraint Deliv_Lim_Morris :
153 { condition : abs_period > 1
154   expression : ddelivery0477 <= _Stor_Final_Morris(-1)
155 }
156
157 Constraint Deliv_Lim_Orange :
158 { condition : abs_period = 1
159   expression : ddelivery0921 <= [WS_Orange_Fraction] * [Max_WS_Storage]
160 }
161
162 Constraint Deliv_Lim_Orange:
163 { condition : abs_period > 1
164   expression : ddelivery0921 <= _Stor_Final_Orange(-1)
165 }
166
167 Constraint Deliv_Lim_Holly :
168 { condition : abs_period = 1
169   expression : dflow0479.0923 <= [WS_Holly_Fraction] * [Max_WS_Storage]
170 }
171
172 Constraint Deliv_Lim_Holly :
173 { condition : abs_period > 1
174   expression : dflow0479.0923 <= _Stor_Final_Holly(-1)
175 }
176
177 Constraint Deliv_Lim_Hillsb :
178 { condition : abs_period = 1
179   expression : dflow1151.1106 <= [WS_Hillsb_Fraction] * [Max_WS_Storage]
180 }
181
182 Constraint Deliv_Lim_Hillsb :
183 { condition : abs_period > 1
184   expression : dflow1151.1106 <= _Stor_Final_Hillsb(-1)
185 }
186
187
188 // Water quality release
```

Jordan_ops.ocl

```
189
190
191 Constraint Release_Limit_Jordan :
192 { condition : abs_period = 1
193   expression : dflow0470.0480 <= [Max_WQ_Storage]
194 }
195
196 Constraint Release_Limit_Jordan :
197 { condition : abs_period > 1
198   expression : dflow0470.0480 <= _WQ_Storage(-1)
199 }
200
201
202 // Compute Jordan hydro production (total kW)
203 Set : _Jordan_Hydropower { Value : lookup { JordanHydro, convert_units { flow0470.0480, af, cfs } } }
204
```

Jordan_WQ_WS_Accounts.ocl

```
1 /* Jordan_WQ_WS_Accounts.ocl */
2
3 // Note this file is included after the solve statement in the main.ocl file, so references to decision variables like flow and delivery
4 // have already been solved.
5
6
7 /* The conservation storage between elevation 202 and 216 feet consists of the water supply storage for up to six users and the
8 water quality storage.
9
10 Fraction of conservation storage and inflow :
11 WQ = 67.38% allocated (94,600 acft.)
12 WS = 32.62% allocated (45,800 acft.), which is broken down by user:
13
14 The accounts are numbered as follows:
15
16 Cary-Apex (node 471)
17 Chatham County (node 473)
18 Wake (RTP South) (node 474)
19 Durham (arc1151)
20 Morrisville (node 477)
21 Orange County (node 921)
22 OWASA (arc 1151.431, via 479.1151) - now via arc 0468.1151
23 Holly Springs (arc 479.923)
24 Pittsboro (no path to access yet defined) - now 0468.0401
25 Hillsborough (arc 1151.1106, via arc 0471.1151)
26
27 To this we add an allocation to a "dummy" account to track the unallocated water or to increase
28 demands on the water supply storage without changing other allocations
29
30 Other (node 475)
31
32 The allocations for each account are defined below (formerly in constants table for DWR model) */
33
34
35 /* INFLOW DISTRIBUTION BY WATER SUPPLY ACCOUNT */
36
37 /* Start with Leila's spreadsheet calculating the water supply inflow distribution */
38
39 // Evap (0) since this file is included after the solve statement and we want today's evap, not tomorrow's */
40
41 Set : _JLakeInf { value : flow0410.0470 + inflow0470 - evap0470(0) } /* Base it on net inflow */
42 Set : _JLake_WQ_Inf { value : _JLakeInf * [Max_WQ_Storage] / [Max_WQ_WS_Storage] }
43 Set : _JLake_WS_Inf { value : _JLakeInf * [Max_WS_Storage] / [Max_WQ_WS_Storage] }
44 /* Calculate total inflow available to pool to include any spillover from the water quality account. */
45 Set : _Inf_avail_to_WS_pool { value : _WQ_Pool_Excess(-1) + _JLake_WS_Inf }
46
47 /* Calculate the total water supply demand and delivery for all accounts */
```

Jordan_WQ_WS_Accounts.ocl

```
48 Set : _WS_Total_Demand { value : demand0471 + demand0473 + demand0474 + demand0475
49     + flow0470.0468 + demand0477 + demand0921 + 0 + 0 } // Since OWASA & Durham, and Hillsborough
50     // are arcs and not demand nodes, sub in
51     // zero, can be changed if a Jordan transfer
52     // is used. No Holly Springs either.
53 Set : _WS_Total_Deliv { value : delivery0471 + delivery0473 + delivery0474 + delivery0475
54     + flow0479.1151 + delivery0477 + delivery0921 + flow0479.0923 + flow0470.0468 }
55
56 // Reset water supply account to 100% if elevation reaches 216 or projected water supply is full.
57 // For the first day of simulation, use the starting storage based on the individual accounts
58 // as defined in the constants table.
59 Set : _Total_WS_Storage
60 { condition : abs_period = 1
61 value : [Starting_Storage_CaryAp] + [Starting_Storage_Chatham] + [Starting_Storage_RTP] + [Starting_Storage_Other]
62     + [Starting_Storage_Durham] + [Starting_Storage_Morris] + [Starting_Storage_Orange] + [Starting_Storage_OWASA]
63     + [Starting_Storage_Holly] + [Starting_Storage_Pitt] + [Starting_Storage_Hillsb]
64
65 condition : elevation0470 >= 216.0 or (_Total_WS_Storage(-1) + _Inf_avail_to_WS_pool - _WS_Total_Deliv ) >= [Max_WS_Storage]
66 value : [Max_WS_Storage]
67
68 condition : default
69 value : _Total_WS_Storage(-1) + _Inf_avail_to_WS_pool - _WS_Total_Deliv
70 }
71
72 Set : _Total_WS_Storage_Pct { value : 100 * _Total_WS_Storage / [Max_WS_Storage] }
73
74 Set : _Req_Refill_WS_Pool { value : [Max_WS_Storage] - _Total_WS_Storage + _WS_Total_Deliv }
75 Set : _WS_Pool_Excess { value : max { 0, _JLake_WS_Inf - _Req_Refill_WS_Pool } }
76 Set : _Inf_used_for_WS_pool { value : min { _Inf_avail_to_WS_pool, _Req_Refill_WS_Pool } }
77
78
79 /* ----- */
80
81 // Determine required refill for each account.
82
83 Set : _Req_Refill_CaryAp
84 { condition : abs_period = 1
85 value : delivery0471
86
87 condition : default
88 value : [WS_CaryAp_Fraction] * [Max_WS_Storage] - _Stor_Final_CaryAp(-1) + delivery0471
89 }
90
91 Set : _Req_Refill_Chatham
92 { condition : abs_period = 1
93 value : delivery0473
94
```

Jordan_WQ_WS_Accounts.ocl

```
95 condition : default
96 value : [WS_Chatham_Fraction] * [Max_WS_Storage] - _Stor_Final_Chatham(-1) + delivery0473
97 }
98
99 Set : _Req_Refill_RTP
100 { condition : abs_period = 1
101 value : delivery0474
102
103 condition : default
104 value : [WS_RTP_Fraction] * [Max_WS_Storage] - _Stor_Final_RTP(-1) + delivery0474
105 }
106
107 Set : _Req_Refill_Other
108 { condition : abs_period = 1
109 value : delivery0475
110
111 condition : default
112 value : [WS_Other_Fraction] * [Max_WS_Storage] - _Stor_Final_Other(-1) + delivery0475
113 }
114
115 Set : _Req_Refill_Durham
116 { condition : abs_period = 1
117 value : flow0468.1151 - flow1151.0431
118
119 condition : default
120 value : [WS_Durham_Fraction] * [Max_WS_Storage] - _Stor_Final_Durham(-1) + flow0468.1151 - flow1151.0431
121 }
122
123 Set : _Req_Refill_Morris
124 { condition : abs_period = 1
125 value : delivery0477
126
127 condition : default
128 value : [WS_Morris_Fraction] * [Max_WS_Storage] - _Stor_Final_Morris(-1) + delivery0477
129 }
130
131 Set : _Req_Refill_Orange
132 { condition : abs_period = 1
133 value : delivery0921
134
135 condition : default
136 value : [WS_Orange_Fraction] * [Max_WS_Storage] - _Stor_Final_Orange(-1) + delivery0921
137 }
138
139 Set : _Req_Refill_OWASA
140 { condition : abs_period = 1
141 value : flow1151.0431
```

Jordan_WQ_WS_Accounts.ocl

```
142
143 condition : default
144 value : [WS_OWASA_Fraction] * [Max_WS_Storage] - _Stor_Final_OWASA(-1) + flow1151.0431
145 }
146
147 Set : _Req_Refill_Holly
148 { condition : abs_period = 1
149 value : flow0479.0923
150
151 condition : default
152 value : [WS_Holly_Fraction] * [Max_WS_Storage] - _Stor_Final_Holly(-1) + flow0479.0923
153 }
154
155 Set : _Req_Refill_Pitt
156 { condition : abs_period = 1
157 value : 0
158
159 condition : default
160 value : [WS_Pitt_Fraction] * [Max_WS_Storage] - _Stor_Final_Pitt(-1) + flow0468.0401 // Pittsboro 6% Rnd 4 JLA
161 }
162
163 Set : _Req_Refill_Hillsb
164 { condition : abs_period = 1
165 value : flow1151.1106
166
167 condition : default
168 value : [WS_Hillsb_Fraction] * [Max_WS_Storage] - _Stor_Final_Hillsb(-1) + flow1151.1106 // Hillsborough 1% Rnd 4 JLA
169 }
170
171
172 /* Establish initial inflow to the accounts */
173
174 // Determine initial inflow to each account
175 Set : _Inf_CaryAp { value : min { [WS_CaryAp_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_CaryAp } }
176 Set : _Inf_Chatham { value : min { [WS_Chatham_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Chatham } }
177 Set : _Inf_RTP { value : min { [WS_RTP_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_RTP } }
178 Set : _Inf_Other { value : min { [WS_Other_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Other } }
179 Set : _Inf_Durham { value : min { [WS_Durham_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Durham } }
180 Set : _Inf_Morris { value : min { [WS_Morris_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Morris } }
181 Set : _Inf_Orange { value : min { [WS_Orange_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Orange } }
182 Set : _Inf_OWASA { value : min { [WS_OWASA_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_OWASA } }
183 Set : _Inf_Holly { value : min { [WS_Holly_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Holly } }
184 Set : _Inf_Pitt { value : min { [WS_Pitt_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Pitt } } // new for JLA Round 4 6%
185 Set : _Inf_Hillsb { value : min { [WS_Hillsb_Fraction] * _Inf_avail_to_WS_pool, _Req_Refill_Hillsb } } //new for JLA Round 4 1%
186
187 /* Determine remaining inflow to be distributed */
188 Set : _Inf_Rem_WS { value : _Inf_used_for_WS_pool - (_Inf_CaryAp + _Inf_Chatham + _Inf_Durham + _Inf_Other + _Inf_RTP
```

Jordan_WQ_WS_Accounts.ocl

```
189      + _Inf_Morris + _Inf_Orange + _Inf_OWASA + _Inf_Holly + _Inf_Pitt
190      + _Inf_Hillsb ) }
191
192 /* Determine remaining deficit by account */
193
194 :FOR:
195 { [Account] = { CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb } }
196
197 Set : _Rem_def_[Account] { value : _Req_Refill_[Account] - _Inf_[Account] }
198
199 :NEXT:
200
201 Set : _Rem_def_Total { value : _Rem_def_CaryAp + _Rem_def_Chatham + _Rem_def_Durham + _Rem_def_Other + _Rem_def_RTP
202      + _Rem_def_Morris + _Rem_def_Orange + _Rem_def_OWASA + _Rem_Def_Holly + _Rem_Def_Pitt
203      + _Rem_Def_Hillsb }
204
205 :FOR:
206 { [Account] = { CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb } }
207
208 // Distribute remaining inflow proportional to remaining deficit
209 Set : _Rem_Inf_[Account]
210 { condition : _Rem_def_total > 0
211     value : min { _Rem_def_[Account], _Inf_Rem_WS * _Rem_def_[Account] / _Rem_def_total }
212
213     condition : default
214     value : 0
215 }
216
217 // Compute total inflow to each pool
218 Set : _Inf_Total_[Account] { value : _Inf_[Account] + _Rem_Inf_[Account] }
219
220 :NEXT:
221
222
223 // Determine water supply storage in each account. For initialization in the udef list, set equal to the starting storage defined in the constants table.
224 // Set the storage to account for starting storage less the delivery plus the total inflow. If that exceeds the max storage for that account, reset
225 // the account to full. The accounts are not allowed to go negative.
226
227 Set : _Storage_CaryAp { value : max { 0, min { [WS_CaryAp_Fraction] * [Max_WS_Storage],
228     _Stor_Final_CaryAp(-1) + _Inf_Total_CaryAp - delivery0471 } } }
229 Set : _Storage_Chatham { value : max { 0, min { [WS_Chatham_Fraction] * [Max_WS_Storage],
230     _Stor_Final_Chatham(-1) + _Inf_Total_Chatham - delivery0473 } } }
231 Set : _Storage_RTP { value : max { 0, min { [WS_RTP_Fraction] * [Max_WS_Storage],
232     _Stor_Final_RTP(-1) + _Inf_Total_RTP - delivery0474 } } }
233 Set : _Storage_Other { value : max { 0, min { [WS_Other_Fraction] * [Max_WS_Storage],
234     _Stor_Final_Other(-1) + _Inf_Total_Other - delivery0475 } } }
235 Set : _Storage_Durham { value : max { 0, min { [WS_Durham_Fraction] * [Max_WS_Storage],
```

Jordan_WQ_WS_Accounts.ocl

```
236      _Stor_Final_Durham(-1) + _Inf_Total_Durham - flow0468.1151 - flow1151.0431 } } }
237 Set : _Storage_Morris { value : max { 0, min { [WS_Morris_Fraction] * [Max_WS_Storage] ,
238      _Stor_Final_Morris(-1) + _Inf_Total_Morris - delivery0477 } } }
239 Set : _Storage_Orange { value : max { 0, min { [WS_Orange_Fraction] * [Max_WS_Storage] ,
240      _Stor_Final_Orange(-1) + _Inf_Total_Orange - delivery0921 } } }
241 Set : _Storage_OWASA { value : max { 0, min { [WS_OWASA_Fraction] * [Max_WS_Storage] ,
242      _Stor_Final_OWASA(-1) + _Inf_Total_OWASA - flow1151.0431 } } }
243 Set : _Storage_Holly { value : max { 0, min { [WS_Holly_Fraction] * [Max_WS_Storage] ,
244      _Stor_Final_Holly(-1) + _Inf_Total_Holly - flow0479.0923 } } }
245 Set : _Storage_Pitt { value : max { 0, min { [WS_Pitt_Fraction] * [Max_WS_Storage] , _Stor_Final_Pitt(-1)
246      + _Inf_Total_Pitt - flow0468.0401 } } } //new for JLA Round 4 JLA
247 Set : _Storage_Hillsb { value : max { 0, min { [WS_Hillsb_Fraction] * [Max_WS_Storage] ,
248      _Stor_Final_Hillsb(-1) + _Inf_Total_Hillsb - flow1151.1106 } } } //new for JLA Round 4 JLA
249 // Assume pools are automatically reset to full if the total water supply storage account has refilled (do this by overwriting initial calculation).
250 // Account is refilled automatically when Jordan elevation reaches 216 feet.
251
252 :FOR:
253 { [Account] = { CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb } }
254
255 Set : _Stor_Final_[Account]
256 { condition : _Total_WS_Storage >= [Max_WS_Storage] //
257   value : [WS_[Account]_Fraction] * [Max_WS_Storage] //
258
259   condition : default
260   value : _Storage_[Account]
261 }
262
263 :NEXT:
264
265 // Calculate pool volume as percent of max storage
266
267 :FOR:
268 { [Account] = { CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb } }
269
270 Set : _Stor_Final_Pct_[Account]
271 {
272   condition : [WS_[Account]_Fraction] = 0
273   value : 0
274
275   condition : default
276   value : _Stor_Final_[Account] / ( [WS_[Account]_Fraction] * [Max_WS_Storage] ) * 100 } //
277 :NEXT:
278
279
280 /* WQ ACCOUNTING */
281
282 /* The _WQ_Release is the amount of water required to be released from Jordan Lake to meet the Lillington flow target for days
```

Jordan_WQ_WS_Accounts.ocl

```
283 when the lake is not full. This variable's value should be the same as the model's computed Jordan release when the lake
284 is not full. It is done by setting the WQ Release to the model's computed Jordan releases at the dam. When the lake is full,
285 we set the WQ Release to the value that would have been required to meet the Lillington target were the lake not full.
286 So it is the Lillington target minus the Moncure flow minus the Harris Lake release plus demands between the
287 dam at Jordan Lake and Lillington minus the discharges between the dam and Lillington. */
288
289
290 /* The water quality release from Jordan = outflow from Jordan. The release is constrained in the main.ocl file to the amount
291 in the water quality storage pool plus the inflow to that account. This way, the release will not be made if the account
292 has emptied. Note the outflow may include releasing surplus water above the rule curve, which technically would be more than
293 the water quality release. But since the account is reset to full above the rule curve, it makes no difference. However,
294 to make it more realistic, set the WQ release to the minimum flow from Jordan when the elevation is at 216 or above. */
295 Set : _WQ_Release
296 {   condition : elevation0470 >= 216
297     value     : min_flow0470.0480
298
299     condition : default
300     value     : flow0470.0480
301 }
302
303
304 // Initial value set in the udef list based on starting WQ storage reported in the constants table
305 Set : _WQ_Storage
306 {   condition : elevation0470 >= 216.0
307     value     : [Max_WQ_Storage]
308
309     // the WQ storage is not allowed to go negative
310     condition : default
311     value     : max { 0, min { [Max_WQ_Storage], _WQ_Storage(-1) + _JLake_WQ_Inf + _WS_Pool_Excess - _WQ_Release } }
312 }
313
314 Set : _WQ_Storage_Pct { value : _WQ_Storage / [Max_WQ_Storage] * 100 }
315 Set : _Req_Refill_WQ { value : [Max_WQ_Storage] - _WQ_Storage + _WQ_Release }
316
317 Set : _WQ_Pool_Excess
318 {   condition : _Req_Refill_WS_Pool > _JLake_WS_Inf
319     value     : max { 0, _JLake_WQ_Inf - _Req_Refill_WQ }
320
321     condition : default
322     value     : 0
323 }
324
325
326
```

main.ocl

```
1 /* MAIN.OCL */
2
3 :INCLUDE: OCL\constants.ocl
4 :INCLUDE: OCL\constants_removed.ocl
5 :INCLUDE: OCL\Forecast-Trigger_Parms.ocl
6 :INCLUDE: OCL\Forecast_Horizon_Days.ocl
7 :Static: statdata.mdb
8 :Time: [HomeDir]\basedata\basedata.dss
9
10 :if: {[UseForecast]=1}
11 :if: {[ForecastData]=cond}
12 :Time: [HomeDir]\basedata\forecasts_sim_cond_durham.dss
13 :Time: [HomeDir]\basedata\forecasts_cond.dss
14 :else:
15 :Time: [HomeDir]\basedata\forecasts_sim_noncond_durham.dss
16 :Time: [HomeDir]\basedata\forecasts_non_cond.dss
17 :endif:
18 :endif:
19
20 :if: {[Drought_Plans_On] = 1}
21 :Time: [HomeDir]\basedata\forecasts_non_cond.dss
22 :endif:
23
24 :MODULE: DLL AgricDem = modules\AgricDem.DLL
25
26 :Include: ocl\undef_list.ocl
27
28 :Commands:
29
30 // For both basins
31
32 :Include: ocl\Agric_Calculation.ocl
33 :Include: ocl\Agric_Allocation.ocl
34 :Include: ocl\filter_inflows.ocl
35
36 // For the Cape Fear
37
38 /* :Include: ocl\user_def_ops.ocl */
39
40 :Include: ocl\routing_cf.ocl
41 :Include: ocl\Harris_ops.ocl
42 :Include: ocl\drought_protocol_jordan.ocl
43 :Include: ocl\Greensboro_ops.ocl
44 :Include: ocl\owasa_ops.ocl
45 :Include: ocl\Jordan_ops.ocl
46 :Include: ocl\Pitt_Chatham_ops.ocl
47 :Include: ocl\Randleman_ops.ocl
```

main.ocl

```
48 :Include: ocl\SilerCity_ops.ocl
49 :Include: ocl\Fayetteville_ops.ocl
50 :Include: ocl\FtBragg_ops.ocl
51 :Include: ocl\SpringLake_ops.ocl
52 :Include: ocl\drought_plans_cf.ocl
53 :Include: ocl\WW_Returns.ocl
54
55 // For the Neuse
56
57 :Include: ocl\routing_neuse.ocl
58 :Include: ocl\crabtree_ops.ocl
59 :Include: ocl\upper_eno_ops.ocl
60 :Include: ocl\HawR_Or_Almnc.ocl
61 :Include: ocl\durham_ops.ocl
62 :Include: ocl\falls_bdam_ops.ocl
63 :Include: ocl\falls_flood_ops.ocl
64 :Include: ocl\raleigh_ops.ocl
65 :Include: ocl\Fuquay_ops.ocl
66 :Include: ocl\Johnston_ops.ocl
67 :Include: ocl\buckhorn_Wilson_ops.ocl
68 :Include: ocl\Raleigh_Quarry_ops.ocl
69 :Include: ocl\NRWWTP_intake.ocl
70 :Include: ocl\drought_plans_neuse.ocl
71 :Include: ocl\drought_plan_durham.ocl
72 :Include: ocl\Benson_ops.ocl
73
74
75 // For both basins, this captures miscellaneous operations
76 :Include: ocl\misc_ops.ocl
77
78
79 // Solve model
80
81 Solve : {Priority : 1}
82
83 //Compute actual shortages based on drought plans
84 :Include: ocl\Shortages.ocl //added during Fuquay IBT study to calculate shortages based on cosnvn demands
85
86 // Compute the Falls/Beaverdam and Jordan water quality and supply accounting after the SOLVE statement
87
88 :Include: ocl\Falls_Bdam_WQ_WS_accounts.ocl
89 :Include: ocl\Jordan_WQ_WS_Accounts.ocl
90
91
92 :End:
93
```

Misc_Ops.ocl

```
1 /* Misc_Ops */
2
3
4
5 // Misc. Cape Fear Ops.
6
7 // Set Cape Fear Arcs/Interconnects not used in basecase to zero
8 Constraint : {dFlow0319.0077 = 0} // Green Level Gr-Meb WS
9 Constraint : {dFlow0479.0923 = 0} // JL Holly Springs
10 Constraint : {dFlow0920.0319 = 0} // Orange Co. Gr-Meb
11 Constraint : {dFlow0920.1106 = 0} // Orange Co. Hills
12 Constraint : {dFlow0920.1162 = 0} // Orange Co. Durham
13
14 // Add arc from Sanford to Pittsboro. Limit the current supply to Pittsboro
15 // from the Haw River to 2 mgd; the rest will come from Sanford.
16 Constraint : {dFlow0400.0401 = convert_units {2, mgd, af} } // Haw River supply to Pittsboro
17
18 // Add arc from Sanford to Holly Springs with baseload supply of 4 mgd. Use a constraint.
19 // Rest of Holly Springs demand will be met from the supply from Harnett County.
20 Constraint : {dFlow0489.0923 = convert_units {4, mgd, af} } // Sanford to Holly Springs
21
22
23 // Let's add the corrected min release for Graham-Mebane Lake. Since drought triggers are tied
24 // to usable storage (days of supply remaining), base min release adjustment on usable storage.
25 // The WTP process return (about 5% of the demand, applied to arc 319.100) can be used to help meet the min release
26
27 Set : min_flow0320.0100
28 { condition : (storage0320 - lower_rule0320) / (upper_rule0320 - lower_rule0320) < 0.4
29 value : convert_units {3, cfs, af} - flow0319.0100
30
31 condition : default
32 value : convert_units {5, cfs, af} - flow0319.0100
33 }
34
35
36 // Misc. Neuse Ops.
37
38 /* Set demands not used in basecase run to zero */
39 Set : demand1318 { value : 0 } /* Old Burlington Industries */
40
41 /* Set interconnects not used in basecase run to zero */
42 Constraint : {dFlow1300.0471 = 0} /* Raleigh-Cary Interconnect */
43 Constraint : {dFlow1300.0923 = 0} /* Raleigh-Holly Springs Interconnect */
44
45 /* Set inflows not used in basecase run to zero */
46 Set : inflow1252 { value : 0 } /* Kerr Lake indirect transfer */
47 Set : inflow1403 { value : 0 } /* Quarry dewatering */
```

Misc_Ops.ocl

```
48 Set : inflow1528 { value : 0 } /* Tar River transfer - Wilson */  
49  
50  
51
```

NRWWTP_intake.ocl

```
1 /* NRWTP_Intake.OCL */
2
3 /* This subroutine dictates the operation of the NRWTP intake alternative G2. */
4
5 Set Neuse_intake : max_flow1620.1305 {value: convert_units {[NR_DS_intake], mgd, af}}
6
7 Target Deliv_NRintake_to_Raleigh : dflow1620.1305
8 { condition : abs_period<=1
9   priority : 1
10  penalty+ : 1000
11  penalty- : 1000
12  Value    : 0
13
14 // This code is being written so that the sum of withdrawals from Lake Benson and NR Intake
15 // equals whatever we set the Benton WTP capacity. This would only serve for Operational
16 // yield tests as reality would dictate running at lower than max plant capacity
17 condition : abs_period > 1
18 priority : 1
19 penalty+ : 500
20 penalty- : 500
21 Value    : convert_units {[DE_Benton_WTP_Capacity], mgd, af}-max_flow1440.1305
22
23 condition : default
24 priority : 1
25 penalty+ : 1000
26 penalty- : 0
27 value    : 0
28 }
29
30 Set Total_Intake_Pumping: _tot_intake_pump
31 { condition : flow1620.1305 > 0
32   value    : _tot_intake_pump(-1) + flow1620.1305
33
34   condition : default
35   value    : 0
36 }
37
38
39
```

OWASA_ops.ocl

```
1 // Operations policy for OWASA's system
2
3 // Set the Stone Quarry inflow - area adjustment of the Univ. Lake inflow
4 // Quarry = 1.2 sq. mi., Univ. Lake = 28.7 sq. mi.
5
6 Set : inflow0395 { value : 1.2 * inflow0430 / 28.7 }
7
8
9 //Set to refill Stone Quarry w/ spill from Cane Ck Res.
10 Target CaneCk_SQ_Trans : dflow0390.0395
11 { condition : storage0390 >= upper_rule0390
12   priority : 1
13   penalty+ : 350
14   penalty- : 300
15   Value : max { 0, min { upper_rule0395 - storage0390 - inflow0395 + evap0395 * stor_to_area { 0395, storage0395 } / 12 ,
16     inflow0390 - evap0390 * stor_to_area { 0390, storage0390 } / 12 - min_flow0390.0370 - upper_rule0390 } }
17
18   condition : default
19   priority : 1
20   penalty+ : 350
21   penalty- : 350
22   Value : 0
23 }
24
25
26 // Anticipated OPERATING POLICY
27 //This is only necessary because dFlow can't be used in RHS of equation below in the
28 //next two targets - particularly the second one
29 Set : _OWASA_JL_Use_Targ
30 { // Use JL when in WSRP stages 1-3
31   condition : ( _OWASA_Trigger_3_On(-1) + _OWASA_Trigger_2_On(-1) + _OWASA_Trigger_1_On(-1) ) >=1
32     and _Storage_OWASA(-1) > convert_units { 4, mg , af } //if any trigger is on, and there is
33       // water in their JL Account, then buy
34       // water from WIP WTP
35   Value : convert_units { 4, mg , af }
36
37   // No regular JL use if not in WSRP
38   condition : default
39   Value : 0
40 }
41
42 Target JL_Access : dFlow1151.0431 // Access JL supply if WSRP stage >=1
43 {
44   condition : default
45   priority : 1
46   penalty+ : 1000
47   penalty- : 1000
```

OWASA_ops.ocl

```
48 Value : _OWASA_JL_Use_Targ
49 }
50
51 // EXISTING OPERATING POLICY
52 // Set the WD from Cane Creek Reservoir, depending on reservoir levels
53 // Stone Quarry will be utilized last.
54
55 Target CaneCkWD : dflow0390.0431
56 { // If Univ. Lake full and CCR is below full, make all WDs from Univ. Lake
57   condition : storage0430 >= upper_rule0430 - 0.1 and storage0390 < upper_rule0390
58   priority : 1
59   penalty+ : 310
60   penalty- : 310
61   Value : 0
62
63   // If both reservoirs are full split the WD
64   condition : storage0430 >= upper_rule0430 and storage0390 >= upper_rule0390
65   priority : 1
66   penalty+ : 310
67   penalty- : 310
68   Value : min { 0.5 * demand0431, max_flow0390.0431 }
69
70
71   // Split WDs for the first 100 MG of drawdown (50 MG from Univ Lake)
72   condition : upper_rule0430 - storage0430 <= convert_units { 50, mg, af}
73   priority : 1
74   penalty+ : 310
75   penalty- : 310
76   Value : min { 0.5 * demand0431, max_flow0390.0431 }
77
78   // After that withdraw the majority, less 1 mgd, from Cane Creek
79   condition : upper_rule0430 - storage0430 > convert_units { 50, mg, af}
80   priority : 1
81   penalty+ : 310
82   penalty- : 310
83   Value : min { demand0431 - convert_units { 1, mgd, af } - _OWASA_JL_Use_Targ, max_flow0390.0431 }
84
85   // Then draw down Cane Creek completely if Univ Lake is depleted
86   condition : default
87   priority : 1
88   penalty+ : 310
89   penalty- : 310
90   Value : min { demand0431 - _OWASA_JL_Use_Targ, max_flow0390.0431 }
91 }
92
```

OWASA_wsrp.ocl

```
1 /* OWASA's Drought Plan - based on the risk that usable storage will drop below 20% over the next year */
2
3 Set : _OWASA_Max_Usable_Stor { Value: (upper_rule0390 - lower_rule0390) + (upper_rule0395 - lower_rule0395)
4     + (upper_rule0430 - lower_rule0430) }
5 Set : _OWASA_Usable_Stor { Value : min { _OWASA_Max_Usable_Stor,
6     (storage0390 - lower_rule0390) + (storage0395 - lower_rule0395)
7     + (storage0430 - lower_rule0430) } }
8 Set : _OWASA_Usable_Stor_Pct { Value : 100 * _OWASA_Usable_Stor / _OWASA_Max_Usable_Stor }
9
10 // Compute the projected total inflows, demand, min. flow and evap at various forecast horizons over the next 52 weeks
11 :For:
12 { [hrz] = {08, 12, 16, 20, 24, 52}
13     [lag] = {56, 84, 112, 140, 168, 364}
14 }
15
16 // Trigger 1 horizon.
17 Set : _OWASA_ProjInflow1_[hrz]
18 { condition : weekday{year, month, day} <= 1
19     value : 7 * ( timesers(0380/R02W[hrz]) + (1.2 / 28.7) * timesers(0430/R02W[hrz]) + timesers(0430/R02W[hrz]) )
20
21     condition : default
22     value : _OWASA_ProjInflow1_[hrz](-1)
23 }
24
25
26 Set : _OWASA_ProjDemand1_[hrz]
27 { condition : weekday{year, month, day} <= 1
28     value : accumulate { demand0431 , 0 , +[lag] }
29
30     condition : default
31     value : _OWASA_ProjDemand1_[hrz](-1)
32 }
33
34
35 Set : _OWASA_ProjMinFlow1_[hrz]
36 { condition : weekday{year, month, day} <= 1
37     value : accumulate { min_flow0390.0370 , 0 , +[lag] }
38
39     condition : default
40     value : _OWASA_ProjMinFlow1_[hrz](-1)
41 }
42
43
44 Set : _OWASA_ProjEvap1_[hrz]
45 { condition : weekday{year, month, day} <= 1
46     value : (stor_to_area { 0390 , storage0390 } * 7 * timesers(0390/EVAP_R02W[hrz]) / 12) +
47         (stor_to_area { 0395 , storage0395 } * 7 * timesers(0395/EVAP_R02W[hrz]) / 12) +
```

OWASA_wsrp.ocl

```
48      (stor_to_area { 0430 , storage0390 } * 7 * timesers(0430/EVAP_R02W[hrz]) / 12)
49  condition : default
50  value   : _OWASA_ProjEvap1[hrz](-1)
51 }
52
53 // Trigger 2 horizon.
54 Set : _OWASA_ProjInflow2[hrz]
55 {   condition : weekday{year, month, day} <= 1
56     value   : 7 * ( timesers(0380/R10W[hrz]) + (1.2 / 28.7) * timesers(0430/R10W[hrz]) + timesers(0430/R10W[hrz]) )
57
58     condition : default
59     value   : _OWASA_ProjInflow1[hrz](-1)
60 }
61
62
63 Set : _OWASA_ProjDemand2[hrz]
64 {   condition : weekday{year, month, day} <= 1
65     value   : accumulate { demand0431 , 0 , +[lag] } * 0.9
66
67     condition : default
68     value   : _OWASA_ProjDemand1[hrz](-1)
69 }
70
71
72 Set : _OWASA_ProjMinFlow2[hrz]
73 {   condition : weekday{year, month, day} <= 1
74     value   : accumulate { min_flow0390.0370 , 0 , +[lag] }
75
76     condition : default
77     value   : _OWASA_ProjMinFlow1[hrz](-1)
78 }
79
80
81 Set : _OWASA_ProjEvap2[hrz]
82 {   condition : weekday{year, month, day} <= 1
83     value   : (stor_to_area { 0390 , storage0390 } * 7 * timesers(0390/EVAP_R10W[hrz]) / 12) +
84             (stor_to_area { 0395 , storage0395 } * 7 * timesers(0395/EVAP_R10W[hrz]) / 12) +
85             (stor_to_area { 0430 , storage0390 } * 7 * timesers(0430/EVAP_R10W[hrz]) / 12)
86     condition : default
87     value   : _OWASA_ProjEvap1[hrz](-1)
88 }
89
90 // Trigger 3 horizon.
91 Set : _OWASA_ProjInflow3[hrz]
92 {   condition : weekday{year, month, day} <= 1
93     value   : 7 * ( timesers(0380/R20W[hrz]) + (1.2 / 28.7) * timesers(0430/R20W[hrz]) + timesers(0430/R20W[hrz]) )
94
```

OWASA_wsrp.ocl

```
95   condition : default
96   value    : _OWASA_ProjInflow1_[hrz](-1)
97 }
98
99
100 Set : _OWASA_ProjDemand3_[hrz]
101 {   condition : weekday{year, month, day} <= 1
102   value    : accumulate { demand0431 , 0 , +[lag] } * 0.85
103
104   condition : default
105   value    : _OWASA_ProjDemand1_[hrz](-1)
106 }
107
108
109 Set : _OWASA_ProjMinFlow3_[hrz]
110 {   condition : weekday{year, month, day} <= 1
111   value    : accumulate { min_flow0390.0370 , 0 , +[lag]}
112
113   condition : default
114   value    : _OWASA_ProjMinFlow1_[hrz](-1)
115 }
116
117
118 Set : _OWASA_ProjEvap3_[hrz]
119 {   condition : weekday{year, month, day} <= 1
120   value    : (stor_to_area { 0390 , storage0390 } * 7 * timesers(0390/EVAP_R20W[hrz]) / 12) +
121             (stor_to_area { 0395 , storage0395 } * 7 * timesers(0395/EVAP_R20W[hrz]) / 12) +
122             (stor_to_area { 0430 , storage0390 } * 7 * timesers(0430/EVAP_R20W[hrz]) / 12)
123   condition : default
124   value    : _OWASA_ProjEvap1_[hrz](-1)
125 }
126
127
128 // Compute projected storage for the entire system for each trigger. Projected storage will not exceed the max usable storage
129
130 :For:
131 {   [trig] = {1, 2, 3}
132 }
133
134 Set : _OWASA_ProjStorage[trig]_[hrz]
135 {   Condition : weekday{year, month, day} <= 1
136   Value    : min{_OWASA_Usable_Stor + _OWASA_ProjInflow[trig]_[hrz] - _OWASA_ProjDemand[trig]_[hrz]
137     - _OWASA_ProjEvap[trig]_[hrz] - _OWASA_ProjMinFlow[trig]_[hrz] ,
138     _OWASA_Max_Usable_Stor}
139
140   Condition : default
141   Value    : _OWASA_ProjStorage[trig]_[hrz](-1)
```

OWASA_wsrp.ocl

```
142 }
143
144 Set : _OWASA_ProjStorage_Pct[trig]_[hrz]
145 { Condition : weekday{year, month, day} <= 1
146 Value : 100 * _OWASA_ProjStorage[trig]_[hrz] / _OWASA_Max_Usable_Stor
147
148 Condition : default
149 Value : _OWASA_ProjStorage_Pct[trig]_[hrz](-1)
150 }
151
152 :Next:
153 :Next:
154
155 /* This section evaluates whether any of the three triggers were on during the
156 last time step. If so, it checks to see whether the reservoir has re-filled
157 to the release storage, in which case the triggers are released.
158 If the trigger was not on in the last timestep, it compares the projected stage with
159 the threshold to determine whether it should be turned on.
160
161 Note the projected storage is calculated only at beginning of week, so determination of triggers
162 is kept to the beginning of the week. That provides some delay in enactment of triggers and duplicates
163 to some extent the waiting period requirement below.
164 */
165
166 // Enact only if trigger storage is met and put in some waiting period as shown below.
167 // Triggers 2 and 3 can only turn on in sequence after trigger 1 has turned on.
168
169 Set : _OWASA_Trigger_3_On
170 { Condition : _OWASA_Trigger_3_On(-1) = 1
171 { Condition : _OWASA_Usable_Stor >= _OWASA_Max_Usable_Stor
172 Value : 0
173
174 Condition : default
175 Value : _OWASA_Trigger_3_On(-1)
176 }
177
178 Condition : _OWASA_Stage_2_Counter(-1) >= 7 // Require a 7 day waiting period before going into phase 3
179 { Condition : weekday{year, month, day} <= 1
180 { Condition : _OWASA_ProjStorage_Pct3_08 <= 20 or _OWASA_ProjStorage_Pct3_12 <= 20
181 or _OWASA_ProjStorage_Pct3_16 <= 20 or _OWASA_ProjStorage_Pct3_20 <= 20
182 or _OWASA_ProjStorage_Pct3_24 <= 20 or _OWASA_ProjStorage_Pct3_52 <= 20
183 Value : 1
184 }
185 Condition : default
186 Value : _OWASA_Trigger_3_On(-1)
187 }
188 Condition : default
```

OWASA_wsrp.ocl

```
189 Value : _OWASA_Trigger_3_On(-1)
190 }
191
192
193 Set : _OWASA_Trigger_2_On
194 { Condition : _OWASA_Trigger_2_On(-1) = 1
195   { Condition : _OWASA_Usable_Stor >= _OWASA_Max_Usable_Stor
196     Value : 0
197
198     Condition : default
199     Value : _OWASA_Trigger_2_On(-1)
200   }
201
202   Condition : _OWASA_Stage_1_Counter(-1) >= 7 // Require a 7 day waiting period before going into phase 2
203   { Condition : weekday{year, month, day} <= 1
204     { Condition : _OWASA_ProjStorage_Pct2_08 <= 20 or _OWASA_ProjStorage_Pct2_12 <= 20
205       or _OWASA_ProjStorage_Pct2_16 <= 20 or _OWASA_ProjStorage_Pct2_20 <= 20
206       or _OWASA_ProjStorage_Pct2_24 <= 20 or _OWASA_ProjStorage_Pct2_52 <= 20
207       Value : 1
208     }
209     Condition : default
210     Value : _OWASA_Trigger_2_On(-1)
211   }
212   Condition : default
213   Value : _OWASA_Trigger_2_On(-1)
214 }
215
216
217 Set : _OWASA_Trigger_1_On
218 { Condition : _OWASA_Trigger_1_On(-1) = 1
219   { Condition : _OWASA_Usable_Stor >= _OWASA_Max_Usable_Stor
220     Value : 0
221
222     Condition : default
223     Value : _OWASA_Trigger_1_On(-1)
224   }
225
226   Condition : weekday{year, month, day} <= 1
227   { Condition : _OWASA_ProjStorage_Pct1_08 <= 20 or _OWASA_ProjStorage_Pct1_12 <= 20
228     or _OWASA_ProjStorage_Pct1_16 <= 20 or _OWASA_ProjStorage_Pct1_20 <= 20
229     or _OWASA_ProjStorage_Pct1_24 <= 20 or _OWASA_ProjStorage_Pct1_52 <= 20
230     Value : 1
231
232     Condition : default
233     Value : _OWASA_Trigger_1_On(-1)
234   }
235   Condition : default
```

OWASA_wsrp.ocl

```
236 Value : _OWASA_Trigger_1_On(-1)
237 }
238
239 :For:
240 { [trig] = {1, 2, 3}
241 }
242
243 Set : _OWASA_Stage_[trig]_Counter
244 { Condition : _OWASA_Stage_[trig]_Counter(-1) > 0 and _OWASA_Trigger_[trig]_On = 0
245 Value : 0
246
247 Condition : _OWASA_Trigger_[trig]_On = 1
248 Value : _OWASA_Stage_[trig]_Counter(-1) + 1
249
250 Condition : default
251 Value : _OWASA_Stage_[trig]_Counter(-1)
252 }
253
254 /* Count all trigger events lasting at least 7 days */
255
256 Set : _OWASA_Ph_[trig]_event_counter
257 { Condition : _OWASA_Stage_[trig]_Counter = 7 and _OWASA_Stage_[trig]_Counter(-1) = 6
258 Value : _OWASA_Ph_[trig]_event_counter(-1) + 1
259
260 Condition : default
261 Value : _OWASA_Ph_[trig]_event_counter(-1)
262 }
263
264 :Next:
265
266 /* This section determines the demand depending upon which level of conservation
267 is in place. */
268
269 Set : _OWASA_Consvn_1_Demand
270 {
271 Condition : _OWASA_Trigger_1_On = 1
272 Value : Demand0431 * ( 1 - ( 10/ 100 ))
273
274 Condition : default
275 Value : Demand0431
276 }
277
278 Set : _OWASA_Consvn_2_Demand
279 {
280 Condition : _OWASA_Trigger_2_On = 1
281 Value : Demand0431 * ( 1 - ( 15 / 100 ))
282
```

OWASA_wsrp.ocl

```
283 Condition : default
284 Value : Demand0431
285 }
286
287 Set : _OWASA_Consvn_3_Demand
288 {
289 Condition : _OWASA_Trigger_3_On = 1
290 Value : Demand0431 * ( 1 - ( 20 / 100 ))
291
292 Condition : default
293 Value : Demand0431
294 }
295
296 :For:
297 { [trig] = {1, 2, 3}
298 }
299
300 Constraint OWASA_Demand_Limit_Consvn_[trig] :
301 { Condition : _OWASA_Trigger_[trig]_On = 1
302 Expression : ddelivery0431<= _OWASA_Consvn_[trig]_Demand }
303
304 :Next:
305
```

Pitt_Chatham_ops.ocl

```
1 /* Pittsboro_Ops.ocl */
2 /* Operational policies for Town of Pittsboro */
3
4 // Since supply from Jordan Lake WIP to Pittsboro may not occur, set the flow to 0 in this arc. Ignore the rest below.
5 Constraint : {dFlow0468.0401 = convert_units {0, mgd, af} } // JLake supply to Pittsboro
6
7 /*
8
9 // Balance use of the two water sources for Pittsboro in accordance with rough guidance from J. Hennessy in fall of 2021
10 Target Pittsboro_WIP_usage : dflow0468.0401
11 {
12   condition : _Storage_Pitt(-1) > demand0401 //Sufficient storage in JL is available
13   priority : 1
14   penalty+ : 20
15   penalty- : 20
16   Value : 0.75 * demand0401
17
18   condition : default
19   priority : 1
20   penalty+ : 5
21   penalty- : 5
22   Value : min {_Storage_Pitt(-1), 0.5 * demand0401}
23
24 }
25
26 */
27
28 Constraint : {dFlow0468.0473 = 0} // WIP to Chatham - for calculation simplicity, not what will actually happen.
29 // This way Chatham gets all it water directly from the 0470.0473 arc
30
31 // Ignore the rest below.
32
33 // Balance use of the two water sources for Chatham Co. in accordance with rough guidance from J. Hennessy
34 // in fall of 2021 that Chatham will supply it's North zone/region from the WIP facility
35 // Data on usage from WIP demands.xlsx
36
37 /*Target Chatham_WIP_usage : dflow0468.0473
38 {
39   condition : default
40   priority : 1
41   penalty+ : 10
42   penalty- : 10
43   Value : 0.64 * demand0473
44
45 }*/
46
47
```

Raleigh_ops.ocl

```
1 /* RALEIGH_OPS.OCL */
2
3 /* Set flow from Falls Lake to Raleigh demand to zero when performing analysis on the Swift Creek system in isolation. */
4 //Constraint : {dFlow1300.1305 = 0 }
5
6 /* This code block was moved from Falls_Bdam_WQ_WS_Accounts.ocl in order that the variable _Raleigh_Sys_Stor_Pct
7 (see end of file) can be appropriately calculated here. These variables will mostly be used in
8 Falls_Bdam_WQ_WS_Accounts.ocl*/
9
10 /* The Falls conservation storage zone is divided into water quality and water storage accounts
11 Fraction of conservation storage and inflow :
12 WQ = 57.7% allocated (61,322 acft.)
13 WS = 42.3% allocated (45,000 acft.)
14
15 Beaverdam is also included in the WQ/WS accounting, the proportion to each is the same as Falls. */
16 /* WQ and WS accounts by lake */
17
18 set : _FLake_Max_WQ_WS_Storage
19 { condition : Default
20   value : 101705 // removed algorithm that allows adjustment to Falls Conservation Pool - RNP
21 }
22
23 set : _FLake_Max_WS_Storage
24 { condition : Default
25   value : _FLake_Max_WQ_WS_Storage - [FLake_WQ_Stor] // This latter number should be the volume of the reallocated
26           // WQ Poolin Falls only (w/o Beaver Dam portion)
27
28 }
29
30 set : _FLake_Max_WQ_Storage
31 { condition : Default
32   value : _FLake_Max_WQ_WS_Storage - _FLake_Max_WS_Storage
33
34 }
35
36
37 Set : _Pct_Max_WS_Storage
38 { value : ( _FLake_Max_WS_Storage / _FLake_Max_WQ_WS_Storage ) * 100 } // removed algorithm allowing
39           //easy adjustment to pool percentage - RNP 1/25/21
40 Set : _Pct_Max_WQ_Storage { value : 100 - _Pct_Max_WS_Storage }
41
42 set : _Total_Max_WQ_WS_Storage {value: _FLake_Max_WQ_WS_Storage + [Bdam_WQ_WS_Stor] }
43 set : _Total_Max_WS_Storage { value : _FLake_Max_WS_Storage + [Bdam_WQ_WS_Stor] * _Pct_Max_WS_Storage / 100 }
44 set : _Total_Max_WQ_Storage { value : _Total_Max_WQ_WS_Storage - _Total_Max_WS_Storage}
45
46 Set : _Bdam_Max_WQ_Storage { value : [Bdam_WQ_WS_Stor] * _Pct_Max_WQ_Storage / 100 }
47 Set : _Bdam_Max_WS_Storage { value : [Bdam_WQ_WS_Stor] * _Pct_Max_WS_Storage / 100 } // add this when Beaver Dam Sediment
```

Raleigh_ops.ocl

```
48          // Storage is to be included in Alt
49          // A3: + (elev_to_stor{230, [Falls_lower_rule]} - lower_rule230)
50
51
52 /* Set inflow and evaporation on farm ponds in Little River Sub-basin */
53 Set : evap1739 { value :0.40 * evap1740}
54 :Substitute: [farm_inflow_fraction] = 0.46 // I believe this was a GIS estimate of the fraction of the LRR watershed
55          // that passes through an upstream pond before reaching the LRR
56 Set : inflow1739 { value : [farm_inflow_fraction] * inflow1740}
57 Set : inflow1740 { value : inflow1740 - inflow1739}
58
59 // Set operational policy for Swift Creek system
60
61 Set : Swift_Sys_WS_Stor_Pct
62 { value: ((storage1420 - dead_stor1420 + storage1440 - dead_stor1440)
63   / (max_stor1420 - dead_stor1420 + max_stor1440 - dead_stor1440)) *100 }
64
65 /* Set the minimum release for Benson/Wheeler - based on useable storage */
66 Set : min_flow1440.1700
67 { condition : Swift_Sys_WS_Stor_Pct < 30
68   Value    : convert_units { 1 , cfs , af }
69
70   condition : Swift_Sys_WS_Stor_Pct < 60
71   Value    : convert_units { 2 , cfs , af }
72
73   condition : default
74   Value    : convert_units { 3 , cfs , af }
75 }
76
77
78
79 /* Operational policy for withdrawals from Benson/Wheeler */
80
81
82 /* Set the maximum delivery from Raleigh WTP's (change the capacities using the substitutes below) */
83
84 :Substitute: [EMJ_WTP_capacity] = 120 //MGD - Reed changed from 86 to 120 since this run is used for long-term planning out beyond 2040
85
86 Set : max_flow1440.1305 //Set max WTP flows based on Final EA for D.E. Benton WTP
87 {
88
89   condition : (Swift_Sys_WS_Stor_Pct + 10) < _Total_WS_Pct(-1) // adjusted margin to +10% and low Benton production to 6 mgd
90   Value    : convert_units {6, mgd, af}
91
92   condition : Swift_Sys_WS_Stor_Pct < 30
93   Value    : convert_units { 11.2, mgd, af }
94
```

Raleigh_ops.ocl

```
95 condition : Swift_Sys_WS_Stor_Pct < 60
96 Value : convert_units { 12.6, mgd, af }
97
98 condition : default
99 Value : convert_units { 14, mgd, af }
100 }
101
102
103 Set : max_flow1300.1305
104 { condition : default
105 Value : convert_units { [EMJ_WTP_capacity], mgd, af }
106
107 }
108
109 // Don't allow Falls/EMJ WD to drop below 36 MGD
110 Target Falls_WTP_Min_production : dflow1300.1305
111 { condition : default
112 priority : 1
113 penalty+ : 0
114 penalty- : 200
115 Value : convert_units{ 36, mgd, af }
116 }
117
118 /* Set delivery target for DE Benton WTP */
119 Target Benton_WTP_Min_production : dflow1440.1305
120 { condition : default
121 priority : 1
122 penalty+ : 1000
123 penalty- : 10
124 Value : max_flow1440.1305
125 }
126
127
128 /* RESERVOIR BALANCING -- Raleigh - Attempt to draw down the Falls/Bdam WS account and the usable storage
129 in Benson/Wheeler proportionally. */
130
131 Constraint Balance1300 : { d_StorRatio2 > (( Dstorage1300 + Dstorage1230 - elev_to_stor { 1300, [Falls_lower_rule] }
132 - elev_to_stor { 1230, [Falls_lower_rule] } - _Total_WQ_Stor(-1))
133 / ( (elev_to_stor { 1300, [Falls_upper_rule] } - elev_to_stor { 1300, [Falls_lower_rule] }) +
134 (elev_to_stor { 1230, [Falls_upper_rule] } - elev_to_stor { 1230, [Falls_lower_rule] })
135 - _Total_Max_WQ_Storage )) }
136
137 Constraint Balance1440 : { d_StorRatio2 > (( Dstorage1440 + Dstorage1420 - dead_stor1440 - dead_stor1420 )
138 / (max_stor1440 + max_stor1420 - dead_stor1440 - dead_stor1420)) }
139
140
141
```

Raleigh_ops.ocl

```
142
143 // Assume Little River Reservoir is not operational in the 2055 scenario since its projected demand can
144 // be met from the existing supply sources.
145
146 /*
147 Target LRR_WTP_Min_production : dflow1740.1305
148 { condition : abs_period > 1 and ((storage1740 - dead_stor1740)/(max_stor1740 - dead_stor1740) + 0.07) < _Total_WS_Pct(-1)/100
149   priority : 1
150   penalty+ : 30
151   penalty- : 30
152   Value    : convert_units{ 6, mgd, af }
153
154   condition : abs_period > 1 and ((storage1740 - dead_stor1740)/(max_stor1740 - dead_stor1740)) - 0.07 > _Total_WS_Pct(-1)/100
155   priority : 1
156   penalty+ : 50
157   penalty- : 30
158   Value    : convert_units{ 20, mgd, af }
159
160   condition : default
161   priority : 1
162   penalty+ : 0
163   penalty- : 30
164   Value    : convert_units{ 7.5, mgd, af }
165 }
166 */
167
168 // Set delivery to Raleigh to 0.
169 Set : max_flow1740.1305
170 { condition : default
171   Value    : convert_units { 0, mgd , af }
172 }
173
174
175 // Set the minimum release. Set to 0 since reservoir is not active for the 2055 scenario.
176
177 Set : min_flow1740.1747
178 { /*condition : (storage1740 - dead_stor1740) / (max_stor1740 - dead_stor1740) < 0.5
179   Value    : convert_units { 0.48 , cfs , af }
180
181   condition : (storage1740 - dead_stor1740) / (max_stor1740 - dead_stor1740) < 0.7
182   Value    : convert_units { 2.31 , cfs , af }
183 */
184
185   condition : default
186   Value    : convert_units { 0 , cfs , af }
187 }
188
```

Raleigh_ops.ocl

```
189
190 // More reservoir balancing -- include Little River. Shut off for the 2055 scenario since it is not active.
191
192 /*
193 Constraint Balance1740 : { d_StorRatio2 > (( Dstorage1740 - dead_stor1740) / (max_stor1740 - dead_stor1740)) }
194
195 Minimax : d_StorRatio2
196
197 { priority : 1
198   penalty : 50
199   tolerance : .02
200 }
201
202 */
203
204
205 /* System Storage for Raleigh - including Little River Reservoir should it be evaluated.
206 Little River set to 0 storage since not used for this scenario. */
207
208 Set : _Raleigh_Sys_Stor_Pct
209 { value : ( _Total_WS_Stor(-1) + storage1420 - dead_stor1420 + storage1440 - dead_stor1440 + storage1740 - dead_stor1740 ) /
210           ( _Total_Max_WS_Storage + max_stor1420 - dead_stor1420 + max_stor1440 - dead_stor1440 + max_stor1740 - dead_stor1740)
211
212 }
```

Raleigh_Quarry_ops.ocl

```
1 /* Raleigh_Quarry_ops.OCL */
2
3 /* This subroutine dictates the operation of the Raleigh Quarry WS concept. */
4
5
6
7 // Ensure that the minimum release obligation from Falls is also met below the Quarry and Lag node
8 Constraint FallsDownstreamFlow1 :
9 { condition : month > 3 and month < 11
10   expression: dflow1310.1320 >= convert_units { 100, cfs, af } * ( 1 + [FLakeMin_SafeFact] / 100 )
11 }
12
13 Constraint FallsDownstreamFlow2 :
14 { condition : month<=3 or month>=11
15   expression: dflow1310.1320 >= convert_units { lookup { PiggybackGate, elevation1300 }, cfs, af }
16 }
17
18
19 Set : Expected_Durham_Spill
20 {
21   value : max {0, inflow1140 + inflow1200 + storage1140 + storage1200 - evap1140 - evap1200 - demand1162 - max_stor1140 - max_stor1200}
22 }
23
24 Set : Expected_Falls_Spill
25 { // Spill is expected
26   condition : (inflow1300 + flow1163.1300(-1) + inflow1080 + inflow1100 + inflow1110 + inflow1115 + flow1256.1300(-1)
27     + inflow1270 + inflow1230 + Expected_Durham_Spill - delivery1302 - evap1300 - evap1230 - demand1306
28     - min_flow1300.1304 + storage1300 + storage1230 - elev_to_stor{1300, [Falls_upper_rule]}
29     - elev_to_stor{1230, elevation1300}) > 0
30
31   value : inflow1300 + flow1163.1300(-1) + inflow1080 + inflow1100 + inflow1110 + inflow1115 + flow1256.1300(-1)
32     + inflow1270 + inflow1230 + Expected_Durham_Spill - delivery1302 - evap1300 - evap1230 - demand1306
33     - min_flow1300.1304 + storage1300 + storage1230 - elev_to_stor{1300,[Falls_upper_rule]}
34     - elev_to_stor{1230, elevation1300}
35   // No spill expected
36   condition : default
37   value : 0
38 }
39
40
41
42 Set Raleigh_Quarry_Refill : max_flow1304.1340 // Fill conditions
43 {
44   condition : Expected_Falls_Spill > 0 and storage1340 < max_stor1340
45   value : max {0, min{ convert_units { [Max_Quarry_refill_rate] , mgd , af }, max_stor1340
46     - storage1340, Expected_Falls_Spill}}
47 }
```

Raleigh_Quarry_ops.ocl

```
48  condition : default
49  value      : 0
50 }
51
52
53
54
55
56 //Quarry release rule
57 Target Raleigh_Quarry_Outflow : dflow1340.1305
58 {  condition : elevation1300 < [Falls_upper_rule] - 0.5
59   priority   : 1
60   penalty+   : 1000
61   penalty-   : 50
62   Value      : convert_units { [Max_Quarry_refill_rate] , mgd , af }
63 }
64
65  condition : default
66  priority   : 1
67  penalty+   : 1000
68  penalty-   : 0
69  Value      : 0
70 }
71
72 //Quarry refill target
73 Target Raleigh_Quarry_Refill : dflow1304.1340
74 {  condition : default
75   priority   : 1
76   penalty+   : 1000
77   penalty-   : 50
78   Value      : max_flow1304.1340
79 }
80
81
82 }
```

Randleman_ops.ocl

```
1 /* Randleman_Ops.ocl */
2 /* Operational policies for Randleman Lake */
3
4
5 Set MinReleaseRandleman : min_flow0270.0280
6 { condition : storage0270 / max_stor0270 <= 0.30
7   value    : convert_units {10, cfs, af }
8
9   condition : storage0270 / max_stor0270 <= 0.60
10  value    : convert_units {20, cfs, af }
11
12  condition : default
13  value    : convert_units {30, cfs, af }
14 }
15
```

routing_cf.ocl

```
1 /* File is ROUTING_CF.OCL, which has the coding to handle the Jordan - Lillington,
2    and Lillington to Fayetteville routing, daily time step only. */
3
4 /* Jordan-to-Lillington.
5     Jordan Release seen at Lill.
6     = .5 * yesterday's release + .5 * today's release.
7
8 Lillington-to-Fayetteville.
9     Lillington flow seen at Fayetteville
10    = Average flow of previous day
11
12 Nodes 555 and 749 are reservoirs used for channel storage.
13 The flow into these three nodes is unrouted; the release from them is routed.
14 The storage in the nodes makes up the difference.
15
16 Note that for the first day of the simulation the routed flows need to be
17 estimated; the current values set the routed flows equal to the flow
18 for that day when the simulation is started on 01/01/1930; they may need to be
19 adjusted if the run is started on a different date. */
20
21 Target JordanRout : dflow0555.0650 - 0.5 * dflow0550.0555
22 { Condition : abs_period <= 1
23   priority : 1
24   penalty+ : 10000
25   penalty- : 10000
26   value    : convert_units { 3711, cfs, af }
27
28   Condition : default
29   priority : 1
30   penalty+ : 10000
31   penalty- : 10000
32
33   value    : 0.5 * flow0550.0555(-1)
34 }
35
36 Target LillRout : dflow0749.0770
37 { Condition : abs_period <= 1
38   priority : 1
39   penalty+ : 10000
40   penalty- : 10000
41   value    : convert_units { 4381, cfs, af }
42
43
44   Condition : default
45   priority : 1
46   penalty+ : 10000
47   penalty- : 10000
```

routing_cf.ocl

```
48   value : flow0740.0749(-1)
49 }
```

routing_neuse.ocl

```
1 /* File is ROUTING_NEUSE.OCL, which has the coding to handle the Falls - Clayton,
2 Clayton - Goldsboro and Goldsboro - Kinston routing, daily time step only. */
3
4 /* Falls-to-Clayton.
5     Falls Release seen at Clayton
6     = .5 * yesterday's release + .5 * today's release.
7
8 Clayton-to-Goldsboro.
9     Clayton flow seen at Goldsboro
10    = Average flow of previous four days
11
12 Goldsboro-to-Kinston.
13     Goldsboro flow seen at Kinston
14     = Average flow of previous two days
15
16 Nodes 310, 640 and 790 are reservoirs used for channel storage.
17 The flow into these three nodes is unrouted; the release from them is routed.
18 The storage in the nodes makes up the difference.
19
20 Note that for the first day of the simulation the routed flows need to be
21 estimated; the current values set the routed flows equal to the upstream flow
22 for that day when the simulation is started on 01/01/1929; they may need to be
23 adjusted if the run is started on a different date. */
24
25 Target FallsRout : dflow1310.1320 - .5 * dflow1300.1304
26 { Condition : abs_period <= 1
27     priority : 1
28     penalty+ : 10000
29     penalty- : 10000
30     value    : convert_units { 49.25, cfs, af }
31
32 Condition : default
33     priority : 1
34     penalty+ : 10000
35     penalty- : 10000
36     value    : .5 * flow1304.1310(-1)
37 }
38 Target ClaytRout : dflow1640.1650
39 { Condition : abs_period <= 1
40     priority : 1
41     penalty+ : 10000
42     penalty- : 10000
43     value    : convert_units { 353.6, cfs, af }
44
45 Condition : abs_period = 2
46     priority : 1
47     penalty+ : 10000
```

routing_neuse.ocf

```
48  penalty- : 10000
49  value    : flow1630.1640(-1)
50
51  Condition : abs_period = 3
52  priority  : 1
53  penalty+  : 10000
54  penalty-  : 10000
55  value     : ( flow1630.1640(-2) + flow1630.1640(-1) ) / 2
56
57  Condition : abs_period = 4
58  priority  : 1
59  penalty+  : 10000
60  penalty-  : 10000
61  value     : ( flow1630.1640(-3) + flow1630.1640(-2) + flow1630.1640(-1) ) / 3
62
63  Condition : default
64  priority  : 1
65  penalty+  : 10000
66  penalty-  : 10000
67  value     : ( flow1630.1640(-4) + flow1630.1640(-3) + flow1630.1640(-2) + flow1630.1640(-1) ) / 4
68 }
69 Target GoldsRout : dflow1790.1795
70 { Condition : abs_period <= 1
71   priority : 1
72   penalty+ : 10000
73   penalty- : 10000
74   value    : convert_units { 1047.6, cfs, af }
75
76   Condition : abs_period = 2
77   priority  : 1
78   penalty+  : 10000
79   penalty-  : 10000
80   value     : flow1780.1790(-1)
81
82   Condition : default
83   priority  : 1
84   penalty+  : 10000
85   penalty-  : 10000
86   value     : ( flow1780.1790(-2) + flow1780.1790(-1) ) / 2
87 }
```

Shortages.ocl

```
1 //Shortages.ocl
2 //Calculates shortages using conservation demands from drought plans to determine actual shortages
3
4 //Neuse drought demands
5
6
7 set:_Durham_Shortage_Calc
8 { condition : default
9   value : demand1162 - delivery1162
10 }
11
12 :For:
13 { [trig] = {1,2,3,4}
14 }
15 set:_Durham_Shortage_Calc
16 { condition : _Durham_Trigger_[trig]_On = 1
17   value : _Durham_Consvn_[trig]_Demand-delivery1162
18 }
19 :Next:
20
21
22 set:_Ral_Shortage_Calc
23 { condition : default
24   value : demand1306 - delivery1306
25 }
26
27 :For:
28 { [trig] = {1,2,3}
29 }
30 set:_Ral_Shortage_Calc
31 { condition : _Ral_Trigger_[trig]_On = 1
32   value : _Ral_Consvn_[trig]_Demand-delivery1306
33 }
34 :Next:
35
36 set:_SGWASA_Shortage_Calc
37 { condition : default
38   value : demand1256 - delivery1256
39 }
40
41 :For:
42 { [trig] = {1,2,3,4,5}
43 }
44 set:_SGWASA_Shortage_Calc
45 { condition : _SGWASA_Trigger_[trig]_On = 1
46   value : _SGWASA_Consvn_[trig]_Demand-delivery1256
47 }
```

Shortages.ocf

```
48 :Next:
49
50 set:_Wilson_Shortage_Calc
51 { condition : default
52 value : demand1506 - delivery1506
53 }
54
55 :For:
56 { [trig] = {1,2,3,4,5}
57 }
58 set:_Wilson_Shortage_Calc
59 { condition : _Wilson_Trigger_[trig]_On = 1
60 value : _Wilson_Consvn_[trig]_Demand-delivery1506
61 }
62 :Next:
63
64
65 set:_Benson_Shortage_Calc
66 { condition : default
67 value : demand1756 - delivery1756
68 }
69
70 :For:
71 { [trig] = {1,2,3,4,5,6}
72 }
73 set:_Benson_Shortage_Calc
74 { condition : _Benson_Trigger_[trig]_On = 1
75 value : _Benson_Consvn_[trig]_Demand-delivery1756
76 }
77 :Next:
78
79
80 ////Cape Fear drought demands
81 //
82
83 set:_OWASA_Shortage_Calc
84 { condition : default
85 value : demand0431 - delivery0431
86 }
87
88 :For:
89 { [trig] = {1,2,3}
90 }
91 set:_OWASA_Shortage_Calc
92 { condition : _OWASA_Trigger_[trig]_On = 1
93 value : _OWASA_Consvn_[trig]_Demand-delivery0431
94 }
```

Shortages.ocl

```
95 :Next:
96
97 set:_Burl_Shortage_Calc
98 { condition : default
99   value   : demand0341 - delivery0341
100 }
101
102 :For:
103 { [trig] = {1,2,3,4,5}
104 }
105 set:_Burl_Shortage_Calc
106 { condition : _Burl_Trigger_[trig]_On = 1
107   value   : _Burl2_Consvn_[trig]_Demand-delivery0341
108 }
109 :Next:
110
111 set:_Gree_Shortage_Calc
112 { condition : default
113   value   : demand0123 - delivery0123
114 }
115
116 :For:
117 { [trig] = {1,2,3,4,5}
118 }
119 set:_Gree_Shortage_Calc
120 { condition : _Gree_Trigger_[trig]_On = 1
121   value   : _Gree2_Consvn_[trig]_Demand-delivery0123
122 }
123 :Next:
124
125 set:_High_Shortage_Calc
126 { condition : default
127   value   : demand0223 - delivery0223
128 }
129
130 :For:
131 { [trig] = {1,2,3,4}
132 }
133 set:_High_Shortage_Calc
134 { condition : _High_Trigger_[trig]_On = 1
135   value   : _High_Consvn_[trig]_Demand-delivery0223
136 }
137 :Next:
138
139 set:_Reid_Shortage_Calc
140 { condition : default
141   value   : demand0031 - delivery0031
```

Shortages.ocl

```
142 }
143
144 :For:
145 { [trig] = {1,2,3,4,5}
146 }
147 set:_Reid_Shortage_Calc
148 { condition : _Reid_Trigger_[trig]_On = 1
149 value : _Reid_Consvn_[trig]_Demand-delivery0031
150 }
151 :Next:
152
153 set:_Rams_Shortage_Calc
154 { condition : default
155 value : demand0301 - delivery0301
156 }
157
158 :For:
159 { [trig] = {1,2,3,4,5}
160 }
161 set:_Rams_Shortage_Calc
162 { condition : _Rams_Trigger_[trig]_On = 1
163 value : _Rams_Consvn_[trig]_Demand-delivery0301
164 }
165 :Next:
166
167 set:_GramMeb_Shortage_Calc
168 { condition : default
169 value : demand0321 - delivery0321
170 }
171
172 :For:
173 { [trig] = {1,2,3,4,5}
174 }
175 set:_GramMeb_Shortage_Calc
176 { condition : _GramMeb_Trigger_[trig]_On = 1
177 value : _GramMeb_Consvn_[trig]_Demand-delivery0321
178 }
179 :Next:
180
181
182 set:_Cary_Shortage_Calc
183 { condition : default
184 value : demand0471 - delivery0471
185 }
186
187 :For:
188 { [trig] = {1,2,3,4}
```

Shortages.ocf

```
189 }
190 set:_Cary_Shortage_Calc
191 { condition : _Cary_Trigger_[trig]_On = 1
192   value  : _Cary_Consvn_[trig]_Demand-delivery0471
193 }
194 :Next:
195
196
197 set:_Dunn_Shortage_Calc
198 { condition : default
199   value  : demand0663 - delivery0663
200 }
201
202 :For:
203 { [trig] = {1,2,3,4,5,6}
204 }
205 set:_Dunn_Shortage_Calc
206 { condition : _Dunn_Trigger_[trig]_On = 1
207   value  : _Dunn_Consvn_[trig]_Demand-delivery0663
208 }
209 :Next:
210
211
```

SilerCity_ops.ocl

```
1 /* SilerCity_Ops.OCL */
2
3 /* Minimum release policy for Siler City's Charles Turner Reservoir on the Rocky River - based on combined usable
4 storage remaining in the reservoirs. */
5
6 Set : _SilerCity_UsableStor { Value : max { 0,
7     min { (max_stor0324 - dead_stor0324 + max_stor0325 - dead_stor0325),
8         (storage0324 - dead_stor0324 + storage0325 - dead_stor0325) } } }
9 Set : _SilerCity_UsableStorPct { Value : 100 * _SilerCity_UsableStor
10     / (max_stor0324 - dead_stor0324 + max_stor0325 - dead_stor0325) }
11
12
13 // Trigger when reaching tier 2
14 Set : _SilerCityTrig2
15 { condition : _SilerCity_UsableStorPct < 70
16     value : 1
17
18     condition : default
19     value : 0
20 }
21
22
23 // Trigger when reaching tier 3
24 Set : _SilerCityTrig3
25 { condition : _SilerCity_UsableStorPct < 40
26     value : 1
27
28     condition : default
29     value : 0
30 }
31
32
33 Set : _Tier_MinRelease
34 { // Tier 3
35     condition : _SilerCityTrig3 = 1
36     Value : convert_units {pattern(Tier3_RockyRiver),cfs,af}
37
38     // Tier 2
39     condition : _SilerCityTrig2 = 1
40     Value : convert_units {pattern(Tier2_RockyRiver),cfs,af}
41
42     // Tier 1
43     condition : default
44     Value : convert_units {pattern(Tier1_RockyRiver),cfs,af}
45 }
46
47 // Also provide pulsing to simulate storm events (if those do not occur) of 20 cfs for 12 hours, or 20 acre feet per day, once per month,
```

SilerCity_ops.ocl

```
48 // whenever combined usable storage exceeds 40%. 401 Water Quality Certificate says pulses only required when no natural events of similar
49 // magnitude are observed. Assume we will provide this at the beginning of each month regardless of natural flows.
50
51 // Set min flow
52 Set : min_flow0325.0328
53 { condition : day = 1 and _SilerCity_UsableStorPct > 0.4
54   value      : max{_Tier_MinRelease, 20}
55
56   condition : default
57   value      : _Tier_MinRelease
58 }
```

SpringLake_ops.ocl

```
1 /*SPRINGLAKE_OPS.OCL */
2
3 /* Operational policy for Spring Lake */
4
5 // Set the fraction coming from Harnett w/ a substitute
6
7 :Substitute: [SpringLakeWS_Harnett] = .28/0.21 old value
8
9
10 // Set targets to dictate WDs between sources
11 Target Harnett_WD : dflow0549.0719
12 { condition : default
13   priority : 1
14   penalty+ : 100
15   penalty- : 100
16   Value    : [SpringLakeWS_Harnett] * demand0719 // 72% from Fayetteville from 2019 LWSP rest will be from Harnett
17 }
```

undef_list.ocl

```
1 /* File is undefs_list.ocl */
2
3 :Udef:
4
5 // -----
6
7
8 /* Udefs for inflow filtering */
9 :For:
10 { [node] = { 0020, 0040, 0070, 0090, 0300, 0310, 0324, 0325, 0590, 0760, 0110, 0140, 0145, 0170, 0210, 0220, 0260, 0270, 0280, 0340,
11 0380, 0400, 0430, 0450, 0470, 0490, 0520, 0527, 0550, 0640, 0700, 0780, 0820, 1010, 1050, 1060, 1080, 1100, 1110, 1115,
12 1250, 1270, 1290, 1420, 1440, 1445, 1450, 1480, 1500, 1560, 1630, 1740, 1780, 1800, 1900, 0044, 0112, 0120, 0328, 0570,
13 0580, 0600, 0610, 0660, 0680, 0720, 0730, 0770, 0790, 1205, 1320, 1405, 1409, 1471, 1520, 1600, 1620, 1625, 1650, 1660,
14 1700, 1730, 1735, 1747, 1750, 1755, 1760, 1775, 1795, 1570, 1850, 1999 }
15 }
16 Udef : _TempInf[node]
17 Udef : _InfDeficit[node] init{0}
18 :Next:
19
20 /* Udefs for Crabtree inflow filtering */
21 Udef : _TempInfCrabtree
22 Udef : _TotInfCrabtree
23 Udef : _InfDeficitCrabtree init{0}
24
25 // Gibson gain - required for allocating inflows to Higgins & Brandt
26 Udef : _Gibso_Gain
27
28 // For Harris Ops
29 Udef : _Proj_Harris_Storage
30 Udef : _Proj_Harris_Elev
31
32 // For Siler City operations
33 Udef : _SilerCity_UsableStor init {5348.79}
34 Udef : _SilerCity_UsableStorPct init {1}
35 Udef : _SilerCityTrig2
36 Udef : _SilerCityTrig3
37 Udef : _Tier_MinRelease
38
39 // Use for the Jordan Lake drought protocol
40
41 Udef : _JLake_Inflow init {0}
42 Udef : _Avg_JLake_Inflow
43 Udef : _WQZone
44 Udef : _Drought_Stage
45 Udef : _Level_Drawdown
46
47 // FOR:NEXT loop to declare udefs
```

undef_list.ocl

```
48 :FOR: { [level_num] = { 1, 2, 3, 4 } }
49
50 Udef : _Trigger_[level_num]_On      init {0}
51 Udef : _Count_Trigger_[level_num]   init {0}
52 Udef : _Total_Count_Trigger_[level_num] init {0}
53 Udef : _CumDayWithinInt_[level_num]  init {0}
54 Udef : _Lill_Target_[level_num]     init {0}
55 Udef : _Ph_[level_num]_event_count  init {0}
56
57 :NEXT:
58
59 // Jordan hydropower generation
60 Udef : _Jordan_hydropower
61
62 // -----
63
64 /* For the agricultural demand computations */
65
66 // FOR:NEXT loop to declare udefs
67 :FOR: { [county] = { 01, 02, 03, 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21,
68           22, 23, 24, 25, 26, 27, 28, 29, 30, 31 } }
69
70 Udef : dem[county]
71
72 :NEXT:
73
74 // -----
75
76 /* Udefs for the Jordan Lake pool allocation */
77
78 Udef : _JLakeInf
79 Udef : _JLake_WQ_Inf
80 Udef : _JLake_WS_Inf
81 Udef : _Inf_avail_to_WS_pool
82 Udef : _Inf_used_for_WS_pool
83 Udef : _WS_Total_Demand
84 Udef : _WS_Total_Deliv
85
86
87 // FOR:NEXT loop to declare udefs
88
89 :substitute:    [Starting_Storage_CaryAp] = 17953.6      /* Initial condition for the CaryApex account (in acre feet) */
90 :substitute:    [Starting_Storage_Chatham] = 5954        /* Initial condition for the Chatham account (in acre feet) */
91 :substitute:    [Starting_Storage_Durham] = 7557         /* Initial condition for the Durham account (in acre feet) */
92 :substitute:    [Starting_Storage_Holly] = 916           /* Initial condition for the Holly Springs account (in acre feet) */
93 :substitute:    [Starting_Storage_Morris] = 1603        /* Initial condition for the Morrisville account (in acre feet) */
94 :substitute:    [Starting_Storage_Orange] = 687         /* Initial condition for the Orange Co. account (in acre feet) */
```

udef_list.ocl

```
95 :substitute:      [Starting_Storage_Other] = 4030.4      /* Initial condition for the unallocated account (in acre feet) */
96 :substitute:      [Starting_Storage_OWASA] = 2290        /* Initial condition for the OWASA account (in acre feet) */
97 :substitute:      [Starting_Storage_RTP] = 1603          /* Initial condition for the RTP account (in acre feet) */
98 :substitute:      [Starting_Storage_Pitt] = 2748         /* Initial condition for the Pittsboro account (in acre feet) */
99 :substitute:      [Starting_Storage_Hillsb] = 458         /* Initial condition for the Hillsborough account (in acre feet) */
100 :substitute:      [Starting_WQ_Storage] = 94600         /* Initial Jordan Lake WQ storage (in acre feet) */
101
102
103
104 :FOR: { [accounts] = { CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb } }
105
106 Udef : _Req_Refill_[Accounts]
107 Udef : _Inf_[Accounts]
108 Udef : _Rem_def_[Accounts]
109 Udef : _Rem_Inf_[Accounts]
110 Udef : _Inf_Total_[Accounts]
111 Udef : _Storage_[Accounts]  init{ [Starting_Storage_[Accounts]] }
112 Udef : _Stor_Final_[Accounts]
113 Udef : _Stor_Final_Pct_[Accounts]
114
115 :NEXT:
116
117 Udef : _Inf_Rem_WS
118 Udef : _Rem_def_Total
119
120 Udef : _Total_WS_Storage
121 Udef : _Total_WS_Storage_Pct
122 Udef : _Req_Refill_WS_Pool
123 Udef : _WS_Pool_Excess
124 Udef : _WQ_Release
125 Udef : _WQ_Storage  init {[Starting_WQ_Storage]}
126 Udef : _WQ_Storage_Pct
127 Udef : _Req_Refill_WQ
128 Udef : _WQ_Pool_Excess
129
130
131 // FOR THE NEUSE
132 //
133 //
134
135 /* Udefs for cumulative tracking variables */
136 Udef : _CumWSupplyDemand  init {0}
137 Udef : _CumWSupplyDelivery init {0}
138 Udef : _CumWWReturn      init {0}
139 Udef : _CumWSupplyWWReturn init {0}
140
141 /* Udefs for Eno operations */
```

undef_list.ocl

```
142 Udef : _Orange_streamflow init {3.376} /* Initially set to 1.1 mgd*/
143 Udef : _Eno_Channel_Loss init {0}
144 Udef : _Max_Hills_WD init {4.634} /* Initially set to 1.51 mgd */
145 Udef : _Max_OrAl_WD init {2.157} /* Initially set to 0.82 mgd */
146 Udef : _Max_Pied_WD init {1.320} /* Initially set to 0.43 mgd */
147 Udef : _WFER_Tier init {1}
148
149 /* For proportional drawdown for Durham*/
150 Udef : _StorRatio Decision { 0 , unbounded }
151 Udef : _StorRatio2 Decision { 0 , unbounded }
152
153 /* Udef for Local Clayton Inflow for Falls Flood control */
154 Udef : _ClaytLocal init {0}
155
156 /* Udefs for Falls/Clayton minimum flow */
157 Udef : ClaytonTarget_Override
158 Udef : ClaytonTarget_SafeFact
159 Udef : FLake_WQ_Threshold
160 Udef : FLakeMin_SafeFact
161
162 /* Udefs for Raleigh Quarry and Neuse River Intake operations*/
163 Udef : _tot_intake_pump init{0}
164 Udef : Expected_Falls_Spill
165 Udef : Expected_Durham_Spill
166
167 /* Udefs for Raleigh system storage pct. - only used when Swift
168 Creek WD being used. */
169 Udef : _Raleigh_Sys_Stor_Pct
170 Udef : Swift_Sys_WS_Stor_Pct
171
172
173 /* Udefs for operating Johnston County's water supply system*/
174 Udef : Clayton_gage_expected
175 Udef : Expected_JC_WTP_flowby
176 Udef : Middle&Swift_Expected_Discharge
177 Udef : Exp_RBrdgeRd_Upstream
178
179 /* Udefs for the Falls and Beaverdam pool allocation */
180 Udef : _Pct_Max_WQ_Storage
181 Udef : _Pct_Max_WS_Storage
182 Udef : _FLake_Max_WQ_Storage
183 Udef : _FLake_Max_WS_Storage
184 Udef : _Bdam_Max_WQ_Storage
185 Udef : _Bdam_Max_WS_Storage
186 Udef : _Total_Max_WQ_Storage
187 Udef : _Total_Max_WS_Storage
188 Udef : _Total_Max_WQ_WS_Storage
```

undef_list.ocl

```
189 Udef : _FLake_Max_WQ_WS_Storage
190 Udef : _WQ_Stor_fraction
191 Udef : _WS_Stor_fraction
192 Udef : _Bdam_Inf
193 Udef : _Bdam_Inf_WS
194 Udef : _Bdam_WS_Rel
195 Udef : _Bdam_WS_Stor_Init
196 Udef : _Bdam_WStoWQ_Spill
197 Udef : _Bdam_Inf_WQ
198 Udef : _Bdam_WQ_Rel
199 Udef : _Bdam_WQ_Stor    init {[Bdam_WQ_Stor]}
200 Udef : _Bdam_WQtoWS_Spill
201 Udef : _Bdam_WS_Stor    init {[Bdam_WS_Stor]}
202 Udef : _FLake_Inf
203 Udef : _FLake_Inf_WS
204 Udef : _Flake_WS_Rel
205 Udef : _FLake_WS_Stor_Init
206 Udef : _FLake_WStoWQ_Spill
207 Udef : _FLake_Inf_WQ
208 Udef : _Flake_WQ_Rel
209 Udef : _FLake_WQ_Stor    init {[FLake_WQ_Stor]}
210 Udef : _Total_WQ_Stor
211 Udef : _FLake_WQtoWS_Spill
212 Udef : _FLake_WS_Stor    init {[FLake_WS_Stor]}
213 Udef : _Total_WS_Stor
214 Udef : _Bdam_WS_Pct
215 Udef : _Bdam_WQ_Pct
216 Udef : _FLake_WS_Pct
217 Udef : _FLake_WQ_Pct
218 Udef : _Total_WS_Pct
219 Udef : _Total_WQ_Pct
220
221
222 Udef : _WtAvgRunoff
223
224 // Set usable storage & DSR udefs for drought plans
225 Udef : _OWASA_Max_Usable_Stor
226 Udef : _OWASA_Usable_Stor
227 Udef : _OWASA_Usable_Stor_Pct init {100}
228 Udef : _OWASA_JL_Use_Targ
229
230
231 Udef : _Burl_Max_Usable_Stor
232 Udef : _Burl_Usable_Stor
233 Udef : _Burl_Usable_Stor_Pct init {100}
234
235 Udef : _Gree_Max_Usable_Stor
```

undef_list.ocl

```
236 Udef : _Gree_Usable_Stor
237 Udef : _Gree_Usable_Stor_Pct init {100}
238 Udef : _Gree_DSR
239
240 Udef : _High_Max_Usable_Stor
241 Udef : _High_Usable_Stor
242 Udef : _High_Usable_Stor_Pct init {100}
243
244 Udef : _Reid_Max_Usable_Stor
245 Udef : _Reid_Usable_Stor
246 Udef : _Reid_Usable_Stor_Pct init {100}
247 Udef : _Reid_DSR
248
249 Udef : _Rams_Max_Usable_Stor
250 Udef : _Rams_Usable_Stor
251 Udef : _Rams_Usable_Stor_Pct init {100}
252
253 Udef : _GramMeb_Max_Usable_Stor
254 Udef : _GramMeb_Usable_Stor
255 Udef : _GramMeb_Usable_Stor_Pct init {100}
256 Udef : _GramMeb_DSR
257
258 Udef : _Siler_Max_Usable_Stor
259 Udef : _Siler_Usable_Stor
260 Udef : _Siler_Usable_Stor_Pct init {100}
261
262 Udef : _Cary_DSR
263
264 Udef : _ChatNo_Usable_Stor_Pct init {100}
265
266 Udef : _Durham_add_sources init {0}
267 Udef : _Durham_usable_stor
268 Udef : _Max_Durham_usable_stor
269 Udef : _Durham_usable_pct
270 // Udefs below straight from Neuse mode run name "Scenario_2" from 2012 Durham modeling per Reed
271 Udef : _Durham_Tot_Use_Stor
272 Udef : _Durham_Stor
273 Udef : _Durham_Use_Stor
274 Udef : _Durham_Pct_Use_Stor
275 Udef : _Durham_TQ_Pct_Use_Stor
276
277 /* Udefs for Forecasts - ported from Durham model */
278 Udef : Release_storage
279 //Udef : _Trigger_1_On    init{0}
280 Udef : _Consvn_1_Demand
281 Udef : _Proj_1_Demand
282 Udef : _Proj_1_Evap
```

undef_list.ocl

```
283 Udef : _Proj_1_Inflow
284 Udef : _Proj_1_WSPool init{19588} // all these values would need to be updated for 2035 sedimentation to be correct for the first week of a run
285 Udef : _Stage_1_Counter init{0}
286 Udef : _Proj_1_WSPool_Refill init{19588}
287
288 //Udef : _Trigger_2_On init{0}
289 Udef : _Consvn_2_Demand
290 Udef : _Proj_2_Demand
291 Udef : _Proj_2_Evap
292 Udef : _Proj_2_Inflow
293 Udef : _Proj_2_WSPool init{19588}
294 Udef : _Stage_2_Counter init{0}
295 Udef : _Proj_2_WSPool_Refill init{19588}
296
297
298 //Udef : _Trigger_3_On init{0}
299 Udef : _Consvn_3_Demand
300 Udef : _Proj_3_Demand
301 Udef : _Proj_3_Evap
302 Udef : _Proj_3_Inflow
303 Udef : _Proj_3_WSPool init{19588}
304 Udef : _Stage_3_Counter init{0}
305 Udef : _Proj_3_WSPool_Refill init{19588}
306
307
308 //Udef : _Trigger_4_On init{0}
309 Udef : _Consvn_4_Demand
310 Udef : _Proj_4_Demand
311 Udef : _Proj_4_Evap
312 Udef : _Proj_4_Inflow
313 Udef : _Proj_4_WSPool init{19588}
314 Udef : _Stage_4_Counter init{0}
315 Udef : _Proj_4_WSPool_Refill init{19588}
316
317 Udef : _Proj_WSPool_Refill init{19588}
318
319 Udef : _Proj_5_Inflow
320
321 // Udefs for drought plan triggers
322 :FOR: { [Util] = { Burl, Burl1, Burl2, Gree, Gree1, Gree2, High, Reid, Rams, GramMeb, Siler, Cary,
323     RTP, Morris, ChatNo, Dunn, Benson, Carth, Ral, Durham, SGWASA, Wilson } }
324
325 :FOR: { [level_num] = { 1, 2, 3, 4, 5, 6 } }
326
327 Udef : _[Util]_Consvn_[level_num]_Demand
328
329 Udef : _[Util]_Trigger_[level_num]_On init {0}
```

udef_list.ocl

```
330 Udef : _[Util]_Stage_[level_num]_counter  init {0}
331 Udef : _[Util]_Ph_[level_num]_event_counter  init {0}
332
333 :NEXT:
334
335 :NEXT:
336
337 // Setting Durham's drought trigger level
338 Udef : _Trig_Level_Durham
339
340
341 Udef : _CaryApex_WW_Consvn init{1}
342
343 :FOR: { [level_num] = { 1, 2, 3 } }
344
345 :For: { [hrz] = {08, 12, 16, 20, 24, 52} }
346
347   Udef : _OWASA_ProjInflow[level_num]_[hrz]
348   Udef : _OWASA_ProjDemand[level_num]_[hrz]
349   Udef : _OWASA_ProjMinFlow[level_num]_[hrz]
350   Udef : _OWASA_ProjEvap[level_num]_[hrz]
351   Udef : _OWASA_ProjStorage[level_num]_[hrz]
352   Udef : _OWASA_ProjStorage_Pct[level_num]_[hrz]
353
354 :Next:
355
356   Udef : _OWASA_Consvn_[level_num]_Demand
357
358   Udef : _OWASA_Trigger_[level_num]_On      init {0}
359   Udef : _OWASA_Stage_[level_num]_counter  init {0}
360   Udef : _OWASA_Ph_[level_num]_event_counter  init {0}
361
362 :NEXT:
363
364 // Udefs for the Cary/Apex WW system
365 Udef : _CaryApexWW
366 Udef : _RTPWW
367 Udef : _MorrisWW
368 Udef : _CarySystemWW
369
370 // Allocate the total to the various discharge points, assigning monthly patterns and conservation factors (if any)
371 Udef : _CaryNorthWW
372 Udef : _CarySouthWW
373 Udef : _ApexWW
374 Udef : _CaryDTCWWTP
375 Udef : _CaryWestWakeWWTP
376
```

undef_list.ocl

```
377
378
379
380 // For Fuquay IBT
381
382 Udef : _Prelim_Max_JC_Neuse
383 Udef : _Prelim_Max_Alt_Neuse
384 Udef : _Prelim_Max_Sanford_Neuse
385 Udef : _Prelim_Max_HC_Neuse
386 Udef : _Prelim_Max_Alt_CF_to_Neuse
387 Udef : _IBT_CF_to_Neuse
388 Udef : _Final_Max_Flow_Alt
389 Udef : _IBT_Neuse_to_CF
390
391
392 //For calculating actual shortages based on conservation plans
393 Udef : _Durham_Shortage_Calc  init{0}
394 Udef : _Ral_Shortage_Calc    init{0}
395 Udef : _SGWASA_Shortage_Calc init{0}
396 Udef : _Wilson_Shortage_Calc init{0}
397
398 Udef : _OWASA_Shortage_Calc  init{0}
399 Udef : _Burl_Shortage_Calc   init{0}
400 Udef : _Gree_Shortage_Calc   init{0}
401 Udef : _High_Shortage_Calc   init{0}
402 Udef : _Reid_Shortage_Calc   init{0}
403 Udef : _Rams_Shortage_Calc   init{0}
404 Udef : _GramMeb_Shortage_Calc init{0}
405 Udef : _Siler_Shortage_Calc  init{0}
406 Udef : _Cary_Shortage_Calc   init{0}
407 Udef : _ChatNo_Shortage_Calc init{0}
408 Udef : _Dunn_Shortage_Calc   init{0}
409 Udef : _Benson_Shortage_Calc init{0}
410 Udef : _Carth_Shortage_Calc   init{0}
411 Udef : _RTP_Shortage_Calc     init{0}
412 Udef : _Morris_Shortage_Calc  init{0}
413
414
415
416
417 // -----
418
419 // For use in output tables
420 :substitute: [accounts] = "CaryAp, Chatham, RTP, Other, Durham, Morris, Orange, OWASA, Holly, Pitt, Hillsb" // for WQ_WS accounting
421                               // for Jordan Lake
422 :substitute: [level_num] = "1, 2, 3, 4" // for drought trigger and level determination for Jordan Lake drought protocol
423
```

udef_list.ocl

```
424
425 // Natural inflows in both basins
426 :substitute: [InflowNd_CFear] = "0020, 0040, 0044, 0070, 0090, 0110, 0112, 0120, 0140, 0145, 0170, 0210, 0220, 0260, 0270, 0280, 0300,
427     0310, 0324, 0325, 0328, 0340, 0380, 0395, 0400, 0430, 0450, 0470, 0495, 0520, 0527, 0550, 0570, 0580,
428     0590, 0600, 0610, 0640, 0660, 0680, 0700, 0720, 0730, 0760, 0770, 0777, 0780, 0790, 0820"
429
430 :substitute: [InflowNd_Neuse] = "1010, 1050, 1060, 1080, 1100, 1110, 1115, 1140, 1200, 1205, 1230, 1250, 1270, 1290, 1300, 1320, 1400,
431     1402, 1404, 1405, 1406, 1408, 1409, 1410, 1412, 1414, 1416, 1418, 1420, 1422, 1440, 1445, 1450, 1471,
432     1480, 1500, 1520, 1560, 1570, 1600, 1620, 1630, 1650, 1660, 1700, 1740, 1747, 1750, 1755, 1760, 1775,
433     1780, 1795, 1800, 1850, 1900, 1999"
434
435
436 // Reservoir nodes
437 :substitute: [ResNd_CFear] = "0030, 0070, 0112, 0120, 0140, 0220, 0270, 0300, 0320, 0324, 0325, 0340, 0390, 0395,
438     0430, 0470, 0520, 0528, 0760, 0777, 0790"
439 :substitute: [ResNd_Neuse] = "1010, 1050, 1060, 1080, 1100, 1120, 1140, 1200, 1230, 1250, 1270, 1290, 1300, 1420,
440     1440, 1445, 1450, 1500, 1647, 1648, 1740"
441
442 :substitute: [CrabtreeNd] = "1400, 1402, 1404, 1406, 1408, 1410, 1412, 1414, 1416, 1418, 1422" // For Crabtree impoundments
443
444 // for reservoirs that are being modeled with rule curves. for some of the Neuse reservoirs, we are not modeling with a
445 // "rule curve" - see reservoir rules table on GUI
446 :substitute: [ResNd_RCurves_CFear] = "0030, 0070, 0120, 0140, 0220, 0270, 0300, 0320, 0324, 0325, 0340, 0390,
447     0395, 0430, 0470, 0520, 0760"
448 :substitute: [ResNd_RCurves_Neuse] = "1050, 1060, 1140, 1200, 1230, 1250, 1290, 1300, 1420, 1440, 1500"
449
450
451 // For municipal and industrial demands
452 :substitute: [DemandNd_CFear] = "0031, 0123, 0223, 0261, 0301, 0321, 0327, 0341, 0401, 0431, 0471, 0473, 0474, 0475,
453     0477, 0483, 0487, 0491, 0521, 0551, 0601, 0605, 0663, 0701, 0719, 0721, 0733, 0771,
454     0781, 0785, 0823, 0825, 0903, 0904, 0906, 0921, 0923"
455
456 :substitute: [DemandNd_Neuse] = "1046, 1106, 1116, 1162, 1256, 1258, 1306, 1506, 1646, 1666, 1706, 1766, 1786, 1806,
457     1906"
458
459 // For WW returns linked to demands
460 :substitute: [LinkedWWRetArc_CFear] = "0031.0040, 0341.0072, 0072.0100, 0072.0350, 0341.0350, 0121.0140, 0122.0170, 0122.0180,
461     0223.0222, 0261.0280, 0904.0224, 0301.0570, 0321.0100, 0401.0410, 0431.0440, 0473.0470,
462     1162.0453, 1162.0463, 0483.0480, 0487.0490, 0491.0490, 0491.0610, 0521.0520, 0554.0686,
463     0554.0664, 0554.0550, 0554.0556, 0601.0610, 0327.0328, 0663.0680, 0663.0690, 0733.0740,
464     0733.0770, 0771.0770, 0781.0790, 0785.0790, 0923.0520, 0471.0472, 0474.0472, 0477.0472,
465     0472.0453, 0472.0930, 0479.0470"
466
467 :substitute: [LinkedWWRetArc_Neuse] = "1046.1100, 1106.1109, 1162.1163, 1259.1300, 1306.1620, 1306.1500, 1306.1320, 1646.1630,
468     1646.1675, 1666.1675, 0663.1756, 1756.1757, 1766.1770, 1675.1747, 1786.1780, 1806.1795,
469     1806.1850, 1806.1845, 1506.1560, 1906.1999, 1706.1409, 1706.0554, 0472.1401, 0472.1471,
470     0472.1405"
```

undef_list.ocl

```
471
472 // For independent WW returns
473 :substitute: [IndepWWRetNd_CFear] = "0148, 0192, 0227, 0282, 0464, 0591, 0592, 0772, 0774, 0910, 0960, 0962"
474
475 :substitute: [IndepWWRetNd_Neuse] = "1307, 1407, 1563, 1565, 1567, 1569, 1643, 1645, 1705, 1753, 1759, 1787, 1847"
476
477
478 // For agricultural demand
479 :substitute: [AgricNd_CFear] = "0021, 0041, 0043, 0051, 0075, 0077, 0081, 0083, 0111, 0161, 0211, 0231, 0263, 0281, 0311,
480     0331, 0361, 0371, 0381, 0403, 0411, 0441, 0461, 0481, 0511, 0531, 0541, 0553, 0581, 0593,
481     0595, 0603, 0621, 0623, 0671, 0674, 0681, 0691, 0713, 0741, 0773, 0775, 0783, 0801, 0811,
482     0821, 0940"
483
484 :substitute: [AgricNd_Neuse] = "1052, 1062, 1112, 1142, 1202, 1302, 1318, 1482, 1502, 1562, 1632, 1752, 1756, 1782, 1802,
485     1902"
486
487 //all added for task b1+b2 for Durham
488 UDef : _Durham_estim_spill
```

Upper_Eno_Ops.ocl

```
1 /* UPPER_ENO_OPS.OCL */
2 /* Operation policy the Upper Eno, based on the Capacity Use Plan */
3
4 /* Compute channel loss factor, which is used in the Lake Orange and WFER min release computations,
5    and to calculate channel loss at the Hillsborough Gage. Based on the values in the WFER dam safety permit. */
6 Set : _Eno_Channel_Loss
7 {   condition : flow1110.1115 < convert_units{4,cfs,af}
8     Value      : 0.2
9
10    condition : flow1110.1115 <= convert_units{12,cfs,af}
11    Value      : 0.1
12
13    condition : default
14    Value      : 0
15 }
16
17 /* Determine the maximum release from Lake Orange for Hillsborough demand; based on stage. */
18 Set : _Max_Hills_WD
19 {   /* For Dead Storage */
20     Condition : storage1060 / max_stor1060 <= 0.1365
21     Value      : 0
22
23     /* Stages 6 */
24     condition : storage1060 / max_stor1060 <= 0.3
25     Value      : convert_units { 0.68, mgd, af }
26
27     /* Stages 5 */
28     condition : storage1060 / max_stor1060 <= 0.4
29     Value      : convert_units { 1.13, mgd, af }
30
31     /* Stages 3 & 4 */
32     condition : storage1060 / max_stor1060 <= 0.6
33     Value      : convert_units { 1.28, mgd, af }
34
35     /* Stage 2 */
36     condition : storage1060 / max_stor1060 <= 0.8
37     Value      : convert_units { 1.36, mgd, af }
38     /* Stage 1 */
39     condition : default
40     Value      : convert_units { 1.51, mgd, af }
41 }
42
43 /* Determine the maximum release from Lake Orange for Orange-Alamance demand; based on stage. */
44 Set : _Max_OrAl_WD
45 {   /* For Dead Storage */
46     Condition : storage1060 / max_stor1060 <= 0.1365
47     Value      : 0
```

Upper_Eno_Ops.ocl

```
48
49  /* Stages 6 */
50  condition : storage1060 / max_stor1060 <= 0.3
51  Value    : convert_units { 0.37, mgd, af }
52
53  /* Stages 5 */
54  condition : storage1060 / max_stor1060 <= 0.4
55  Value    : convert_units { 0.62, mgd, af }
56
57  /* Stages 3 & 4 */
58  condition : storage1060 / max_stor1060 <= 0.6
59  Value    : convert_units { 0.70, mgd, af }
60
61  /* Stage 2 */
62  condition : storage1060 / max_stor1060 <= 0.8
63  Value    : convert_units { 0.74, mgd, af }
64  /* Stage 1 */
65  condition : default
66  Value    : convert_units { 0.82, mgd, af }
67 }
68
69 /* Determine the maximum release from Lake Orange for Piedmont Minerals demand; based on stage. */
70 Set : _Max_Pied_WD
71 {
72   /* Stages 6 */
73   condition : storage1060 / max_stor1060 <= 0.3
74   Value    : convert_units { 0.00, mgd, af }
75
76   /* Stages 5 */
77   condition : storage1060 / max_stor1060 <= 0.4
78   Value    : convert_units { 0.19, mgd, af }
79
80   /* Stages 4 */
81   condition : storage1060 / max_stor1060 <= 0.5
82   Value    : convert_units { 0.32, mgd, af }
83
84   /* Stages 3 */
85   condition : storage1060 / max_stor1060 <= 0.6
86   Value    : convert_units { 0.36, mgd, af }
87
88   /* Stage 2 */
89   condition : storage1060 / max_stor1060 <= 0.8
90   Value    : convert_units { 0.38, mgd, af }
91   /* Stage 1 */
92   condition : default
93   Value    : convert_units { 0.43, mgd, af }
94 }
```

Upper_Eno_Ops.ocl

```
95 /* Determine the Lake Orange required streamflow augmentation; based on stage. */
96 Set : _Orange_streamflow
97 { /* Stages 6 */
98     condition : storage1060 / max_stor1060 <= 0.3
99     Value : 0
100
101     /* Stages 5 */
102     condition : storage1060 / max_stor1060 <= 0.4
103     Value : 0
104
105     /* Stages 3 & 4 */
106     condition : storage1060 / max_stor1060 <= 0.6
107     Value : convert_units { 0.45, mgd, af }
108
109     /* Stage 2 */
110     condition : storage1060 / max_stor1060 <= 0.8
111     Value : convert_units { 0.65, mgd, af }
112     /* Stage 1 */
113     condition : default
114     Value : convert_units { 1.10, mgd, af }
115 }
116
117 /* Lake Orange minimum release, based on Eno Capacity Use plan. Includes a streamflow augmentation release plus
118 a release for downstream demands. The release for Hillsborough, Or-Al and Pied. Minerals' demand is only up to
119 the maximum specified in the plan. A multiplier for channel loss, the same as for WFER, is also included. */
120 Set : min_flow1060.1080
121 { /* All stage-dependant streamflow augmentation and max. WDs have been determined above */
122     condition : default
123     Value : (1 + _Eno_Channel_Loss) * (_Orange_streamflow + min { demand1046, _Max_OrAl_WD }
124 + min { demand1106, _Max_Hills_WD } + min { demand1116, _Max_Pied_WD })
125 }
126
127 /* Determine which Phase WFER is in. Set to Tier 3 if elevation < 624. Set to Tier 2 if elevation is between 624 and 628 ft.
128 Otherwise set to Tier 1 */
129
130 Set : _WFER_Tier
131 { Condition : elevation1050 < 624
132     Value : 3
133
134     Condition : elevation1050 < 628
135     Value : 2
136
137     Condition : default
138     Value : 1
139 }
140
141 /* WFER Minimm release - depends on storage tier, and remaining Hillsborough demand that cannot be met by Lake Orange.
```

Upper_Eno_Ops.ocl

```
142 From Eno Capacity Use pland and WFER dam safety permit; either enough to meet downstream requirements, or the specified
143 seasonal pattern, whichever is greater */
144 Set : min_flow1050.1080
145 { /* If in Tier1 */
146   condition : _WFER_Tier = 1
147   Value : max { (1 + _Eno_Channel_Loss) * (convert_units{1.0,cfs,af}
148     + max { 0, demand1106 - _Max_Hills_WD }) ,
149     convert_units{pattern(Tier1),cfs,af} }
150
151   /* If in Tier2 */
152   condition : _WFER_Tier = 2
153   Value : max { (1 + _Eno_Channel_Loss) * (convert_units{1.0,cfs,af}
154     + max { 0, demand1106 - _Max_Hills_WD }) ,
155     convert_units{pattern(Tier2),cfs,af} }
156
157   /* If in Tier3 */
158   condition : _WFER_Tier = 3
159   Value : max { (1 + _Eno_Channel_Loss) * (convert_units{1.0,cfs,af}
160     + max { 0, demand1106 - _Max_Hills_WD }) ,
161     convert_units{pattern(Tier3),cfs,af} }
162 }
163
164 /* Compute channel loss at Hills. Gage (computed) */
165 Target Channel_Loss : dflow1110.1107
166 { condition : default
167   priority : 1
168   penalty+ : 1000
169   penalty- : 1000
170   Value : max { 0, _Eno_Channel_Loss * (flow1105.1110 + inflow1110) }
171 }
172
```

WW_Returns.ocl

```
1 /* File is WW_Returns.ocl. */
2
3 // Note that WW only returns are handled as inflows (see inflow pattern under the Node tab for the monthly patterns).
4
5
6 /* Set inflow fractions for WW returns associated with demands */
7
8 // Cape Fear River Basin discharges
9
10 Constraint ReidsvilleWW_nc0024881_WTP_WW_nc0046345 : {dFlow0031.0040 = lookup {ReidsvilleWWTP_NC0024881, month}
11             * dDelivery0031 + lookup {ReidsvilleWTP_WW_nc0046345, month} * dDelivery0031}
12 Constraint BurlingtonTotalWW : {dFlow0341.0072 = lookup {BurlingtonTotalWWRF, month} * dDelivery0341}
13 Constraint BurlingtonEastWW_nc0023868 : {dFlow0072.0100 = lookup {BurlingtonTotalWWRF, month} * (dDelivery0341
14             + dDelivery0075) * 0.41} // Eastside is 41% of total
15 Constraint BurlingtonSouthsideWW_NC0023876 : {dFlow0072.0350 = lookup {BurlingtonTotalWWRF, month} * dDelivery0341
16             * 0.59} // Southside is 59% of total
17 Constraint HawRiverWW_to_Burlington : {dflow0075.0072 = lookup {BurlingtonTotalWWRF, month} * dDelivery0075}
18 Constraint BurlingtonMackintoshWW_NC0023828 : {dFlow0341.0350 = lookup {BurlingtonMackintoshWW_NC0023828, month}
19             * dDelivery0341}
20 Constraint GreensboroLakeTownsendWW_NCG590017 : {dFlow0123.0140 = lookup {GBTownsendWTPNCG590017, month} * dDelivery0123}
21 Constraint GreensboroMitchellWTPNC0081426 : {dFlow0122.0170 = lookup {GBMitchellWTPNC0081426, month} * dDelivery0123}
22 Constraint GBOzborneWWNC0047384 : {dFlow0122.0180 = lookup {GBOzborneWWNC0047384, month} * dDelivery0123}
23 Constraint GBHighPointWW : {dFlow0122.0224 = lookup {GBHighPointWW, month} * dDelivery0123}
24 Constraint HighPointWW_nc0081256_nc0024210 : {dFlow0223.0222 = lookup {HighPointWW, month} * dDelivery0223}
25 Constraint RandlemanWW_nc0025445 : {dFlow0261.0280 = lookup {RandlemanWW_nc0025445, month} * dDelivery0261}
26 Constraint ArchdaleWW : {dFlow0904.0224 = lookup {ArchdaleWW, month} * dDelivery0904}
27 Constraint RamseurWW_nc0026565 : {dFlow0301.0570 = lookup {RamseurWW_nc0026565, month} * dDelivery0301}
28
29 /* For Graham Mebane, we had all WW returns lumped together. Graham's asre permits 0045292 to Haw River (WW, with avg.day
30 = 1.8 mgd in 2020) and 0021211 to Back Creek (WTP process, with avg day = 0.3 mgd); and Mebane's is 0021474 to Moadam's
31 Creek (avg day = 1.5 mgd). Separate the WTP process return since that can be counted toward the min release.
32 Monthly pattern can be left as is. */
33 Constraint GrahamMebaneTotWW_nc0045292_nc0021474 : {dFlow0321.0100 = lookup {GrMebTotWW_nc0045292, month} * dDelivery0321}
34 // Assume 5% based on historical data (0.28 mgd vs. raw water WD from G-M lake of 4.5 mgd). Transfer included from Orange County,
35 // but this may be finished water, not raw water, which means it would be plumbed to the demand node itself. However, an
36 // emergency interconnection that hasn't been used in recent years.
37 Constraint GrahamMebane_WTP_Process_Return : {dFlow0319.0100 = 0.05 * (dflow0320.0319 + dflow0920.0319) }
38
39 Constraint PittsboroWW_nc0020354 : {dFlow0401.0410 = lookup {PittsboroWW_nc0020354, month} * dDelivery0401}
40 Constraint OWASA_WW_nc0025241 : {dFlow0431.0440 = lookup {OWASA_WW_nc0025241, month} * dDelivery0431}
41 Constraint NorthChathamWWWTP_nc0084093 : {dFlow0473.0470 = lookup {NorthChathamWTP_nc0084093, month} * dDelivery0473}
42 Constraint DurhamCtyTriangleWW_nc0026051 : {dFlow1162.0453 = lookup {DurhamCtyTriangleWW_nc0026051, month} * dDelivery1162}
43 Constraint DurhamReclamationWW_nc0047967 : {dFlow1162.0463 = lookup {DurhamReclamationW_nc0047597, month} * dDelivery1162}
44 Constraint AlliedSignalWW_NC0001899 : {dFlow0483.0480 = lookup {AlliedSignalWW_NC0001899, month} * dDelivery0483}
45
46 // Multiple demands met from Sanford; must use the flow to the junction node since that represents the total withdrawal on which the process
47 // loss is calculated. Otherwise, we'd be undercounting process loss since it would be calculated on deliveries to the demand node3,
```

WW_Returns.ocl

```
48 // which represent finished water.
49 Constraint SanfordPW_WTP_nc0002861 : {dFlow0489.0490 = lookup {Sanford_WTP_dis_nc0002861, month} * dflow0490.0489 }
50
51 Constraint Sanford_WWTP_nc0024147 : {dFlow0491.0610 = lookup {Sanford_WWTP_nc0024147, month} * dDelivery0491}
52
53 Constraint GoldstonGulf_nc0024147 : {dFlow0605.0610 = lookup {GoldstonGolfWW_nc0024147, month} * dDelivery0605}
54 Constraint BroadwayWW_nc0059242 : {dFlow0940.0540 = lookup {BroadwayWW_nc0059242, month} * dDelivery0940}
55 Constraint CarolinaTraceWW_nc0038831 : {dFlow0674.0660 = lookup {CarolinaTraceWW_nc0038831, month} * dDelivery0674}
56 Constraint ProgressHarrisWW_nc0039586 : {dFlow0521.0520 = 0 * dDelivery0521} // Accounted for in the consumptive use
57 // represented by the demand value
58 Constraint AngierWW_HarnettCo : {dFlow0654.0664 = lookup {AngierWW_to_HarnettCo, month} * dDelivery0654}
59
60 :Substitute: [HarnettWTP_process] = 0.066 //placeholder based on 2019&2020 LWSP data process/total demand [internal + sales]
61
62 Constraint North_Harnett_WWTP : {dFlow0551.0664 = lookup {HarnettWW_North, month} * dDelivery0551 }
63
64 // Same logic for Sanford above applies to the Harnett County WTP process water; tie it to total withdrawal.
65 Constraint HarnettWTP_process : {dFlow0549.0550 = dflow0550.0549 * [HarnettWTP_process] }
66 Constraint SouthHarnettRegionalWWTP : {dFlow0551.0556 = lookup {HarnettWW_South, month} * dDelivery0551 }
67
68 Constraint PilgrimsPride_nc0083852 : {dFlow0601.0610 = lookup {PilgrimsPride_nc0083852, month} * dDelivery0601}
69 Constraint SilerCityWW_nc0026441 : {dFlow0327.0328 = lookup {SilerCityWW_nc0026441, month} * dDelivery0327}
70 Constraint DunnWTP_nc0078955 : {dFlow0663.0680 = lookup {DunnWW_nc0078955, month} * dDelivery0663}
71 Constraint DunnWWTP_nc0043176 : {dFlow0663.0690 = lookup {DunnWWTP_nc0043176, month} * dDelivery0663}
72 Constraint FtBraggWW_NC0003964 : {dFlow0721.0722 = lookup {FtBraggWW_NC0003964, month} * dDelivery0721}
73 Constraint FayettevilleCrossWWTP_nc0023957 : {dFlow0733.0740 = lookup {FayCrossWW_NC0023957, month} * dDelivery0733}
74 Constraint FayettevilleRockfishCreekWWTP_nc0050105 : {dFlow0733.0770 = lookup {FayRockfishCkWW_NC0050105, month}
75 * dDelivery0733}
76 Constraint HokeRockfishCreekWTP_nc0089176 : {dFlow0735.0770 = lookup {HokeRockfishCkWW_NC0089176, month} * dDelivery0735}
77 Constraint MonsantoWW : {dFlow0771.0770 = lookup {MonsantoWW_NC0003719, month} * dDelivery0771}
78 Constraint DupontWW : {dFlow0781.0790 = lookup {DupontWW_nc0003573, month} * dDelivery0781}
79 Constraint LCFWSA-BladenBluffsWW_nc0078344 : {dFlow0785.0790 = 0 * dDelivery0785} // No return in 2010 scenario
80 Constraint HollySpringsWW_nc0063098 : {dFlow0923.0520 = lookup {HollySpringsWW_nc0063098, month}
81 * dDelivery0923} // Capped at 1.0 to ignore I and I.
82
83
84 // Neuse River Basin discharges
85
86 Constraint OrAlaReturn_nc0082759 : {dFlow1046.1100 = lookup {OrAlaReturn_nc0082759, month} * dDelivery1046}
87 Constraint Hillsborough_nc0026433 : {dFlow1106.1109 = lookup {HillsReturn_nc0026433, month} * dDelivery1106}
88 Constraint Durham_nc0023841 : {dFlow1162.1163 = lookup {DurhamReturn_nc0023841, month} * dDelivery1162}
89 Constraint SGWASA_nc0026824 : {dFlow1256.1300 = lookup {SGWASAReturn_nc0026824, month}
90 * dDelivery1256} // Creedmoor now part of SGWASA
91 Constraint Raleigh_NeuseWWTP_nc0029033 : {dFlow1306.1625 = lookup {RaleighReturn_nc0029033, month} * dDelivery1306}
92 Constraint Raleigh_LittleCreek_nc0079316 : {dFlow1306.1500 = lookup {RalLitCrReturn_nc0079316, month} * dDelivery1306 }
93 Constraint Raleigh_SmithCreek_nc0030759 : {dFlow1306.1320 = lookup {RalSmithCrReturn_nc0030759, month} * 0.05 * dDelivery1306}
94 Constraint ClaytonWW_nc0064564&nc0025453 : {dFlow1646.1630 = lookup {ClaytReturn_nc0064564&nc0025453, month}
```

WW_Returns.ocl

```
95      * dDelivery1646} // Clayton demand is included in Johnst Co.
96 Constraint JohnstReturn_nc0030716 : {dFlow1646.1675 = lookup {JohnstReturn_nc0030716, month} * (dDelivery1646)}
97 Constraint JohnstReturn_Benson : {dFlow1646.1757 = 0.015 * (dDelivery1646)}
98 Constraint JohnstonCoWTP_Retur : {dFlow1655.1650 = 0.1 * (dflow1650.1654)} // This is the 10% process water return to the river
99 Constraint SfieldReturn : {dFlow1666.1675 = lookup {SfieldReturn, month} * (dDelivery1666)}
100 Constraint BensonWW_nc0020389 : {dFlow1756.1757 = lookup {BensonWW_nc0020389, month} * dDelivery1756}
101 Constraint ProgressEnergy : {dFlow1766.1770 = 0.0 * dDelivery1766}
102 Constraint KenlyWW_nc0064891 : {dFlow1675.1747 = lookup {KenlyReturn_nc0064891, month} * dDelivery1646}
103 Constraint GoldsboroWW_nc0023949 : {dFlow1786.1780 = lookup {GoldsReturn_nc0023949, month} * dDelivery1786}
104 Constraint NRWASA_nc0088111 : {dFlow1806.1795 = lookup {NRWASAReturnWTP_nc0088111, month} * dDelivery1806}
105 Constraint KinstonWW_nc0024236 : {dFlow1806.1850 = lookup {KinstonWW_nc0024236, month} * dDelivery1806}
106 Constraint AydenGriftonWW : {dFlow1806.1845 = lookup {AydenGriftonWW, month} * dDelivery1806}
107 Constraint WilsonWW_nc0023906 : {dFlow1506.1560 = lookup {WilsonReturn_nc0023906, month} * dDelivery1506}
108 Constraint Weyerhauser_nc0003191 : {dFlow1906.1999 = lookup {WeyerReturn_nc0003191, month} * dDelivery1906}
109
110 /* Note: in the past, F-V WW return was a function of the total demand x the lookup fractions. For the updates, it is a function
111 of how much demand is in the Neuse and Cape Fear. WW from the Neuse service area is returned to the Terrible Creek plant
112 (in the Neuse); the WW from the Cape Fear service area is returned to North Harnett County plant (in the Cape Fear). Adjust
113 the monthly WW return fractions in the lookup table for FuquayWW_nc00516&nc0066150 above. The return fraction is capped at
114 100% of the respective demand (i.e., I and I is ignored).*/
115
116 Constraint Terrible_Creek_WW_Return : {dflow1706.1409 = lookup {FuquayReturn_nc0066516&nc0066150, month}
117      * dDelivery1706 * [Demand_FV_Neuse] }
118 Constraint Harnett_County_WW_Return : {dflow1706.0664 = lookup {FuquayReturn_nc0066516&nc0066150, month}
119      * dDelivery1706 * (1 - [Demand_FV_Neuse]) }
120
121
122 // Compute Cary/Apex system separately
123 // First compute the amount of reductions to WW discharges expected if the drought plan is active (stages 3-4 only)
124
125 :If: {[Drought_Plans_On] = 1} // First check if drought plan variable is on
126
127 Set : _CaryApex_WW_Consvn
128 { Condition : _Cary_Trigger_4_On
129 {
130 Condition : month > 4 and month < 11
131 Value : 1 - 14 / 100 // 14% reduction for Stg. 4, May-Oct
132
133 Condition : default
134 Value : 1 - 19 / 100 // 19% reduction for Stg. 4, Nov-Apr
135 }
136
137 Condition : _Cary_Trigger_3_On
138 {
139 Condition : month > 4 and month < 11
140 Value : 1 - 6 / 100 // 6% reduction for Stg. 3, May-Oct
141
```

WW_Returns.ocl

```
142 Condition : default
143 Value   : 1 - 7 / 100 // 7% reduction for Stg. 4, Nov-Apr
144 }
145
146 Condition : default
147 Value   : 1
148 }
149
150 :else:
151
152 Set : _CaryApex_WW_Consvn
153 { Condition : default
154   Value   : 1
155 }
156
157 :EndIf:
158
159
160 // Now compute various WW flows and discharges as Udefs, since they'll be used in multiple constraints
161
162 //Total WW for Cary/Apex, RTP and Morrisville
163 Set : _CaryApexWW { Value : lookup {CaryApexReturn, month} * demand0471 * _CaryApex_WW_Consvn }
164 Set : _RTPWW { Value : lookup {RTPReturn, month} * demand0474 * _CaryApex_WW_Consvn }
165 Set : _MorrisWW { Value : lookup {MorrisReturn, month} * demand0477 * _CaryApex_WW_Consvn }
166 Set : _CarySystemWW { value : _CaryApexWW + _RTPWW + _MorrisWW }
167
168 // Allocate the total to the various discharge points, assigning monthly patterns and conservation factors (if any)
169 Set : _CaryNorthWW { Value : _CarySystemWW * 0.29 * lookup{CaryNWRFRReturn, month}}
170 Set : _CarySouthWW { Value : _CarySystemWW * 0.24 * lookup{CarySWRFRReturn, month}}
171 Set : _ApexWW { Value : _CarySystemWW * 0.07 * lookup{ApexWRFReturn, month}}
172 Set : _CaryDTCWWTP { Value : _CarySystemWW * 0.00 }
173
174 /* For Western Wake WRF, put in an adjustment factor of 1.4 since our computed returns to Western Wake WRF relative to 2022
175 data are about 40% too low. Also computed system WW relative to finished water demand was only about 80%; this adjustment
176 factor raises that to almost 90%, which is more consistent with 2022 data. This adjustment is important since IBT
177 compliance (described below) is dependent on it. */
178 Set : _CaryWestWakeWWTP { Value : _CarySystemWW * 0.40 * lookup{WestWakeWRFReturn, month} * 1.4 }
179
180 // Next set the constraints that will force the flows to match the udefs
181 Constraint CaryApexTotalWW : {dflow0471.0472 = (_CaryApexWW / _CarySystemWW)
182   * (_CaryNorthWW + _CarySouthWW + _ApexWW + _CaryDTCWWTP + _CaryWestWakeWWTP) }
183 Constraint RTPWW : {dFlow0474.0472 = (_RTPWW / _CarySystemWW)
184   * (_CaryNorthWW + _CarySouthWW + _ApexWW + _CaryDTCWWTP + _CaryWestWakeWWTP) }
185 Constraint MorrisvilleWW : {dFlow0477.0472 = (_MorrisWW / _CarySystemWW)
186   * (_CaryNorthWW + _CarySouthWW + _ApexWW + _CaryDTCWWTP + _CaryWestWakeWWTP) }
187
188
```

WW_Returns.ocl

```
189 Constraint CaryNorthWW : {dFlow0472.1401 = _CaryNorthWW}
190 Constraint CarySouthWW : {dFlow0472.1471 = _CarySouthWW}
191 Constraint ApexWW : {dFlow0472.1405 = _ApexWW}
192 Constraint CaryDTCWWTP : {dFlow0472.0453 = _CaryDTCWWTP}
193 Constraint CaryWestWakeWWTP : {dFlow0472.0930 = _CaryWestWakeWWTP}
194
195 // Finally, compute the WTF discharge back into Jordan based on the raw water withdrawal from the lake.
196 // Do not use delivery since that represents finished water based on the plumbing.
197 Constraint CaryApexWTFWW : {dflow0479.0470 = lookup {CaryApexWTFReturn, month} * (dflow0470.0479)}
198
199 /* The 2015 IBT certificate for Cary-Apex allows for a 33 mgd WD from the Haw River basin to the Neuse (31 mgd) and Cape Fear
200 basins (2 mgd). A consent order was later issued requiring that WW be returned to the Cape Fear basin = Neuse demand
201 (finished water including non-revenue water) - 9.756 mgd. In 2022, Cary finished water use was 20.82 (raw) -
202 3.08 (process loss) = 17.7 mgd, with 96% going to the Neuse, or 17.0 mgd. Apex used 5.6 - 0.84 = 4.8 mgd, with 29%
203 going to the Neuse, or 1.4 mgd. So total Neuse finished water use was 18.4 mgd. So required discharge back to the
204 Cape Fear would be 18.4 - 9.8 = 8.6. Process water (from the Cary-Apex WTP on the east side of Jordan Lake) can be
205 included in the discharge since it goes into Jordan Lake and amounted to 3.1 + 0.8 mgd (listed above), or 3.9 mgd.
206 So required remaining discharge (through the Western Wake WRF) would be 8.6 - 3.9, or 4.7 mgd. In 2022, the facility
207 discharged 6.5 mgd from Cary and 3.7 mgd from Apex, for a total of 10.2 mgd. All compliance is based on 3-year running
208 annual average daily amounts.
209
210 The model is not imposing any restrictions; to view whether the return requirements are met, the user can track the
211 returns with user-defined output tables. Also note that CaryApex demand (demand473) lumps CaryApex, RTP, and Morrisville
212 demands (demands for RTP [node 474] and Morrisville [node 477] are set to 0). Also, when calculating the return amount,
213 since Apex demand is a reasonable amount of the CaryApex demand (based on 2022 data above), assume the Neuse demand
214 (finished) = 85% of the CaryApex demand (finished). This should be a conservative estimate of the required return amount.
215 Assume the same in the Neuse for future year planning runs. Note if the percentage were 95% or higher, then there might be
216 a deficit in terms of meeting the required IBT return.
217
218 Need to add constraints on the WW returns for High Point, IBT and Spring Lake. Weren't in there before. For now, set to 0
219 for the first -- meaning WW return from upstream nodes will now go back to the Deep River in full. For Spring Lake,
220 assumed 100% of the delivery. Delivery is insignificant. */
221
222 Constraint HighPt : {dflow0222.0225 = 0 }
223 Constraint SpringLake : {dflow0719.0720 = 1.0 * ddelivery0719 }
224
225
226 // There is another WW transfer out of basin in the model, but in this case water is not diverted here since there is no
227 // benefit to doing so. WW returns instead to the Cape Fear. However, a constraint is always safe to impose, in this
228 // case assume 0 flow in the IBT.
229
230 Constraint HokeCounty : {dflow0735.0737 = 0 }
```